

*Archive*

COAL-FIRED OPEN CYCLE MAGNETOHYDRODYNAMIC  
POWER PLANT EMISSIONS AND ENERGY EFFICIENCIES

J. Gruhl

MIT Energy Lab Report #MIT-EL 78-018

November 1977




COAL-FIRED OPEN CYCLE MAGNETOHYDRODYNAMIC  
POWER PLANT EMISSIONS AND ENERGY EFFICIENCIES

by

J. Gruhl  
MIT Energy Laboratory  
Cambridge, Massachusetts 02139

MIT-EL 78-018



MIT Principal Investigator  
J. F. Louis

MIT Project Manager  
A. E. Sotak

Sponsored under a subcontract to  
Exxon Research and Engineering Company  
Linden, New Jersey  
Principal Investigator  
H. Shaw

Sponsored by  
U.S. Environmental Protection Agency  
Program Officer  
W. C. Cain

Contract #68-02-2146

## NOTICE AND ACKNOWLEDGMENTS

This report was prepared at the MIT Energy Laboratory, Cambridge, MA, as an account of a small portion of the work performed as a subcontract to an Exxon Research and Engineering Co., Linden, N.J., program sponsored by the U.S. Environmental Protection Agency, Contract #68-02-2146. Principal Investigator of this project at MIT was Prof. J. Louis; program managers were J.D. Teare and later A. Sotak. Program managers at Exxon and EPA were H. Shaw and W.C. Cain.

None of these organizations nor any person acting on behalf of these organizations: (a) makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report. Mentions of products or policies do not necessarily imply endorsements of those products or policies by any of these organizations.

## ABSTRACT

This study is a review of projected emissions and energy efficiencies of coal-fired open cycle MHD power plants. Ideally one would like to develop empirically-based probabilistic models of MHD performance. However, with the lack of empirical information about full-sized facilities this survey concentrates on modeling analytically developed data. Also presented are discussions of unresolved MHD issues of importance, comprehensive lists of recent and ongoing research, and a bibliography of material related to emissions and efficiencies of coal-fired open cycle MHD power plants.

## TABLE OF CONTENTS

	<u>Page</u>
Notice and Acknowledgments.....	ii
Abstract.....	iii
Table of Contents.....	iv
1. Introduction.....	1
2. MHD Programs in Progress.....	9
3. Plant Design Configurations.....	25
3.1 Operating and Design Parameters.....	27
3.2 Mass Balances of Specific Designs.....	31
3.3 Energy Efficiency Evaluations.....	55
4. Environmental Assessment.....	73
4.1 Air Emissions.....	73
4.1.1 Sulfur Oxides.....	73
4.1.2 Nitrogen Oxides.....	80
4.1.3 Trace Metals.....	90
4.1.4 Particulates.....	98
4.1.5 Other Air Emissions.....	102
4.2 Emissions to Water.....	103
4.3 Solids and Resources.....	105
4.4 Other Fuel Cycle Effects.....	105
5. Conclusions.....	109
6. References and Bibliography.....	112
A. Appendix on MHD Economic-Environmental Simulation.....	127

## 1. Introduction

Recent reports (Pomeroy, et al., 1978) show open cycle (or binary) coal-fired magnetohydrodynamics, OCMHD, playing an extremely important role in our nation's energy future. Under certain assumed scenarios, such as no breeder reactors, open cycle MHD is overwhelmingly preferred once it is available (about the year 2003). That same study shows the large size (1932 MW) to be somewhat of a disadvantage that makes earlier penetration, if available, unlikely. Once available, however, the share of the market for OCMHD could be as large as 90% (Pomeroy, et al., 1978). Most forecasts show MHD dominating future coal-fired power plant markets, especially in scenarios where coal prices escalate rapidly.

Clearly this is an important advanced energy technology, yet there is currently not enough performance data to precisely assess the emissions or efficiency capabilities of OCMHD power plants. Appendix A displays the large uncertainties that exist concerning this information. The theoretically very high performance potential, meeting emissions standards with 50 to 60% conversion efficiency, and absence of moving parts and heat exchanges in the MHD cycle, have been the principal justifications for continued research and development. With the absence of full-sized facilities, this study concentrates on analytically derived data, ongoing research efforts, and problems and potential solutions for meeting the theoretical performance potential.

MHD is envisioned as a topping cycle to be operated in series with a steam cycle, see Figure 1-1. Coal is first processed then sent into a combustor where it is burned at very high temperatures, 2756 K to 3033 K (4500<sup>0</sup>F to 5000<sup>0</sup>F) and at high pressure, 7 to 15 atm. The gaseous




Figure 1-1 Basic Schematic of Open Cycle MHD (NASA, 1977)

combustion products are made electrically conductive, about 10 to 12 mhos/m, by injection of a small fraction, about 1%, of seed material such as potassium carbonate. The conductive gas is then expanded at high velocity, about 1000 m/s, through a high magnetic field, about 5 to 8 Tesla, thus producing direct current at electrodes perpendicular to the flow field and magnetic field. The still hot gases, about 2256 K (3600°F), are then sent to a bottoming steam turbine. Before or after this turbine the gases usually will preheat the coal and/or air. In an open-cycle system the steam turbine exhaust usually goes to a water heater and then eventually up the stack. Some of the possible design variations that have been studied are outlined in Chapter 3.

Even considering nearly identical conditions, about 1617 K (2450°F) direct air preheat and a 24.1 MN/m<sup>2</sup>/811K/811K (3500<sup>0</sup> psi/1000<sup>0</sup>F/1000<sup>0</sup>F) supercritical single reheat steam bottoming cycle, performance estimates are widely scattered, (see Table 1-1 and several others in this report) sometimes almost a factor of two variation on certain estimates (\$642 versus \$1102 investment cost per kWe). This large uncertainty in projected performance is the first major issue discussed in each of the following chapters.

The second issue elaborated is that of barriers that must be hurdled before commercialization of OCMHD. These technological problems are indirectly related to the issues of this paper. Thus they are only roughly summarized in Table 1-2, are listed in order of severity in Chapter 5, and are briefly mentioned in the sections of this report where they bear upon aspects of performance.

TABLE 1-1

AVAILABILITY AND COST COMPARISONS OF PROJECTED FULL-SIZE  
OPEN CYCLE COAL MHD DESIGNS

<u>Capital Cost</u>	
(Pomeroy, et al., 1978)	\$805/kWe
(NASA, 1977)	\$1103/kWe (Westinghouse)
(NASA, 1977)	\$642/kWe (GE Co.)
(Seikel, Harris, 1976)	\$718/kWe
(General Electric, 1975)	\$910-\$1440/kWe
(Pepper, Yu, 1975)	\$340-\$440/kWe
(Rosa, et al., 1970)	\$35-\$55/kWe (peaking)
(Hals, Jackson, 1969)	\$90-\$120/kWe
<u>Cost of Electricity</u>	
(Levi, 1978)	32 mills/kWh
(Pomeroy, et al., 1978)	34-43 mills/kWh (baseload)
(Pomeroy, et al., 1978)	130 mills/kWh (peaking)
(NASA, 1977)	27.1-43.9 mills/kWh
(Seikel, Harris, 1976)	42-49 mills/kWh (GE Co.)
(Seikel, Harris, 1976)	32-50 mills/kWh (WE Co.)
(Seikel, Harris, 1976)	31.8 mills/kWh (GE Co.)
(General Electric, 1975)	41.5-55.5 mills/kWh
(NASA, 1975)	41-48 mills/kWh (GE Co.)
(NASA, 1975)	27-35 mills/kWh (Westinghouse)
(NASA, 1975)	34-42 mills/kWh (low Btu, Westinghouse)
(Hals, Jackson, 1969)	3.34-4.26 mills/kWh
<u>Construction Time</u>	
(Pomeroy, et al., 1978)	5-6.5 years
(Seikel, Harris, 1976)	6.5 years
<u>Date of Commercialization</u>	
(Pomeroy, et al., 1978)	2003
(Penny, Bourgeois, Cain, 1977)	2000
(Seikel, Harris, 1976)	1996-1999
(Pepper, Yu, 1975)	1988

TABLE 1-2  
SUMMARY OF MHD PROBLEM AREAS

Problems	Potential Solutions
<b>Particulate Removal</b> - submicron sizes - high quality plasma with low ash	. facility testing
<b>Seed Recovery</b> - efficiencies of recovery from solids - suitability for reuse - economic problems and energy costs - water contamination - ash composition peculiarities - atmospheric releases	. seed collection . combustion modeling . thermal regeneration
<b>Nitrogen Oxide Control</b> - may not meet standards	. minimize during combustion . reduce oxygen in high-temperature areas and inject air in low-temperature regions . post-combustion control . two-stage combustion . use different pressures . use different air/fuel ratios
<b>Sulfur Oxide</b> - potassium sulfate emissions	. facility testing
<b>Properties of Coal</b> - some fundamentals are important but not known or are widely varying - conductivity, ignition, devolatilization, combustion, gasification, slag vaporization, slag agglomeration	. kinetic conditions testing . devolatilization kinetics studies . ash vaporization studies
<b>Moisture</b> - in low-grade coals	. coal drying

TABLE 1-2 (continued)

SUMMARY OF MHD PROBLEM AREAS

Durable Materials, especially insulators, electrodes and heat exchangers	
- extremely high temperatures	. develop high grade materials
- corrosive exhaust gases	. develop predictive techniques for optimizing conditions and materials
- short life of nozzles, valves, boiler tubes and duct materials	. study high temperature and corrosion effects
- ash and seed corrosion of ceramic and metal parts	. study of thermal cycling and long duty cycle effects
Generator, Duct and Diffuser Life	
- effects of combustion products and slag on walls	. studies of properties of combustion products
- multiplicity of load circuits	. long duration tests
- axial breakdown limitation	. disk generators
Other Component Problems	
- demonstrate air preheaters	. facility testing
- slag coating of heat exchangers	
- high temperature heat exchangers	
- superconducting magnetic system cost, size, and temperature problems	
Combustors	
- 5000°F	. facility testing
- reasonably free of slag vapor 10-20% original ash	. more direct measurements and analytic modeling
- sufficient rate and uniform coal feed	
- good mixing with low pressure drop	
- high slag rejection and topping	
Large Facility Sizes	
- effects of components on each other	. development of smaller modules
- 2000 MW minimums	. testing of component interfaces
- reliability problems associated with large blocks of power	
- scale-up problems	
Turndown and Load Follow	
	. use several smaller modules

TABLE 1-2 (continued)

SUMMARY OF MHD PROBLEM AREAS

Demonstrate Enthalpy Extraction and Isentropic Efficiency	. short duration experiments
Absolute and Convective Instabilities	. large facility testing
Stable Electrical Loading	. large facility characteristics . analytic stability studies
Accurate Performance Estimates	
- efficiency and coal consumption	. optimum design specification
- capital cost and cost of electricity	. facility testing
- availability	. forecast of R&D funding levels
- adaptability to base load	
- likelihood and expected year of commercialization	

It is easy to be optimistic about the future of OCMHD, one just has to review the system's simplicity, the fallback positions, the time and funding available, and the progress to date (compared to the competing technologies, particularly the operating experimental facilities). However, it is also easy to be pessimistic, there are considerable technical problems associated with virtually every major power plant design component. Efficiencies and emissions will be significantly affected by the trade-offs and design changes resulting from future solutions for these technical problems, and this is a major reason for the significant uncertainties in the values reported in the following chapters.

## 2. MHD Programs in Progress

Research and development programs in MHD cycles have progressed erratically for more than a century (Levi, 1978), initially being linked to the work of Michael Faraday in 1831. Translation of the MHD concept into commercial application has been motivated recently by the need for efficient, clean methods of converting coal energy into electricity. Modern efforts began at Westinghouse starting in 1938 and were continued into the 1950's at Cornell University. Feasibility experiments were conducted in the 1960's first at Westinghouse, GE, and Avco and later at University of Tennessee and Stanford University.

Internationally, the Soviet Union has advanced, first in closed-cycle, later in open-cycle, facilities fueled by natural gas. The Japanese have been concentrating on use of heavy oils as fuels, primarily to reduce amounts of petroleum to be imported. In addition to the U.S. and U.S.S.R., Poland and India because of their significant fossil fuel resources have continued to conduct MHD research. The United Kingdom, France, and West Germany have essentially stopped their MHD programs although they have joined an international cooperative with the other principal research countries and some countries with relatively new interests: Australia, Austria, Belgium, Canada, Czechoslovakia, Hungary, Italy, Netherlands, Rumania, Sweden and Switzerland.

A summary of the more recent history of MHD development is shown in Figure 2-1. Excellent further historical discussions are contained in (Kantrowitz, 1977), (Way, 1971), and (Tager, Henry, 1976).

It would take a considerable effort to describe all the current and future plans for MHD in the U.S. Instead Table 2-1 lists the




Figure 2-1 General Description of the Evolution of Recent MHD Developments (Kantowitz, 1977)

TABLE 2-1  
RECENT AND ONGOING MHD RESEARCH

Argonne National Lab	<ul style="list-style-type: none"> <li>- generator phenomena</li> <li>- combustion studies and modeling</li> <li>- project planning and definition</li> <li>- systems studies</li> <li>- magnets</li> </ul>
Arnold Engineering Development Center	<ul style="list-style-type: none"> <li>- component and materials experiments</li> <li>- high enthalpy extraction</li> <li>- magnet testing and building</li> <li>- test facility</li> </ul>
Avco-Everett Research Lab	<ul style="list-style-type: none"> <li>- component and materials experiments</li> <li>- seed recovery</li> <li>- generator design</li> <li>- economic and environmental assessments</li> <li>- auxiliary component development</li> <li>- peaking plants</li> <li>- pollution control by gas cleaning</li> <li>- NO<sub>x</sub> control experiments</li> </ul>
Battelle Pacific Northwest Lab	<ul style="list-style-type: none"> <li>- electrode development</li> </ul>
Bechtel	<ul style="list-style-type: none"> <li>- design evaluation</li> <li>- labor and materials studies</li> <li>- cooling water evaluations</li> </ul>
British Coal Utilization Research Association	<ul style="list-style-type: none"> <li>- combustion modeling</li> </ul>
Brookhaven National Labs	<ul style="list-style-type: none"> <li>- comparative assessments</li> </ul>
Burns and Roe	<ul style="list-style-type: none"> <li>- design</li> </ul>
California Institute of Technology	<ul style="list-style-type: none"> <li>- performance studies</li> </ul>
Central Electricity Generating Board, Great Britain	<ul style="list-style-type: none"> <li>- slag buildup on heat exchangers</li> </ul>
Eindhoven, Holland	<ul style="list-style-type: none"> <li>- closed-cycle facility</li> </ul>
Electrotechnical Lab of Japan	<ul style="list-style-type: none"> <li>- oil-fired MHD -Mark V, VI</li> </ul>

TABLE 2-1 (continued)  
RECENT AND ONGOING MHD RESEARCH

EPRI	- market penetration - R&D funding
Exxon Research & Engineering Co.	- evaluation of designs
Flinders University of South Australia	- comparative assessments
Fluidyne Corporation	- air preheaters - facility design and evaluation
Foster-Wheeler	- design evaluation - evaluation of auxiliaries
Gilbert Associates Inc.	- design studies
General Electric Co.	- MHD market penetration - design and evaluation of facilities - preheater development
Hercules Powder Corp	- support studies
Hittman Associates Inc.	- comparative assessments
Institute of Gas Technology	- comparative assessments
International Atomic Energy Agency, Vienna	- MHD commercialization potential
Krzhizhnavosky Power Institute	- prototype MHD plant
Laboratory of Direct Conversion of Italy	- closed-cycle facility
Arthur D. Little, Inc.	- comparative assessment
Lockheed-Huntsville Research & Engineering	- environmental assessments
Max Planck Institute of Plasma Physics of Germany	- combustion modeling - closed-cycle facility
Maxwell Labs	- support studies

TABLE 2-1 (continued)  
RECENT AND ONGOING MHD RESEARCH

MEPPSCO	<ul style="list-style-type: none"> <li>- generator design</li> <li>- magnet design</li> </ul>
Mississippi State University	<ul style="list-style-type: none"> <li>- corrosion studies</li> </ul>
M.I.T.	<ul style="list-style-type: none"> <li>- magnet design</li> <li>- emission modeling and control</li> <li>- combustion modeling</li> <li>- modular design tool</li> <li>- generator performance</li> <li>- disc generator experiments</li> <li>- materials problems</li> <li>- seed recovery experiments</li> </ul>
Montana Energy and MHD R&D Institute	<ul style="list-style-type: none"> <li>- research facilities</li> </ul>
Montana State University	<ul style="list-style-type: none"> <li>- air preheaters</li> </ul>
National Bureau of Standards	<ul style="list-style-type: none"> <li>- materials problems</li> <li>- electrodes</li> <li>- slag characteristics</li> </ul>
National Science Foundation	<ul style="list-style-type: none"> <li>- basic research funding</li> <li>- comparative study funding</li> </ul>
North Carolina State University	<ul style="list-style-type: none"> <li>- electrode materials</li> </ul>
Nuclear Energy Agency (OECD)	<ul style="list-style-type: none"> <li>- international cooperation</li> </ul>
Oak Ridge National Labs	<ul style="list-style-type: none"> <li>- comparative assessment</li> </ul>
Parsons	<ul style="list-style-type: none"> <li>- design studies</li> </ul>
Rand Corporation	<ul style="list-style-type: none"> <li>- closed-cycle examination</li> <li>- overview studies</li> </ul>
Reynolds Metals	<ul style="list-style-type: none"> <li>- gaseous electrode development</li> </ul>
Rockwell International	<ul style="list-style-type: none"> <li>- design studies</li> <li>- space applications</li> </ul>
Stanford Research Institute	<ul style="list-style-type: none"> <li>- comparative assessments</li> </ul>

TABLE 2-1 (continued)  
RECENT AND ONGOING MHD RESEARCH

Stanford University	<ul style="list-style-type: none"> <li>- test facility</li> <li>- generator phenomena</li> <li>- magnet design and effects</li> <li>- NO<sub>x</sub> modeling and control</li> <li>- cooling requirements</li> </ul>
STD Research Corporation	<ul style="list-style-type: none"> <li>- design and systems studies</li> <li>- coal drying</li> <li>- retrofit to older plants</li> </ul>
Systems Research Labs	<ul style="list-style-type: none"> <li>- support studies</li> </ul>
Teknekron, Inc.	<ul style="list-style-type: none"> <li>- comparative assessments</li> </ul>
Tokyo Institute of Technology	<ul style="list-style-type: none"> <li>- NO<sub>x</sub> modeling</li> </ul>
TRW Energy Systems	<ul style="list-style-type: none"> <li>- evaluation of designs</li> <li>- prototype combustors</li> </ul>
University of Illinois at Chicago	<ul style="list-style-type: none"> <li>- combustion modeling</li> </ul>
University of Mississippi	<ul style="list-style-type: none"> <li>- performance studies</li> </ul>
University of Montana	<ul style="list-style-type: none"> <li>- support studies</li> </ul>
University of Pittsburgh	<ul style="list-style-type: none"> <li>- seed regeneration</li> <li>- slag effects</li> <li>- downstream components</li> </ul>
University of Tennessee	<ul style="list-style-type: none"> <li>- seed recovery</li> <li>- experimental facility</li> </ul>
University of Tokyo	<ul style="list-style-type: none"> <li>- systems studies</li> </ul>
U.S. Bureau of Mines, Morgantown	<ul style="list-style-type: none"> <li>- seed regeneration</li> <li>- seeded coal combustion properties</li> </ul>
U.S. DOE	<ul style="list-style-type: none"> <li>- R&amp;D funding</li> <li>- experimental programs</li> <li>- commercial demonstration</li> </ul>
U.S. DOE Pittsburgh Energy Research Center	<ul style="list-style-type: none"> <li>- seeding and seed recovery and regeneration</li> <li>- environmental emissions</li> <li>- combustion experiments</li> <li>- coal drying</li> </ul>

TABLE 2-1 (continued)

RECENT AND ONGOING MHD RESEARCH

U.S. EPA	- environmental assessments
U.S. NASA	- comparative study funding - design and evaluation
U.S. Senate, Office of Technology Assessment	- overview of government role in MHD - comparison with other energy cycles
U.S.S.R.	- sponsoring MHD research and development
USSR Atomic Energy Institute	- systems studies
USSR Institute for High Temperatures	- MHD research - facilities
Westinghouse Research Labs	- design and evaluation of facilities - systems studies - experimental facility
Whittaker Corporation	- unconventional designs - systems studies
Wright-Patterson AFB	- systems studies

organizations involved and the general research and development areas to which they are contributing. In addition to EPRI sponsorship, a recent tally of government funding of MHD studies (Penny, Bourgeois, Cain, 1977) showed DOE with 81%, DOD 13%, and NSF 6%, of the \$8.15 million being spent on 37 projects. Current facilities are listed in Table 2-2 and some of the future U.S. facilities are listed in Table 2-3. The approximate timing of these future facilities is shown in the ECAS study in Figure 2-2 and in an accelerated forecasted from DOE and EPRI in Figure 2-3. Two ideas about the logical process of the research and development necessary to support this facility timetable are shown in Figures 2-4 and 2-5.

Table 2-2 Main Parameters of Some Open Cycle MHD Generators Presently in Use (Argyropolis, 1976, pp 64-66)

FACILITY	OPERATION TIME	THERMAL POWER MW	ELEC. POWER MW	MASS FLOW (kg/s)	SPECIFIC ELEC. POWER (MJ/kg)	ENTHALPY EXTRACTION $\eta_{ent}$	FUEL	OXIDIZER	GENERATOR VOLUME (cm <sup>3</sup> )	ELEC. POWER DENSITY (MW/m <sup>3</sup> )	T <sub>0</sub> (°K)	P <sub>0</sub> (atm)	M inlet	ELEC-TRODES	SEED (T)
USSR IED Kiev	3 h	8.35	0.015	2	0.0075	0.0016	natural gas	O <sub>2</sub> /N <sub>2</sub> =2/3	-	-	2850	-	0.7	6 pairs	1.5 KOH in alcohol
USSR (ENIN-II)	10 min	140-160	0.2-1.5	12-14	0.014-0.1	0.0013-0.01	-	O <sub>2</sub>	20x20 20x50 L=300	1-7.5	3200	10-12	2	brass 116 pairs	1.5 K <sub>2</sub> CO <sub>3</sub> in water
USSR IHT (U-02)	200 h	5	0.075	1	0.075	0.015	-	O <sub>2</sub> /N <sub>2</sub> =1 T <sub>ox</sub> =1100°C	20x6.4 40x6.4 L=300	1.32	2900	1.2	0.8	ZrO <sub>2</sub> , Sic 52 pairs	1.7 Cs <sub>2</sub> CO <sub>3</sub> in water
USSR IHT (U-25)	1000 h	300	20	50	0.4	0.066	-	O <sub>2</sub> /N <sub>2</sub> =2/3 T <sub>ox</sub> =1200°C	38x77 38x138 L=500	12	2900	3.2	0.8	copper; ceramics 2	K <sub>2</sub> CO <sub>3</sub> in water 65%
POLAND Tech.Univ. Poznan	long term	4	-	0.8	-	-	liquid hydrocarbon	O <sub>2</sub> or pre-heated air	3xi0x50	-	3100	1	1	various materials	3.5 KOH in alcohol
POLAND IBJ	1 h	30	-	3	-	-	-	O <sub>2</sub>	-	-	-	-	-	-	KOH in alcohol
JAPAN ETL (Mark-II) hot wall	10 min	10	0.251	2.5	0.10	0.025	gas, oil	O <sub>2</sub> /N <sub>2</sub> =1 T <sub>ox</sub> =1320°C	9x15 9x25 L=120	11.6	2780	2.8	>1	graphite 30 pairs	3.3 K <sub>2</sub> SO <sub>4</sub> power K in fuel
JAPAN ETL (Mark-II) semi-hot wall	-	-	0.019	-	0.0076	0.0019	-	-	-	0.88	-	-	-	-	ZrB <sub>2</sub> (80%)

Table 2-2 Main Parameters (cont.)

FACILITY	OPERATION TIME	THERMAL POWER	ELEC. POWER	MASS FLOW (kg/s)	SPECIFIC ELEC. POWER (MJ/kg)	ENTHALPY EXTRACTION $\eta_{ent}$	FUEL	OXIDIZER	GENERATOR VOLUME (cm <sup>3</sup> )	ELEC. POWER DENSITY (MW/m <sup>3</sup> )	T <sub>0</sub> (°K)	P <sub>0</sub> (atm)	M	ELEC-TRODES	B	(T)	SEED
JAPAN ETL (Mark III)	100 h	3.6	-	0.5	-	-	diesel oil	air + O <sub>2</sub>	3x12x90	-	-	-	0.8	12 pairs	1.9	-	KOH
JAPAN ETL (Mark VI)	100 h	1	-	0.66	-	-	light oil	enriched air, T <sub>ox</sub> =1400°C	3x12x90	-	-	-	1.9	-	-	-	ag KOH
JAPAN ETL (Mark V)	1 h	25	0.5	1.5-3.5	-	-	light oil	oxygen	F <sub>1</sub> =140 cm <sup>2</sup> F <sub>2</sub> =250 cm <sup>2</sup> L=192 cm	-	-	-	∞	-	-	-	anode: stainless steel cathode: Cu-W
USA AVCO (Mark VIC)	250 sec	20	0.5	2.8	0.17	0.05	oil or kerosene, slag	O <sub>2</sub> /N <sub>2</sub> =2	F <sub>1</sub> =400 cm <sup>2</sup> F <sub>2</sub> =800 cm <sup>2</sup> L=200 cm	12.5	3200	8	2	Inonel	3.2	K <sub>2</sub> CO <sub>2</sub> [STET]	
<b>USA AVCO Mark V</b>	<b>1 min</b>	<b>-</b>	<b>50</b>														
USA WPAFB (KIVA-I)	1 min	6	0.2	0.6	0.5	0.05	toluene, JP4	O <sub>2</sub>	2.6x10 7.2x11 L=85	80	3300	10	2	50 pairs	2.7	Cs <sub>2</sub> CO <sub>3</sub>	
USA Stanford U. (M-2)	3 h	2-3	-	-	-	-	CH <sub>3</sub> OH	N <sub>2</sub> /O <sub>2</sub> =1/2	3x10x61	-	2900	1.5	8	stainless steel	2.5	1% K	
USA Stanford U. (M-8)	3 h	8	0.1	0.5	0.125	-	kerosene	O <sub>2</sub>	3.9x10 6.3x10 L=70	20	3300	5	1.7	various materials	2.5	KOH in alcohol	
USA AEDC (HPDE)	30 sec. to 460	320-460	45-65	50-65	-	.16	toluene, later with slag	N <sub>2</sub> /O <sub>2</sub> =1.25	26x51 102x128 L=920	-	3100	5.4	0.8	copper w/ granite caps	6	KOH in CH <sub>3</sub> OH	

Table 2-2 Main Parameters (cont.)

FACILITY	OPERATION TIME	THERMAL POWER	ELEC. POWER	MASS FLOW (kg/s)	SPECIFIC ELEC. POWER (MJ/kg)	ENTHALPY EXTRACTION $\eta_{ent}$	FUEL	OXIDIZER	GENERATOR VOLUME (cm <sup>3</sup> )	ELEC. POWER DENSITY (MW/m <sup>3</sup> )	T <sub>0</sub> (°K)	P <sub>0</sub> (atm)	M inlet	ELEC-TRODES	B SEED	
USA ABDC	1 min	-	20													
USA LORHO Nesting-house	100 h	4-5	.1	1.5	-	-	toluene, char, later with slag	air, T <sub>ox</sub> =900°C	8x11x100	-	2600	4	0.9	various mat'ls. 50 pairs	3 K <sub>2</sub> CO <sub>3</sub>	
USA (UTSI-I)	8 s	8.35	0.07	0.8	0.09	0.0084	kerosene & power-fuel additives	O <sub>2</sub>	9.5x20.5x120	2.8	3200	3-4.5	2	copper 60 pairs	2.2 KOH and KNO <sub>2</sub> in alcohol Cs <sub>2</sub> CO <sub>3</sub>	
USA (UTSI-II)	8 s	8.35	0.04	0.8	0.04	0.0047	coal	O <sub>2</sub>	5.8x15x90	-	3200	3-5	2	copper 40 pairs	2.2 K	
USA (UTSI-III)	long term	8.35	0.09	0.8	-	-	coal	O <sub>2</sub>	5.8x30x90	-	3000	4.5	1.4	copper	2.2 K	
USA Reynolds Metals	long term	-	-	-	-	-	diesel fuel	N <sub>2</sub> /O <sub>2</sub> =1	2.6x5.1x26	-	2200	-	<1	-	2	K
USA Reynolds Metals	long term	-	-	4.4	-	-	diesel fuel	N <sub>2</sub> /O <sub>2</sub> =1	21x36x154	-	2200	-	<1	-	4.2	K
USA PERC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	5.0

**Table 2-3 Main Parameters of Some Planned Open Cycle MHD Generators**  
 (Argyropolis, 1976, p. 67)

FACILITY	EXPECTED DATE OF OPERATION	THERMAL POWER	MHD ELEC. POWER	STEAM ELEC. POWER	MASS FLOW (kg/s)	FUEL	OXIDIZER	GENERATOR VOLUME (cm <sup>3</sup> )	T <sub>0</sub> (°K)	P <sub>0</sub> (atm)	M inlet	B (T)	SEED
USA (CFFF)	1978	20	-	-	3.6	coal							
USA (CDIF) MEMRDI	1978	50	9	9	10	coal	air T <sub>ox</sub> =2125-2250°C	-	-	8-10	.9	3.5	K <sub>2</sub> CO <sub>3</sub>
USA (ETF) MEMRDI	1981	250	70	70	46	coal	air T <sub>ox</sub> =2125-2250°C	-	-	8-10	.9	3.5	K <sub>2</sub> CO <sub>3</sub>
USA (CDP)	1980's	1000	-	500	-	coal							

Phase	Year																			Cost M\$	
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19		
I. Component/Subsystem Development																					293
II. Pilot Plant																					708
III. Demonstration Plant																					443
Total Cost																				1444*	

Figure 2-2 Schedule and Costs For Development Plan - Open Cycle MHD  
(General Electric, 1976)





Figure 2-3 Major MHD Program Phases (Jackson, et al., 1976)



**Figure 2-4 Avco Logic Flow Diagram for Coal/Open-Cycle MHD/Steam System Development Plan (NASA, 1977)**




Figure 2-5 General Electric's Revised Logic Flow Diagram for Coal/Open-Cycle MHD/Steam System Development Plan (NASA, 1977)

### 3. Plant Design Configurations

In addition to choices between open-cycle and closed-cycle there are a tremendous number of possible MHD design variations. In Phase I of the ECAS study the open-cycle variations included:

- (1) coal, solvent refined coal, or coal gasifier products as fuels;
- (2) air or oxygen-enriched air as oxidant;
- (3) direct air preheat using MHD exhaust, or indirect (separate) preheating using coal volatiles or a coal gasifier product, or combinations of direct and indirect preheats; and
- (4) steam bottoming cycles or gas-turbine bottoming cycles.

An excellent display of the MHD configuration options is shown in Figure 3-1 from (Jackson, et al., 1976). This diagram shows that for coal-fired OCMHD the principal distinguishing feature is the high-temperature preheat or regeneration procedure. The regeneration procedures could involve anything from using the MHD exhaust heat to produce a clean fuel for indirect air preheaters, to using direct air preheaters with the MHD exhaust heat utilized to generate heated, clean fuel for the MHD combustor. The simplicity of the MHD process and the relatively early stage of its development are the reasons for the tremendous variety of designs.

Receiving the most attention lately (due to low expected cost of electricity) is the OCMHD design suggested in Phase II of the ECAS study (General Electric, 1976), called NASA Case 1. This configuration uses direct air preheating at 1316 K to 1371 K (2400<sup>o</sup>F to 2500<sup>o</sup>F), direct coal-fired combustor, and a 24.1 MN/m<sup>2</sup>/811 K/811 K (3500



psi/1000<sup>0</sup>F/1000<sup>0</sup>F) steam bottoming cycle. In this system the coal processor feeds dried crushed coal to a single-stage cyclone combustor. The preheated air is mixed with the coal at a 95% stiochiometric air fuel ratio and is fired to 2700 K (4400<sup>0</sup>F). The cyclone combustor is assumed to remove 80% of the coal ash. Potassium carbonate is the seeding material. The MHD generator conditions (Beecher, et al., 1976) include a .62MPa (6 atm) pressure, .75 Mach flow rate, and 6 T magnetic field (in the equivalent Westinghouse ECAS Base Case). The MHD exhaust is at 1650 K (2511<sup>0</sup>F) and passes to the steam generator. Seed-ash is collected on the superheater surface and in the stack gas cleanup system. The seed is recycled through a Claus plant that converts part of the potassium sulfate to potassium carbonate before reuse. These are the most important features of the frontrunning configuration, additional important parameters are listed in Section 3.1.

### 3.1 Operating and Design Parameters

Even given the exact design configuration there is still a significant variation in system performance that is due to variations in operating and design parameters. For example, the air preheat temperature can play a major role in system efficiency and cost, and values of 1089 K, 1366 K, 1589 K, 1644 K, 1922 K, and 2200 K (1500<sup>0</sup>F, 2000<sup>0</sup>F, 2400<sup>0</sup>F, 2500<sup>0</sup>F, 3000<sup>0</sup>F, and 3500<sup>0</sup>F) have been explicitly investigated. This section begins with a listing of the important operating and design parameters, Table 3.1-1. This list is separated into the parameters related to the various system components, and is further segregated into the independent parameters and the

TABLE 3.1-1

## MAJOR PARAMETERS DETERMINING OCMHD PERFORMANCE

MHD GeneratorIndependent Parameters

- generator type and channel connection; linear Faraday, Hall, diagonal wall, and cylindrical configurations
- generator size and geometry
- materials
- temperatures and pressures
- working fluid
- magnetic flux density
- seed type and feed rate
- flow rate

Dependent Parameters

- enthalpy extraction ratio
- plasma flow rate
- electrical conductivity of fluid
- electron affinities of OH, CO<sub>2</sub> and AlO<sub>2</sub>
- electron-atom collision cross sections
- emissions
- power output
- Hall parameter nonuniformities
- pressure drop
- electrical loading parameter
- heat leak fraction
- enthalpy

Fuel and CombustorIndependent Parameters

- combustor type, design and stages
- combustor pressure and temperature-time history
- coal feed rate and configuration
- coal type and size, or solvent refined or gasified coal characteristics
- oxidizer type and feed rate
- air feed rate and temperature
- coal properties; ash, volatiles, moisture and so on
- drying of coal

Dependent Parameters

- air/fuel ratio
- percent slag rejection
- percent ash in flue gas
- coal moisture
- enthalpy
- pressure drop
- radioactive heat loss
- overall efficiency of combustor
- combustor residence time
- carbon burnout
- uniformity of product distribution

TABLE 3.1-1 (continued)

MAJOR PARAMETERS DETERMINING OCMHD PERFORMANCE

<p><u>Nozzle, Diffuser, Inverters, Electrodes, Insulators, Compressor</u></p> <p><u>Independent Parameters</u></p> <ul style="list-style-type: none"> <li>- size and geometry of channel, etc.</li> <li>- materials</li> <li>- nozzle area, contour</li> <li>- pressure and temperatures</li> </ul> <p><u>Dependent Parameters</u></p> <ul style="list-style-type: none"> <li>- lifetimes</li> <li>- pressure and temperature drops</li> <li>- thermal losses</li> <li>- electrical losses</li> <li>- diffuser exit temperature</li> <li>- diffuser recovery factor</li> <li>- duct wall temperature</li> <li>- heat transfer coefficients</li> <li>- nozzle heat loss</li> <li>- channel loft</li> <li>- efficiencies</li> <li>- enthalpy</li> <li>- flow rates</li> </ul> <p><u>Magnets</u></p> <p><u>Independent Parameters</u></p> <ul style="list-style-type: none"> <li>- magnet size and strength</li> <li>- support</li> <li>- magnet shape and orientation</li> </ul> <p><u>Dependent Parameters</u></p> <ul style="list-style-type: none"> <li>- bending stress</li> <li>- magnetic flux density</li> </ul> <p><u>Air Preheater</u></p> <p><u>Independent Parameters</u></p> <ul style="list-style-type: none"> <li>- design and type</li> <li>- temperatures at stages</li> <li>- pressure</li> </ul> <p><u>Dependent Parameters</u></p> <ul style="list-style-type: none"> <li>- lifetime</li> <li>- air preheater losses</li> <li>- enthalpy</li> <li>- pressure drop</li> </ul>
---

TABLE 3.1-1 (continued)

MAJOR PARAMETERS DETERMINING OCMHD PERFORMANCE

<p><u>Seed and Slag Recovery</u></p> <p><u>Independent Parameters</u></p> <ul style="list-style-type: none"><li>- combustor designs</li><li>- reactor, absorption tower, heat exchanger types and sizes</li><li>- coal properties</li></ul> <p><u>Dependent Parameters</u></p> <ul style="list-style-type: none"><li>- recovery percent</li><li>- seed form</li><li>- cost and energy losses</li></ul>
<p><u>Seed Regenerator</u></p> <p><u>Independent Parameters</u></p> <ul style="list-style-type: none"><li>- reducing process</li><li>- design and type</li></ul> <p><u>Dependent Parameters</u></p> <ul style="list-style-type: none"><li>- efficiency and cost</li><li>- seed form</li></ul>
<p><u>Steam Cycle</u></p> <p><u>Independent Parameters</u></p> <ul style="list-style-type: none"><li>- type and design</li><li>- pressures and temperatures</li><li>- heat rejection type</li></ul> <p><u>Dependent Parameters</u></p> <ul style="list-style-type: none"><li>- boiler lifetimes</li><li>- heat rejection</li><li>- heat transfer coefficients</li><li>- power turbine heat rate</li><li>- compressor turbine heat rate</li><li>- power output</li></ul>

dependent parameters, that is those values that can only be controlled through changes in independent parameters. It should be noted that dependent parameters for some components are independent choices for others.

The values for many of the parameters that are expected to be selected for the first commercial design are shown in Table 3.1-2. The Base Case ECAS OCMHD cycle parameters for (Phase I General Electric) are shown in Table 3.1-3. A comparison of major features of the Base Case with the solvent refined coal case is shown in Table 3.1-4; a comparison of magnet designs in Table 3.1-5 and 3.1-6; and a comparison of preheaters in Tables 3.1-7 and 3.1-8.

Phase I ECAS Base Cases for General Electric and Westinghouse are compared to the General Electric Phase III Base Case in Table 3.1-9. Additional Phase II OCMHD Base Case parameters are shown in Table 3.1-10 and performances in 3.1-11. Finally some interesting miscellaneous performance factors are collected in Table 3.1-12.

### 3.2 Mass Balances of Specific Designs

First it should be reiterated that no large coal-fired OCMHD's are operational. Mass balance computations to date have therefore been calculated analytically not empirically. Computer programs for these computations exist at Westinghouse, General Electric, and elsewhere, and are also being developed at MIT. Thus there is no reason to duplicate these efforts for this study, instead some already published mass balances of important specific OCMHD designs are presented here.

Table 3.1-2 Input Parameters Projected for First Commercial Sized Facility (Jackson, et al., 1976)

POWER INPUT - GROSS	2000 MWth
COMBUSTION	
Coal	Montana, Rosebud Seam
Combustor	Direct, 2-stage, 90% slag-rejection
Seed rate	K - 4% of total combustion products
PREHEATER	
Type	Direct fired, regenerative
Oxidizer temp. (K)	1644
MHD GENERATOR	
Type	Diagonal connected, 15 meter nominal
Load factor	0.7 (variable)
Magnet	Maximum field 6 tesla, superconducting
Flow	High subsonic
DIFFUSER	
Exit pressure (psia)	16.25
Recovery factor	0.8
STEAM BOTTOMING CYCLE	
Steam conditions	3500 psia (1000°F/1000°F)
Heat rejection	wet cooling tower
ENVIRONMENTAL EFFECTS	
SO <sub>2</sub>	< 1.2 lb/10 <sup>6</sup> Btu
NO <sub>x</sub>	< 0.7 lb/10 <sup>6</sup> Btu
Particulates	< 0.1 lb/10 <sup>6</sup> Btu

**Table 3.1-3 Major System Parameters for Open Cycle MHD  
General Electric Base Case (Harris, Shah, 1976)**

<u>PARAMETER</u>	<u>VALUE OR DESCRIPTION</u>
<b><u>FUEL COAL</u></b>	
TYPE	ILL #6, 10788 Btu/LB HHV
SIZE, PULVERIZED	70% THROUGH 200 MESH
MOISTURE CONTENT, DRIED	2%
OXIDIZER	AIR
<b><u>FURNACE, GASIFIER OR FUEL PROCESSING</u></b>	
COMBUSTOR TYPE	SPECIAL
COMBUSTION PRESSURE (ATM)	9
COMBUSTION TEMPERATURE (°F)	4634
AIR PREHEAT TEMPERATURE	2500
F/A RATIO RELATIVE TO STOICHIOMETRIC F/A	1.07
SLAG REJECTION	85%
<b><u>PRIME CYCLE MHD</u></b>	
TYPE	DIAGONAL
WORKING FLUID	COMBUSTION GASES
AVERAGE MAGNETIC FLUX DENSITY (TESLA)	5
COMPRESSOR PRESSURE RATIO	10.75
DIFFUSER OUTLET PRESSURE (ATM)	1.14
ELECTRIC LOAD PARAMETER	0.80
POTASSIUM SEEDING	1%
<b><u>HEAT EXCHANGER(S)</u></b>	
HIGH TEMPERATURE AIR HEATER	REFRACTORY CERAMIC STORAGE
TYPE	
GAS $\Delta P/P$	0.07
AIR $\Delta P/P$	0.02
RADIANT FURNACE	
GAS $\Delta P/P$	0.01
WATER $\Delta P$ (PSI)	570
SECONDARY FURNACE	
GAS $\Delta P/P$	0.03
STEAM $\Delta P$ (PSI)	854
AIR $\Delta P$ (PSI)	21
ECONOMIZERS	
GAS $\Delta P/P$	0.02
WATER $\Delta P$ (PSI)	21
<b><u>STEAM BOTTOMING CYCLE</u></b>	
TYPE	psi 3500/1000F/1000F
HEAT RATE FOR POWER TURBINE (BTU/kW-HR)	8160 ( $\eta = 42$ )
HEAT RATE FOR COMPRESSOR TURBINE (BTU/kW-HR)	8270 ( $\eta = 41$ )
CONDENSING PRESSURE (IN. Hg)	2.3 (106°F)
<b><u>HEAT REJECTION</u></b>	
WET MECHANICAL DRAFT COOLING TOWERS	25 CELLS
STACK GAS TEMPERATURE	251°F

Table 3.1-4 Summary of Important Parameters for ECAS OCMHD Cases (General Electric, 1976)

Base Case SRC Base Case

CYCLE PARAMETER		1932	1895
<u>Power Output (MWel)</u>			
<u>Combustion</u>			
Coal	Solvent refined coal		Illinois No. 6
Oxidizer	Air		Air
Combustor slag rejection (percent)	0		90
<u>Preheater</u>			
Firing	Direct		Direct
Oxidizer temperature (°F)	3100		2500
<u>MHD Generator</u>			
Type	Faraday		Faraday
Inlet pressure (atm)	15		9
Average magnetic field (T)	6		5
Potassium seed (percent)	1.0		1.0
Electrical load parameter	0.8		0.8
<u>Heat Exchangers</u>			
Gas (Δp/psi)	0.15		0.15
Air (Δp/psi)	0.10		0.10
<u>Steam Bottoming Cycle</u>			
Turbine inlet temperature (°F)	1000/1000		1000/1000
Turbine inlet pressure (psi)	3500		3500
Maximum feedwater temperature (°F)	232		232
<u>Air Bottoming Cycle</u>			
Turbine inlet temperature (°F)			
Pressure ratio			
<u>Heat Rejection</u>			
	Wet cooling tower		Wet cooling tower

Major Component	Unit or Module			Total Cost (\$ x 10 <sup>6</sup> )	Units Required	\$/kW Output
	Size (ft) (W x L or D) x H	Weight (lb) (x 10 <sup>3</sup> )	Cost (\$ x 10 <sup>6</sup> )			
Combustor	5.7 dia x 11 long	0.022	2.2	2.20	1	1.14
Nozzle/generator/diffuser	Inlet area 22 ft <sup>2</sup> Exit area 4100 ft <sup>2</sup> } x 250 long	2.92	7.90	7.90	1	4.09
Magnet and dewar	44 dia x 91 long	9.0	43.00	43.00	1	22.26
Radiant furnace	80 x 58.5 x 100	0.76	2.44	2.44	1	1.26
Superheater/reheater	80 x 36.5 x 56.2	8.04	19.91	19.91	1	10.31
Economizer	80 x 28.8 x 6.1	1.50	1.13	1.13	1	0.58
High-temperature air heater	34 dia x 75 high	5.29	2.67	16.00	6	8.28
Low-temperature air heater	80 x 29.0 x 26.4	2.61	10.75	10.75	1	5.56
Seed recovery system			1.00	1.00	1	0.52
Steam turbine generator set	30 x 174 x 25	4.30	12.90	12.90	1	6.68
Inverters			97.40	97.40	1	50.41

**Table 3.1-5 Magnet Design Data for Base Case MHD Generator  
Case 1 - 2000MWE Plant Size  
(General Electric, 1976)**

Channel Specifications

Inlet	1.4297 m × 1.4297 m
Exit	3.653 m × 3.653 m
Active Length	25m
Field: Inlet	2.496 T
Bo max.	5.992 T
Exit	3.12 T
$VB^2 = \int_0^{25} AB^2 dl$	11,600 m <sup>3</sup> T <sup>2</sup>

Magnet Design Data

Warm bore (circular)	Inlet	2.87 m
	Exit	6.50 m
Active length		25 m
Ampere turns		50.8 × 10 <sup>6</sup>
Ampere meters		34.2 × 10 <sup>8</sup>
Stored energy		15,200 megajoules
Current density, winding, average		2.0 × 10 <sup>7</sup> A/m <sup>2</sup>
Dewar O.D.		
	Inlet end	9.3 m
	Exit end	13.6 m
Dewar length, overall		31 m
Conductor weight		900,000 kg
Main structure weight		1,900,000 kg
	(design stress 25,000 psi)	
Internal structure & miscellaneous weight		180,000 kg
Dewar weight		750,000 kg
	Total	<u>3,730,000 kg</u>

Table 3.1-6 Magnet Design Data for Base Case MHD Generator  
Case 24 - SRC As Fuel (General Electric, 1976)

Channel Specifications

Inlet	1.067 m sq.
Exit	3.499 m sq.
Active length	~20 m
Field: Inlet	3.21 T
Peak	7.72 T
Exit	2.40 T

Magnet Design Data

Warm bore (circular):	Inlet	2.60 m
	Exit	6.36 m
Active length		20 m
Field: Inlet		3.2
Peak		7.9
Exit		2.4
$VB^2 = \int_0^{20} AB^2 dl$		13,200 m <sup>3</sup> T <sup>2</sup>
Ampere turns		76.4 × 10 <sup>6</sup>
Current density, average		2.0 × 10 <sup>7</sup> A/m <sup>2</sup>
Dewar O.D.		
Inlet end		9.8 m
Exit end		13.7 m
Dewar length		28 m
Conductor weight		1,036,000 kg
Main structure weight		2,100,000 kg
Intermediate structure & miscellaneous weight		200,000 kg
Dewar weight		<u>750,000 kg</u>
	Total	4,086,000 kg

**Table 3.1-7 Air Preheater Design Data for GE OCMHD  
Cases 1, 2 and 3 (General Electric, 1976)**

	Case 1	Case 2	Case 3
Plant Size MWe	<u>2000</u>	<u>1200</u>	<u>600</u>
Air preheat temp (°F)	2500	2500	2500
Air pressure (atm)	10.5	10.5	10.5
Number of Heaters	6 [ 2 blowdown 3 reheat 1 spare	6 [ 2 blowdown 3 reheat 1 spare	6 [ 2 blowdown 3 reheat 1 spare
Heater bed dia. (ft)	30	24	17
Heater bed height (ft)	40	40	40
Heater total height (ft)	75	70	60
Heater bed weight (tons)	1400	900	450
Heater total weight (tons)	2400	1650	1000
Pressure drop			
Air side (atm)	0.01	0.01	0.01
Gas side (atm)	0.06	0.06	0.06

**Table 3.1-8 Air Preheater Design Data for GE OCMHD  
Case 24 - Base Case with SRC As Fuel  
(General Electric, 1976)**

Air preheat temperature (°F)	3100
Air pressure (atm)	16
Number of Heaters	6 [ 2 blowdown 3 reheat 1 spare
Heater bed diameter (ft)	30
Heater bed height (ft)	40
Heater total height (ft)	75
Heater bed weight (tons)	1600
Heater total weight (tons)	2600
Pressure drop	
Air side (atm)	0.01
Gas side (atm)	0.10

**Table 3.1-9 Comparison of Performance Data for Coal/Open Cycle MHD/ Steam Systems Between ECAS Phases 1 and 2 (NASA, 1977)**

	Phase 2 G. E. conceptual powerplant	Phase 1	
		Westinghouse base case 2, point 17	G. E. base case 1
Net output power, MWe	1932	1988	1895
Coal thermal input to combustor, MWt	3688	3870	3700
Air preheat temperature, °F	2500	2400	2500
MHD inlet temperature, °F	4634	4503	4634
MHD diffuser exit temperature, °F	3662	3655	3625
MHD inlet pressure, atm	9.0	7.0	9.0
Compressor exit pressure, atm	10.7	7.6	10.5
Airflow, lb/sec:			
Primary	2492	2653	2486
Secondary	189	279	187
MHD inverter output power, MWe	1406	1230	1399
Compressor power required <sup>a</sup> , MWe	377	307	361
Steam turbine-generator output, MWe	587	821	555
Powerplant gross power output, MWe	1993	2051	1954
Ratio of the difference of MHD power and compressor power to plant gross power	0.52	0.45	0.53
Auxiliary power required, MWe	50.7	63	55.6
Ratio of auxiliary power to powerplant gross power	0.025	0.031	0.028
Coal thermal input to seed-reprocessing system, MWt	311	213	231
Ratio of coal for seed reprocessing to total coal	0.078	0.052	0.059
MHD efficiency, MHD power minus compressor power divided by amount of coal to combustor	0.279	0.238	0.281
Steam-cycle efficiency (including generator)	0.420	0.420	0.400
Thermodynamic efficiency, ratio of gross power to amount of coal to combustor	0.540	0.530	0.528
Overall efficiency, ratio of net power to total coal used	0.483	0.487	0.483

<sup>a</sup>Given in electric power even if shaft driven.

**Table 3.1-10 Major Design Parameters of Coal/Open Cycle MHD/ Steam System - ECAS Phase 2 (NASA, 1977)**

Coal type . . . . .	Illinois #6
Moisture content of coal delivered to combustor, percent . . . . .	2
Air preheat temperature, °F . . . . .	2500
Combustion pressure, atm . . . . .	9
Combustion temperature, °F . . . . .	4634
Combustor fuel-air ratio relative to stoichiometric . . . . .	1.07
Combustor slag rejection, percent . . . . .	85
Slag carryover to channel, percent . . . . .	15
Generator type . . . . .	Diagonal wall
Average magnetic flux density, T . . . . .	5
Electrical load parameter. . . . .	0.8
Potassium seed, percent . . . . .	1
Steam-bottoming-cycle conditions, psig/°F/°F . . . . .	3500/1000/1000
Cooling tower type. . . . .	Wet mechanical draft
Stack-gas temperature, °F . . . . .	251

**Table 3.1-11 Summary of Performance and Cost for Coal/Open Cycle MHD/Steam System - ECAS Phase 2 (NASA, 1977)**

Net powerplant output (60 Hz; 500 kV), MWe . . . . .	1932.2
Thermodynamic efficiency, percent . . . . .	54.0
Powerplant efficiency, percent . . . . .	49.8
Overall energy efficiency, percent . . . . .	48.3
Coal consumption, lb/kW-hr . . . . .	0.655
Total wastes, lb/kW-hr . . . . .	0.082
Powerplant capital cost, dollars . . . . .	1391.1×10 <sup>6</sup>
Powerplant capital cost, \$/kWe . . . . .	720.0
Cost of electricity (capacity factor, 0.65), mills/kW-hr:	
Capital . . . . .	22.7
Fuel . . . . .	7.3
Operation and maintenance . . . . .	1.7
Total. . . . .	31.8
Estimated time of construction, yr . . . . .	6.5
G. E. estimate of approximate date of first commercial service . . . . .	1996-1999

TABLE 3.1-12

## PROJECTED OCMHD OPERATING CHARACTERISTICS

<u>Full Load Heat Rate</u> (Pomeroy, <u>et al.</u> , 1978) (Pepper, Yu, 1974)	7068 Btu/kWh 6600 Btu/kWh
<u>Forced/Planned Outage Rate</u> (Pomeroy, <u>et al.</u> , 1978) (Jackson, <u>et al.</u> , 1976)	20%/15% 20% total unavailability
<u>Minimum Load</u> (Pomeroy, <u>et al.</u> , 1978) (Pomeroy, <u>et al.</u> , 1978)	60% full capacity 85% of full efficiency
<u>Lifetime</u> (Beecher, <u>et al.</u> , 1976)	30 years


Perhaps the most important design, certainly the most often cited, is the ECAS General Electric Base Case. The first mass and energy balance schematic of this case showed the potential of flexibility of input fuels, Figure 3.2-1. A slightly revised and later version of this schematic is shown in Figure 3.2-2.

The ECAS Phase I Westinghouse equivalent Base Case is shown in the schematic diagram in Figure 3.2-3 (Base Case 2). The other major configurations studied by Westinghouse included a coal gasifier, shown in Figure 3.2-4, and a char fuel option, shown in Figure 3.2-5.

Another important mass and energy schematic is that developed for the U.S. Department of Energy that is to represent the goal for the first commercial facility, see Figures 3.2-6 and 3.2-7.


EPRI has also sponsored mass and energy schematics, and that closest to the ECAS Base Cases is shown in Figure 3.2-8. Figure 3.2-9 shows a scheme for increasing the stoichiometric air ratio to 120%. This cycle is incorporated into the other EPRI-sponsored schematic in Figure 3.2-10 as an attempt to maximize  $\text{NO}_x$  and extract it as a fixed nitrogen source for fertilizers.

Aside from these system-wide schematics there are a number of mass and energy balances of particular types of components. For example, perhaps the most important of these are the seed regeneration schematics which include the ECAS schematics, Figure 3.2-11, Tables 3.2-1 and 3.2-2, as well as others, Figure 3.2-12, Tables 3.2-3, 3.2-4 and 3.2-5.




**Figure 3.2-1 Open-Cycle MHD for GE ECAS Base Case 1 (General Electric, 1976)**





Location	Point No.	Pressure, Psla	Temperature, °F	Flow, lb/s
Ambient	0	14.696	59.0	2768.5
Compressor Inlet	1	14.40	59.0	2768.5
Compressor Outlet	2	95.36	465.2	2768.5
Preheater Outlet	3	92.58	2398.4	2768.5
Combustor Outlet	4	88.18	4414.4	3144.3
MHD Duct Entrance	5	59.18	4185.8	3144.3
MHD Duct Exit	6	13.09	3460.4	3144.3
Diffuser Exit	7	17.00	3644.0	3144.3
Preheater Exit	8	16.52	2538.0	3435.8
Air Quench Chamber Exit	9	15.58	1880.0	3435.8
Steam Generator Exit	10	14.696	305.0	3435.8

**Figure 3.2-3** Schematic Diagram and State Points for Open Cycle MHD Westinghouse ECAS Base Case 2 (Westinghouse, 1976)



Location	Point No.	Pressure, Psia	Temperature, °F	Flow, lb/s
Ambient	0	14.696	59.0	1710.2
Compressor Inlet	1	14.40	59.0	1710.2
Compressor Outlet	2	158.94	603.8	1710.2
Air Preheater Outlet	3	154.31	2587.4	1710.2
Combustor Outlet	4	146.96	4400.0	3030.2
MHD Duct Entrance	5	99.02	4119.6	3030.2
MHD Duct Exit	6	13.54	3280.4	3030.2
Diffuser Exit	7	17.00	3446.0	3030.2
Air Preheater Exit	8	16.52	2230.4	3210.2
Air Quench Chamber Exit	9	15.58	1680.0	3210.2
Steam Generator Exit	10	14.696	305.0	3210.2
Fuel Preheater Entrance	11	158.90	1600.0	1282.9
Fuel Preheater Exit	12	154.31	2591.0	1282.9

**Figure 3.2-4 Schematic Diagram and State Points for Open Cycle MHD Westinghouse ECAS Base Case 3 (Westinghouse, 1976)**






Figure 3.2-6 Air-Gas Side Balance of OCMHD (Jackson, et al., Oct. 1976)

LEGEND:

- H - ENTHALPY - BTU/LB
- W - FLOW / LB/HR
- P - PRESSURE - PSIA
- F - TEMPERATURE - F DEGREES




Figure 3.2-7 Steam Side Balance of OCMHD (Jackson, et al., Oct. 1976)




Figure 3.2-8 Air-Gas Side Flow Diagram-EPRI Case 2 (Cutting, et al., 1977)




Figure 3.2-9 Thermodynamic State Points and Flowrates for Topping Cycle-120% Stoichiometric Air EPRI Case 4 (Cutting, et al., 1977)





Figure 3.2-10 Air-Gas Side Flow Diagram-EPRI Case 4 (Cutting, et al., 1977)



**Figure 3.2-11** Simplified Flow Diagram of Seed Regenerative System for Westinghouse ECAS Base Case 2 (Westinghouse, 1976)

Table 3.2-1 Flow Chart for Seed Regeneration System for Westinghouse ECAS Base Case 2 (Westinghouse, 1976)

Flow Name	Air Feed	N <sub>2</sub> Rejection	Power	O <sub>2</sub>	Power	Coal Feed	Power	Ash Reject	Exhaust	O <sub>2</sub>	O <sub>2</sub>	Process Gas	Seed + Ash	Solids + Gas	Warmed Gas
Flow Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Mass Rate, kg/s	73.99	56.75	17.24	300	21.72	300	2.09	1144	7.18	14.2	3.04	43.5	36.55	80.05	36.3
Temperature, °K	300	300	300	101	101	101	1520	101	370	669	669	1144	350	960	760
Pressure, kPa	101	101	101	101	101	101	1520	101	101	1722	1722	1520	101	1520	1418
Power, kW		16136	1483		331.65				0.7066						
N <sub>2</sub> , Mole Fraction	0.79	1.0		0					0	0	0	0	0	0	0
H <sub>2</sub>	0	0		0					0	0	0	0.2788		0.2788	0.2167
CO	0	0		0					0.1632	0	0	0.3764		0.3764	0.2927
CO <sub>2</sub>	0	0		0					0.1048	0	0	0.1464		0.1464	0.3921
H <sub>2</sub> O	0	0		0					0	0	0	0.1324		0.1324	0.0128
H <sub>2</sub> S	0	0		0					0	0	0	0.011		0.011	0
CH <sub>4</sub>	0	0		0					0	0	0	0.0551		0.0551	0.0856
SO <sub>2</sub>	0	0		0					0.0254	0	0	0		0	0
O <sub>2</sub>	0.21	0		1.0					0	1.0	1.0	0		0	0
S, kg/s													0	0	0
K <sub>2</sub> SO <sub>4</sub>													32.71	32.71	
K <sub>2</sub> CO <sub>3</sub>													0	0	
Ash								2.09					3.84	3.84	
Molecular Weight (Gas)	28.6	28							29.66	32	32	21.3		21.3	27.5

**Table 3.2-2 Flow Chart for Seed Regeneration System for Westinghouse ECAS  
Base Case 2 (cont'd)**

Flow Name	Steam	Process Gas	Cold Gas	Expanded Gas	Cool Process Gas	Cool Process Gas	Cool Process Gas	Power	Power	Cool Water Make	Evap. Water	Sulfur + Water	K <sub>2</sub> CO <sub>3</sub> + K <sub>2</sub> SO <sub>4</sub>	Ash + Seed	Hot Gas to MHD	Steam Water
Flow Number	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	
Mass Rate, kg/s	11.89	80.05	36.3	36.3	80.05	49.39	36.3	36.3	8.6	8.6	16.13	22.61	8.05	35.2	11.89	
Temperature, °K	478	1040	332	598	541	541	1428	607	300	373	420	541	541	899	478	
Pressure, kPa	1722	1499	1428	607	1469	1444			101	101	1418	1418	1418	607	1722	
Power, kW							9.2	221								
N <sub>2</sub> Mole Fraction	0	0	0	0	0	0			0	0	0	0	0	0	0	0
H <sub>2</sub>	0	0.1522	0.2167	0.2167	0.1522	0.1522			0	0	0	0	0	0	0.2167	0
CO	0	0.2055	0.2927	0.2927	0.2055	0.2055			0	0	0	0	0	0	0.2927	0
CO <sub>2</sub>	0	0.2753	0.3921	0.3921	0.2753	0.2753			0	0	0	0	0	0	0.3921	0
H <sub>2</sub> O	1.0	0.2078	0.0128	0.0128	0.2078	0.2078			1.0	1.0	1.0	1.0	1.0	0.0128	1.0	
H <sub>2</sub> S	0	0.0990	0	0	0.0990	0.0990			0	0	0	0	0	0	0	0
CH <sub>4</sub>	0	0.0601	0.0856	0.0856	0.0601	0.0601			0	0	0	0	0	0.0856	0	
SO <sub>2</sub>	0	0	0	0	0	0			0	0	0	0	0	0	0	0
O <sub>2</sub>	0	0	0	0	0	0			0	0	0	0	0	0	0	0
S, kg/s		0										6.01	0	0		
K <sub>2</sub> SO <sub>4</sub>		4.28										0	3.61	0.673		
K <sub>2</sub> CO <sub>3</sub>		22.54										0	19.0	3.54		
Ash		3.84										0	0	3.84		
Molecular Weight (Gas)	18	26.3	27.5	27.5	26.3	26.3			18	18	18	18	18	27.5	18	



**Table 3.2-3 Solid and Liquid Streams - Material Balance for Base Case MHD Processing Scheme (Bergman, et al., 1977)**

<u>Solid or Liquid Streams</u>								
Flow Stream*	Coal**	Ash***	K <sub>2</sub> SO <sub>4</sub>	Sulfur (lb/hr)	K <sub>2</sub> S	K <sub>2</sub> CO <sub>3</sub>	H <sub>2</sub> O	Enthalpy**** H (Btu/hr)  x 10 <sup>-6</sup>
A		4750	82100			4700		
B			820			50		
C		4700	810			50		
D		50	80460			4600	345080	
E		50	80460			4600		
F							345080	
G							78500	
H							33500	
I		10	12070			700		
J		40	68390			3900		-257.32
K	25370						1015	-29.76
L	1270	2280						-11.19
M		300	1370		42300	3910		-68.27
N		300	1370		1270	55470		-192.90
O				11600				0.87
P			1750					
Q		310	15190		1270	55470		

\*See Figure 3.2-12

\*\*Coal Analysis (4.95% H, 76.1% C, 1.0% N, 4.93% O, 3.0% S, 10.0% Ash, 4 Kg H<sub>2</sub>O/100 Kg dry coal)

\*\*\*Ash Analysis (28.0% Al<sub>2</sub>O<sub>3</sub>, 4.4% CaO, 15.0% Fe<sub>2</sub>O<sub>3</sub>, 1.6% K<sub>2</sub>O, 1.1% MgO, 0.8% Na<sub>2</sub>O, 0.5% P<sub>2</sub>O<sub>5</sub>, 46.5% SiO<sub>2</sub>, 1.3% TiO<sub>2</sub>)

\*\*\*\*At 298 K and 1 atm the enthalpy of all elements in that physical state is 0.

**Table 3.2-4 Gaseous Streams - Material Balance for Base Case MHD Seed Processing Scheme (Bergman, et al., 1977)**

Flow Stream*		Mole %									Volumetric Flow Rate	Enthalpy
No	Name	Ar	CO <sub>2</sub>	CO	H <sub>2</sub>	H <sub>2</sub> O	H <sub>2</sub> S	N <sub>2</sub>	O <sub>2</sub>	X	scfh** X 10 <sup>-6</sup>	H*** X 10 <sup>-6</sup> Btu/hr
1.	Gasifier Air	0.92	0.03	-	-	1.26	-	77.10	20.69	-	1.43	21.91
2.	Producer Gas	0.70	3.06	24.86	8.80	3.67	0.29	58.64	-	0.08	1.92	-5.68
3.	Reducer Off-gas to heat recovery	0.70	24.25	3.67	1.31	11.16	0.29	58.54	-	0.08	1.25	-153.33
4.	Reducer Off-gas to regeneration	0.70	24.25	3.67	1.31	11.16	0.29	58.54	-	0.08	0.66	-80.60
5.	Steam	-	-	-	-	100.00	-	-	-	-	0.087	-23.32
6.	Regenerator Off-gas	0.75	4.34	3.95	1.40	4.34	22.01	63.12	-	0.09	0.62	-16.29
7.	Claus Plant Air	0.92	0.03	-	-	1.26	-	77.10	20.69	-	0.40	-1.48
8.	Claus Plant Tail Gas	0.64	5.46	-	-	18.23	.35	74.95	-	0.40	0.955	-65.57

\* See Figure 3.2-12

\*\* The molar gas volume is taken to be 359 ft<sup>3</sup> at 273 K and 1 atm.

\*\*\* At 298 K and 1 atm the enthalpy of all elements in that physical is 0.

**Table 3.2-5 Energy Requirements for Seed Desulfurization in Base Case (Bergman, et al., 1977)**

Coal Input (Mwt)	98.2
Thermal Input (Mwt)	(6.92)
Air preheat	(0.51)
Steam for regeneration reaction	
Total	(7.43)
Thermal Output (Mwt)	
Gasifier steam	2.63
Reducer steam	11.79
Regenerator steam	11.44
Claus plant steam	13.77
Reducer gas, sensible heat, and heating value	15.87
Solids sensible heat	3.59
	59.09
Net heat recovered (Mwt)	51.60
Electricity produced (40% efficiency, MWe)	20.64
Electrical input for auxiliaries (compressors, pumps, etc., MWe)*	(0.32)
Credit for carbonate production (MWe)	3.00
Net electricity production (MWe)	23.32
Effect on Efficiency	
$\frac{1000 + 23.32}{2000 + 98.2} = \frac{1023.3}{2098.2} = 48.77$	
Loss of Efficiency	50.00 - 48.80 = 1.23 points

\*Includes seed leaching system energy consumption and assumes steam drives for pumps and gas compressors above 50 HP.

### 3.3 Energy Efficiency Evaluations

Table 3.3-1 shows the wide spread of estimates of OCMHD efficiencies. Of course some of this variation is due to lack of data and some is due to differences in designs. The energy losses at the points in several specific designs can be computed from the schematics in the previous section. This section begins with some general energy loss information and proceeds to the specific energy effects of changes in various design and operating parameters.

In comparison with other advanced energy cycles the Phase I ECAS studies shown how OCMHD's appear now to be competitive, Figures 3.3-1 and 3.3-2. With the axes reversed Figure 3.3-3 shows a slightly different set of results directly from the Westinghouse ECAS report. In the detailed ECAS Phase II studies the energy balance is shown in the flow chart in Figure 3.3-4. Table 3.3-2 displays a slightly more explicit breakdown of combustion losses; Table 3.3-3 shows additional detail on energy use of auxiliary components, and Table 3.3-4 shows a similar loss breakdown for the "reference" commercial facility of the future.

The best way to determine the energy efficiency changes due to particular parameter variations is currently through parametric investigations in the analytic system models. Some of these studies have been done as part of ECAS Phase I, Table 3.3-5. Unfortunately there were not enough of these parameteric studies to allow for a unique solution for the effects of various parametric changes. Statistically stated there are not enough values to ensure that predictive formulae would not capitalize on chance effects in the observed data. There have been some

TABLE 3.3-1

PROJECTED OVERALL OCMHD ENERGY EFFICIENCIES

Reference	Estimate
(Pomeroy, et al., 1978)	48.3% - 49.2%
(Cutting, et al., 1977)	46% - 46.9%
(NASA, 1977)	48.3% - 48.7%
(Penny, Bourgeois, Cain, 1977)	55% - 60%
(Bergman, Bienstock, 1976)	45.6% - 50.14%
(Jackson, et al., 1976)	47%
(NASA, 1976)	46% - 54% low Btu Westinghouse data
(NASA, 1976)	loss of 3% for seed reprocessing associated with high-sulfur coal
(Seikel, Harris, 1976)	41% - 53% (GE Co.)
(Seikel, Harris, 1976)	42% - 50% (WE Co.)
(Seikel, Harris, 1976)	48.3% (GE Co.)
(Westinghouse, 1976)	44% - 49% direct air preheat
(Westinghouse, 1976)	44% - 54%
(General Electric, 1975)	44% - 55%
(General Electric, 1975)	40% - 46% with solvent refined coal
(Pepper, Yu, 1975)	52% thermal
(Powell, Ulmer, 1974)	50% - 55%
(Feldmann, Simons, Bienstock, 1970)	50.8% - 51.9% thermal efficiency
(Hals, Jackson, 1969)	50% - 60%






Figure 3.3-1 Effect of Overall Energy Efficiency on Cost of Electricity in General Electric Results with Shaded Area OCMHD (Seikel, Harris, 1976)




**Figure 3.3-2 Effect of Overall Energy Efficiency on Cost of Electricity in Westinghouse Results with Shaded Areas OCMHD (Seikel, Harris, 1976)**



- A-Fuel Cell Steam Bottoming
  - 1-Molten-Carbonate
  - 2-Solid Electrolyte
- B-Fuel Cell (Phosphoric Acid)
- C-Alkaline Fuel Cells
- D-Liquid Metal MHD
- E-Recuperated-Open-Cycle Gas Turbine
- F-Closed Recuperated Gas Turbine (Coal)
- G-Recuperated-Closed-Cycle Gas Turbine
- H-Steam (Atmospheric Boiler)
- I-Steam (Pressurized Fluidized Bed Boiler)
- J-Steam (Pressurized Boiler)
- K-Distillate-Burning Combined-Gas Turbine
- L-Open-Cycle MHD
- M-Metal Vapor Rankine Topping Cycle
- N-Combined-Closed-Cycle Gas-Steam Turbine
- O-Coal Burning Combined-Cycle-Gas Steam Turbine

**Figure 3.3-3** Advanced Energy-Conversion Systems - Range of Results with Shaded Area UCMHD (Beecher, et al. 1976)



**Figure 3.3-4** Simplified Energy Flow Diagram for Phase 2 Conceptual Powerplant - Coal/Open Cycle MED/Steam System (NASA, 1977)

**Table 3.3-2 Energy Balance for Combustion Flow  
(Harris, Shah, 1976)**

---

<u>Energy Outputs</u>		
*MHD power output		1420
*Combustor/channel/diffuser cooling		235
*Radiant furnace heat transfer		983
*HTAH heat transfer		857
*Secondary furnace heat transfer		1298
*(Economizers		328
(Coal dryers		8
Leaving losses		370
Coal ash (sensible + latent)	22	
K <sub>2</sub> SO <sub>4</sub> (sensible + latent)	10	
Combustion gas (sensible)	183	
Combustion gas (latent)	155	
<u>Energy Inputs Other Than Combustion</u>		
Air heating (857 + 539)		1396
Air compressor power		372
Coal heating in mills, dryers		8
<u>Net Energy Output</u>		3723 MWt
<u>Combustion Energy Input</u>		3750 MWt
Fuel HHV @ 10.788 Btu/lb	3688	
Correction for SO <sub>x</sub> + K <sub>2</sub> SO <sub>4</sub> (G)	17	
Condensation and solidification of K <sub>2</sub> SO <sub>4</sub>	45	
Excess Energy Input		27 MWt

---

\*Values specified by system advocate

**Table 3.3-3 Auxiliary Power Requirements and Electrical Losses for ECAS Open Cycle MHD (Harris, Shah, 1976)**

<u>ITEM</u>	<u>ASSUMPTIONS</u>	<u>NO. OF UNITS</u>	<u>MW<sub>e</sub> EACH</u>	<u>TOTAL MW<sub>e</sub></u>
<b>PUMPS</b>				
CONDENSATE CIRCULATING WATER	A/E ESTIMATE	4		1.46
	PROPORTIONAL TO COOLING TOWER HEAT LOAD	3		4.61
AIR BLOWER	$\eta = 80\%$	1		1.00
COOLING TOWERS	PROPORTIONAL TO HEAT LOAD	25		2.15
COAL HANDLING	% OF EQUIPMENT RATING			2.25
COAL PROCESSING	EQUIPMENT RATING			14.00
MHD COMPONENTS	0.75% MHD POWER			10.50
TURBINE AUXILIARIES	0.75% STEAM POWER			6.90
"HOTEL" LOAD	A/E ESTIMATE			6.37
MAKEUP WATER TREATMENT	A/E ESTIMATE			.75
INTAKE STRUCTURE	A/E ESTIMATE			.75
INVERTER LOSSES	1% MHD D-C OUTPUT			14.2
TRANSFORMER LOSSES	0.5% 60 Hz GENERATION			9.96
				<b>74.9</b>

**Table 3.3-4 OCMHD System Energy Balance for Eventual Commercial OCMHD (Jackson, et al., 1976)**

	KW	KW
<b>GENERATORS</b>		
MHD	634,000	
Steam Turbine	370,408	
Subtotal Generators		1,004,408
<b>MOTORS (CALCULATED)</b>		
Secondary Air Fan	484	
Circulating Water Pump	4,907	
Condensate Pump	1,230	
Boiler Feed Booster Pump	766	
Induced Draft Fan	7,556	
Subtotal Motors		-14,943
<b>PLANT AUXILIARIES (ESTIMATED)</b>		
Main Steam Turbine	295	
Fuel Handling	6,307	
Ash Handling	1,636	
Service Water System	293	
MHD Transformer	12,683	
Steam Turbine Transformer	5,548	
Seed Handling	10,000	
Inverter	6,311	
Cleanup System	13,671	
Magnet	1,000	
Miscellaneous	1,936	
Subtotal Auxiliaries		-59,680
<b>TOTAL PLANT OUTPUT (NET)</b>		929,785
<b>COAL BURNER</b>		
LB/HR	616,009	
HHV	11,081	
BTU/SEC	1,896,111	
KW <sub>th</sub>	2,000,000	
<b>STATION HEAT RATE (BTU/KWH)</b>		7341
<b>(BASED ON HHV)</b>		
<b>STATION EFFICIENCY (%)</b>		46.50

**Table 3.3-5 Parametric Variations for General Electric ECAS Task I Study Open Cycle MHD (Corman, et al., 1976)**

Parameters	Common Elements: Direct Coal Combustion, Avco Combustors, and Refractory S														
	Case 1*	2	3	4	5	6	7	8**	9	10	11	12	13	14	15
<b>Power Output (MWe)</b>	1895	1180	599	1870	1867	1888	1888	1426	1991	1994	2017	2073	1738	1929	1799
<b>Combustion</b>															
Coal	Ill. #6	→		Mont	N. D.	Ill. #6									
Oxidizer	Air								Air/O <sub>2</sub>	Air					
Combustor slag rejection (percent)	90					80	0	90							
<b>Preheater</b>															
Firing	Direct									Indirect	Direct				
Oxidizer temperature (°F)	2500								1500	3100			2000	2500	
<b>MHD Generator</b>															
Type	Faraday														
Inlet pressure (atm)	9	8.9	8.7	7	6.5	9	→	7	10.2	11.5	13.0	16	6	8.7	9
Average magnetic field (T)	5											6	5		
Potassium seed (percent)	1.0														
Electrical load parameter	0.8													0.85	0.7
<b>Heat Exchangers</b>															
Gas (Δp/p)	0.15														
Air (Δp/p)	0.10														
<b>Steam Bottoming Cycle</b>															
Turbine inlet temperature (°F)	1000/1000														
Turbine inlet pressure (psi)	3500														
Maximum feedwater temperature (°F)	232														
<b>Air Bottoming Cycle</b>															
Turbine inlet temperature (°F)	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Pressure ratio	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
<b>Heat Rejection (in. Hg)</b>	WCT														
	1.5														
<b>Actual Powerplant Output (MWe)</b>	1895	1180	599	1870	1867	1888	1888	1426	1991	1994	2017	2073	1738	1929	1799
<b>Thermodynamic Efficiency (percent)</b>	52.8	52.0	52.3	49.6	48.4	52.7	52.7	51.6	50.0	55.5	56.1	57.7	48.6	53.7	50.2
<b>Powerplant Efficiency (percent)</b>	49.2	48.5	48.7	47.9	46.5	49.1	49.1	47.2	46.9	51.8	52.4	53.9	45.1	50.1	46.8
<b>Overall Energy Efficiency (percent)</b>	48.3	47.6	47.8	47.8	46.3	48.1	48.1	46.1	46.1	50.8	51.4	52.8	44.3	49.2	45.9
<b>Coal Consumption (lb/kWh)</b>	0.65	0.67	0.66	0.80	1.07	0.66	0.66	0.69	0.69	0.62	0.62	0.60	0.71	0.64	0.69
<b>Plant Capital Cost (\$ million)</b>	2090	1239	715	2060	2107	2092	2091	2018	2016	2164	2152	2173	2052	2116	2059
<b>Plant Capital Cost (\$/kWe)</b>	1102	1049	1193	1101	1128	1108	1107	1415	1012	1085	1067	1068	1181	1096	1144
<b>Cost of Electricity, Capacity Factor = 0.65</b>															
Capital (mills/kWh)	34.9	33.2	37.7	34.8	35.7	35.0	35.0	44.7	32.0	34.3	33.7	33.1	37.3	34.7	36.2
Fuel (mills/kWh)	6.2	6.3	6.3	6.1	6.3	6.3	6.3	6.6	8.8	5.9	5.9	5.7	6.8	6.1	6.6
Maintenance and operating (mills/kWh)	2.8	2.9	3.2	2.9	2.9	2.8	2.8	3.6	2.3	2.9	2.7	2.6	3.0	2.7	2.9
Total (mills/kWh)	43.9	42.4	47.3	43.8	44.9	44.1	44.1	55.0	43.1	43.1	42.3	41.4	47.1	43.5	45.6
<b>Sensitivity</b>															
Capacity factor = 0.50 (total mills/kWh)	55.1	53.2	59.6	55.2	56.5	55.4	55.4	69.5	53.4	54.2	53.2	52.1	59.2	54.7	57.4
Capacity factor = 0.80 (total mills/kWh)	36.8	35.6	39.6	36.8	37.7	37.0	37.0	45.9	36.6	36.1	35.4	34.7	39.6	36.5	38.3
Capital Δ = 20 percent (Δ mills/kWh)	7.0	6.6	7.5	7.0	7.1	7.0	7.0	8.9	6.4	6.9	6.7	6.6	7.5	6.9	7.2
Fuel Δ = 20 percent (Δ mills/kWh)	1.2	1.3	1.3	1.2	1.3	1.3	1.3	1.3	1.3	1.2	1.2	1.1	1.4	1.2	1.3
<b>Estimated Time for Construction (years)</b>	7	6	6	7	7	7	7	7	7	7	7	7	7	7	7
<b>Estimated Date of 1st Commercial Service (year)</b>	1997	1997	1997	1997	1997	1997	1997	1997	1993	1993	1999	1999	1995	1997	1997

\*Base case 1.  
 \*\*Base case 1 configuration, reduced power output.  
 † Base case 2.

DCT = Dry cooling tower  
 HT = High temperature  
 Ill. = Illinois  
 Mont = Montana  
 N. D. = North Dakota  
 WCT = Wet cooling tower

Table 3.3-5 (cont'd)

Parameters	Storage HT Air Preheater								Common Elements: SRC Fuel, Avco Combustor, and Refractory Storage HT Air Preheater						
	16	17	18	19	20	21	22	23	24+	25	26	27	28	29	30
<b>Power Output (MWe)</b>	1701	1895	1895	1883	1901	1870	1999	1889	1932	1754	2005	1931	1937	1942	1919
<b>Combustion</b>															
Coal															
Oxidizer															
Combustor slag rejection (percent)									0						
<b>Preheater</b>															
Firing															
Oxidizer temperature (°F)									3100	2500	3600	3100			
<b>MHD Generator</b>															
Type				Diagonal Faraday					Faraday						
Inlet pressure (atm)									15	9	20	15			
Average magnetic field (T)		6	7	5					6			5	7	6	
Potassium seed (percent)					0.5	1.5	1.0							0.5	1.5
Electrical load parameter	0.6	0.8													
<b>Heat Exchangers</b>															
Gas (Δp/p)															
Air (Δp/p)															
<b>Steam Bottoming Cycle</b>															
Turbine inlet temperature (°F)									1000/1000						
Turbine inlet pressure (psi)									3500						
Maximum feedwater temperature (°F)									232						
<b>Air Bottoming Cycle</b>															
Turbine inlet temperature (°F)	--	--	--	--	--	--	2400	--	--	--	--	--	--	--	--
Pressure ratio	--	--	--	--	--	--	10	--	--	--	--	--	--	--	--
<b>Heat Rejection (in. Hg)</b>								DCT 1.8	WCT 1.5						
<b>Actual Powerplant Output (MWe)</b>	1701	1895	1895	1883	1901	1870	1999	1889	1932	1754	2005	1931	1937	1942	1919
<b>Thermodynamic Efficiency (percent)</b>	47.6	52.8	52.8	52.5	53.0	52.1	55.5	52.8	58.2	53.0	60.4	58.2	58.4	58.6	57.9
<b>Powerplant Efficiency (percent)</b>	44.2	49.2	49.2	48.9	50.4	47.6	51.9	49.1	56.8	51.6	58.9	56.8	56.9	57.1	56.4
<b>Overall Energy Efficiency (percent)</b>	43.4	48.3	48.3	48.0	49.9	46.3	50.9	48.1	44.3	40.2	46.0	44.3	44.4	44.5	44.0
<b>Coal Consumption (lb/kWh)</b>	0.73	0.65	0.65	0.66	0.63	0.68	0.62	0.66	0.71	0.79	0.69	0.71	0.71	0.71	0.72
<b>Plant Capital Cost (\$ million)</b>	2036	2028	2024	2089	2105	2089	2304	2153	1866	1783	1883	1870	1852	1873	1859
<b>Plant Capital Cost (\$/kWe)</b>	1197	1069	1067	1109	1107	1117	1152	1140	965	1016	939	968	956	964	968
<b>Cost of Electricity, Capacity Factor = 0.65</b>															
Capital (mills/kWh)	37.8	33.8	33.8	35.1	35.0	35.3	36.4	36.0	30.5	32.1	29.7	30.6	30.2	30.5	30.6
Fuel (mills/kWh)	7.0	6.2	6.2	6.3	5.9	6.6	5.9	6.3	10.8	11.9	10.4	10.8	10.8	10.8	10.9
Maintenance and operating (mills/kWh)	3.1	2.8	2.8	2.8	2.7	2.8	3.2	2.8	2.8	3.0	3.0	2.8	2.8	2.8	2.8
Total (mills/kWh)	47.9	42.8	42.7	44.1	43.7	44.7	45.6	45.1	44.1	47.0	43.1	44.2	43.8	44.0	44.3
<b>Sensitivity</b>															
Capacity factor = 0.50 (total mills/kWh)	60.2	53.8	53.7	55.5	55.0	56.1	57.5	56.7	54.1	57.6	52.9	54.3	53.7	54.0	54.4
Capacity factor = 0.80 (total mills/kWh)	40.2	36.0	35.9	37.0	36.6	37.6	38.1	37.8	37.9	40.4	37.0	38.0	37.6	37.8	38.1
Capital Δ - 20 percent (Δ mills/kWh)	7.6	6.8	6.8	7.0	7.0	7.1	7.3	7.2	6.1	6.4	5.9	6.1	6.0	6.1	6.1
Fuel Δ - 20 percent (Δ mills/kWh)	1.4	1.2	1.2	1.3	1.2	1.3	1.2	1.3	2.2	2.4	2.1	2.2	2.2	2.2	2.2
<b>Estimated Time for Construction (years)</b>	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
<b>Estimated Date of 1st Commercial Service (year)</b>	1997	1997	1997	1997	1997	1997	1999	1997	1999	1995	2003	1999	1999	1999	1999

additional investigations of efficiency changes due to variations in one parameter, the moisture content of the coal, Tables 3.3-6, 3.3-7 and 3.3-8. Attempts to model the effects of parameter changes have been made for sulfur content of coal, Figure 3.3-5, and for channel wall temperature and pressures, Figures 3.3-6 and 3.3-7.

Some crude initial models of OCMHD efficiencies are shown in Figures 3.3-8 and 3.3-9.

**Table 3.3-6 Energy Balance for 2000 MWt MHD Power Plant Operating on Eastern and Western Coal with Thermal Drying (Bergman, Bienstock, 1976)**

	<u>Pittsburgh Seam</u>		<u>Rosebud Seam</u>	
	2	2	10	27.4
Moisture Level (wt. H <sub>2</sub> O)x100/(wt. dry coal)				
Gross MHD Channel Power, MWe	634.54	601.12	581.96	532.15
Gross Steam Plant Power, MWe	583.31	593.50	592.80	595.25
Compressor Power, MWe	171.17	172.23	172.23	172.23
Plant Auxiliaries and Electrical Losses, MWe	43.82	43.60	43.19	42.32
Net Power, MWe	1002.86	978.79	959.34	912.85
Drying Energy, MWt <sup>1/</sup>	0	93.0	66.1	0
Efficiency, %	50.14	46.74	46.43	45.64

<sup>1/</sup> Drying energy is supplied by combustion of an auxiliary fuel in the dryer.

**Table 3.3-7 Energy Balance for 2000 MWt MHD Power Plant Operating on Eastern and Western Coal with Steam Drying (Bergman, Bienstock, 1976)**


	<u>Pittsburgh Seam</u>		<u>Rosebud Seam</u>	
	2	2	10	27.4
Moisture (wt H <sub>2</sub> O) x 100/ (wt dry coal)				
Gross MHD Channel Power, MWe	634.54	601.12	581.96	532.15
Gross Steam Plant Power, MWe	583.31	585.47	587.10	595.25
Compressor Power, MWe	171.17	172.23	172.23	172.23
Plant Auxiliaries and Electrical Losses, MWe	43.82	43.26	42.94	42.32
Net Power, MWe	1002.86	971.10	953.89	912.85
Drying Energy, <sup>1/</sup> MWt	0	33.8	24.0	0
Efficiency, %	50.14	48.56	47.69	45.64

<sup>1/</sup> Drying energy comes from waste steam deposited in steam bottoming plant from MHD topping cycle.


**Table 3.3-8 Energy Efficiency Effects of Various Systems Parameters (Annen, Eustis, 1977)**

Air Preheat Temp.	Illinois #6 Coal						Montana Rosebud Coal					
	Separate Flow Air Turbine		Separate Flow Gas Turbine		Single Flow Gas Turbine		Separate Flow Air Turbine		Separate Flow Gas Turbine		Single Flow Gas Turbine	
	2000°K	1800°K	2000°K	1800°K	2000°K	1800°K	2000°K	1800°K	2000°K	1800°K	2000°K	1800°K
Net Power from MHD cycle (MHD PWR-compressor power), MW	636.7	544.5	599.8	513.8	707.9	599.6	648.3	554.7	628.8	541.9	734.0	619.1
Net Power from Air/Gas Turbine, MW	269.9	319.6	297.7	343.4			271.6	321.6	284.5	335.2		
Net Power from Bottoming Cycle, MW	130.2	143.6	134.1	142.8	327.8	383.0	119.2	133.3	110.8	128.8	313.5	368.7
Total Power, MW	1036.8	1007.7	1031.6	1000.0	1035.7	982.6	1039.1	1009.6	1030.1	1005.9	1047.5	987.8
Thermal Efficiency (based on lower heating value) %	51.8	50.4	51.6	50.0	51.8	49.1	52.0	50.5	51.5	50.3	52.4	49.4
Bottoming Cycle and Intercooler Heat Rejection (proportional to cooling water requirement) MW	384.4	424.0	400.6	424.9	540.1	631.3	352.0	391.3	366.3	397.7	516.7	607.7
MHD Mass Flow Rate kg/sec	763		665		806		772		692		826.6	
Air/Gas Turbine Mass Flow Rate kg/sec	1479	1751	830	1080			1488	1762	838	1111		
MHD Combustor Flame Temp. °K	2932	2841	2963	2870	2794	2689	2934	2843	2963	2871	2805	2700
MHD Duct Length	18.2	15.2	20.1	16.7	13.4	10.3	18.8	15.4	20.2	17.2	14.5	10.7

(Thermal Input = 2000 MW)



**Figure 3.3-5 Baseline Plant Station Efficiency and Sulfur Control Costs vs. Coal Sulfur Content (Jackson, et al., 1976)**



**Figure 3.3-6 Effect of MHD Channel Wall Temperature and Associated Heat Losses on Cycle Efficiency for Two Different Combustion Pressures (REA, 1975)**




Figure 3.3-7 Open Cycle MHD Efficiency Variation with Changes in Combustor Pressure (Amend, 1975)

Model of Overall Energy Efficiency of OCMHD:

$$\begin{aligned} E = & .415 - 1.392C + 3.977A - .00056R - .004F + .0229T - .0115G \\ & + 1.535P - 10.98M - 1.842S + 23.13L + 1.87B + .0122W \\ & + .00615W M - .00216W P - .00001W T + .218M P \\ & - .000836M T + .00057P T - 1.035(C-2.2)^2 \end{aligned}$$

- E = Overall energy efficiency of OCMHD design, in percent  
C = Coal type: Ill #6=1, Montana= 2, N.D.=3, SRC=4  
A = Combustion oxidizer: air=1, air/O2=2  
R = Combustor slag rejection in percent  
F = Preheater firing: direct=1, indirect=2  
T = Temperature in °F of preheated air  
G = Generator type: Faraday=1, diagonal Faraday=2  
P = Generator inlet pressure in atmospheres  
M = Average magnetic field strength in Teslas  
S = Potassium seeding in percent  
L = Electrical load parameter, as fraction  
B = Bottom cycle type: steam=1, air=2  
W = power output of OCMHD, in megawatts

Fit to 39 parametric designs with arithmetic standard deviation  
equal to 0.28%  
Correlation of actual to predicted values is  $R^2=.985$

Figure 3.3-8 Simplified model fit to the energy efficiency  
result from GE ECAS Task 1 (Corman, et al., 1976).




Figure 3.3-9 Scatterplot of predicted efficiencies versus those analytically derived in GE ECAS Task 1, different letters refer to different types of system configurations.

#### 4. Environmental Assessment

The primary impetus for developing open cycle MHD power plants is the economic attractiveness. Some of this economic potential is due to the very high efficiencies of these cycles and part is due to the lack of need for scrubbers. Investigations to date indicate that there are other environmental gains possible, but data are still lacking on many key points. In particular only a few of the potential air pollution emissions have been studied whereas the list of possible pollutants from fossil-fuel facilities includes more than 602 inorganic pollutants and 491 organics. Liquid emissions are expected to be total suspended solids, oil, grease, copper, iron, other heavy metals, and thermal discharges (Penny, et al., 1977). Solids will be dominated by furnace wastes, other collected solids, and sulfur. The following sections deal in more detail with the particular emissions that have been studied to date.

##### 4.1 Air Emissions

When they come on line OCMHD power plants will have to meet either the EPA New Sources Performance Standards or updated (probably stricter) standards for air pollution from stationary coal-fired power plants, presented in Table 4.1-1. The following sections deal specifically with these emissions, and a summary of these and other environmental and economic data can be found in Appendix A.

##### 4.1.1 Sulfur Oxides

Some projections of OCMHD sulfur oxide emissions are shown in Table 4.1.1-1. The ash holds about 2.4% of the sulfur, and high combustion efficiencies reduce sulfur emissions, see Figure 4.1.1-1, but the

TABLE 4.1-1  
 ENVIRONMENTAL EMISSION STANDARDS FOR SOLID-FUELED SOURCES

Pollutant	Standard (lb/MBtu)	Possible Future Standard (EPRI-predicted) (lb/MBtu)
SO <sub>x</sub>	1.20 (as SO <sub>2</sub> )	0.60 to 0.30 (as SO <sub>2</sub> )
NO <sub>x</sub>	0.70 (as NO <sub>2</sub> )	0.40 to 0.13 (as NO <sub>2</sub> )
Total Particulates	0.10	0.10 to 0.05
Fine Particulates ( less than 3 microns)	none	0.10 to 0.02

TABLE 4.1.1.-1  
ESTIMATES OF SULFUR OXIDE EMISSIONS FROM OCMHD

Reference	lb/10 <sup>6</sup> Btu input	lb/kWh output
(General Electric, 1976) base case	1.2	.008
(General Electric, 1976) SRC	0.8	.0062
(Jackson, <u>et al.</u> , 1976) reference	less than 1.2	-
(Shaw, Cain, 1977)	0.77 g/kWht	1.6 g/kWhe
(Penny, <u>et al.</u> , 1977)	-	5 ppm
(Hals, Jackson, 1977) fertilizer recovery system	-	100 ppm
(Harris, Shah, 1976)	0.5	.0034
(REA, 1976)	0.045	-




Figure 4.1.1-1 SO<sub>2</sub> Emissions as a Function of Power Plant Efficiency (Bienstock, et al., 1971)




Figure 4.1.1-2 Sulfur Removal by Potassium Carbonate Addition (Dicks, et al., 1977)

overwhelmingly dominant influence on the level of these emissions is the amount of seed material used. As can be seen from Table 4.1.1-2 or from Figure 4.1.1-2 the concentration of SO<sub>2</sub> in the emissions can be lowered to almost any desired value, see Figure 4.1.1-3. This is a very impressive advantage of MHD cycles, however, there are fairly substantial economic and energy-efficiency penalties for high removal percentages. An interesting trade-off then presents itself requiring a choice among low-sulfur coal, beneficiated coal, high seeding levels, and post-combustion sulfur oxide removal. Expectations for commercial-sized facilities (Jackson, et al., 1976) show that the seed recovery method of sulfur oxide control is likely to be the most cost effective technique, 0.5% efficiency penalty versus 1.5% and 3.0% for flue gas desulfurization and coal cleaning (Jackson, et al., 1976), and 1.5% for nitrogen maximization (Cutting, et al., 1977).

**Table 4.1.1-2 Removal of Sulfur Oxides in MHD Power Generation with K<sub>2</sub>CO<sub>3</sub> as Seed (Bienstock, et al., 1971)**

Wgt % of sulfur in coal: 2.2  
 105% of stoichiometric oxygen  
 N<sub>2</sub>/O<sub>2</sub> = 2

Seed concentration		SO <sub>2</sub> in combustion gas, ppm	SO <sub>2</sub> removal, %	Actual SO <sub>2</sub> removal / stoichiometric removal <sup>a</sup> × 100
g moles K <sub>2</sub> CO <sub>3</sub> / kg coal	lb K <sub>2</sub> CO <sub>3</sub> / 100 lb coal			
0	0	2735	-	-
0.37	5	1608	41.2	78 94
0.72	10	102	96.3	87 95
0.90	12.5	35	98.7	73 82
1.02		5	99.8	65

<sup>a</sup>Based on formation of K<sub>2</sub>SO<sub>4</sub>.




Figure 4.1.1-3 MHD Plasma Seeding Levels for Completely Eliminating Sulfur From Coal (Bienstock, et al., 1974)




Figure 4.1.1-4 Effect of Sulfur Content on Cycle Efficiency Loss (Bergman, et al., 1977)





Figure 4.1.1-5 Energy Consumed in Seed Regeneration vs. Type of Coal Employed (Bergman, et al., 1977)

Once the seeding technique has been selected there are several factors that affect the economics of the process:

- (1) the seed material used, almost certainly potassium carbonate, but possibly cesium carbonate or a mixture;
- (2) the sulfur content of the coal, Figures 4.1.1-4 and 4.1.1-5, and degree of control desired will affect the amount of potassium sulfate that must be regenerated, see Table 4.1.1-3;
- (3) lesser control translates into lesser requirements for reducing gas and thus less equipment; and
- (4) threshold standard, Figure 4.1.1-6.

From the initial sulfur in the coal to the sulfur that would come from a Claus plant, the principal reactions are:



A previously mentioned alternative to the seeding procedure is the post-combustion removal option. In the particular design where NO is maximized to be drawn off as a fixed nitrogen source for fertilizers the nitrogen oxides convert the SO<sub>2</sub> to SO<sub>3</sub> which is easily removed as sulfuric acid (Hals, Jackson, 1969). Concentrations as low as 100 ppm are apparently possible with this operating configuration, described a little further in the following section.

Table 4.1.1-3 Required Percent of  $K_2SO_4$  to Sulfur-free Potassium Compounds (Jackson, et al., 1976)

<u>Coal</u>	<u>Wt. % Sulfur</u>	<u>Conversion %</u>
Pennsylvania (Pittsburgh)	1.6	16
West. Kentucky	3.3	52
Illinois #6	3.3	57-71
Montana (Rosebud)	0.85	8-12




Figure 4.1.1-6 Change of Cycle Efficiency Loss with  $SO_2$  Emissions Level (Bergman, et al., 1977)

As has been stated before, the best method currently available for computing  $SO_x$  or other emissions from MHD's is the composite analytic models. One such model is the GPES system of the MIT Energy Laboratory which can be used to construct hypothetical systems, see Figure 4.1.1-7. Sample results are shown in Figure 4.1.1-8. There are several other such analytic models including those of Argonne National Labs, see Table 4.1.1-4. A crude parametric model of OCMHD emissions is shown in Figure 4.1.1-9.

#### 4.1.2 Nitrogen Oxides

As can be seen in Table 4.1.2-1 there is a considerable variation in the estimated  $NO_x$  emissions from OCMHD. In the combustion of fossil fuels the process of nitric oxide formation is a function of temperature, see Figures 4.1.2-1 and 4.1.2-2. With the extremely high temperatures in OCMHD it might be possible to produce levels of  $NO_x$  emissions at almost 10 times those for conventional gas- and oil-fired plants, almost 10 times the current standard or 6.6 lbs  $NO_2/10^6$  Btu (Beinstock, Demski, Demeter, 1971). Fortunately there are relatively easy methods of substantially reducing these  $NO_x$  emissions, namely:

- (1) using two-stage combustion,
- (2) maximizing  $NO_x$  production then scrubbing it out as a valuable fixed nitrogen source for fertilizers, or
- (3) using pure oxygen instead of air for the combustion oxidant.

The first of these control options, two-stage combustion, not only reduces  $NO_x$  emissions but also can increase the power density by 10 to 20% by operating at 90% of stoichiometric air (Beinstock, Demski, Demeter, 1971). The measured  $NO_x$  values in a staged combustion simulation are shown in Table 4.1.2-2. Although it is not the intent of this review to deal explicitly with the various (6 to 60 reaction






Figure 4.1.1-8 Sample Mole Fractions of Sulfur Compounds at Different Portions in MHD Cycle as Computed by GPES System

Table 4.1.1-4 Comparison of Equilibrium Conditions Between  
Computer Codes (Chung, Smith, 1977)

<u>Parameter</u>	<u>Present Code</u>		<u>NASA Code</u>
$c_{pg}$ , average	.31	.33	Computed internally for each specie
Pressure, atm	4	4	4
Gas Temp., °R	4704	4598	4568
Average Molecular Wt.	29.5	29.6	29.5
Mass Fractions			
O <sub>2</sub>	.020	.017	.012
CO	.035	.030	.028
CO <sub>2</sub>	.2028	.2116	.2125
N <sub>2</sub>	.692	.692	.674
NO	.0044	.0044	.0058
SO <sub>2</sub>	.0021	.0021	.0020
H <sub>2</sub>	.00021	.00021	.00018
H <sub>2</sub> O	.0424	.0427	.0495
Ar	-	-	.011

Preheat temp., 1300°R

Stoichiometric Ratio, 1.0

Higher Heating Value, 11946 Btu/lb

Coal, Montana Rosebud with ash removed




Figure 4.1.1-9 Very crude model of SOx removal based upon data from (Dicks, et al., 1977) and (Bienstock, et al., 1971).

TABLE 4.1.2-1  
ESTIMATED NO<sub>x</sub> EMISSIONS FOR OCMHD

Reference	lb/10 <sup>6</sup> Btu input	ug/J	lb/kWh output	ppm
(General Electric, 1976) base case	0.3	0.129	.002	248
(General Electric, 1976) SRC	0.3	-	.0023	-
(Jackson, <u>et al.</u> , Oct. 1976)	less than			
Reference	0.7	-	-	-
(Shaw, 1978)	0.71	0.304	-	585
(Folsom, 1978) Old EER set	0.72	0.309	-	595
(Folsom, 1978) New EER set	0.685	0.295	-	566
(Mori, Taira, 1972)	-	-	-	243
(Mori, Taira, 1973)	-	-	-	50
(Pepper, Eustis, Kruger, 1972)	-	-	-	283
(Penny, Bourgeois, Cain, 1977)	-	-	-	135-300
(Bienstock, <u>et al.</u> , 1973)	-	-	-	150
(Hals, Lewis, 1972)	-	-	-	160-260
(REA, 1976)	-	-	-	155
(Shaw, Cain, 1977)	1.10g/kWht		2.3g/KWhe	




Figure 4.1.2-1 NO-Equilibrium Concentrations in Combustion Gases (Hals, Lewis, 1972)




Figure 4.1.2-2 The Variation in Nitric Oxide (NO) Equilibrium Concentrations for Combustion Products From Coal with Air for Different Preheat Temperatures and Fuel-air Ratios (Hals, Jackson, 1969)

Table 4.1.2-2 NO<sub>x</sub> Formation in 2-Stage Combustion (Bienstock, et al., 1973)

First Stage			Second Stage							
Sampling at 3500-3600 °F			Gas entrance temperature, °F				Effluent concentration			
% Stoichiometric oxygen	NO <sub>x</sub> , ppm	CO vol-%	2000	2150	2450	2850	% Stoichiometric	NO <sub>x</sub> , ppm	lb NO <sub>2</sub> / 10 <sup>6</sup> Btu	CO vol-%
110	4400	1.14					110	4086	3.13	0
102	2695	2.17					102	2612	2.00	0.1
101	2650	2.27					101	2225	1.70	0.4
95	880	4.30					106	150	0.12	0
94	782	6.61	x				103	351	0.27	0
94	727	6.90		x			105	550	0.40	0
92	543	8.11			x		107	575	0.43	0
92	496	7.53				x	107	885	0.66	0
91	496	9.95				x	104	885	0.64	0
88	356	10.40				x	104	814	0.59	0

equation) analytic models, some of this discussion is really in order to explain extrapolation of the results in Table 4.1.2-2 to large facilities. Comparisons of analytic models is therefore made at a couple of key points in their simulations.

Using principles of thermodynamic chemical equilibria and postulated kinetic mechanisms the principal concern of analytic models of  $\text{NO}_x$  emissions is the temperature-time-composition environments of the process. The tremendous amount of nitric oxide formed during combustion slowly decomposes to its elements. At some point in this process the mix is frozen and remains unchanged, and analytic models of the time-temperature history are aimed at estimating that freeze point.

In addition to a considerable amount of work at MIT there have been analytic models developed and used by:

- (1) NASA-Lewis TRAN-72 (Patel, et al., 1976)
- (2) US Bureau of Mines (Bienstock, et al., 1973)
- (3) Avco (Hals, Lewis, 1972)
- (4) Stanford (Pepper, Eustis, Kruger, 1972)
- (5) Tokyo Institute of Technology (Mori, Taira, 1972)
- (6) STD (Patel, et al., 1976)
- (7) Exxon (Shaw, 1978)
- (8) EER (Folsom, 1978)
- (9) Argonne (Chung, Smith, 1977)

Comparisons of these models can first be made for the temperature-time profiles of their simulations, see Figures 4.1.2-3 through 4.1.2-7. Exact specification of the cooling rate is essential because high




Figure 4.1.2-3 Temperature Profiles in MHD Plants (Bienstock, et al., 1973)




Figure 4.1.2-4 MHD-steam Power Plant with Two Stage Combustions for Control of Nitrogen Oxides. 200°F assumed Air Preheat Temperature (Hals, Lewis, 1972)




Figure 4.1.2-5 MHD-steam Power Plant with Two Stage Combustions for Control of Nitrogen Oxides. 300°F Assumed Air Preheat Temperature (Hals, Lewis, 1972)




Figure 4.1.2-6 Temperature-Time History in OCMHD (Pepper, Eustis, Kruger, 1972)




Figure 4.1.2-7 Analytic Results for Temperature-Time History (Mori, Taira, 1973)




Figure 4.1.2-8 NO<sub>x</sub> Levels in MHD Plant (Bienstock, et al., 1973)




Figure 4.1.2-9 NO-Time History in OCMHD (Pepper, Eustis, Kruger, 1972)




Figure 4.1.2-10 Analytical Results for the Optimized Power Plant, (Mori, Taira, 1973)

cooling rates cause decomposition to stop, or freeze, at high  $\text{NO}_x$  concentrations. Translation of these temperature profiles into  $\text{NO}_x$  histories, including the end frozen flow point are shown in Figures 4.1.2-8 through 4.1.2-11. Gas resident times at high temperatures and substoichiometric air, SA, conditions can be seen to be very important see Figures 4.1.2-12 through 4.1.2-15. Other important factors for  $\text{NO}_x$  control are method, position, temperature, and pressure of secondary air injection, with some illuminating sensitivity analysis on this subject shown in Table 4.1.2-3.

The second  $\text{NO}_x$  control scheme is now taken up, namely, that of maximizing  $\text{NO}_x$  formation and then scrubbing it out as a saleable fertilizer additive (Hoover, et al., 1976), (Cutting, et al., 1977), see Figure 4.1.2-16. It has been determined that  $\text{NO}_x$  emissions could be as high as 4800 ppm and that a Mitsui wet process could be best for its recovery. The process has been concluded (Cutting, et al., 1977) to be not competitive, losing four points in efficiency with 10% higher capital investment and cost of electricity. The third  $\text{NO}_x$  control scheme, use of pure oxygen, also is at a substantial cost disadvantage (Hals, Lewis, 1972).

A crude parametric model of  $\text{NO}_x$  from the staged OCMHD process is developed in Figure 4.1.2-17.

#### 4.1.3 Trace Metals

There are no experimental studies of trace metals from MHD facilities. Some very crude analytic work would be very useful. There is speculation (Harris, Shah, 1976) that all trace elements will vaporize





Figure 4.1.2-11 Property Variation Through Isentropic Channel - Diffuser from Other Research on this Exxon - EPA Contract




Radiant Furnace Residence Time, (seconds)


Radiant Furnace Exit Temperature = 1830<sup>o</sup>K

Exit Plenum Residence Time = 221 MSEC


**Figure 4.1.2-12** Open Cycle MHD Emission Control Option Radiant Furnace Modification (Folsom, 1978)



**Figure 4.1.2-13 Final NO<sub>x</sub> concentrations in MHD Exhaust Gas According to Experimental and Analytical Data (Hals, Lewis, 1972)**



**Figure 4.1.2-14 NO Emissions in an MHD Power Plant as a Function of Residence Time for the Radiant Boiler and Air Preheater Each (Jackson, et al., 1976)**




**Figure 4.1.2-15 Open Cycle MHD Emission Control Option Stoichiometry Variation (Folsom, 1978)**

**Table 4.1.2-3 Open Cycle MHD Sensitivity of NO<sub>x</sub> Emissions Estimates (Folsom, 1978)**

SYSTEM MODIFICATION	NO CONCENTRATION AT END OF EXIT PLENUM (PPM)	PERCENT CHANGE FROM BASELINE
Baseline Configuration	566	0
MHD Channel Residence Time Reduced by Factor of Two	572 *	+ 1.06
Diffuser Residence Time Reduced by Factor of Two	568 *	+ 0.35
Linear MHD Channel Pressure Profile	566	0
Frozen Chemistry in Nozzle		
Combustor NO Concentration Reduced to Zero	565 *	- 0.18
Linear Temperature Profile in Radiant Furnace	590	+ 4.24
Radiant Furnace Residence Time Increased by 0.5 sec.	516	- 8.83
Secondary Air Injection in Exit Plenum Delayed 0.5 sec.	417	-26.3
First Order Approximation of Radiant Furnace Three Dimensional Temperature Profile	677 *	+19.6

\* NEW RESULT



**Figure 4.1.2-16 Fixed Nitrogen and Sulfur Recovery Process for Fossil Fueled MHD Power Plants (Hals, Jackson, 1969)**




Figure 4.1.2-17 Very crude model of NOx exhaust from two-stage combustor based upon (Bienstock, et al., 1973) data.

in the combustor and form sulfates, oxides, chlorides, and fluorides and should be collected with the  $K_2SO_4$ . (Adding to this the inevitable corrosion products of the facility materials, and some refining of the seed material thus appears necessary.) In (Harris, Shah, 1976) they reason that 1% of these elements will appear in the stack gas. Considering particle size distributions, adhesions, and actions of vapors it could be that the eventual levels will be somewhere between the conventional coal combustor levels and these optimistic 99% removal levels, see Table 4.1.3-1. If any of the numbers in these fairly broad ranges are causes of concern then research ought to be directed at those sensitive areas.

#### 4.1.4 Particulates

Estimates of particulate emissions from full-sized OCMHD are shown in Table 4.1.4-1. There are several reasons why particulates may not present a problem for OCMHD's:

- (1) to be economically viable 99.5% of seed and ash particles must be captured, see Figure 4.1.4-1;
- (2) mechanical cyclones, Venturi scrubbers, baghouse filters, electrostatic precipitators and other collection devices are available technologies;
- (3) some pre-generation, hot-side precipitators may be necessary to avoid slag buildups and this would further reduce particulate emissions;
- (4) combustion parameters that reject most of the ash as slag will pay great dividends in seed recovery, see Figure 4.1.4-2.

The materials that reach the precipitators consist of approximately 10% of the total coal ash and 50% of the  $K_2SO_4$  formed in the flow (Harris, Shah, 1976).

TABLE 4.1.3-1  
ESTIMATED TRACE METAL REMOVAL PERCENTAGES IN OCMHD

Element	Percent of Element Entering System That Is Removed Before Stack Emission
Antimony	25-99
Arsenic	60-99
Beryllium	25-99
Boron	25-99
Cadmium	35-99
Chromium	0-99
Cobalt	20-99
Iron	0-99
Lead	60-99
Manganese	0-99
Mercury	90-99
Selenium	70-99
Uranium	0-99
Vanadium	30-99
Zinc	28-99

TABLE 4.1.4-1  
ESTIMATED PARTICULATE EMISSIONS FROM OCMHD

Reference	lb/10 <sup>6</sup> Btu input	lb/kWh output
(General Electric, 1976) base case	0.1	.0008
(General Electric, 1976) SRC	0.06	.00046
(Jackson, <u>et al.</u> , Oct. 1976) reference	less than 0.1	-
(Shaw, Cain, 1977) total particulates	0.15 g/kWh	0.32 g/kWh
(Shaw, Cain, 1977) fine particulates	-	-
(Harris, Shah, 1976)	0.1	.0007
(General Electric, 1976)	0.1	.0007
(REA, 1976)	0.1	-





Figure 4.1.4-1 Precipitator Efficiencies for 39 Cases Investigated in Westinghouse Phase I ECAS Studies (Hoover, et al., 1976).



**Figure 4.1.4-2 Potassium Recovery from Fly Ash Versus Slag Rejection in Combustor (Bienstock, et al., 1973).**

A slightly different collection procedure may be required for peaking MHD's, but dust concentrations less than 0.01 grain/SCF are expected (Rosa, et al., 1970).



#### 4.1.5 Other Air Emissions

Estimates of some of the other air emissions from OCMHD are given in Table 4.1.5-1. Thermal discharges to the air would be considerable in an MHD-Gas turbine design, but in the MHD-Steam these would be less than for conventional combustors, due to the greater expected efficiencies of MHDs. Although heat is the pollutant in air most positively correlated with excess mortalities, the heat dispersive potential of the atmosphere is considered so enormous that there have been considerations of pushing additional heat up the stack to increase the buoyancy of the MHD plume (Rosa, et al., 1970) for better dispersion of the other gaseous and solid pollutants.

TABLE 4.1.5-1  
OTHER AIR EMISSIONS FROM OCMHD

<u>Heat to Air</u> (General Electric, 1976) base case	606 Btu/kWh
<u>CO</u> (Shaw, Cain, 1977) (Bienstock, <u>et al.</u> , 1971) (General Electric, 1976) (Hals, Lewis, 1972) with single stage (Hals, Lewis, 1972) with secondary stage	nil 0 0 4.0% 0.4 to 0.6%
<u>Hydrocarbons</u> (General Electric, 1976) (Rosa, <u>et al.</u> , 1970)	0 0

There is a considerable amount of CO created in the combustion process. The carbon monoxide concentrations exist in accordance with several equilibrium relationships including:




The fraction of CO in these chambers can be as much as 10.4%, see Table 4.1.2-2. In the OCMHD design currently of interest, however, this CO is completely oxidized in the second stage, see again Table 4.1.2-2.

There is no expectation for MHD exhaust to contain any unburned fuel or hydrocarbons (Rosa, et al., 1970).

Noise from an MHD facility will be less than that from gas turbines of the same power (Rosa, et al., 1970). With the secondary heat recovery cycles attached there should be sufficient suppression of noise so that no additional attenuation will be necessary.

#### 4.2 Emissions to Water

Table 4.2-1 shows estimates of some of the water wastes and emissions from OCMHD facilities. Figure 4.2-1 indicates the substantial reduction in thermal emissions to water from OCMHD. The principal reason for this amount can be seen to be the higher expected efficiency of these facilities. Quantifications have not been attempted of what amounts of total suspended solids, oil, grease, copper, iron and other heavy metals might be released to the water system supporting the OCMHD facility.



**Figure 4.2-1 Effect of Power Generation Efficiency upon Thermal Pollution (Bienstock, et al., 1971).**

TABLE 4.2-1  
ESTIMATES OF WATER EMISSIONS FROM OCMHD

<u>Heat to Water</u>	
(General Electric, 1976) base case	2468 Btu/kWh
(Harris, Shah, 1976)	2377 Btu/kWh
(General Electric, 1976) SRC	2040 Btu/kWh
<u>Waste Water</u>	
(Shaw, Cain, 1977)	0.051 kg/kWh
(Harris, Shah, 1976)	0.75 lb/kWh
(General Electric, 1976)	0.09 lb/kWh
<u>Liquid Waste</u>	
(Shaw, Cain, 1977)	24.60 g/kWh
(Shaw, Cain, 1977)	51.0 g/kWh

#### 4.3 Solids and Resources

The ash wastes shown in Table 4.3-1 are just slightly under the total ash that comes in with the coal. The same is true of the sulfur output shown in Table 4.3-2. The coal input to the plant is held outside in a 60-day supply pile; seed material is held inside. Slag and other wastes are held temporarily onsite before trucking to disposal. With holding ponds and all of this storage for the 30-year life of the plant it can be seen why the plant land requirements are only a small fraction of the total land requirements once disposal needs are considered.

#### 4.4 Other Fuel Cycle Effects

The effects of coal extraction and transportation, facility construction, aesthetics, and other indirect environmental consequences of MHD plants will be very similar to those consequences for conventional

TABLE 4.3-1

## ESTIMATES OF SOLID WASTES FROM OCMHD

<u>Furnace Solids</u> (General Electric, 1976)	.0534 lb/kWh
<u>Fly Ash</u> (General Electric, 1976)	.006 lb/kWh
(Shaw, Cain, 1977)	0.029 kg/kWh
(Harris, Shah, 1976)	0.058 lb/kWh
<u>Total</u> (Shaw, Cain, 1977)	14.01 g/kWh
(Shaw, Cain, 1977)	29 g/kWh
(General Electric, 1976)	0.082 lb/kWh

TABLE 4.3-2

## CONSUMPTION OF NATURAL RESOURCES AND SOLIDS

<u>Land (acres/100 MWe)</u>	
(General Electric, 1976) base case main plant	3.71
(General Electric, 1976) SRC main plant	3.71
(Harris, Shah, 1976) main plant	5.1
(Harris, Shah, 1976) disposal land	84.0
(Hoover, et al., 1976) main plant	11.64 to 24.38
(Hoover, et al., 1976) disposal land	11.36 to 14.75
(Hoover, et al., 1976) railroad access	23.05 to 28.13
<u>Total Water (gal/kWh)</u>	
(General Electric, 1976) base case	0.22
(General Electric, 1976) SRC	0.21
(Shaw, Cain, 1977)	0.727 kg/kWhe
(Harris, Shah, 1976) disposal land	0.33
(Hoover, et al., 1976)	0.530 to 0.612
<u>Cooling Water (gal/kWh)</u>	
(General Electric, 1976) base case	0.22
(General Electric, 1976) SRC	0.21
(Harris, Shah, 1976)	0.32
(Hoover, et al., 1976)	0.516 to 0.596
<u>K<sub>2</sub>SO<sub>4</sub> Seed Material</u>	
(Shaw, Cain, 1977)	.00059 kg/kWh
(Harris, Shah, 1976)	.00120 lb/kWh
(Hoover, et al., 1976)	.00027 to 0.00535 lb/kWh
<u>Sulfur Output</u>	
(Shaw, Cain, 1977)	11.4 g/kWhe
(Shaw, Cain, 1977)	4.60 g/kWht
(Harris, Shah, 1976)	0.021 lb/kWh
<u>Coal Input</u>	
(General Electric, 1976) base case	0.65 lb/kWh
(General Electric, 1976) SRC	0.71 lb/kWh
(Shaw, Cain, 1977)	0.297 g/kWhe
(Harris, Shah, 1976)	0.655 lb/kWh
(Hoover, et al., 1976)	0.65 to 1.07 lb/kWh

coal-fired facilities. There are computer programs that can be used to simulate some of these effects, such as direct fuel cycle effects from MERES at Brookhaven National Labs or indirect national environmental effects from SEAS at U.S. Environmental Protection Agency. A listing of some of these general impacts from coal-fired facilities can be found in (Jahnig, Shaw, 1977).

## 5.0 Conclusions

There is considerable trade-off potential between the various performance measures for OCMHD power plants. As such there is little doubt that current source emission standards, or even stricter standards, could be met. As increased demands are put on various aspects of OCMHD performance, however, the ultimate performance measure that is likely to suffer is economic cost. And thus the eventual market penetration of this technology will depend directly upon the comparative degree to which the costs have been held in line after all the problems have been solved and the emission and resource constraints met.

Some of the problems that have been perceived to most severely tax that ultimate performance measure are, in order of priority:

- (1) considerable variations in types and severity of problems at different facility sizes;
- (2) short life of materials exposed to exhaust gases and particulates, particularly electrodes and insulators, and the mutual compatibility of the materials under thermal cycling;
- (3) slag coating of components, particularly the heat exchangers, slag tapping techniques, and high slag rejection in combustion area;
- (4) arcs in passage of currents through cooler layers, and power conditioning system;
- (5) workable and durable air preheater;
- (6) good uniform mixing and feed of air and fuel;
- (7) suitability for reuse of regenerated seed, and homogeneous seeding with that regenerated material;

- (8) cost of stable superconducting magnet system;
- (9) durability of heat exchanger surfaces in secondary furnace;
- (10) energy costs of seed recovery system;
- (11) cost of seed losses, especially in the slag, and investment cost of seed regenerator;
- (12) avoidance of excessive heat losses, and effects of necessary thermal gradients between superhot and supercool areas;
- (13) workability of NO<sub>x</sub> control;
- (14) prediction, optimization, and maintenance of working fluid conductivity, particularly boundary layer and particulate influences, and feedback from channel to combustor;
- (15) expense of integrated power plant control system;
- (16) costs of high-temperature heat exchangers; and
- (17) costs of coal drying and handling.

Although most of these problems are only indirectly related to emissions and energy efficiencies it is believed that the trade-offs involved in solving these problems will significantly affect those performance measures in the commercial OCMHD. To ensure that the most appropriate trade-off of cost versus emissions is reached it seems essential that emission standards be based upon power plant outputs, so investments in high MHD efficiencies are adequately rewarded.

From the standpoint of recommending future work in this area it would be desirable to have maintained an updated data base of MHD emissions and efficiency information. An ongoing project at MIT is concerned with putting together just such a data base for fluidized

bed combustors. There are several advantages to having such data bases available for all of the advanced energy technologies:

- (1) they can be used as design tools to search for attractive configurations and operating parameters, particularly those unexpected synergistic effects that could be identified and exploited;
- (2) they can be a ready source of latest information on the performance of that energy cycle;
- (3) analytical models can be systematically tested against such a data base to evaluate the gap between theoretical and experimental information; and finally,
- (4) they can be used to systematically identify and quantify the need for key pieces of information that are now inadequately known.

This final objective is perhaps the most important in that it could be a mechanism for developing R&D strategies.

## 6. References and Bibliography

- Alad'ev, I.T., et al., 1969. "Studies of Liquid-Metal MHD Cycles at the Krzhizhanovskii Power Institute," Tenth Symposium on Engineering Aspects of Magnetohydrodynamics, Cambridge, MA, pp. 39-40, March 26, CONF-690348.
- Alyautdinov, R.A., et al., 1974. "Computer Model of the U-25 Installation," Colloquium on the Problems of MHD Energy Conversion, Moscow, pp. 233-239, February, CONF-740242.
- Amend, W.E., et al., 1975, "Investigation of Two-Phase Liquid-Metal Magnetohydrodynamic Power Systems," Argonne National Lab., Argonne, Ill., 14 p., CONF-750810-1.
- Amend, W.E., 1975. "Open Cycle MHD Systems Modeling Studies," Argonne National Lab., Argonne, Ill., 13 p., CONF-750669-2.
- Annen, K.D., R.H. Eustis, 1977. "MHD Systems with Low Cooling Requirements," 16th Symposium on Engineering Aspects of MHD, Pittsburgh, PA, May 16-18.
- Argyropoulos, G., 1976. "Magnetohydrodynamic (MHD) Cycles for Electric Power Generation," Issue paper to U.S. Senate Office of Technology Assessment.
- Atomic Energy Review, 1972. "MHD Electrical Power Generation -- 1972 Status Report," Vol. 10(3), pp. 304-361.
- AVCO Everett Research Lab., Inc., 1970. "Study of MHD Power System Burning Char with Oxygen," Everett, MA., 27 p., Feb. DI-14-32-0001-1201. PB-235-776.
- AVCO Everett Research Lab., Inc. 1974. "Development Program for MHD Power Generation," Interim Technical Report, Everett, MA, 250 p., June.
- Bates, J.L., 1976. "Characterization and Evaluation of Materials for the US-USSR MHD Program," Quarterly Report, Battelle Pacific Northwest Labs., Richland, WA, 70 p., January-March, BNWL-2004-2.
- Beecher, D.T., et al., 1976. "Energy Conversion Alternatives Study (ECAS), Westinghouse, Volume III. Summary and Advanced Steam Plant with Pressurized Fluidized Bed Boilers," Westinghouse Research Labs., Pittsburgh, PA, November. PB-268-558. NSF/RA-760590.
- Beecher, D.T., 1975. "Study of Advanced Energy Conversion Techniques for Utility Applications Using Coal and Coal-Derived Fuels," Westinghouse Report No. 75-9E9-ECAS-R1, pp. 4-43.

- Bergman, P.D., D. Bienstock, 1973. "Mixed Potassium-Cesium Seeding in Open-Cycle MHD Power Generation," 13th Symposium for Engineering Aspects of MHD, Stanford, March.
- Bergman, P.D. et al., 1975. "Conceptual Design and Economics of an MHD Pilot Plant," Intersociety Conference on Energy Conversion, Newark, Delaware, pp. 512-23, August.
- Bergman, P.D., D. Bienstock, 1976. "Utilization of Western Coal for MHD Energy Conversion," 15th Symposium on Engineering Aspects of MHD, Philadelphia, PA, May 24-26.
- Bergman, P.D., D. Bienstock, 1977. "Economic and Energy Considerations in MHD Seed Regeneration," 16th Symposium for Engineering Aspects of MHD, Pittsburgh, PA, May 16-18.
- Bienstock, D., et al., 1970. "High-Temperature Combustion of Coal Seeded with Potassium Carbonate in the MHD Generation of Electric Power," Bureau of Mines Report of Investigations 7361, 33 p.
- Bienstock, D., et al., 1971. "Environmental Aspects of MHD Power Generation," 1971 Intersociety Energy Conversion Engineering Conference, New York, pp. 1210-17.
- Bienstock, D., et al., 1973. "Coal Combustion Aspects of MHD Power Generation," Conference on American-Soviet Cooperation in the Field of MHD Power.
- Bienstock, D., et al., 1973. "Air Pollution Aspects of MHD Power Generation," Engineering Aspects of Magnetohydrodynamics, University of Mississippi, pp. vii.1.1-vii.1.10, March 26, CONF-730311.
- Bienstock, D., et al., 1974. "Coal Combustion Aspects of MHD Power Generation," Colloquium on the Problems of MHD Energy Conversion, Moscow, pp. 50-62, February, CONF-740242.
- Blair, D., 1977. "Open Cycle MHD," Draft of Paper, Exxon Research and Engineering Co., Linden, N.J., April 12.
- Bogdanova, T.N., et al., 1973. "Study of the Energy Efficiency of Thermal Electric Power Stations with MHD Generators," Izv. Akad. Nauk SSSR, Ener. Transp. No. 5, pp. 143-9, Sept.-Oct.
- Bohn, T., et al., 1972. "Applied Magnetohydrodynamics Volume 10. MHD Experimental Installation AGRAS II: Description and Operating Experience," Kernforschungsanlage, Juelich, 85 p., August. Jul-883-TP.
- Brogan, T.R., 1963. "Electrical Properties of Seeded Combustion Gases," in Progress in Astronautics and Aeronautics, Vol. 12, pp. 319-345, Academic Press, New York.

- Brogan, T.R., et al., 1974. "Preliminary Design of a Magnetohydrodynamic (MHD) Channel for the USSR U-25 Facility." Final Report. MEPPSCP, Inc., Boston, MA, 304 p., November. FE-1733-T-1.
- Brouns, R.J., 1976. "Environmental Impacts of Nonfusion Power Systems," Battelle Pacific Northwest Labs, Richland, WA, 130 pp., Sept.
- Brown, D.H., et al., 1976. "Energy Conversion Alternatives Study (ECAS). General Electric Phase II Final Report Volume I, etc..." General Electric Corporate Research and Development, Schenectady, NY, December. PB-268-466 NSF/RA-760582.
- Brunsvold, A.R., E.S. Pierson, 1976. "Liquid-Metal MHD Coupled to Coal-Fired Fluidized-Bed Combustors," Argonne National Lab., Argonne, IL, 9 p., CONF-760556-1
- Buende, R., J. Raider, 1973. "Designing MHD Generator Systems for Minimum Power Production Costs," Energy Convers. 13, No. 4, pp. 143-148, October.
- Burkhart, J.A., et al., 1977. "Open-Cycle Magnetohydrodynamic/Steam System," in (NASA, 1977), pp. 201-245.
- Carter, C., 1969. "Convective and Absolute Instabilities in an Open Cycle MHD Generator," in Proc. Tenth Symp. on Engr. Aspects of MHD, Mass. Inst. Tech., Cambridge, Mass.
- Chung, P.M. and R.S. Smith, 1977. "An Analysis of a High-Temperature Coal Combustor According to a One-dimensional Flow Model," Argonne National Lab, ANL/MHD-77-2, October.
- Corman, J.C. et al., 1976. "Energy Conversion Alternatives Study (ECAS). General Electric Phase II Final Report Volume I, etc...." General Electric Corporate Research and Development, Schenectady, NY, December. PB-268-466 NSF/RA-760582.
- Corman, J.C., R.B. Fleming, L.P. Harris, and P.V. Pohl, 1976. "Energy Conversion Alternatives Study (ECAS), General Electric Phase I. Final Report, Vol. II, Advanced Energy Conversion Systems: Part 3, Direct Energy Conversion Cycles," NASA CR-134948-II-3, Feb.
- Cutting, J.C., et al., 1977. "Open-Cycle Coal Burning MHD Power Plants for Commercial Service," 16th Symposium Engineering Aspects of MHD, Pittsburgh, PA, May 16-18.
- Dicks, J.B., 1972. "MHD Central Power: A Status Report," Mech. Eng., p. 14, May.
- Dicks, J.B., et al., 1974. "The Direct Coal-Fired MHD Generator System," 14th Symposium Engineering Aspects of MHD, April.

- Dicks, J.B., et al., 1974. "Direct Coal-Fired MHD Power Generation," J. Eng. Power, 96, No. 2, pp. 153-157.
- Dicks, J.B., et al., 1975, 1976. "Development Program for MHD Direct Coal-Fired Power Generation Test Facility," Quarterly Progress Reports, Tennessee University, Tullahoma, TN, FE-1760-1, 2, 10, 22.
- Dicks, J.B., et al., 1977. "A Description of the Direct Coal-Fired MHD Facility at the University of Tennessee Space Institute," 12th IECEC, pp. 995-1003.
- Dicks, J.B., et al., 1977. "Investigation of Direct Coal-Fired MHD Power Generation," 16th Symposium Engineering Aspects of MHD, Pittsburgh, PA, May 16-18.
- Dinelli, G., 1966. Effect of Various Parameters on the Efficiency of the MHD Power Stations," International Atomic Energy Agency, Vienna, Austria, 26 p., July 4, CONF-660704-54.
- Donshoi, K.V., et al., 1966. "Problems of MHD Conversion: Some Experimental Results," International Atomic Energy Agency, Vienna, Austria, 20 p., July 4, CONF-660704-56.
- Duggan, J.L., Cloutier, R.J. (eds.), 1975. "Energy Sources for the Future. Proceedings of a Conference Held July 7-25, 1975 in Oak Ridge, TN," Oak Ridge Associated Universities, Inc., TN, 312 p., July. CONF-750733.
- Edelston, B.S., E.S. Rubin, 1976. "Current and Future Use of Coal in the Northeast," Brookhaven National Lab., Upton, NY, 151 p., May, BNL-50560.
- Electric Power Research Institute, 1975. "An Overall Program for the Development of Open Cycle MHD Power Generation," June, EPRI-SR-12.
- Electric Power Research Institute, 1974. "EPRI/OCR Workshop on the Development of Open-Cycle MHD," Electric Power Research Institute and Office of Coal Research, Palo Alto, CA, May.
- ERDA, 1974, 1975. "U-25 MHD Pilot Plant," Inst. Vysokikh Temperatur, USSR, ERDA-tr-102-P1, 2, 3.
- ERDA, 1975. "Magnetohydrodynamics Power Generation and Theory," Technical information Center, Oak Ridge, TN, 875 p., November, TID-3356.
- ERDA, 1975. "Second US-USSR Colloquium on Magnetohydrodynamic Electrical Power Generation," Washington, D.C., 327 p. CONF-750669.
- ERDA, 1976. "Third US-USSR Colloquium on MHD Electrical Power Generation," Moscow, USSR, October 20-21, CONF-761015.

- Eustis, R.H., C.M. Kruger, 1975. "Atmospheric Pollution Aspects of Magnetohydrodynamic Power Plants," Stanford Univ., EPRI-110-FR, (PB-248 331), November.
- Eustis, R.H., S.A. Self, 1975. "MHD Phenomena at High Magnetic Fields. Interim Technical Report July 1972 - December 1974," Stanford Univ. Dept. of Mechanical Engineering, Calif. 13 p., February. FE-1227-1.
- Fabris, G., et al., 1976. "Influence of Wall-Jet Gas Injection on Liquid-Metal MHD Generator Performance," Argonne National Lab., Ill., 8 p. CONF-760556-2.
- Federal Register, 1971. "Standards of Performance for New Stationary Sources," 36(247), 24876-24895, December 23.
- Feldman, H.F., et al., 1970. "The Effect of Air/Fuel in the MHD-Generator on the Operation of an Open-cycle MHD-topped Power Plant," 10th Symposium on Engineering Aspects of Magnetohydrodynamics, Cambridge, MA, March 26-28.
- Feldman, H.F., et al., 1970. "The Effect of Air/Fuel in the MHD-Generator on the Operation of an Open-cycle MHD-topped Power Plant," Energy Conversion, Vol. 10, #2, April.
- Feldman, H.F., Simons, W.H. and Bienstock, D., 1968. "Factors Affecting the Optimum Feeding Levels of Coal or Char Fired, Open Cycle MHD Power Plants," SM107/36, Electricity from MHD, IAEA, Vienna.
- Feldman, H.F., et al., 1970. "Kinetics of Recovering Sulfur from the Spent Seed in an MHD Power Plant," Environmental Science and Technology 4(6), pp. 496-502.
- Feldman, H.F., et al., 1970. "Thermodynamic, Electrical, Physical, and Compositional Properties of Seeded Coal Combustion Products," Bureau of Mines Bulletin 655, Washington, DC.
- Fishman, F., 1968. "Instability of Hall MHD Generators to Magneto-acoustic Waves," in 9th Symp. on Engr Aspects of MHD, Univ. of Tenn. Space Inst., Tullahoma, Tenn.
- Flinders University of South Australia, 1974. "Physics and the Energy Industry," Bedford Park, Australia, January, CONF-740137, INIS-mf-2006.
- Folsom, B.A., 1978. "Environmental Assessment of Advanced Energy Conversion Technologies," EER Corp. presentation to EPA-IERL, Cincinnati, OH, May 17.
- Fushini, K. et al., 1973. "Construction of a Small-scale MHD Test Plant (ETL MARK VI)," Engineering Aspects of Magnetohydrodynamics, Univ. of Mississippi, pp. iv-1.1-iv.1.6, March 26, CONF-730311.

- Gadda, "Recent Experimental Results Relating to the Seeding of MHD Combustion Gases," SM107/207, in Electricity from MHD, IAEA, Vienna.
- Gannon, R.E., S.K. Ubhayakar, C.W. Von Rosenberg, Jr., D.B. Stickler, and F.A. Hals, 1968. Application of the Rapid Devolatilization of Coal in MHD Power Cycles, Symposium on Engineering Aspects of MHD, VII.2.1.
- Gaponov, I.M., L.P. Poberezhskii, 1975. "Study of the Electrical Conductivity of a Plasma in Combustion Productions, (An SSSR Moscow Inst. Vyspokikh Temperatur)," 45 p. ERDA-tr-186.
- General Electric Company, 1975. "Study of Advanced Energy Conversion Techniques for Utility Applications Using Coal or Coal Derived Fuels," Vol. II, Oral Briefing on the Results of Task I at NASA Lewis Research Center, Cleveland, OH, May 20, NAS3-19406.
- General Electric Company, 1976. "Comparative Study and Evaluation of Advanced Cycle Systems," General Electric Corporate Research and Development, Schenectady, NY, May. PB-254-392, EPRI/AF-158.
- General Electric Company, 1976. "Energy Conversion Alternatives Study - ECAS - Phase 1," NASA, CR-134948.
- General Electric Company, 1976. "Energy Conversion Alternatives Study, Phase II Report," NASA Report NASA-CR-134949, General Electric Co., Schenectady, NY, December.
- General Electric Company, 1976. "Study of Advanced Energy Conversion Techniques for Utility Applications Using Coal or Coal Derived Fuels," General Electric Report, February 17.
- General Electric Company, 1977. "Coal/Open-Cycle Magnetohydrodynamic/Steam System." in (NASA, 1977).
- Gilbert Assoc. Inc., STD Research, 1976. "Baseline Power Plant Overall Plant Design Description," ERDA, MHD Power Generation Program, December.
- Goldenburg, S.A., et al., 1975. "Experimental Investigation of the Effect of the Excess Fuel Coefficient on the Electrical Conductivity of Potassium-seeded Hydrocarbon Fuel Combustion Products," Electricity from MHD, Vol. IV, Vienna, Austria, pp. 2239-2248, July 24.
- Golyashevich, S.L. et al., 1975. "Investigations of Coal Combustion for MHD Conversion of Energy," 6th International Conference on Magnetohydrodynamic Electrical Power Generation, Vol. II, Washington, DC, pp. 321-334, June 9, CONF 750601-P2.

- Gubarev, A.V., I.G. Nosov, 1970. "Study of the Efficiency of Electric Power Generation at Thermal Electric Power Plants with Faraday-type Open-cycle MHD Generators," Institut Atomnoi Energii, Moscow, USSR, IAE-2021.
- Hals, F., L. Keefe, 1964. "A Method of Seed Recovery in Coal Fired MHD Power Plants," 5th Symposium on Engineering Aspects of Magnetohydrodynamics, Cambridge, MA.
- Hals, F., W.D. Jackson, 1969. "MHD Power Generation: Economic and Environmental Implications," 10th Symposium on Engineering Aspects of Magnetohydrodynamics, Cambridge, MA, pp. 136-141, March 26, CONF-690348.
- Hals, F., P. Lewis, 1972. "Control Techniques for Nitrogen Oxides in MHD Power Plants," Engineering Aspects of Magnetohydrodynamics, Argonne, IL, pp. VI.5.1.-VI.5.10.
- Hals, F.A., et al., 1974. "Auxiliary Component Development Work at Avco Everett Research Laboratory Inc.," 14th Symposium on Engineering Aspects of Magnetohydrodynamics, Tullahoma, TN, pp. II.3/1-13, April 8-10.
- Hals, F.A., et al., 1975. "Development and Design of High-Temperature Air Preheaters and Techniques for Emission Control of Nitrogen Oxides for Open Cycle MHD Power Systems," 6th International Conference on Magnetohydrodynamic Electric Power Generation, Vol. II, Washington, DC, pp. 267-288, June 9, CONF-750601-P2.
- Harris, L.P. and R.P. Shah, 1976. "Energy Conversion Alternatives Study (ECAS) General Electric Phase II Final Report, Vol. II Advanced Energy Conversion Systems -- Conceptual Designs: part 3, Open Cycle Gas Turbines and Open Cycle MHD," NASA-CR 134949-II-3, December.
- Hart, A.B., et al., 1964. "Some Factors in Seed Recovery," International Symposium on Magnetohydrodynamic Electric Power Generation, Vol. 3, pp. 1348-64, July 6-11.
- Hauser, L.G., 1973. "Assessing Advanced Methods of Generation," Westinghouse Electric Co., Arch. Energiewirt., 17(20), pp. 989-999.
- Heywood, J.B., G.J. Womack, 1969. Open-Cycle MHD Power Generation, Pergamon Press, Ltd.
- Hoover, D.Q., et al., 1966. "Feasibility Study of Coal Burning MHD Generation," Westinghouse Research Lab., March, PB 235 460.
- Hoover, D.Q., et al., 1976. "Energy Conversion Alternatives Study (ECAS), Westinghouse Phase I Final Report, Vol. III, Open-Cycle MHD," Westinghouse Research Labs., NASA CR-134941, 425 p., February.

- Horn, G., and E.M. Hughes, 1967. "Engineering Aspects of Magnetohydrodynamic Power Generation," Trans. Inst. Chem. Eng., London, T-182-9, June.
- Hughes, E., et al., 1974. "Control of Environmental Impacts from Advanced Energy Sources," EPA, March, EPA-600/2-74-002.
- Jackson, W.D., et al., 1970. "Critique of MHD Power Generation," J. Eng. Power, 92, pp. 217-30, July.
- Jackson, W.D., et al., 1973. "Coal Fired MHD for Central Station Power Generation," 6th Annual Frontiers of Power Technology Conference, Stillwater, OK, pp. 4/1-17, October 10-11.
- Jackson, W.D., et al., 1974. "The Role of the Office of Coal Research in the National Program for MHD Development," in (NSF, 1974), pp. 17-26.
- Jackson, W.D., et al., 1975. "Consideration in the Development of Open Cycle MHD Systems for Commercial Service," 6th International Conference on MHD Electric Power Generation, Vol. V., Washington, DC, p. 21, June, CONF-75061-P5.
- Jackson, W.D., et al., 1975. "MHD Power Generation - Technology Status and Development Plan," Institute of Gas Technology Symposium, Chicago, IL, June 23.
- Jackson, W.D., P.S. Zygielbaum, 1975. "Open Cycle MHD Power Generation - Status and Engineering Development Approach," American Power Conference, Chicago, IL.
- Jackson, W.D., 1976. "MHD Electrical Power Generation: Prospects and Issues," AIAA 9th Fluid and Plasmadynamics Conference, San Diego, CA, July, AIAA 76-309.
- Jackson, W.D., et al., 1976. "Design Considerations for a Coal-Fired 2000 MW (th) Open Cycle MHD/Steam Baseload Powerplant," 3rd US-USSR Colloquium on MHD Electric Power Generation, Moscow, USSR, October 20-21.
- Jackson, W.D., et al., 1976. "Development of a Baseline Reference Design for an Open Cycle MHD Power Plant for Commercial Service," 15th Symposium on EAM, Philadelphia.
- Jackson, W.D., et al., 1976. "MHD Power Generation 1976 Status Report," IECEC, pp. 1006-1019.
- Jackson, W.D., et al., 1977. "Status of the Reference Dual-Cycle MHD-Steam Power Plant," 16th Symposium on Engineering Aspects of MHD, Pittsburgh, PA, May 16-18.

- Jackson, W.D., et al., 1977. "Design of the Montana Magnetohydrodynamics Component Development and Integration Facility," 12th IECEC, pp. 988-994.
- Jahnig, C.E. and H. Shaw, 1976. "Environmental Assessment of an 800 MWe Conventional Steam Power Plant," Exxon/GRU.1.DJAD.76, Exxon R&E, 54 pp., September.
- Jedrzyowski, Zb., St. Andrzejewski, 1966. "Study of Cycle Diagrams of Power Plants with MHD Generators," International Atomic Energy Agency, 20 pp., July 4, CONF-660704-81.
- Joint Publications Research Service, 1975. "First Joint Soviet-American Colloquium on the Problem of MHD Energy Conversion," JPRS-63794, 254 pp., January.
- Joubert, J.I., et al., 1976. "Kinetics of Regeneration of Spent Seed from MHD Power Generation Systems," 15th Symposium on Engineering Aspects of MHD, Philadelphia, May 24-26.
- Kantrowitz, A., R.J. Rosa, 1974. "MHD Power Generation," American Physical Society Topical Conference on Energy, Chicago, IL, February.
- Kantrowitz, A., 1977. "The First 20 Years of MHD Development," Conference on High Temperature Sciences Related to Open-Cycle, Coal-Fired MHD Systems, Argonne, IL, pp. 289-298, April 4-6, ANL-77-21.
- Karr, C., Jr., et al., 1974. "Composition of Fly Ash from a Coal-Fired MHD Generator with Potash Seed," J. Inst. of Fuel, Vol. 52, pp. 177-80.
- Kiepeia, J.E. (ed.), 1975. "Sixth International Conference on Magnetohydrodynamic Electrical Power Generation," Vol. II, ERDA, Washington, DC, 336 p., June 9-13, CONF 750601-P1, P2, P3, P4, P5, P6.
- Kirillia, V.A., et al., 1967. "The Prospective Economics and Thermal Efficiency of Large Scale Open Cycle MHD Stations," Phil. Trans. Roy. Soc. London Ser. A., 261, pp. 394-400, July 6.
- Klepeis, J., and J.F. Louis, 1971. "Disk Generator Applied to Open Cycle Power Generation," Proc. of the 5th International Conf. of MHD Electrical Power Generation, Munich.
- Kolb, G., et al., 1974. "Applied Magnetohydrodynamics No. 13. Theoretical Bases of MHD Energy Conversion with Combustion Gases," Inst. fuer Technische Physik, Kernforschungsanlage Juelich G. m.b. H., 215 p., March. Jul-1055-TP.

- Kontos, J., 1969. "System Analysis and Simulation in Magneto-hydrodynamics," NTIS # DEMO-69/2, May.
- Kuehne, W.D., et al., 1972. "Applied Magnetohydrodynamics Volume 9. Calculation of the Characteristic Quantity of the Working Gas of the MHD-Combustion Gas Generator," Kernforschungsanlage, Juelich, W. Germany, 124 p. Jul-874-TP.
- Lane, J.A., 1974. "Outlook for Alternative Energy Sources," Energy Research and Development Administration, Washington, D.C., 36 p. CONF-75-614-1.
- Levi, E., 1978. "MHD's Target: Payoff by 2000," IEEE Spectrum, pp. 46-51, May.
- Lindsay, W.T., E.V. Somers, W.S. Emmerich, 1964. "Fixed Nitrogen By-Products in Open Cycle MHD Generators," Westinghouse Research Labs., CONF-640701-38, 7 pp.
- Little, A.D., Inc., 1975. "Benefits/Costs of Advanced Power Cycle Research: A Mid-1974 Analysis," Final Report, Cambridge, MA, 83 p., December. FE-1756-1.
- Louis, J.F., 1968. "Disk Generator," AIAA Journal, 6, 9, p. 1674.
- Louis, J.F., (ed.), 1971. "Open Cycle Coal Burning MHD Power Generation; An Assessment and a Plant for Action," MIT, Cambridge, MA, June.
- Louis, J.F., 1974. "MHD: Systems and Characteristics," in (NSF, 1974), pp. 27-30.
- Louis, J.F., 1975, 1976. "Critical Contributions in MHD Power Generation," Annual Report, Quarterly Reports, MIT, E(49-18)-2215 (ERDA), FE-2215-1, 2, 3.
- Louis, J.F., et al., Open Cycle Coal Fired MHD Power Generation, Final Report for the Period 21 May (1971) - 31 May (1975), Dept. of Aeronautics and Astronautics, MIT, prepared for ERDA Fossil Energy Contract No. E(49-18)-1209, Vols. I and II.
- Marston, C.H., et al., 1976. "MHD Generator Investigations," General Electric Company, Philadelphia, March (AD-A023 417), November (AD-A032 790).
- McGrath, I.A., M.W. Thring, 1964. "Open Cycle Magnetohydrodynamic Power Generation," J. Inst. Fuel, 37, No. 287, pp. 525-30, December.
- Migra, R.P., et al., 1976. "Comparative Evaluation of Phase I Results from the Energy Conversion Alternatives Study (ECAS)," NASA, February, NASA TMX-71855.

- Millet, J., 1968. Electricity from MHD, Proceedings from Warsaw Symposium, pp. 2979-2990.
- MIT, 1975. "Open Cycle Coal Fired MHD Power Generation," Final Report, Cambridge, MA, 701 p., July 31.
- Mori, Y., "Cycle and Efficiency of Large Scale Open-Cycle MHD Power Plants", in Proc. of 5th International Conf. on MHD Electrical Power Generation, (Munich, 1971).
- Mori, Y., T. Taira, 1972. "Kinetic Study of Oxides of Nitrogen in MHD Power Plants," Engineering Aspects of Magnetohydrodynamics, Argonne, IL, pp. VI.7.1-VI.7.6.
- Mori, Y., T. Taira, 1973. "Reduction of  $\text{NO}_x$  Concentrations in MHD Steam Power Plant Systems," 13th Symposium on Engineering Aspects of Magnetohydrodynamics, Stanford, CA, March.
- Mori, Y., K. O. Atake, S. Irobe, and T. Taira, 1975. "Decomposition of NO on Alumina Surface under Reducing Conditions for Emission Control of NO in MHD Power Plants," CONF-750601-P1, pp. 61-76.
- Mori, Y., et al., 1975. "Prediction of NO Concentrations in MHD Power Plants by Axi-Symmetric Two Dimensional Analyses," Tokyo Inst. of Tech., CONF-750601-P1, pp. 77-89.
- NASA Lewis Research Center, 1976. "Comparative Evaluation of Phase I Results from the Energy Conversion Alternatives Study (ECAS)," NASA TMX-71855, February.
- NASA, 1977. "Evaluation of Phase 2 Conceptual Designs and Implementation Assessment Resulting from the Energy Conversion Alternatives Study (ECAS)," Cleveland, OH, NASA TMX-73515, April.
- NSF, 1974. "NSF-OCR Engineering Workshop on MHD Materials," MIT, November 20-22.
- Nedospasov, A.V., et al., 1976. "Thermophysical and Electrophysical Properties of Combustion Products with Seed," Inst. Vysokikh Temperatur, Moscow, USSR, 68 p., September. ERDA-tr-183.
- Novosadov, V.B., 1976. "Errors of Measurement of Plasma Temperature in MHD Generator Channels," 35 p., October. ERDA-tr-184.
- Nowacki, P.J., 1968. "Recent Developments in the Direct Conversion of Heat into Electricity by Means of Magnetohydrodynamic Electrical Power Generation," Neue Tech., 1-, No. B1, pp. 3-24, February.
- Olds, F.C., 1971. "SO<sub>2</sub> Control: Focusing on New Targets," Power Engineering 77(8), pp. 24-29.
- Oliver, D.A., P.H. Byer, 1972. "Physical and Economic Models of an Open Cycle Coal Burning MHD Power Generation," Gas Turbine Laboratory Report No. 197, MIT, Cambridge, MA, June.

- Patel, N.J., et al., 1976. "Influence of Coal Type and Drying upon MHD Power Plants and Components," 15th Symposium for Engineering Aspects of MHD, Philadelphia, PA, May 24-26.
- Penny, M.M., et al., 1977. "Development Status and Environmental Hazards of Several Candidate Advanced Energy Systems," 12th IECEC, pp. 646-654 (also EPA/IERL-Ci-092, 1976).
- Pepper, J.W., et al., 1970. "NO Concentrations in MHD Steam Power Plant Systems," 11th Symposium on Engineering Aspects of Magnetohydrodynamics, Pasadena, CA.
- Pepper, J.W., et al., 1972. "NO Concentrations in MHD Steam Power Plant Systems," Engineering Aspects of Magnetohydrodynamics, Argonne, Illinois, pp. VI.6.1.-VI.6.5.
- Pepper, J.W., C.H. Kruger, 1973. "Accurate Modeling of NO Decomposition in MHD Steam Power Plant Systems," Engineering Aspects of Magnetohydrodynamics, Univ. of Mississippi, pp. VII.2.1.-VII.2.3, March 26, CONF-730311.
- Pepper, J. and O.S. Yu, 1974. "The Application of Open Cycle MHD in an Electric Utility System," Proceedings of NSF-OCR Engineering Workshop on MHD Materials, MIT, November 20-22.
- Pepper, J.W., et al., 1974. "NO Concentrations in MHD Steam Power Plant Systems," 14th Symposium on Engineering Aspects of Magnetohydrodynamics, Univ. of Tennessee Space Inst., Tullahoma, TN, pp. 111.5/1-2, April 8-10.
- Pepper, J.W., 1974. "Effect of Nitric Oxide Control on MHD-Steam Power Plant Economics and Performance," Stanford Univ. SU-IPR Report No. 614, December.
- Pepper, J. and O.S. Yu, 1974. "The Application of Open Cycle MHD in an Electric Utility System," in (NSF, 1974) pp. 31-46.
- Pepper, J.W., 1975. "Effect of Nitric Oxide Control on MHD-Steam Power Plant Economics and Performance," Stanford Univ., 127 p.
- Petrick, M., et al., 1976. "Experimental Two-Phase Liquid-Metal Magnetohydrodynamic Generator Program," Argonne National Lab., Argonne, IL, 102 p., November, ANL/ENG 76-04.
- Pomeroy, B.D., et al., 1978. "Comparative Study and Evaluation of Advanced Cycle Systems," General Electric, EPRI Report AF-664, February.
- Poncelet, J., L. Lozano, 1968. "Chemi-ionization and MHD: The Effect of CO<sub>2</sub> and Additives," Electricity from MHD, Vol. IV, Vienna, Austria, pp. 2141-2159, July 24.

- Powell, C.A., 1974. "Utility Requirements for MHD Power Generation," in (NSF, 1974), pp. 7-16.
- Powell, E.M., R.C. Ulmer, 1974. "Controlling Emissions from Fossil-Fueled Power Plants, Combustion 45, No. 7, pp. 24-34, January.
- Reeder, J., R. Buende, 1973. "Basic Equations and Fundamental Data for Combustion MHD Generators," Max-Planck-Institut fuer Plasmaphysik, Garching Munich, R.F. Germany, 225 p., July. IPP-IV-60.
- Research and Education Association, 1975. "Chapter 46, MHD Power Generation" in Modern Energy Technology, REA, New York, pp. 1359-1412.
- Rikov, A.I., et al., 1975. "Development and Study of High Temperature Materials for Various Components of MHD Installations," Inst. Vysokikh Temperatur, Moscow, USSR, 51 p., ERDA-tr-185.
- Rockwell International Corp., 1976. "MHD Combustor Design Study," Final Report, Rockwell International Corp. Rocketdyne Div., Canoga Park, Calif., 440 p. May. TID-27144.
- Rosa, R., et al., 1970. "Advanced Peaking Power Plants," 11th Symposium on Engineering Aspects of Magnetohydrodynamics, Pasadena, CA.
- Rosa, R.J., 1975. "MHD Power Generation Development Program," AVCO Everett Research Lab., Everett, MA, 227 p., June. PB-243-233.
- Rudins, G., 1974. "U.S. and Soviet MHD Technology: A Comparative Overview," Rand Corp., Santa Monica, CA. AD-A0004-614.
- Sarofim, A.F., 1977. "Combustion and Characterization of Coal," "Conference on High Temperature Sciences Related to Open-Cycle, Coal-Fired MHD Systems, Argonne, IL, April 4-6, ANL 77-21.
- Seikel, G.R., et al., 1971. "The Potential of Nuclear MHD Electric Power Systems," NASA, 12 p., NASA-TM-X-67829. N71-24578.
- Seikel, G.R., et al., 1976. "A Summary of the ECAS Performance and Cost Results for MHD Systems," 15th Symposium Engineering on Aspects of MHD, Philadelphia, May 24-26.
- Seikel, G.R., and L.P. Harris, 1976. "A Summary of the ECAS MHD Power Plant Results," 3rd US-USSR Colloquium on MHD, Moscow, USSR, October 21-22, NASA TMX-73481.
- Shaw, H., 1978. "Environmental Assessment of Advanced Energy Conversion Technologies," Exxon R&E presentation to EPA-IERL, May 17.

- Shaw, H., W.C. Cain, 1977. "Environmental Considerations in Advanced Energy Conversion Technology Assessments," 12th IECEC, pp. 655-660.
- Sheindlin, A.E., G.I. Rossievskii, 1972. "Analysis of Factors Influencing the Thermal Efficiency and Economic Vitality of Electric-Power Stations Using Open-Cycle MHD Generators," Foreign Technology Div., Wright-Patterson AFB, OH, 18 p., September, AD-753708.
- Shumiatskii, B. Ya., et al., 1976. "Studies Conducted at the U-15 Facility (IV)," Inst. Vysokikh Temperatur, Moscow, USSR, 60 p., ERDA-tr-182.
- Siniasky, N.A. and I.A. Yavorsky, 1968. "The Effect of Phase Changes in Mineralized Composition of the Inorganic Part of Natural Coals on the Electrical Conductivity of a Colloidal Plasma," Electricity from MHD, IAEA, Vienna, SM 107/186.
- Solbes, A. S.W. Petty, 1977. "Progress in Channel Development for Direct Coal Fired MHD," 12th IECEC, pp. 1004-1014.
- Somers, E.V., D. Berg, and A.P. Fickett, 1976. "Advanced Energy Conversion," in Annual Review of Energy-1976, pp. 345-368.
- Sonju, O.K., J. Teno and T.R. Brogan, 1970. "Comparison of Experimental and Analytical Results for a 20-MW Driven Hall Configuration MHD Generator," 11th Symp. on Engr. Aspects of MHD, California Inst. of Tech., Pasadena, California.
- Sporn, Philip, Arthur Kantrowitz, 1959. "Large Scale Generation of Electric Power by Application of the Magnetohydrodynamic Concept," Power, Vol. 103, pp. 62-65.
- STD Research Corp., 1971, 1972, 1973, 1974. "Realistic Modeling and Performance Prediction of MHD Generator Channels," Progress Reports, Pasadena, CA, May 17, 1971, February 16, 1972, March 16, 1973, January 15, 1974, FE-1211-T-1, 2, 3, 4.
- STD Research Corp., 1977. "Open-Cycle MHD Systems Analysis," Annual Report, EPRI, March, RP-640-2.
- Tager, S.A. and J.M. Henry, 1976. "Fuel and Combustion," US-USSR text on MHD.
- TRW Defense and Space Systems Group, 1976. "TRW 25 MW/sub T/Staged MHD Coal Combustor Conceptual Design Study," Redondo Beach, CA, 363 p., June. TID-27145.
- Tempelmeyer, E.D., et al., 1977. "Investigation of Factors Influencing Potassium Seed Recovery in a Direct Coal-Fired Generator System," 16th Symposium for Engineering Aspects of MHD, Pittsburgh, PA, May 16-18.

- Teno, J., et al., "Research Studies and Development of MHD Generators and Accelerators," AVCO Everett Research Laboratory Report.
- USSR Institute for High Temperatures, 1974, "Influence of Ash on the Operation of MHD Generator Channel in the U-02 Facility," 20 p. ERDA-66.
- USSR Institute for High Temperatures, 1975. "Principal Results of Scientific Research Done for 1974," Moscow, 62 p. ERDA-tr-162.
- Way, S., 1964. "MHD Power Generation," Combustion: 36, No. 3, pp. 34-41, September.
- Way, S., 1967. "Problems of the Coal-Fired MHD Power Plant," in Advances in Plasma Dynamics, T.P. Anderson and R.W. Springer (eds.), Northwestern University Press, Evanston, IL.
- Way, S., 1971. "MHD Power Plant for Early Realization," 5th International Symposium MHD, Munich, W. Germany, pp. 615-26, May.
- Way, S., 1974. "Combustion Aspects of MHD Power Generation," Chapter 10, Combustion Technology, edited by H.B. Palmer and J.M. Beer, Academic Press, New York and London.
- Westinghouse, 1976. "Energy Conversion Alternatives Study - ECAS - Phase 1," Vols. 1-12, NASA, CR-134941.
- Witwer, J.G., 1976. "Costs of Alternative Sources of Electricity," Stanford Research Inst., Menlo Park, CA, July, PB-255-765.
- Wu, Y.C.L., et al., 1968. "Two Terminal Connected Open Cycle MHD Generators," 9th Symp. on Engr. Aspects of MHD, Univ. of Tenn. Space Institute, Tullahoma, Tenn.
- Wu, Y.C.L., et al., 1974. "On Direct Coal-Fired MHD Generator," 14th Symposium on Engineering Aspects of MHD, April.
- Wu, Y.C.L., et al., 1975. "Experimental and Theoretical Investigation of a Direct Coal-Fired MHD Generator," 6th International Conference on MHD Electric Power Generation, Washington, DC, June 9-13.
- Young, W.E., et al., 1967. "Recent Studies of Advanced Coal Burning Power Plants," 1967 Intersociety Energy Conversion Engineering Conference, pp. 485-492.
- Young, W.E., et al., 1974-1975. "Magnetohydrodynamic Investigation for Coal-Fired Open Cycle Systems," Monthly Prog. Rep. 1-20, OCR Contract No. 14-32-0001-1540, Office of Coal Research, Washington, DC.

## Appendix A MHD Economic-Environmental Simulation

A computerized model has been developed at the MIT Energy Laboratory that has the capability of simulating the siting of many technologies including MHD power plants. This model, AEGIS - Alternative Electric Generation Impact Simulator, can be obtained from James Gruhl, principal investigator, at the MIT Energy Laboratory. To date the sponsors have been New England Electric System (NEES), Bradley Schrader program manager, and Northeast Utilities Service Co. (NUSCO), Denning Powell and William Renfro program managers.

Table A-1 shows the interactive nature of the program's input routine. Table A-2 displays the listing of the input assumptions and acts both as a means for the user to verify the assumptions and for the formal record of the simulation run.

The output from the OCMHD simulation is shown in Table A-3, displaying the range of uncertainty associated with each of the 109 performance measures. Minus numbers, such as -1., or letters, such as NA, are indications that these are performance values that are not predicted by the particular modules chosen by the user.

Table A-4 presents the code for identifying specific pieces of information that the user may be interested in retrieving from the online documentation. Tables A-5 and A-6 show the retrievals of all OCMHD power plant information and LAMM health impact information. References are almost all available in this report's bibliography. The AEGIS program and bibliography will be available to the public late in 1978 upon completion of the NEES-NUSCO Project.

Table A-1 Input session for use of AEGIS program - terminal responses are in CAPITALS, user responses are in lower case; this is an example of the no-prompt option.

```

exec aegis
CHECK TERMINAL LINESIZE = 120 OR MORE
EXECUTION BEGINS...
ALTERNATIVE ELECTRIC GENERATION IMPACT SIMULATOR
  AEGIS - VERSION 6
  DATA UPDATED 7/78

      AT ANY TIME USE NAMELIST VARIABLE=0 TO STOP OR RESTART RUN
      IS THIS AN ACTUAL RUN OR DEBUG RUN? TYPE A OR D

a  ALL OPTION VARIABLE DEFAULTS ARE 1
   NN=1 TO 10 FOR NUMBER OF EXAMPLES CARRIED, NN=1 ONLY FOR VERSION 2,
   NP=1 FOR PROB OR 2 FOR MEDIAN DISPLAYS,
   ND=1 FOR JUST FINAL DISPLAY OR =2 FOR DISPLAY ALONG THE WAY,
   NQ=1 FOR FULL PROMPTING DESCRIPTIONS OR 2 FOR MINIMUM PROMPTS, 3 FOR NO PROMPTS

&PRINT NN, NP, ND, NQ &END <AS INTEGERS>
&print nn=1, np=1, nd=1, nq=3 &end

Z1=SIZE, Z2=YEAR, Z3=FUEL, Z4=PREC, Z5=COMB, Z6=SORR, Z7=DCAP, Z8=PART
&ZLIST Z1, Z2, Z3, Z4, Z5, Z6, Z7, Z8 &END <AS INT>
&ZLIST Z1=1900, Z2=1998, Z3=1, Z4=1, Z5=6, Z6=1, Z7=70, Z8=1 &end

Z9=SCRUB, Z10=STACK, Z11=MET, Z12=SULF, Z13=SMOC, Z14=POP, Z15=SCAL, Z16=HEAL, Z17=RAD, Z18=INDEX
&ZLIST Z9, Z10, Z11, Z12, Z13, Z14, Z15, Z16, Z17, Z18 &END <AS INT, EXC Z15 DEC>
&ZLIST Z9=1, Z10=235, Z11=1, Z12=1, Z13=1, Z14=2, Z15=.9, Z16=3, Z17=1, Z18=1 &end
  AEGIS - VERSION M 6D 13  UPDATED 7/78

```

Table A-2 Display to user of the assumptions that will be used in this particular session.

```

!-----!
! ASSUMPTIONS !
!-----!
SIZE<MVE>          1900.0
YEAR COMPL         1998.0
FUEL TYPE          NAT RANGE BITUMINS COALS
PRECL TYPE        NONE
GENERATYPE        COALFIRED OPEN CYCLE MHD
DES CAPAC FAC<%>  70.000
STORAGE CAP<MWH> .0
SORBENT TYPE      NONE
ABATE TYPES:
PART TYPE         NONE
SCRUB TYPE        NONE
STACK HT<M>       235.00
MET SITE TYPE     STANDARD AMBIENT SCALING
AEROCHEN MODELS:
SULFATION TYPE   NONE
SHOG TYPE        NONE
DENSITY PATTERN  INDIAN POINT IN 1980 EST
SCALED BY        .90000
HEALTH/IMPACTS:
CHEM HEALTHI MOD LINEAR ADD MORT MODEL
RAD HEALTHI MOD  NONE
POLLUTION INDEX NONE
}
FOR CHANGES NQ=4, OTHERWISE NQ=3
&PRINT NQ &END
&print nq=3 &end

```

Table A-3 Performance measures for the technology/site options chosen for this simulation.

CUMULATIVE PROB MEASURES PROB VALUE < THIS VALUE	MINIMUM .0000	1 DEV LO .1587	MEDIAN .5000	1 DEV HI .8413	MAXIMUM 1.0000
ECONOMIC FACTORS					
INVEST COST<MIL \$>	1219.8	1364.2	1529.5	2095.7	2736.0
NORMALIZED INVEST<\$1000/MWE>	642.00	718.00	805.00	1103.0	1440.0
OPERATING COSTS:					
FIXED OPER COST<\$/MWE/YR>	.11248E+06	.12579E+06	.14104E+06	.19325E+06	.25229E+06
VARIABLE OPER COST<\$/MWH>	7.4159	8.8692	11.229	14.377	19.852
OPERATIVE<\$/MWH>	1.6000	1.7000	2.8000	3.2000	4.0000
FUEL<\$/MWH>	5.8159	7.1602	8.4289	11.177	15.852
COST OF ELECT<MILS/KWH>	25.759	29.383	34.229	45.892	60.995
CAP COST<MILS/KWH>	18.343	20.514	23.000	31.514	41.143
OP COST<MILS/KWH>	1.6000	1.7000	2.8000	3.2000	4.0000
FUEL COST<MILS/KWH>	5.8159	7.1692	8.4289	11.177	15.852
PERFORMANCE FACTORS					
OPER CAP FAC<% <td>55.000</td> <td>63.000</td> <td>68.000</td> <td>70.000</td> <td>75.000</td>	55.000	63.000	68.000	70.000	75.000
ENERGY EFF ONSITE<%	39.819	43.347	46.147	48.068	49.867
APPLICABILITY					
COMMERC YR<2000MWE ONLINE>	1995.0	1996.0	1999.0	2003.0	2021.0
INSTALLED CAP<MWE>	583.00	583.00	583.00	583.00	583.00
LARGEST FACILITY<MWE>	500.00	500.00	500.00	500.00	500.00
RESOURCE REQUIREMENTS					
LAND USE ONSITE<ACRES>	70.490	96.900	370.50	659.30	1187.5
LAND DISTURB FUEL<ACRES/YR>	63.776	99.243	120.60	146.74	179.70
LAND DISPOSE WASTE<ACRES/YR>	59.850	86.450	119.70	151.62	196.84
WATER CONSUMP<MIL GAL/YR>	2394.0	2926.0	4123.0	5995.0	7315.0
ENVIRONMENTAL CONSEQUENCES					
AIR EMIS ONSITE<GM/MIN>:					
SOX	101.82	1287.7	42475.	.12090E+06	.48523E+06
SULFATES	8.1452	90.141	2973.3	9093.0	33819.
SULF ACID AEROS	1.2727	12.877	504.40	1515.5	5661.0
NOX	5700.0	14250.	17100.	29450.	64600.
NO	5700.0	14250.	17100.	29450.	64600.

Table A-3 Continued display of performance measures.

O3, OXID	.64600E-03	.20000E-02	.64600E-02	.20330E-01	.64600E-01
PART TOTAL	9690.0	47500.	77900.	98800.	11590F+06
PART RESPIR	7030.0	32300.	55100.	68400.	81700.
CO	15060.	53200.	.15960E+06	.53200E+06	.15960E+07
CO2	.38000E+07	.47500E+07	.57000E+07	.76000E+07	.11400E+08
HC TOTAL	3.0400	9.8800	30.400	98.800	304.00
INERT HC	2.4320	7.9800	24.320	79.800	243.20
REACTIVE HC	3.0400	.98800	3.0400	9.8800	30.400
OXYG HC	.30400E-01	.98800E-01	.30400	.98800	3.0400
POLY ORG MAT	.26600	.89300	2.6600	8.9300	27.360
TRACE ELEM:					
ARSEN	.34397E-01	3.8291	23.482	150.89	398.10
BERYL	.13759E-01	.79669	5.1235	14.164	32.105
CAD	.68794E-02	.37236	6.9642	134.90	452.14
CHROM	.27518	8.5587	57.575	163.29	577.89
COB	.68794E-01	2.5087	32.058	104.33	368.13
LEAD	.27518	8.0305	58.253	372.98	933.18
MANG	.41276	12.190	206.85	695.06	1037.0
MERC	.13759E-02	.23272E-01	.83745E-01	.29607	1.7123
NICK	.20638	11.500	88.225	256.64	847.57
SELEN	.30957E-01	.45614	2.6128	7.3554	24.721
TIN	.68794E-01	2.2683	20.057	131.24	540.32
VANAD	.75673	19.251	95.875	244.22	584.31
ZINC	.41276	30.254	820.91	9270.6	41223.
RADIOACT TO AIR<CUR/YR>	.31402E-03	.29245E-01	.11002	.23652	.58511
WATER EMIS ONSITE<TONS/YR>	.44245E+06	.52351E+06	.60302E+06	.71259E+06	.88853E+06
INORGANIC<TONS/YR>	.39860E+06	.47140E+06	.54272E+06	.64197E+06	.79868E+06
ORGANIC<TONS/YR>	43846.	52103.	60302.	70617.	88853.
THERMAL<10*12 BTU/YR>	25.510	28.119	30.151	33.016	36.939
RADIOACT TO WAT<CUR/YR>	.0	.0	.0	.0	.0
SOLID WASTES<TONS/YR>	.60753E+06	.26624E+07	.38457E+07	.53221E+07	.11083E+08
RADIOACT SOLIDS<CUR/YR>	.0	.0	.0	.0	.0
ATMOS DILU FAC<UG/M3/G/MIN>					
GASEOUS:					
1 HOUR	.83301E-06	.14072E-05	.33154E-05	.66555E-05	.11353E-04
3 HOUR	.15048E-05	.25421E-05	.59892E-05	.12023E-04	.20509E-04
8 HOUR	.19885E-05	.33592E-05	.79143E-05	.15887E-04	.27101E-04
24 HOUR	.25796E-05	.43578E-05	.10267E-04	.20611E-04	.35158E-04
3 DAY	.32783E-05	.55381E-05	.13048E-04	.26193E-04	.44680E-04
1 MON	.44069E-05	.74446E-05	.17540E-04	.35210E-04	.60062E-04
ANNUAL	.53742E-05	.90788E-05	.21390E-04	.42939E-04	.73246E-04
PARTICULATES:					
1 HOUR	.57056E-06	.74611E-06	.19311E-05	.34233E-05	.51789E-05
3 HOUR	.10307E-05	.13478E-05	.34885E-05	.61841E-05	.93554E-05
8 HOUR	.13620E-05	.17810E-05	.46098E-05	.81719E-05	.12363E-04
24 HOUR	.17669E-05	.23105E-05	.59802E-05	.10601E-04	.16038E-04
3 DAY	.22454E-05	.29363E-05	.75999E-05	.13473E-04	.20381E-04
1 MON	.30184E-05	.39472E-05	.10216E-04	.18111E-04	.27398E-04
ANNUAL	.36810E-05	.48136E-05	.12459E-04	.22086E-04	.33412E-04



Table A-4 Code and format for on-line documentation retrieval.

AEGIS DOCUMENTATION IDENTIFICATION CODE

AEGIS - ALTERNATIVE ELECTRIC GENERATION IMPACT SIMULATOR, VERSION M005D012  
 FOR FURTHER INFORMATION CONTACT: J. GRUHL, F38-408, 77 MASS. AVE., CAMBRIDGE MA  
 (617)253-8025 OR MESSAGE AT -3404

D = DOCUMENTATION TEXT IDENTIFIER  
 INN = MODULE NUMBER

- 01=FUELS
- 02=PRETREATMENT
- 03=COMBUSTION
- 04=ADDITIVE
- 05=PARTICULATE ABATEMENT
- 06=OTHER ABATEMENT
- 07=ATMOSPHERIC CHARACTERISTICS AND DISPERSION MODEL
- 08=AEROCHEMICAL MODEL
- 09=DEMOGRAPHIC CHARACTERISTICS
- 10=CHEMICAL HEALTH IMPACTS
- 11=RADIATION HEALTH IMPACTS
- 12=OTHER IMPACT MEASURES

INN = SPECIFIC MODEL (WITHIN MODULE)  
 INN = DESCRIPTIVE INFORMATION (FOR SPECIFIC MODEL)  
 INN = LINE NUMBERS (FOR SAME DESCRIPTIVE INFORMATION)  
 LINES 01=CONCENSUS PROBABILISTIC BREAKDOWN, FIVE NUMBERS  
 MINIMUM, .00 CUMULATIVE PROBABILITY  
 ONE DEV LOW, .16 CUMULATIVE PROBABILITY  
 MEDIAN, .50 CUMULATIVE PROBABILITY  
 ONE DEV HIGH .84 CUMULATIVE PROBABILITY  
 MAXIMUM, 1.06 CUMULATIVE PROBABILITY

02 TO 09=CORRELATED CONDITIONALS  
 10 TO 99=SPECIFIC SOURCES AND NUMBERS

D11223344

IS EXAMPLE DOCUMENTATION LINE IDENTIFIER FOR INFORMATION ABOUT MODULE 11,  
 MODEL 22, ROW OF DESCRIPTIVE INFORMATION 33, LINE 44

Table A-5 On-line retrieval of Open Cycle Coal-Fired MHD data.

ID	DESCRIPTION	VERSION	DATA 1	DATA 2	DATA 3	DATA 4	DATA 5
D03060000	VERSION D013						
D03060001	DESCRIPTION OPEN CYCLE COAL-FIRED MHD						
D03060002	DIRECT AIR PREHEATING AT 1350K, 95% STOICHIOMETRIC AIR, 2 STAGE						
D03060003	COMBUSTOR, DIRECT COAL-FIRED, 80% SLAG REJECTION, 1.0% K2CO3 SEEDING,						
D03060004	.75 MACH FLOW RATE, 6 ATM, 6 TESLA MAGNETIC FIELD, STEAM BOTTOMING						
D03060005	CYCLE OF 24.1MN/M2/811K/811K		45.6	47.0	48.3	48.7	49.2
D03060101	OVERALL ENERGY EFF%						
D03060102	+(1.-SULFUR% OF COAL TIMES 0.9)						
D03060103	+0 FOR ILL6, -.35 MONT ROSEBUD, -2.0 N.D., -6.05 SRC (GRUHL, NOV1977)						
D03060104	TIMES 1. FOR 2%MOISTURE, .97 FOR 10%, .86 FOR 27.4% (CUTTING, 1977)						
D03060110	(WITWER, 1976) 46-55						
D03060111	(GRUHL, NOV1977) 45.6-49.2						
D03060112	(POMEROY, ET AL, 1978) 48.3-49.2						
D03060113	(HALS, JACKSON, 1969) 50-60						
D03060114	(FELDMANN, SIMONS, BIENSTOCK, 1970) THERMAL 50.8-51.9						
D03060115	(BERGMAN, BIENSTOCK, 1976) 45.6-50.14						
D03060116	(JACKSON, ET AL, 1976) 47						
D03060117	(CUTTING, ET AL, 1977) 46-46.9						
D03060118	(SEIKEL, HARRIS, 1976) 41-53, 42-50 (W.E.CO.), 48.3 (G.E.CO.)						
D03060119	(POVELL, ULMER, 1974) 50-55						
D03060120	(PENNY, BOURGEOIS, CAIN, 1977) 55-60						
D03060121	(GENERAL ELECTRIC, 1976) 44-55						
D03060122	(GENERAL ELECTRIC, 1976) SRC 40-46						
D03060123	(NASA, 1977) 48.3-48.7						
D03060124	(PEPPER, YU, 1975) 52 THERMAL						
D03060125	(WESTINGHOUSE, 1976) DIRECT AIR PREHEAT 44-49, 44-54						
D03060126	(NASA, 1976) LOW BTU PREHEAT 46-54						
D03060201	CAP INVEST 1978\$/KWE		642.	718.	805.	1103.	1440.
D03060210	(WITWER, 1976) BASELOAD 1975\$ 600						
D03060211	(POMEROY, ET AL, 1978) 805						
D03060212	(HALS, JACKSON, 1969) 90-120						
D03060213	(ROSA, ET AL, 1970) 35-55 PEAKING						
D03060214	(SEIKEL, HARRIS, 1976) 718						
D03060215	(GENERAL ELECTRIC, 1976) 910-1440						
D03060216	(NASA, 1977) 1103 (W.E.CO.)						
D03060217	(PEPPER, YU, 1975) 340-440						

Table A-5 (continued)

D03060218	(NASA, 1977) 642 (G.E.CO.)					
D03060301	C O E 1978MILS/KWH	27.1	36.0	42.0	48.5	55.5
D03060302	THIS HAS A TIGHTER DISTRIBUTION THAN THE SUM OF ITS COMPONENT					
D03060303	PROBABILITIES DUE TO INVESTMENT/OPERATING COST TRADEOFFS					
D03060310	(WITWER, 1976) 1977\$ WITH 1\$/MRTU COAL	28				
D03060311	(LEVI, 1978) 32					
D03060312	(NASA, 1975) 41-48(G.E.CO.), 27-35(W.E.CO.), 34-42(L.O.W BTU)					
D03060313	(POMEROY, ET AL, 1978) 34-43 BASELOAD					
D03060314	(POMEROY, ET AL, 1978) 130 PEAKING					
D03060315	(HALS, JACKSON, 1969) 3.34-4.26					
D03060316	(SEIKEL, HARRIS, 1976) 42-49(G.E.CO.), 32-50(W.E.CO.), 31.8(G.E.CO.)					
D03060317	(GENERAL ELECTRIC, 1975) 41.5-55.5					
D03060318	(NASA, 1977) 27.1-43.9					
D03060401	C O E CAP 1978MILS/KWH	14.0	22.7	25.5	34.8	37.7
D03060402	COE CAP= CAPITAL INV TOTAL X CAPITAL COST FACTOR / (LOAD FACTOR X CAP)					
D03060403	CAP COST FACT = ABOUT 10% PUBLIC, 20% PRIVATE SECTOR					
D03060404	20% IS USED IN SIMULATOR, THESE VALUES ARE FOR COMPARISON PURPOSES					
D03060405	ONLY WITH THESE VALUES DETERMINED ENDOGENOUSLY					
D03060410	(WITWER, 1976) CCF 10% 10.6, CCF 20% 21.2					
D03060411	(GENERAL ELECTRIC, 1976) 22.7, 22.7, 24.4, 25.5, 29.5, 18.4					
D03060412	(CORMAN, ET AL, 1976) 34.9, 33.2, 37.7, 34.8, 35.7, 35, 44.7, 32.0					
D03060413	(NASA, 1977) 22.7					
D03060414	(HALS, JACKSON, 1969) 2.57-1.93					
D03060415	(POMEROY, ET AL, 1978) CAP FAC .7=14, .4=24.5, .15=65.3					
D03060501	C O E O&M 1978MILS/KWH	1.6	1.7	2.8	3.2	4.0
D03060510	(WITWER, 1976) 1.0					
D03060511	(GENERAL ELECTRIC, 1976) 1.7, 1.7, 1.7, 1.7, 1.8, 1.7					
D03060512	(CORMAN, ET AL, 1976) 2.8, 2.9, 3.2, 2.9, 2.9, 2.8, 2.8, 3.6, 2.3					
D03060513	(HALS, JACKSON, 1969) .27-.33					
D03060514	(NASA, 1977) 1.7					
D03060515	(POMEROY, ET AL, 1978) CAP FAC = .7=3.2, .4=3.6, .15=4.8					
D03060601	C O E FUEL MILS/KWH	6.1	6.3	7.3	8.8	11.0
D03060602	COE FUEL = \$/MRTU COAL X .003412MRTU/KWH / .01EFFICIENCY%					
D03060603	DETERMINED ENDOGENOUSLY, THESE VALUES FOR COMPARISON ONLY					
D03060610	(WITWER, 1976) 6.2 FOR 6200BTU/KWH, \$1.00/MRTU COAL					
D03060611	(NASA, 1977) 7.3					

Table A-5 (continued)

D03060612	(HALS, JACKSON, 1969)	.20/MBTU COAL = 1.36		
D03060613	(POMEROY, ET AL, 1978)	16.5		
D03060614	(GENERAL ELECTRIC, 1976)	7.3, 7.3, 7.3, 7.3, 7.3, 7.3, 11.0		
D03060615	(CORMAN, ET AL, 1976)	6.2, 6.3, 6.1, 6.3, 6.3, 6.3, 6.6, 8.8		
D03060616	(CORMAN, ET AL, 1976)	CHANGE 20% FUEL = 1.3 CHANGE		
D03060701	MAX AVAILAB %	55.	63.	68.
D03060702	SHOULD BE DECREASING FN OF SIZE OF MODULES BUT NO DATA		70.	75.
D03060710	(JACKSON ET AL, 1976)	70		
D03060711	(JACKSON, ET AL, 1976)	20% TOTAL UNAVAILABILITY		
D03060712	(POMEROY, ET AL, 1978)	65 = 100-20FORCED-15PLANNED		
D03060801	COMMERC YR	1995	1996	1999
D03060802	FOR COAL-FIRED FACILITIES, NOT GAS OR OIL WHICH ARE MUCH SOONER		2003	2021
D03060810	(WITWER, 1976)	1995		
D03060811	(PEPPER, YU, 1975)	1988		
D03060812	(POMEROY, ET AL, 1978)	2003		
D03060813	(SEIKEL, HARRIS, 1976)	1996-1999		
D03060814	(PENNY, BOURGEOIS, CAIN, 1977)	2000		
D03060815	(CORMAN, ET AL, 1976)	1997		
D03060901	INSTALLED CAP MWE	83.	583.	2600.
D03060902	AT YEARS 1985 1990 1995 2000 2005			
D03060910	(GRUHL, NOV1977)	.2 1978, 4.3 1979, 13 1981, 83 1985, 583 1989		
D03061001	LARGEST FAC MWE	70.	500.	2000.
D03061002	AT YEARS 1985 1990 1995 2000 2005			
D03061010	(GRUHL, NOV1977)	.2 1978, 4 1979, 9 1981, 70 1985, 500 1989		
D03061101	LAND ONSITE ACRES/MW	.0371	.051	.195
D03061110	(GENERAL ELECTRIC, 1976)	MAIN PLANT 3.71 PER 100MWE		.625
D03061111	(HARRIS, SHAH, 1976)	5.1 PER 100MWE		
D03061112	(HOOVER, ET AL, 1976)	11.64 TO 24.38 PER 100MWE		
D03061113	(HOOVER, ET AL, 1976)	PLUS RAILROAD ACCESS 23.05 TO 28.13 PER 100MWE		
D03061201	LAND USE WASTE ACRES/MW	.045	.065	.090
D03061210	(HARRIS, SHAH, 1976)	84/1932MW		
D03061211	(HOOVER, ET AL, 1976)	11.36 TO 14.75/100MW		
D03061301	WATER CONS MIL GAL/MW	1.8	2.2	3.1
D03061310	(JACKSON, ET AL, 1977)	24MWE 163GAL/MIN		4.5
D03061311	(GENERAL ELECTRIC, 1976)	.22 GAL/KWH		5.5
D03061312	(SHAW, CAIN, 1977)	.727KG/KWH		

Table A-5 (continued)

D03061313	(HARRIS, SHAH, 1976) .33 GAL/KWH				
D03061314	(HOOVER, ET AL, 1976) .53 TO .612 GAL/KWH				
D03061401	OUTLET VEL M3/MIN/MW	17.25	17.25	17.25	17.25
D03061402	THIS NUMBER NOT USED IN CURRENT VERSION OF PROGRAM				
D03061403	HAS NOT BEEN COMPUTED, 17.25 IS CONV COAL NUMBER				
D03061410	(GENERAL ELECTRIC, 1976) 10.97 MIL LB/HR 14.7PSIA, 1932MW				
D03061411	(WESTINGHOUSE, 1976) 3435.8 LB/S, 14.7PSIA, 1900MW				
D03061501	SOX % REL	0.4	1.0	16.	66.
D03061510	(ARGYROPOLIS, 1976) 0.4				
D03061511	(GENERAL ELECTRIC, 1976) ASSUMING 3%S COAL 66.				
D03061512	(HARRIS, SHAH, 1976) ASSUMING 3%S COAL 18.				
D03061512	(RESEARCH AND EDUC ASSOC, 1976) ASSUMING 3%S COAL 16.				
D03061601	SULFATES % REL	0.032	0.07	1.12	4.60
D03061602	ASSUMPTION ON K2SO4 COLLECT EFF AND SO2/SO3 RATIO THIS IS				
D03061603	ABOUT .07 OF THE SOX RELEASE NUMBER				
D03061701	SULF ACID % REL	0.005	0.010	0.190	0.770
D03061702	ABOUT 1/6 OF SULFATES, NO DATA				
D03061801	NOX G/MIN/MW	3.0	7.5	9.0	34.0
D03061802	CONVERSION IS LB/MBTU INPUT = ABOUT 830PPM = .0067LB/KWH				
D03061803	OR APPROXIMATELY 50.2 G/MIN/MW				
D03061810	(GENERAL ELECTRIC, 1976) 0.3 LB/MBTU				
D03061811	(SHAW, 1978) 0.71 LB/MBTU				
D03061812	(FOLSON, 1978) OLD 0.72, NEW .685 LB/MBTU				
D03061813	(MORI, TAIRA, 1972) 243PPM				
D03061814	(MORI, TAIRA, 1973) 50PPM				
D03061815	(PEPPER, EUSTIS, KRUGER, 1972) 283PPM				
D03061816	(PENNY, BOURGEOIS, CAIN, 1977) 135 TO 300PPM				
D03061817	(RIENSTOCK, ET AL, 1973) 150PPM				
D03061818	(HALS, LEVIS, 1972) 160-260PPM				
D03061819	(REA, 1976) 155PPM				
D03061901	NO G/MIN/MW	3.0	7.5	9.0	34.0
D03061902	ESSENTIALLY THE SAME AS NOX, UNSTABLE AND GOES TO ZERO				
D03062001	OXID MG/MIN/MW	.0034	.0011	.0034	.0340
D03062002	SET AT ABOUT .0001PPM, ESSENTIALLY ZERO IN FINE-TUNED DEVICE				
D03062101	PART TOT G/MIN/MW	5.1	25.	41.	61.
D03062102	PRECIPITATION MUST BE 99.5% OR BETTER TO BE				

Table A-5 (continued)

D03062103	ECONOMIC IN RECOVERING VALUABLE SEED FOR RECYCLE								
D03062104	SRC FUEL YIELDS 1/17TH PARTICULATES OF OTHERS								
D03062105	LB/MBTU = .075LB/KWH = ABOUT 570G/MIN/MW								
D03062110	(GENERAL ELECTRIC, 1976) .1LB/MBTU INPUT, .008LB/KWH								
D03062111	(HARRIS, SHAH, 1976) .1LB/MBTU INPUT, .007LB/KWH OUTPUT								
D03062112	(SHAW, CAIN, 1977) 0.15G/KWHT, 0.32G/KWHE								
D03062113	(GENERAL ELECTRIC, 1976) SRC .06LB/MBTU, .00046LB/KWH								
D03062201	PART RESP G/MIN/MW	3.7	17.0	29.0	36.0				43.0
D03062202	PRESUME ABOUT 70% PARTICULATES RESP AFTER SECOND CYCLONE								
D03062301	CO G/MIN/MW	8.4	28.0	84.0	280.				840.
D03062310	(SHAW, CAIN, 1977) NIL								
D03062311	(BIENSTOCK, ET AL, 1971) 0								
D03062312	(GENERAL ELECTRIC, 1976) 0								
D03062313	(HALS, LEWIS, 1972) WITH SECONDARY STAGE 0.4 TO 0.6%								
D03062314	(GRUHL, NOV1977) TUNED TO YIELD JUST A TRACE								
D03062401	CO2 G/MIN/MW	2000.	2500.	3000.	4000.				6000.
D03062402	FLUID BEDS YIELD ABOUT 15% =? 3000G/MIN/MW?								
D03062501	TOTAL HC G/MIN/MW	.0016	.0052	.016	.052				.160
D03062502	1.6 FROM FLUID BEDS								
D03062510	(GENERAL ELECTRIC, 1976) 0								
D03062511	(ROSA, ET AL, 1970) 0								
D03062601	INERT HC MG/MIN/MW	1.28	4.20	12.8	42.0				128.0
D03062602	PRESUME ABOUT 80% OF HC								
D03062701	REACT HC MG/MIN/MW	.16	.52	1.60	5.20				16.00
D03062702	PRESUME ABOUT 10% OF HC								
D03062801	OXYG HC MG/MIN/MW	.016	.052	.160	.520				1.600
D03062802	PRESUME ABOUT 1% OF HC								
D03062901	POM MG/MIN/MW	.14	.47	1.40	4.70				14.40
D03062902	PRESUME ABOUT 9% OF HC								
D03063001	ARSEN % REL	1.0	8.0	20.	33.				40.
D03063010	(GRUHL, NOV1977) 1-40								
D03063101	BERYL % REL	1.0	13.0	38.0	63.0				75.0
D03063110	(GRUHL, NOV1977) 1-75								
D03063201	CAD % REL	1.0	12.0	33.0	54.0				65.0
D03063210	(GRUHL, NOV1977) 1-65								
D03063301	CHROM % REL	1.0	17.0	50.0	84.0				100.

Table A-5 (continued)

D03063310	(GRUHL, NOV1977) 1-100	1.0	14.0	40.0	67.0	80.0
D03063401	COB % REL					
D03063410	(GRUHL, NOV1977) 1-80	1.0	8.0	20.0	33.0	40.0
D03063501	LEAD % REL					
D03063510	(GRUHL, NOV1977) 1-40	1.0	17.0	50.0	84.0	100.0
D03063601	MANG % REL					
D03063610	(GRUHL, NOV1977) 1-100	1.0	3.0	5.0	8.0	10.0
D03063701	MERC % REL					
D03063710	(GRUHL, NOV1977) 1-10	1.0	17.0	50.0	83.0	99.0
D03063801	NICK % REL					
D03063802	TOP VALUE SHOULD REFLECT GOOD NUMBER FROM CONVENTIONAL COAL PLANT	1.0	17.0	50.0	83.0	99.0
D03063810	(HARRIS, SHAH, 1976) 1					
D03063901	SELEN % REL	1.0	6.0	15.0	25.0	30.0
D03063910	(GRUHL, NOV1977) 1-30					
D03064001	TIN % REL	1.0	17.0	50.0	83.0	99.0
D03064002	TOP VALUE SHOULD REFLECT GOOD NUMBER FROM CONVENTIONAL COAL PLANT	1.0	17.0	50.0	83.0	99.0
D03064010	(HARRIS, SHAH, 1976) 1					
D03064101	VANAD % REL	1.0	12.0	35.0	59.0	70.0
D03064110	(GRUHL, NOV1977) 1-70					
D03064201	ZINC % REL	1.0	13.0	36.0	60.0	72.0
D03064210	(GRUHL, NOV1977) 1-72					
D03064301	RAD226 % REL	1.0	17.0	50.0	84.0	100.0
D03064310	(GRUHL, NOV1977) 1-100					
D03064401	RAD228 % REL	1.0	17.0	50.0	84.0	100.0
D03064410	(GRUHL, NOV1977) 1-100					
D03064501	WAT EM TOT TONS/10*12BTU IN 5000. 6300.			7000.	7700.	8900.
D03064502	LB/KVHE = ABOUT 70600 TONS/10*12BTU IN					
D03064510	(SHAW, CAIN, 1977) 24.6 G/KVHT, 51.6/KVHE					
D03064511	(HARRIS, SHAH, 1976) .75LB/KVH					
D03064512	(GENERAL ELECTRIC, 1976) .09LB/KVH					
D03064601	WAT EM INORG T/10*12BTU IN 5000. 5700.			6300.	7000.	8000.
D03064602	ASSUMING APPROXIMATELY 90% OF TOTAL WASTE IS INORGANIC					
D03064701	WAT EM ORG T/10*12BTU IN 550. 630.			700.	770.	890.
D03064702	ASSUMING APPROXIMATELY 10% OF TOTAL WASTE IS ORGANIC					
D03064801	WAT EM THERM % OF BTU IN 32. 34.			35.	36.	37.
D03064802	EARLIER DATA SET VERSION WAS BTU THERMAL/10*12BTU IN					

Table A-5 (continued)

D03064810	(GENERAL ELECTRIC, 1976)	2468RTU/KWH, SRC	20408TU/KWH			
D03064811	(HARRIS, SHAH, 1976)	2377RTU/KWH				
D03064901	RAD TO WAT CUR/10*12BTU IN	0.0	0.0	0.0	0.0	0.0
D03065001	SOL WASTES T/10*12BTU IN	4500.	5100.	5600.	6200.	7100.
D03065002	LB/KVHE = ABOUT 70600TONS/10*12BTU IN					
D03065003	ASSUMING 48.3% EFFICIENCY, SOLID WASTES SHOULD BE					
D03065004	COMPUTED AS 99.5% OF ASH OF INCOMING COAL					
D03065010	(SHAW, CAIN, 1977)	14.0IG/KVHT, 29.G/KVHE				
D03065011	(GENERAL ELECTRIC, 1976)	0.082LB/KVH				
D03065101	OTHER SOL WASTES T/10*12	0.0	0.0	0.0	0.0	0.0
D03065102	SULFUR IS RECOVERED THAT ENTERS SYSTEM AND DOES NOT EXHAUST BUT					
D03065103	THIS IS CONSIDERED (MARGINALLY) SALEABLE PRODUCT, NO SEED LOSS					
D03065201	RAD SOL CUR/10*12BTU IN	0.0	0.0	0.0	0.0	0.0
D03065301	OCC HEALTH MORT/10*12BTU IN	0.0080	.00100	.00125	.00150	.00180
D03065302	IN ABSENSE OF DATA SAME AS COAL PLANT, ALTHOUGH PRESSURIZED					
D03065303	VESSEL SHOULD INCREASE THESE NUMBERS					
D03065401	OCC HEALTH MORB/10*12BTU IN	0.008	.0106	.0215	.0360	.0450
D03065402	AGAIN SAME AS COAL PLANT IN ABSENSE OF DATA					
D03065501	OCC HEALTH HDL/10*12BTU IN	3.0	4.41	9.20	14.0	18.0
D03065502	WORK DAYS LOST ALSO PRESUMED SAME AS CONVENT COAL IN ABSENSE OF DATA					
D03065601	PUB H CATAST PROB/10*12	.10E-08	.48E-08	.80E-08	1.28E-08	1.6E-08
D03065602	REFLECTS THE PROBABILITY OF EXPLOSION OR COALPILE FIRE					
D03065603	ASSUMES COAL FIRE 1/100 TO 1/1000 PROBABILITY OF OIL PIPE					
D03065604	1000M/YR=29.89X10*12BTU IN X .01CAPFAC%/0.01EFFIC%					
D03065610	(BECKMAN, 1976)	10-4 FOR OIL-FIRED PLANT WHERE > 10 MORTALITIES				
D03065701	PUB H CATAST MORT/10*12	.008	.015	.018	.021	.028
D03065702	FOR CONVENT 36%EFF 100%CAPFAC COAL PLANT 12.0M/YR=ABOUT 10*12BTU IN					
D03065703	SHOULD INCLUDE MORTALITIES RESULTING FROM COALPILE FIRE PLUME					
D03065704	AS WELL AS PUBLIC MORTALITIES FROM PRESSURIZED VESSEL EXPLOSION					
D03065705	AND PUBLIC MORTALITIES FROM COAL TRANSPORT					
D03065710	(CEQ, 1973)	2.30/750M/Y AT RR CROSSINGS				
D03065711	(SAGAN, 1974)	1.3/1000M/PLANT/YR				
D03065712	(AEC, 1974, WASH-1224)	0.55/1000M/PLANT/YR				
D03065713	(GRUHL, SEP1976)	1.8X10*2 OIL-FIRE MORT / PLANT / FIRE / 10*7 POP				
D03065801	PUB H CATAST CANC/10*12	.05E-06	.31E-06	.66E-06	3.9E-06	8.7E-06
D03065802	SHOULD BE CANCINOGENIC IMPACTS OF COALPILE FIRE PLUME					

Table A-5 (continued)

D03065803	ASSUMING BETWEEN 1 AND 10 MILLION PERSONS EXPOSED TO PLUME			
D03065810	(HICKEY, ET AL, 1970) 54.6 ADDIT CANCERS PER MILLION FROM SO4			
D03065901	PUB H CATAST BRPU/10*12 1.5E-07 0.6E-06 2.5E-06 5.5E-06 12.E-06			
D03065902	SHOULD BE BRONCHOPULM CASES FROM COALPILE FIRE PLUME			
D03065903	ASSUME ABOUT SAME AS ANNUAL CASES			
D03065910	(NAS, 1975) .9-3.6X10*4 FOR 1000MWE REGULAR OPERATION			
D03066001	PUB H CATAST CRVS/10*12 .1E-05 .45E-05 1.0E-05 2.2E-05 9.E-05			
D03066002	SHOULD BE CARDIOVASCULAR CASES FROM COALPILE FIRE PLUME			
D03066003	ASSUME ABOUT SAME AS ANNUAL CASES FROM NORMAL OPERATION			
D03066010	(NAS, 1975) .7-2.8X10*5 FOR 1000MWE NORMAL OPERATION			
D03066101	PUB H CATAST MORB/10*12 IN .08 .21 .28 .35 .41			
D03066102	SHOULD INCLUDE COALPILE FIRE CASES			
D03066110	(CEQ, 1973) 23.4/750MWY AT RR CROSSINGS			
D03066201	PUB H CATAST WDL/10*12 IN 8.0 21. 28. 35. 41.			
D03066202	SHOULD INCLUDE COALPILE FIRE CASES			
D03066210	(CEQ, 1973) 2340./750MWY AT RR CROSSINGS			
D03066301	AIR EM THERM % OF BTU IN 7.2 8.0 8.9 9.8 10.5			
D03066302	NOT DISPLAYED AS EMISSION, JUST USED FOR PLUME RISE COMPUTATIONS			
D03066310	(GENERAL ELECTRIC, 1976) 606BTU/KWH			

Table A-6 On-line retrieval of documentation of LAMM health impact model.

D10030000	VERSION D013
D10030001	DESCRIPTION LINEAR ADDITIVE MORTALITY MODEL - LAMM
D10030002	CRUDE, LINEAR MODEL BASED UPON CONSENSUS STANDARDS, IT ONLY
D10030003	PREDICTS ANNUAL INCREASES IN MORTALITY RATES, SOURCE IS
D10030004	(GRUHL, ET AL, NOV1976, P106), ACCURACY DEPENDS ON AMONG OTHER THINGS
D10030005	SMALLNESS OF REGIONS CONSIDERED
D10030010	TOTAL ADDITIONAL ANNUAL MORTALITIES PER 10*6 PERSONS IN SOME
D10030011	REGION NEAR POINT SOURCE = SUMMATION (REGIONAL MAXIMUM UG/M3 24HR
D10030012	AVERAGE CONCENTRATIONS OF NOX/455 + SOX/365 + CO/710000 + PART/260
D10030013	+ ARSEN/.15 + BERYL/.01 + MERC/.10 + NICK/.03 +
D10030014	+ RADIUMS(CURIES/YR)/.02 )