RELATIONSHIP OF SAFETYANALYSES TO LICENSING AND TECH SPECS

Radioactive material

Whose release is prevented by

Clad, pressure vessel & containment

Whose integrity is assured by

Adherence to GDC of 10CFR50, App A

Which is checked by

Analyses of credible transients and accidents

Which give acceptable results for

A range of plant and core characteristics

To which range, operation is restricted by

Technical 5 specifications