

MITNE-167

**A METHOD OF SHORT-RANGE  
SYSTEM ANALYSIS FOR ELECTRIC UTILITIES  
CONTAINING NUCLEAR PLANTS**

**Raymond Eng**

**Manson Benedict**

**Edward A. Mason**

**Department of Nuclear Engineering  
Massachusetts Institute of Technology  
Cambridge, Massachusetts**

A METHOD OF SHORT-RANGE SYSTEM ANALYSIS  
FOR ELECTRIC UTILITIES CONTAINING NUCLEAR PLANTS  
by Raymond Eng,

Submitted to the Department of Nuclear Engineering on January 15, 1975, in partial fulfillment of the requirements for the degree of Doctor of Philosophy.

ABSTRACT

An optimization procedure has been formulated and tested that will solve for the optimal generation schedule of several nuclear power reactors in an electric utility system, under short-range resource-limited conditions.

The growing fraction of electricity supplied by nuclear energy is presenting conventional utility systems with unique unit commitment problems. Due to the batch nature of the nuclear fuel cycle, a nuclear reactor, once loaded, is limited to utilize a fixed amount of thermal nuclear energy (when limited to full-power reactivity-limited burnup). Thus, due to unforeseen circumstances situations may arise when the nuclear power reactors can not or should not be based loaded at full power until their scheduled refueling date. An optimization procedure has been devised to calculate the best generation schedule for the nuclear reactor to follow until refueling is possible. The optimization is with respect to minimizing system costs over the short-range planning horizon.

The optimization procedure utilizes a concept called Opportunity Cost of Nuclear Power (OCNP) to optimally assign the resource-limited nuclear energy to the different weeks in the short-range planning horizon. OCNP is a function of a week's system reserve capacity, its economic loading order, the customer demand function, and the composition of the utility system components. The optimized OCNP value of the short-range planning period is the utility's short-range cost of replacement energy. The system simulation program, PROCOST, used to calculate OCNP is a deterministic linear programming model capable of simulating five types of electric power plants: nuclear, fossil, peaking, hydro, and pumped-storage units. PROCOST is a versatile program capable of using load-duration curves, chronologic or modified chronologic load models. The survey nature of PROCOST allows it to be adapted to study the great variety of short-range options in the operation of a nuclear power reactor.

Using a model utility system, based on data provided by American Electric Power Service Corporation, three system optimization studies were performed. Case 1 was a single-reactor optimization, Case 2 was a two-reactor

optimization to demonstrate the optimization procedure for a multi-reactor situation. Case 3 was a modification of Case 1 where the outage schedule was adjusted to yield constant minimum monthly system reserves. Analysis of the results of the simulations lead to the following conclusions:

(1) Short-range nuclear system analysis can yield very large savings in fossil fuel costs, on the order of millions of dollars per reactor per optimization cycle.

(2) A logical method has been devised to calculate the short-range price of nuclear power, based on the system's substitutional cost of energy.

(3) The system parameters having the greatest effect on total system operating cost are (a) system reserves, (b) economic loading order and (c) the demand shape.

Thesis Supervisor: Manson Benedict  
Title: Institute Professor, emeritus

Thesis Supervisor: Edward A. Mason  
Title: Professor of Nuclear Engineering  
and Head of Department

Dedication

I dedicate this thesis, the culmination of twenty-one years of schooling to my dear parents who have waited patiently these many years, and to my loving wife, Mary, for her forbearance and her encouragement during the most difficult last two years.



Acknowledgements

I am most grateful for the assistance and guidance offered by my thesis supervisors, Manson Benedict and Edward A. Mason, encouraged by their faith and understanding, and propelled by their probing insights and standard of excellence.

I wish to acknowledge the substantial financial support received from the Atomic Energy Commission fellowship program and the Research Assistantship sponsored by American Electric Power Service Corporation. I wish to thank Nicholas Tibberts and Myron Adams of AEP for their active interest and constructive suggestions during the course of my research.

In preparing this thesis, I also appreciate the assistance from my wife Mary, my brother Tommy, and typists Bea and Allison.

TABLE OF CONTENTS

Abstract	2
Dedication	4
Acknowledgements	5
Table of Contents	6
List of Tables	11
List of Figures	16
Terminology	20
1.0 Summary	
1.1 Introduction	22
1.2 Method of Solution	25
1.3 Implementation	28
1.4 Computer Programs	29
1.5 The Utility System	33
1.6 Case 1	44
1.7 Case 2	51
1.8 Case 3	55
1.9 Conclusions	63
2.0 Short-Range System Analysis	
2.1 Introduction	65
2.2 Motivation for Resource Limited Case	67
2.3 Goals of Thesis	69
2.4 Perspective on Short-Range System Analysis	70

### 3.0 Resource-Limited Case

3.1 Introduction	77
3.1.1 Method of Solution	78
3.1.2 Implementation	85
3.2 Assumptions and Idealizations	91
3.2.1 Deterministic Optimization Model	91
3.2.2 Load Models	94
3.2.3 Nuclear	97
3.2.4 Financial	99

### 4.0 Optimization Models

4.1 Introduction	101
4.2 PROCOST	103
4.2.1 Nuclear L.P. Formulation	105
4.2.2 Pumped-Storage Scheduling Models	111
4.2.2.1 Pumped-Storage Economic Theory	112
4.2.2.2 Pumped-Storage Economic Scheduling Algorithm	119
4.2.2.3 Pumped-Storage Security Theory	125
4.2.2.4 Pumped-Storage Security Scheduling Algorithm	127
4.3 ALLOCAT	129
4.4 FOSSIL	130

### 5.0 System Simulation

5.1 The System	132
5.2 Load Model Study	145
5.3 Single Reactor Optimization-Case 1	160
5.4 Multi Reactor Optimization-Case 2	172

5.5 Single Reactor Optimization-Case 3	184
5.6 Applicability	193

## 6.0 Conclusions and Recommendations

6.1 Conclusions	200
6.2 Recommendations	202

## Appendices

### A: Load Models

A.1 Introduction	205
A.2 PROFILE	212
A.2.1 Input Specifications	212
A.2.2 Program Listing and JCL	213
A.2.3 Sample Output	215
A.3 REGRESS	216
A.3.1 Input Specifications	216
A.3.2 Program Listing and Sample Input	217
A.3.3 Sample Output	221
A.4 MODEL	234
A.4.1 Input Specifications	234
A.4.2 Program Listing and Sample Input	236
A.4.3 Sample Output	238
A.5 Chronologic Load Model Sensitivity Study	246
A.6 Load-Duration Sensitivity Study	268

B: System Parameters

B.1 Nuclear Heat Rates	298
B.2 Fossil Heat Rates	298
B.3 OCNP Values from Case 2	304

C: PROCOST

C.1 Introduction	316
C.2 L.P. Model	322
C.3 MPSX	324
C.3.1 Control Language Program	324
C.3.2 Sample 1	330
C.3.3 Sample 2	331
C.4 Pumped-Storage Security Algorithm	334
C.5 Input Specifications	338
C.6 Program Listing	346
C.7 PROCOST Input for Case 3	392
C.8 Sample Output	406

D: ALLOCAT

D.1 Input Specifications	433
D.2 Program Listing and Sample Input	434
D.3 Sample Output	437

E: Time Value of Money Study	439
------------------------------	-----

F: FOSSIL

F.1 Input Specification	445
-------------------------	-----

F.2 Program Listing and Sample Input	446
F.3 Sample Output	450

References	460
------------	-----

Biographical Note	463
-------------------	-----



LIST OF TABLES

1.1	Maintenance and Forced Outage Schedule of Peaking and Fossil Units	34
1.2	Plant Parameters of Peaking and Fossil Units	37
1.3	Weekly Energy Forecast for Planning Period	39
1.4	Operational Constraints on Nuclear Unit 2 During the Two-Reactor Optimization, Case 2	41
1.5	Optimal Weekly Nuclear Capacity Factor Distribution for the Single Reactor Optimization, Case 1	45
1.6	Monthly Average Fossil Fuel Costs of the Fossil Configurations of Case 1	46
1.7	Weekly System Reserves for Cases 1 and 2	47
1.8A	System Fossil Fuel Costs and Saving For the Single Reactor Optimization (Case 1)	49
1.8B	Programmed Constant Power Levels of Nuclear Unit 2 for Cases 1 and 3	50
1.9	Optimal Capacity Factor Distribution for Case 2	52
1.10	Summary of Two-Reactor Optimization Cost Savings as a Function of the Number of Iteration	54
1.11	Minimum Monthly System Reserves for Cases 1 and 3	56

1.12	Monthly Average Fossil Fuel Costs of the Fossil Configurations for Case 3	57
1.13	Optimal Weekly Nuclear Capacity Factor Distribution for the Single Reactor Optimization (Case 3)	58
1.14	System Fossil Fuel Costs and Saving for Case 3	60
5.1	Maintenance and Forced Outage Schedule of Peaking Units and Fossil Units	134
5.2	Plant Parameters of Peaking and Fossil Units	137
5.3	Weekly Energy Forecast for Planning Period	138
5.4	Operational Constraints on Nuclear Unit 2 During the Two-Reactoer Optimization, Case 2	141
5.5	Maintenance and Forced Outage Schedule of Peaking and Fossil Units of Case 3	143
5.6	Comparison of a Typical Summer Weekly OCNF Function from Six Load Models	148
5.7	August Economic Fossil Loading Order	150
5.8	Nuclear-Fossil Generation Schedule of Three Load Models for a Typical Summer Week at 0.75 Nuclear Capacity Factor	154
5.9	Comparison of the Weekly OCNF Functions Between a Six-Interval Load-Duration Model (E) and a 40-Interval Modified Chronologic Model (D)	156

5.10	Weekly OCNF Functions from the Single Reactor Optimization (Case 1)	161
5.11	Optimal Weekly Nuclear Capacity Factor Distribution for the Single Reactor Optimization, Case 1	164
5.12	Monthly Average Fossil Fuel Costs of the Fossil Configurations for Case 1	166
5.13	Weekly System Reserves for Cases 1 and 2	167
5.14	System Fossil Fuel Costs and Savings for the Single Reactor Optimization (Case 1)	170
5.15	Programmed Constant Power Levels of Nuclear Unit 2 for Cases 1 and 3	171
5.16	Optimal Weekly Nuclear Capacity Factor Distribution for the Multi-Reactor Simulation, Case 2	175
5.17	Optimal Nuclear Energy Distribution for Case 2	178
5.18A	System Fossil Fuel Costs and Savings for Two-Reactor Optimization, Case 2	180
5.18B	Programmed Constant Power Levels of Nuclear Unit 2 for Case 2.A	181
5.19	Summary of Two-Reactor Optimization Cost Savings as a Function of the Number of Iterations, Case 2	182
5.20	Weekly OCNF Functions from the Single Reactor Optimization, Case 3	185
5.21	Weekly System Reserves for Case 3	186

5.22	Monthly Average Fossil Generation Costs of the Fossil Configurations for Case 3	187
5.23	Optimal Weekly Nuclear Capacity Factor Distribution for the Single Reactor Optimization (Case 3)	188
5.24	System Fossil Fuel Costs and Savings for Case 3	190
5.25	Optimal Weekly Nuclear Capacity Distribution for Case 4	194
5.26	System Fossil Fuel Costs and Saving for Case 4	196
A.1	Relative Daily (Weekday) Energy Consumption	207
A.2	Optimal System Cost Comparison of Six Load Models	251
A.3	Fossil Plant Data Used In Sensitivity Study	264
A.4	Optimal System Cost Comparison of 40 Int/wk Load Model With 168 Int/wk Load Model	266
A.5	Typical Economic Loading Order	269
A.6	OCNP Comparison for the Load-Duration Sensitivity Study (One-Reactor, April Load Data Case)	271
A.7	Weekly System Cost Comparison for Load- Duration Sensitivity Study (One-Reactor, April Load Data Case)	272
A.8	Incremental Capacity Factor Comparison for the Load-Duration Sensitivity Study (Single-Reactor, April Load Data Case)	273

A.9	The OCNP Comparison for the Load-Duration Sensitivity Study (One-Reactor, August Load Data Case)	283
A.10	The Weekly Production Cost Comparison for the Load-Duration Sensitivity Study (One-Reactor, August Load Data Case)	284
A.11	Incremental Capacity Factor Comparison for the Load-Duration Sensitivity Study (Single-Reactor, August Load Data Case)	285
A.12	OCNP Comparison for the Load-Duration Sensitivity Study (Two-Reactor, April Load Data Case)	294
A.13	System Cost Comparison for the Load-Duration Sensitivity Study (Two-Reactor, April Load Data Case)	295
A.14	OCNP Comparison for the Load-Duration Sensitivity Study (Two-Reactor, August Load Data Case)	296
A.15	System Cost Comparison for the Load-Duration Sensitivity Study (Two-Reactor, August Load Data Case)	297
B.3.1	Weekly OCNP Functions from the Multi-Reactor Optimization (Case 2)	304
E.1	Parameters of the Cost of Money Experiment	440

LIST OF FIGURES

1.1	Supply and Demand Curves for Nuclear Energy	27
1.2	Typical Weekly OCNP Functions from the Single Reactor Optimization Study	43
1.3	Sample Optimal Weekly Nuclear Dispatching Schedule	62
3.1	Sample Supply and Demand Curves	80
3.2	Supply and Demand Curves for Nuclear Energy	80
3.3	Formation of Market Demand Curves for Nuclear Energy	82
3.4	Allocation of Energy by Equilibrium Price Method	83
3.5	Determination of System Cost Function	84
3.6	Determination of OCNP	84
3.7	Example of Determination of OCNP	87
4.1	PROCOST Algorithm	104
4.2	Illustrative Weekly Load-Duration Curve	114
4.3	Operation of an Idealized Pumped-Storage Facility	114
4.4	Pumped-Storage Duration Curve of Figure 4.3	114
4.5	Fossil Duration Curve of Figure 4.3	114



4.6	Operation of an Infinitely Large Pumped-Storage Facility	116
4.7	Pumped-Storage Duration Curve of Figure 4.6	116
4.8	Fossil Duration Curve of Figure 4.6	116
4.9	Operation of a Finite Pumped-Storage Facility	117
4.10	Pumped-Storage Duration Curve of Figure 4.9	117
4.11	Fossil Duration Curve of Figure 4.9	117
4.12	ECO Flowchart	120
4.13	Full Utilization of a Pumped-Storage Facility without Regard for Cost	122
4.14	Pumped-Storage Duration Curve of Figure 4.13	122
4.15	Fossil Duration Curve of Figure 4.13	122
4.16	Initial Starting Solution of the Pumped-Storage Algorithm	123
4.17	Pumped-Storage Duration Curve of Figure 4.16	123
4.18	Fossil Duration Curve of Figure 4.16	123
4.19	Typical Economic Pumped-Storage Schedule	126
5.1	Weekly OCNF Functions from the Single Reactor Optimization Study, Case 1	162
5.2	Sample Optimal Weekly Nuclear Dispatching Schedule	199

A.1	Winter Customer Demand (Jan.11, 1971) 168-Hour Representation	208
A.2	168-Hour Representation of the Customer Demand for the Week of Jan.4, 1971	247
A.3	84-Interval Representation of the Customer Demand for the Week of Jan.4, 1971	248
A.4	56-Interval Representation of the Customer Demand for the Week of Jan.4, 1971	249
A.5	Comparison of 4-Interval Load Model with 168-Interval Load Model on Winter Data	250
A.6	Comparison of Incremental Fossil Capacity Factors on Winter Load Data and Cost Plan 1	253
A.7	Comparison of 42-Interval Load Model with 168-Interval Load Model on Winter Data	254
A.8	Comparison of 84-Interval Load Model with 168-Interval Load Model on Winter Data	255
A.9	Comparison of Incremental Fossil Capacity Factors on Winter Load Data and Cost Plan 1	256
A.10	Comparison of 19-Interval Load Model with 168-Interval Load Model on Winter Data	257
A.11	Comparison of Incremental Fossil Capacity Factors on Winter Load Data and Cost Plan 1	258

A.12	Comparison of 40-Interval Load Model with 168-Interval Load Model on Winter Data	260
A.13	Comparison of Incremental Fossil Capacity Factors on Winter Load Data and Cost Plan 1	261
A.14	Comparison of 40-Interval Load Model with 168-Interval Load Model on Summer Data	262
A.15	Comparison of Incremental Fossil Capacity Factors on Summer Load Data and Cost Plan 1	263
A.16	Comparison of Incremental Fossil Capacity Factors on Winter Load Data and Cost Plan 2	265
B.1	Nuclear Heat Rate Curve	299
B.2	Large Fossil Heat Rate Curve	301
B.3	Medium Fossil Heat Rate Curve	302
B.4	Small Fossil Heat Rate Curve	303
C.1	PROCOST Algorithm	317
C.2	Pumped-Storage Security Flow Chart	335
E.1	Fossil Production Schedule	442
E.2	Nuclear Production Schedule	443

TERMINOLOGY

Capacity factor: The ratio of electrical energy generated divided by the rated electrical energy.

Customer demand: The power distribution over time required to be met by the utility.

Demand shape: The distributional shape of a customer demand function.

Incremental capacity factor: The ratio of the electrical energy generated divided by the rated electrical energy for a given increment of the generating capability of a power plant.

Interval: A basic individual unit of time, as compared to a period which is a group of time intervals.

Hybrid load model: A modified chronologic load model where the three average workdays (excluding the high and low workdays) have been combined into one average workday.

Load model: The model representation of customer demand function.

Must-run: That portion of unit capacity representing its minimum level of operation without shutting down.

Nuclear capacity factor: The ratio of the thermal nuclear energy generated divided by the rated thermal nuclear energy of the reactor.

Opportunity cost: The value of a limited resource determined by the cost of the next best substitutional resource.

Period: A group of basic time units, as compared to interval, which is a single unit of time.

Scratch disk: A storage device used by computer to store information temporarily.

System configuration: The collection of power plants available to generate power on a utility system.

System reserve capacity: The margin of system capacity above the peak load level.

Valve points: The location of throttles on the steam line of the turbine-generator.

## 1.0 SUMMARY

### 1.1 Introduction

Nuclear power system analysis is concerned with the optimal coordination of nuclear power reactors with the conventional power plants of an electric power supply system. This study is interested in the short-range time frame where the nuclear fuel has been charged to the core and the thermal energy potential available for power generation is fixed (\*) until the reactor's next refueling. The short-range problem is that of optimizing the scheduling of the generation of the electricity potential available from the fuel over the short-range time horizon. This thesis study is concerned only with the resource-limited situation where the amount of available energy from the reactor is insufficient to operate the reactor at full capacity continuously until scheduled refueling. A shortage of energy is possible considering the large number of factors that are related to the original decision on the energy content in the reactor (i.e., long lead times involved in the nuclear fuel cycle, poor forecasting judgement, or forced outages). Examples of changes in the original planning assumptions which could lead to an energy-short situation are:

- (1) The fuel is required to be removed from the reactor after burnup reaches 20,000 MWD/T instead of the

-----

(\*) Only the full-power reactivity-limited burnup case is considered.



originally planned 30,000 MWD/T.

- (2) The plant availability has matured faster than anticipated.

In such cases, available energy of the reactor must be rationed until the next scheduled refueling (if the refueling can not be advanced).

The motivation for the study of the resource-limited case is to develop the tools and procedures and provide a reference case to make possible the study of more complex short-range situations. Thus, the objectives of this thesis are to:

- (1) Develop for the resource-limited case, a calculational model to optimize the short-range production schedule of the nuclear power plants.

Corollary: Develop a calculation model from which more complex short-range problems can be considered.

- (2) Define the parameters that have significant influence on system cost, locating areas of greatest sensitivity.

- (3) Develop generalized rules of thumb for utility dispatcher on the optimal use of nuclear power reactors.

Corollary: Develop a model that will present the dispatcher with a budget of nuclear energy to be expended over the short-range time horizon.

To make this complex problem tractable, a number of assumptions are made to simplify the problem. The major financial assumptions are: (1) the nuclear fuel cycle costs

are fixed and independent of the reactor generation schedule; and (2) the time value of money is ignored over time horizons shorter than one year.

The major nuclear assumptions are (1) that there is no constraint on the rate of change in the power level of the reactors' operation, and (2) that in the full-power reactivity-limited situation, the total amount of thermal energy obtained from a given reactor before refueling is constant, independent of the power history of the reactor. The corollary resulting from these assumptions is that the nuclear energy in the short-range sense is cost-free. Thus, to maximize its utility to the system, the nuclear energy should be scheduled for generation in times of its greatest value to the system.

## 1.2 Method of Solution

The resource-limited case is viewed as an economic problem, a resource allocation problem, in deciding how to allocate a resource (nuclear energy) among many consumers (individual time intervals). The classical economic method of solution is to let the free market place decide which consumers receive the resource and the amount each receives. The free market determines allocation by the forces of supply and demand. For the short-range nuclear allocation problem, where the "actual" market price of nuclear power is ambiguous, the economist uses "shadow prices". In the resource-limited case, the supply is limited, Figure 1.1 shows the supply and demand curves for the short-range nuclear allocation problem. The market demand curve for nuclear energy is a summation of the energy demanded from all the individual time intervals. The intersection of the supply and demand curves determines an equilibrium trading price for nuclear energy that balances supply with demand. The equilibrium trading price is a mechanism that determines the allocation of the nuclear energy among all the time intervals. Each interval is allocated that amount which satisfies its own demand curve at the equilibrium price.

The determination of an interval's demand curve for nuclear energy is the key to solving the original short-range nuclear allocation problem. The shadow price an

interval will pay for nuclear power is set by the competition (\*), the cost of the next best substitutional source of energy. This is called the Opportunity Cost of Nuclear Power (OCNP). It is obvious that OCNP will depend on the system environment in which the time interval is, i.e., the customer demand, the system reserves, the economic loading order, the amount of nuclear energy available, etc.

---

(\*). This economic analysis assumes perfect competition and perfect communication of prices. The commodity of interest is electricity, where many sources of energy may compete with nuclear to supply this commodity.




Figure 1.1 SUPPLY AND DEMAND CURVES FOR NUCLEAR ENERGY

### 1.3 Implementation

The basic cyclic nature of the problem makes it convenient to choose one week as the basic time interval within which to derive OCNP (demand) curves. The physical interpretation of OCNP is the cost of the displaced energy when optimally distributed nuclear energy is marginally increased. A linear programming model of a utility system that solves for the minimum system production cost with a limited amount of nuclear energy (via peak-shaving techniques) will calculate an OCNP.

A weekly OCNP curve is obtained from explicitly calculating the OCNP for a number of values of nuclear energy. The optimization procedure requires a weekly OCNP curve for each week in the planning horizon to derive the gross demand curve for nuclear energy. The latter is compared with the supply of nuclear energy to establish a global OCNP for the planning period. Where the global OCNP intersects each weekly OCNP curve determines the quantity of nuclear energy allocated to each week.



#### 1.4 Computer Programs

PROCOST and ALLOCAT are the two principal programs developed to implement the optimization procedures. PROCOST takes a series of assumed nuclear energy allotments for a particular week and determines the minimal system cost in each allotment of nuclear power via peak shaving techniques and from this OCNP. ALLOCAT takes a set of weekly OCNP values over a larger period of time and determines how much nuclear energy to allocate to each week by using the criterion that the OCNP for all weeks shall be the same.

PROCOST, the system simulation program, is a deterministic L.P. model capable of simulating five types of power plants (nuclear, fossil, peaking, hydro, and pumped-storage units) and three types of load models (chronologic, load-duration, and modified chronologic). PROCOST is composed of three parts: (1) NUC\_OPT, the L.P. formulating program; (2) MPSX, the L.P. package (IBM program product); (3) PUMP\_ST, the pumped-storage simulator. In the NUC\_OPT section, the peaking and hydro units are explicitly simulated, and the fossil economic loading order is calculated. NUC\_OPT also formats the L.P. formulation of the fossil-nuclear optimization problem for MPSX to solve. MPSX in turn writes the solution on a scratch disk for PUMP\_ST to read. PUMP\_ST analytically calculates the optimal pumped-storage scheduling solution. The pumped-storage unit can either operate in an economic mode to minimize system cost or in a security mode to maximize

system reserve generation capability. The L.P. formulation of the nuclear scheduling problem is:

Objective function: minimize

$$\sum_j \sum_i (c_i) (F H_i) (F X_i^j) (T_j) \quad (1.1)$$

subject to the following constraints:

(customer demand constraint)

$$\left\{ \sum_i F X_i^j + \sum_n \sum_i I_n X_i^j = D^j \right\}_{j=1, \dots, J} \quad (1.2)$$

(limited thermal nuclear resource constraint)

$$\left\{ \sum_j \sum_i (n X_i^j) (n H_i) (T_j) = K_n \right\}_{n=1, \dots, N} \quad (1.3)$$

(bounds, separable programming constraint)

$$\left\{ \begin{array}{l} \text{if and only if } F_n X_{i-1}^j = F_n B_{i-1} \\ \text{then } 0 \leq F_n X_i^j \leq F_n B_i \\ \text{else } F_n X_i^j = 0 \end{array} \right\}_{\substack{n=1, \dots, N \\ j=1, \dots, J \\ i=2, \dots, I_n}} \quad (1.4)$$

where:

$F X_i^j$  = fossil power level of the i-th increment and the j-th time period (MW)

$n X_i^j$  = power level of the i-th increment and the j-th time interval of the n-th nuclear reactor (MW)

- $F, n X_i^j$  = either  $F X_i^j$  or  $n X_i^j$   
 $F H_i$  = incremental fossil heat rate of the i-th increment of the loading order (million BTU/MWht)  
 $n H_i$  = incremental nuclear heat rate of the i-th nuclear increment of the n-th nuclear reactor (million BTU/MWht)  
 $C_i$  = fossil fuel cost (\$/million BTU) of the i-th increment  
 $D^j$  = modified customer demand of the j-th time interval (MW)  
 $K_n$  = full-power reactivity-limited thermal energy available from the n-th reactor (million BTU)  
 $F, n B_i$  = upper bound of the i-th increment (MW)  
 $J$  = total number of time intervals  
 $N$  = total number of nuclear reactors  
 $I_n$  = total number of increments in a nuclear reactor  
 $T_j$  = duration of j-th time interval (hours)

The objective function, Eq. (1.1), to be minimized is a summation of the incremental production cost over all the increments in the economic fossil loading order (index i) and over all the time intervals in the one-week time horizon (index j). The incremental production cost is a product of the fuel cost (\$/million BTU), the incremental heat rate (million BTU/MWH) and the energy production (MWH) for each time interval. The constraints to be met are: (1) the summation of the power levels of the individual nuclear and fossil units in each time period must satisfy the modified customer demand, Eq. (1.2), while (2) limiting the total nuclear production to the available resources, Eq. (1.3).

In addition, each variable is bounded, Eq. (1.4). This is where the "separable programming" aspect is featured. All increments are fixed at the lower bound of zero until all the preceding increments have been set to their upper bound. For example, the third increment of the loading order can't be started until the second (and the first) increments are fully loaded. Without this feature, variable heat rates could not be modelled.

### 1.5 The Utility System

To test the optimization procedures discussed earlier, three system optimization problems were solved. The first was a single-reactor optimization problem, and the second was a multi-reactor optimization problem. The multi-reactor optimization was performed under conditions more severe than "typical" operating conditions. The third optimization problem was a modification of the first in which the monthly configurations were adjusted to yield constant system reserves over the planning horizon.

American Electric Power Service Corp. (AEP) provided the basic data from which the utility system configuration (16) was constructed. The system, composed of 52 units of five power plant types, was simulated for a short-range planning period of six months, April through September. The system included two nuclear plants (of 1100 MWe each), one hydro plant (with limited pondage and 200 MWe peak generating capacity), one pumped-storage unit (of 300 MWe generating capacity), seven peaking units and 41 fossil units for a total generating capacity of 19250 MWe.

The maintenance schedule (scheduled outage) of the individual fossil and peaking units proposed by AEP is displayed in Table 1.1. Most of the scheduled outage was placed in the spring and fall months. Since the model is deterministic, forced outage effects are simulated, treating them as scheduled outages also. Table 1.1 also displays the systematic treatment of forced outages. Peaking units are



TABLE 1.1 (CONT'D)

Month	Maintenance Schedule												Assumed Forced Outage Schedule											
	J	F	M	A	M	J	J	A	S	O	N	D	J	F	M	A	M	J	J	A	S	O	N	D
<u>Fossil (Cont'd)</u>																								
31	X																			X	X			
32				X																		X		
33	X	X	X	X	X	X	X	X	X															
34											X											X	X	
35									X													X	X	
36											X										X			
37			X																					
38			Y				Z								Z	Z		Y	Y				X	
39											X						X							
40				X									X	X										
41										X					Y	Y		Z	Z					

**Note:** An "X" represents a simulated outage for the entire month. The total time of scheduled outage for each plant corresponds to the actual observed outage rate for similar sized units. The specific forced outage schedule for each unit was chosen randomly. The maintenance schedule was chosen to lie mainly in the spring and fall months.

The "X" represents a simulated outage for Cases 1, 2, 3.

The "Y" represents a simulated outage for Cases 1 and 2.

The "Z" represents a simulated outage for Case 3.

scheduling to peak-shave until their input capacity factors are fulfilled. All the peakers had estimated capacity factors of 10% and start-up and shut-down cost of \$100/start-up, except for two gas-turbine units (of 51 and 4 MWe) which has zero start-up and shut-down costs.

The individual plant parameters were supplied by AEP in 1973. The rated capacity, fuel costs and average heat-rate at rated capacity for the 41 fossil units and seven peaking units are tabulated in Table 1.2. The fuel costs do not reflect the sharp rise in fuel costs during 1974. The hydro unit with limited pondage was scheduled to generate 200 MWe for nine peak demand hours during each workday and 50 MWe at all other times. The pumped-storage unit's operating parameters were: 300 MWe capacity generator, 160 MWe capacity pump, 70% cycle efficiency, 9300 MWH reservoir capacity and 2300 MWH/week free water inflow into the reservoir.

The system treated also contained two nuclear units of 1100 MWe each. Nuclear Unit 1 was scheduled for refueling on October 1. In the six months prior to refueling which make up the planning period, Unit 1 was assumed to have 70% of the thermal energy required to operate base loaded at full rated power. In the first simulation, Unit 2 was treated as a new unit just being introduced to service under a gradual programmed start-up: 20% of full rated power throughout April, 40% of full rated power throughout May, 60% during June, 80% during July, and 100% during August and



Table 1.2

PLANT PARAMETERS OF PEAKING AND FOSSIL UNITS

<u>Peakers</u>	<u>Capacity Mw</u>	<u>Fuel Cost \$/10<sup>6</sup> Btu</u>	<u>Heat Rate 10<sup>6</sup> Btu/MWh</u>
1	4	1.70	15.0
2	51	1.70	15.0
3	95	1.70	12.5
4	95	1.05	12.0
5	95	1.05	12.0
6	90	0.55	12.9
7	90	0.55	12.9
<u>Fossil</u>			
1	145	1.70	9.8
2	105	0.40	12.0
3	110	0.40	12.0
4	100	0.55	10.8
5	105	1.0	11.8
6	150	0.95	9.4
7	150	0.95	9.4
8	150	0.95	9.4
9	150	0.95	9.4
10	150	0.55	9.7
11	150	0.55	9.7
12	215	0.55	9.5
13	240	1.0	9.1
14	205	0.55	9.8
15	205	0.55	9.8
16	215	0.55	9.8
17	215	0.55	9.8
18	225	0.50	10.0
19	225	0.50	10.0
20	225	0.50	10.0
21	215	0.55	9.2
22	210	0.55	9.2
23	240	0.80	9.1
24	240	0.80	9.1
25	240	0.80	9.1
26	280	1.05	9.3
27	400	0.55	9.2
28	450	0.95	9.0
29	525	0.35	9.1
30	580	0.55	9.0
31	600	0.50	9.1
32	600	0.50	9.1
33	615	0.50	9.0
34	800	1.05	9.4
35	800	0.40	9.5
36	800	0.40	9.5
37	800	1.10	9.0
38	800	1.10	9.0
39	1,300	1.25	8.4
40	1,300	0.80	8.5
41	1,300	0.80	8.5

September.

The forecasted weekly energy consumption during the six-month (26 week) planning period is tabulated in Table 1.3. The six-month planning period spanned three seasons, spring (April and May), summer (June, July, and August) and fall (September). The weekly energy consumption was input to a seasonal load model, MODEL, to generate the detailed hourly customer demand numbers.

In the six-month period prior to refueling, a reactor with insufficient energy to run at full power until scheduled refueling can be considered a candidate for short-range resource-limited optimization. The second reactor, Nuclear Unit 2, coming on-line with a fully fueled core had an abundant supply of energy and an undetermined forced outage rate and would be undergoing a planned start-up program, so that the reactor's operation was determinate over the short range. Only reactors with limited resource and a fairly certain availability (\*) over the short-range time horizon are amenable to short-range system analysis using PROCOST. Availability, at best, can only be fairly certain over a short-range time horizon.

The first system optimization (Case 1) was then to find

-----

(\*) The deterministic approach (used in the PROCOST program) assumes the availability of the reactor is known with certainty. Hence, this assumption imposes certain restrictions on the use of this short-range optimization technique. This restriction can possibly be eliminated by the utilization of the Booth-Balerieux probabilistic technique, ref. (18), for modeling forced outages in PROCOST.

TABLE 1.3

WEEKLY ENERGY FORECAST FOR PLANNING PERIOD

<u>Month</u>	<u>Week</u>	<u>Weekly Energy (MWH)</u>	<u>Monthly Total (MWH)</u>	<u>Demand Peak (MWH)</u>	<u>Average Power (MWH/H)</u>
April	1	1,860,288	7,238,361	13,577	11,073
	2	1,894,814		13,795	11,279
	3	1,801,320		13,207	10,722
	4	1,681,939		12,472	10,011
May	5	1,792,155	8,771,712	13,149	10,668
	6	1,728,221		12,747	10,287
	7	1,758,492		12,937	10,467
	8	1,801,151		13,207	10,721
	9	1,691,693		12,517	10,070
June	10	1,839,877	7,299,798	13,951	10,952
	11	1,883,604		14,227	11,212
	12	1,814,876		13,793	10,803
	13	1,761,441		13,456	10,485
July	14	1,681,810	9,122,626	12,954	10,011
	15	1,870,344		14,143	11,133
	16	1,826,914		13,869	10,874
	17	1,883,382		14,226	11,211
	18	1,860,176		14,079	11,072
August	19	1,833,500	7,589,101	13,911	10,914
	20	1,950,649		14,650	11,611
	21	1,895,024		14,299	11,280
	22	1,909,928		19,393	11,369
September	23	1,955,031	7,653,173	13,919	11,637
	24	1,868,715		13,034	11,123
	25	1,872,805		13,074	11,148
	26	<u>1,956,622</u>		13,939	11,647
<b>Total</b>		<b>47,674,771</b>			

the optimal distribution of weekly nuclear capacity factors of Nuclear Unit 1, whose overall thermal energy availability is 70% of rated capacity for the six-month planning period prior to refueling. The second power reactor was operated at programmed steps in power levels.

Thus, although the system contained two reactors, the first system simulation (Case 1) was a single-reactor optimization. The second system simulation (Case 2) was a complex two-reactor optimization. Case 2 used exactly the same system configuration as in Case 1, except for additional constraints on Nuclear Unit 2, which was limited to 80% of the energy used in the corresponding periods of Case 1, see Table 1.4. The goal of Case 2 was to find the optimal weekly nuclear capacity factor distribution of both nuclear reactors. Case 2 was admittedly a contrived case to illustrate: (1) a multi reactor optimization, and (2) the feasibility of the procedures to handle a complex and involved situation. Case 2 is not an ordinary straight-forward two-reactor optimization. Nuclear Unit 2 had five smaller separate planning periods, requiring a separate optimization in each period. (Nuclear Unit 2 was analogous to a collection of five reactors, with each reactor operating for only one period and shut down for the other periods.)

Case 3 is a single reactor optimization similar to Case 1. The only difference (between Case 1 and 3) is that the monthly fossil configurations were adjusted in Case 3 to

TABLE 1.4

OPERATIONAL CONSTRAINTS ON NUCLEAR UNIT 2  
DURING THE TWO-REACTOR OPTIMIZATION, CASE 2


<u>Weeks</u>	<u>Time Period</u>		<u>Limitation</u>	
	<u>Months</u>		<u>Energy</u> <u>(% Rated)</u>	<u>Power</u> <u>(% Rated)</u>
1-4	April		16	20
5-9	May		32	40
10-13	June		48	60
14-18	July		64	80
19-26	Aug.-Sept.		80	100

levelize the minimum monthly system reserves over the six-month planning horizon (see Table 1.1). All other system parameters of Case 3 are identical to Case 1.

Before discussing the optimization results, some fundamental characteristics of OCNP will be reviewed. Examining Figure 1.2 these distinguishing characteristics of weekly OCNP functions are discernable: (1) The OCNP functions are monotonically decreasing functions with respect to an increasing nuclear capacity factor. (2) The weekly OCNP function of different weeks (but the same monthly configurations) never cross. (3) For weeks of increasing weekly energy consumption, the OCNP function likewise increases. (4) The larger the weekly energy consumption, the larger the slope of the OCNP function. (5) The weekly OCNP functions assume a shape characteristic of their respective economic loading order. (6) The amplitude of the OCNP function varies inversely with the weekly system reserve. (7) The amplitude of the OCNP function is proportional to the average fossil fuel cost of the monthly system configuration.

Figure 1.2

TYPICAL WEEKLY OCNF FUNCTIONS  
FROM THE SINGLE REACTOR  
OPTIMIZATION STUDY



Note: Circled numbers refer to the week numbers from the Case 1 simulation

### 1.6 Case 1

The results of Case 1, the optimized weekly nuclear capacity factor distribution, Table 1.5, reflects many of the OCNP principles stated above. The overall nuclear capacity factor for the six-month planning period was 70%. The high weekly nuclear capacity factor for September reflects the unusually high fossil fuel cost for that month. All the other months have about the same fossil fuel cost, as shown in Table 1.6. Hence September due to its significantly more expensive fossil fuel cost configuration is scheduled to generate at near full capacity to displace as much of the expensive fossil fuel as possible. August and July have the lowest average weekly nuclear capacity factor, in fact, the lowest allowed, because of their large reserve capacity, Table 1.7. April has the lowest system reserve, hence the second largest set of weekly nuclear capacity factors. Thus, May is the second tightest month system reserve-wise, and also has the second highest fossil fuel configuration. May also has an above average monthly nuclear capacity factor. Within each monthly schedule, the weekly allotments of nuclear energy are proportional to the weekly energy consumption forecast, see Table 1.3.

The overall impression from the results of this optimization study for the system simulated is that the maintenance scheduled was too unbalanced in excluding summer maintenance. Gross generating capacity is large enough to handle the summer peaks while still scheduling more



Table 1.5

OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE SINGLE REACTOR OPTIMIZATION (CASE 1)

<u>Month</u>	<u>Week</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average Energy (10<sup>3</sup> MWH)</u>
April	1	0.85	157.08	609.84	152.46
	2	0.95	175.56		
	3	0.85	157.08		
	4	0.65	120.12		
May	5	0.85	157.08	711.48	142.29
	6	0.75	138.60		
	7	0.75	138.60		
	8	0.85	157.08		
	9	0.65	120.12		
June	10	0.65	120.12	480.48	120.12
	11	0.75	138.60		
	12	0.65	120.12		
	13	0.55	101.64		
July	14	0.55	101.64	508.20	101.64
	15	0.55	101.64		
	16	0.55	101.64		
	17	0.55	101.64		
	18	0.55	101.64		
August	19	0.55	101.64	406.56	101.64
	20	0.55	101.64		
	21	0.55	101.64		
	22	0.55	101.64		
September	23	0.95	175.56	646.80	161.70
	24	0.85	157.08		
	25	0.85	157.08		
	26	0.85	157.08		
<b>Total</b>			<b>3,363.36</b>		<b>129.36</b>

TABLE 1.6

MONTHLY AVERAGE FOSSIL FUEL COSTS OF  
THE FOSSIL CONFIGURATION  
FOR CASES 1 AND 2

<u>Month</u>	<u>Fuel Costs</u> <u>Mills/KWH</u>
April	6.84
May	7.10
June	6.63
July	6.80
August	6.88
September	7.49

Table 1.7

WEEKLY SYSTEM RESERVE  
FOR CASES 1 AND 2

Month Week	April				May				
	1	2	3	4	5	6	7	8	9
Total gross generating capacity, MW	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750
Fossil maintenance outage, MW	2,505	2,505	2,505	2,505	2,690	2,690	2,690	3,690	2,690
Nuclear scheduled outage,* MW	880	880	880	880	660	660	660	660	660
Fossil forced outage, MW	2,420	2,420	2,420	2,420	2,570	2,570	2,570	2,570	2,570
Net generating capacity MW	13,945	13,945	13,945	13,945	13,830	13,830	13,830	13,830	13,830
Weekly peak load, MW	13,577	13,795	13,207	12,472	13,149	12,747	12,937	13,206	12,517
Net reserve, MW	368	150	738	1,473	681	1,083	893	624	1,313
Month Week	June				July				
	10	11	12	13	14	15	16	17	18
Total gross generating capacity, MW	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750
Fossil maintenance outage, MW	1,340	1,340	1,340	1,340	895	895	895	895	895
Nuclear scheduled outage,* MW	440	440	440	440	220	220	220	220	220
Fossil forced outage, MW	2,555	2,555	2,555	2,555	2,045	2,045	2,045	2,045	2,045
Net generating capacity, MW	15,415	15,415	15,415	15,415	16,600	16,600	16,600	16,600	16,600
Weekly peak load, MW	13,951	14,227	13,793	13,456	12,954	14,143	13,869	14,226	14,079
Net reserve, MW	1,464	1,188	1,632	1,959	3,646	2,457	2,731	2,374	2,521
Month Week	August				September				
	19	20	21	22	23	24	25	26	
Total gross generating capacity, MW	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	
Fossil maintenance outage, MW	750	750	750	750	2,225	2,225	2,225	2,225	
Nuclear maintenance outage, MW	0	0	0	0	0	0	0	0	
Fossil forced outage, MW	2,065	2,065	2,065	2,065	2,015	2,015	2,015	2,015	
Net generating capacity, MW	16,915	16,915	16,915	16,915	15,510	15,510	15,510	15,510	
Weekly peak load, MW	13,911	14,650	14,299	14,393	13,919	13,034	13,076	13,936	
Net reserve, MW	3,054	2,315	2,666	2,572	1,591	2,476	2,434	1,574	

\*Program startup limitation for Nuclear Unit 2.

147

maintenance during August and July, and less during April and May. Also, a better mix of fossil plants should be scheduled for September to give lower fossil fuel costs. Such considerations led to the calculation of Case 3, to be discussed below.

A total system cost calculation from the optimization results of Case 1 showed a very large dollar savings, see Table 1.8. Comparing the situation of no nuclear optimization, Case 1.A (uniform hourly nuclear power generation for the entire six months), with the situation of constant weekly nuclear capacity factor, Case 1.B (optimized hourly generation), the saving was \$4.1 million in fossil fuel costs. By further optimizing the weekly nuclear capacity factor distribution over the six month time horizon, Case 1.C, the saving increased by another \$340,000. The total fossil fuel savings is equivalent to 65% of the nuclear fuel cost of Nuclear Unit 1, at 2.0 mills/KWhe. The order of magnitude of the savings for Case 1 indicates that even for a single-reactor utility system, short-range optimization is worth-while in the resource-limited situations.

TABLE 1.8A

SYSTEM FOSSIL FUEL COSTS AND SAVINGS FOR CASE 1

<u>Month</u>	<u>Week</u>	<u>Case 1.A</u>	<u>Case 1.B</u>	<u>Case 1.C</u>
		<u>No Nuclear Optimization (\$)</u>	<u>Hourly Optimization (\$)</u>	<u>Hourly and Weekly Optimization (\$)</u>
April	1	10,897,641	10,703,601	10,524,562
	2	11,310,309	11,002,306	10,708,211
	3	10,401,792	10,220,996	10,056,930
	4	9,496,691	9,326,228	9,373,436
May	5	10,585,981	10,406,225	10,227,973
	6	10,078,719	9,886,612	9,830,631
	7	10,316,433	10,126,110	10,063,502
	8	10,660,648	10,482,397	10,300,385
	9	9,762,971	9,611,780	9,660,533
June	10	9,899,898	9,755,839	9,802,719
	11	10,210,651	10,063,304	10,013,456
	12	9,725,349	9,586,475	9,632,938
	13	9,369,029	9,242,724	9,387,855
July	14	8,847,012	8,746,190	8,873,310
	15	9,950,572	9,816,608	9,959,853
	16	9,670,594	9,555,670	9,692,954
	17	10,037,142	9,858,900	10,004,974
	18	9,883,377	9,753,496	9,894,948
August	19	9,623,066	9,517,456	9,652,246
	20	10,378,333	10,230,513	10,380,137
	21	10,002,896	9,877,511	10,016,482
	22	10,101,697	9,968,648	10,109,134
September	23	11,538,985	11,379,984	11,101,378
	24	10,879,069	10,716,938	10,559,049
	25	10,908,873	10,745,769	10,586,767
	26	<u>11,551,409</u>	<u>11,390,192</u>	<u>11,216,616</u>
<b>Total</b>		266,089,137	261,988,509	261,648,975
<b>Comparison with Case 1.A</b>		-	(4,100,628)	(4,440,162)

Case 1.A: Unit 1 is run at constant power (725 Mw), and Unit 2 is run at programmed power levels (Table 1.8B) for all three cases.

Case 1.B: The weekly energy output of Unit 1 is the same as in Case 1.A, but the hourly power level within each week is optimized.

Case 1.C: Unit 1's power levels for each hour of each week are optimized for the entire six-month planning period.

Total energy output of Unit 1 is the same in all three cases.

TABLE 1.8B

PROGRAMMED CONSTANT POWER LEVELS OF  
NUCLEAR UNIT 2 FOR CASES 1 AND 3

<u>Month</u>	<u>Power Level (MWe)</u>
April	220
May	440
June	660
July	880
August	1100
September	1100

### 1.7 Case 2

Case 2 is a two-reactor optimization, which must be solved iteratively. A summary of the optimal capacity factor distribution and system costs with each iteration for Case 2 are given in Table 1.9 and 1.10, respectively. The complete two-reactor optimization, Case 2.C, results in a total savings of \$6.48 million compared with the situation of no nuclear optimization, Case 2.A. Of this, \$600,000 represents the improvement from the situation of optimal hourly generation, Case 2.B, compared with the total optimization results, Case 2.C. Table 1.10 indicates that most of the savings are realized after only one complete cycle of iterations in this two-reactor system. Other simulations have confirmed the hypothesis that the multi-reactor iteration process is a rapidly convergent one.

The major conclusions of this multi-reactor all simulation are that: (1) the short-range resource-limited optimization process described in this thesis has been shown adaptable to a two-reactor situation; (2) convergence takes only a few complete cycles of iterations; (3) most of the cost savings are realized after one or two complete cycles of iterations; (4) substantial savings in fossil fuel cost are possible with short-range optimization; (5) potential cost savings increase as the amount of nuclear capacity and energy that are optimized is increased.

TABLE 1.9

OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE TWO REACTOR OPTIMIZATION (CASE 2)

<u>Month</u>	<u>Week</u>	<u>Unit 1</u>				<u>Unit 2</u>			
		<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average (10<sup>3</sup> MWH)</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average (10<sup>3</sup> MWH)</u>
April	1	0.85	157.08	591.36	147.84	0.20	36.96	118.272	29.568
	2	0.95	175.56			0.16	29.568		
	3	0.75	138.60			0.16	29.568		
	4	0.65	120.12			0.12	22.176		
May	5	0.85	157.08	711.48	142.296	0.32	59.136	295.680	59.136
	6	0.75	138.60			0.32	59.136		
	7	0.75	138.60			0.32	59.136		
	8	0.85	157.08			0.32	59.136		
	9	0.65	120.12			0.32	59.136		
June	10	0.65	120.12	443.52	110.88	0.48	88.704	354.816	88.704
	11	0.65	120.12			0.54	99.792		
	12	0.55	101.64			0.48	88.704		
	13	0.55	101.64			0.42	77.616		
July	14	0.55	101.64	508.20	101.64	0.48	88.704	591.360	118.272
	15	0.55	101.64			0.72	133.056		
	16	0.55	101.64			0.64	118.272		
	17	0.55	101.64			0.72	133.056		
	18	0.55	101.64			0.64	118.272		



TABLE 1.9 (CONT'D)

<u>Month</u>	<u>Week</u>	<u>Unit 1</u>				<u>Unit 2</u>			
		<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average (10<sup>3</sup> MWH)</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average (10<sup>3</sup> MWH)</u>
August	19	0.55	101.64	406.56	101.64	0.70	129.36	554.40	138.60
	20	0.55	101.64			0.80	147.84		
	21	0.55	101.64			0.80	147.84		
	22	0.55	101.64			0.70	129.36		
September	23	0.95	175.56	702.24	175.56	0.90	166.32	628.32	157.08
	24	0.95	175.56			0.80	147.84		
	25	0.95	175.56			0.80	147.84		
	26	0.95	<u>175.56</u>			0.90	<u>166.32</u>		
<b>Total</b>			<b>3,363.36</b>		<b>129.36</b>		<b>2,542.848</b>		<b>97.80</b>

Table 1.10

SUMMARY OF TWO-REACTOR OPTIMIZATION COST SAVINGS  
AS A FUNCTION OF NUMBER OF ITERATIONS

Case Iterations on Weekly Energy Allocations	<u>2.A</u>	<u>2.B</u>	<u>2.C</u>			
			<u>I</u>	<u>II</u>	<u>III</u>	<u>IV</u>
Total Cost, \$	271,307,945	265,428,422				264,827,357
Savings Relative to Case 2.B, \$	-5,879,523	0	555,334	593,897	601,065	601,065

### 1.8 Case 3

The purpose of Case 3 was to examine the effect of system reserves on OCNP and on the optimal weekly nuclear capacity factor distribution. Case 3 is a modification of Case 1 where the fossil outage schedule has been adjusted to obtain a (nearly) constant minimum monthly system reserve. A comparison of the minimum monthly system reserves for Cases 1 and 3 is listed in Table 1.11. The average fossil generation costs of the monthly fossil configurations are listed in Table 1.12. The optimal weekly nuclear capacity factor distribution is listed in Table 1.13.

A comparison of the optimal nuclear capacity factor distribution for Case 1 and Case 3 shows a decrease of allocated energy for April and May, and an increase for July, August, and September. The June allotment is the same for both cases. The change in monthly allocation of nuclear energy is consistent with the change in the monthly minimum system reserve, both in direction and magnitude. April and May had large increases in reserves, thus, resulting in significant decreases in nuclear energy allotments. July and August had large decreases in system reserve, thus, resulting in significant increases in nuclear energy allotments. June had the smallest monthly change in system reserves (210 MW), not enough to change its nuclear energy allocation. September had a slight decrease in system reserves (225 MW), resulting in a slight increase the nuclear energy allotment. The comparison of the solution of

TABLE 1.11

Month:	Minimum Monthly System Reserves (Mw)					
	<u>April</u>	<u>May</u>	<u>June</u>	<u>July</u>	<u>August</u>	<u>September</u>
Case 1	150	893	1,188	2,374	2,315	1,574
Case 3	1,450	1,349	1,398	1,437	1,325	1,349

TABLE 1.12

MONTHLY AVERAGE FOSSIL GENERATION COSTS OF  
THE FOSSIL CONFIGURATION FOR CASE 3

<u>Month</u>	<u>Generation Costs</u> <u>(Mills/KWH)</u>
April	6.84
May	6.85
June	6.39
July	6.90
August	7.04
September	7.54

Table 1.13

OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE SINGLE REACTOR OPTIMIZATION (CASE 3)

<u>Month</u>	<u>Week</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average Energy (10<sup>3</sup> MWH)</u>
April	1	0.85	157.08	554.40	138.60
	2	0.85	157.08		
	3	0.75	138.60		
	4	0.55	101.64		
May	5	0.85	157.08	674.52	134.90
	6	0.75	138.60		
	7	0.75	138.60		
	8	0.75	138.60		
	9	0.55	101.64		
June	10	0.65	120.12	480.48	120.12
	11	0.75	138.60		
	12	0.65	120.12		
	13	0.55	101.64		
July	14	0.55	101.64	545.16	109.03
	15	0.65	120.12		
	16	0.55	101.64		
	17	0.65	120.12		
	18	0.55	101.64		
August	19	0.55	101.64	443.51	110.88
	20	0.65	120.12		
	21	0.55	101.64		
	22	0.65	120.12		
September	23	0.95	175.56	665.28	166.32
	24	0.85	157.08		
	25	0.85	157.08		
	26	0.95	175.56		
<b>Total</b>			<b>3,363.36</b>		<b>129.36</b>

Case 1 with Case 3 shows conclusively the significant effect an unequal system reserve has on the optimal distribution of nuclear energy.

In terms of total system costs, Case 3 showed an improvement of about \$2.2 million compared with Case 1, see Table 1.14. The comparison of case 3.A with Case 3.C, no nuclear optimization to weekly nuclear optimization, showed a savings of \$4.7 million, equivalent to 70% of Unit 1 fuel cost at \$2.0 mills/KWhe. This is about the same as Case 1.

Comparing Cases B to Cases C, hourly optimization to weekly optimization, the savings are \$160,000 for Case 3 and \$340,000 for Case 1. It is to be expected that as the system reserves becomes equalized, the optimal distribution of capacity factors becomes narrower and hence the difference in savings between hourly optimization and weekly optimization diminishes. Also, the lower capacity factors of the summer months are partially due to a seasonal influence on the shape of their customer demand function. Both spring and summer have about the same average weekly energy consumption. However summer has much higher demand peaks than the spring, hence summer also has lower demand minimums than spring. Since the lower part of the load-duration curve plays an active role in determining OCNP, it is no surprise that summer months should have lower average nuclear capacity factors (with all other parameters equal).

Because of changing economic conditions, fossil fuel

TABLE 1.14  
SYSTEM FOSSIL FUEL COSTS AND SAVINGS FOR CASE 3

	<u>Case 3.A*</u>	<u>Case 3.B*</u>	<u>Case 3.C*</u>
System Costs (\$)	263,857,559	259,348,663	259,187,244
Comparison with Case 3.A	-	(4,508,896)	(4,670,315)

Case 3.A: Unit 1 is run at constant power (725 Mw), and Unit 2 is run at programmed power levels (Table 1.8B) for all three cases.

Case 3.B: The weekly energy output of Unit 1 is the same as in Case 3.A, but the hourly power level within each week is optimized.

Case 3.C: Unit 1's power levels for each hour of each week are optimized for the entire six-month planning period.

Total energy output of Unit 1 is the same in all three cases.



costs show a great amount of variance from station to station. Hence, the monthly economic loading order will show different patterns for different maintenance schedules. The main conclusion from the system simulations performed is that equal consideration must be given to fossil fuel arrangements as well as system reserves when determining the monthly maintenance schedule.

The sample optimization problems showed that peak-shaving the nuclear energy first resulted in savings on the order of millions of dollars (per reactor per optimization cycle) and optimally distributing the weekly energy next resulted in saving on the order of hundreds of thousands of dollars (per reactor per optimization cycle). These two optimization steps were reversed to find if the order of optimization had any significant effect on their savings. The result showed that the (order of magnitude of) savings from each optimization steps is independent of their order of application.

A sample of the type of optimal load-following pattern recommended by PROCOST is shown in Figure 1.3. As shown, the reactor is essentially operated in an on-off mode. The reactor is turned off (to its minimum operating levels) during low demand intervals and turned on to full capacity during high demand intervals.




Figure 1.3 SAMPLE OPTIMAL WEEKLY  
NUCLEAR DISPATCHING SCHEDULE

### 1.9 Conclusions

(1) The system simulation performed showed the short-range optimization procedure developed to be flexible and reliable in handling a wide range of system conditions including an adaptability to multi-reactor problems as well as to single reactor optimization problems.

(2) The system simulations showed that very large savings in fossil fuel costs, on the order of millions of dollars per reactor per optimization cycle, are possible from short-range nuclear system analysis. Thus adoption of these short-range system optimization technique by the utility industry would be a worth-while undertaking.

(3) Procedural guidelines for optimal dispatching of nuclear generation (under resource-limited conditions) are to (a) peak-shave the dispatching of nuclear energy by operating at full rated power during peak demand time intervals and shutting down (or operating at minimum power) during low demand intervals, (b) follow a weekly budget of nuclear energy rationing until the next scheduled refueling date. The system simulations show that independent of the order of optimization most of short-range optimization savings (millions of dollars per reactor per optimization cycle) comes from peak-shaving the nuclear energy within each week. Hence, peak-shaving should receive the primary attention. The savings from the weekly redistribution of energy were lower, on the order of hundreds of thousands of dollars per reactor per optimization cycle.

(4) The system parameters having greatest effect on total system operating costs are (a) system reserves, (b) seasonal customer demand shape, and (c) the economic loading order (in turn comprised of the system configuration and its basic parameters such as heat rates, and fuel costs). These are the system parameters that must be considered by the system planner in devising the allocation budget of nuclear energy over the short-range planning horizon.

(5) Using the optimization techniques discussed in this thesis, an unambiguous and logical method has been developed to calculate the short-range substitutional cost of nuclear power, the OCNP. OCNP is the trade price that should be used when transferring nuclear power by utilities.

## 2.0 INTRODUCTION TO SHORT-RANGE SYSTEM ANALYSIS

### 2.1 Introduction

In electric utility system planning, there are three principal time periods, the long-range (10-30 years), the mid-range (1-10 years), and the short-range (less than 1 year). The major task in long-range system analysis is the planning required to meet system expansion. The major considerations are the power plant type, its size, its location, and its date of introduction to the system. The over-all economics of nuclear power has been so favorable that over half of all new capacity planned in the U.S. is nuclear (1).

The unconventional batch nature of the nuclear power process and the long lead times in its fuel cycle requires careful planning; this aspect of system analysis is handled in mid-range planning. The major variables are the reactor's refuel batch size and enrichment. The eight-year lead time necessary for contracting enrichment services and one-year lead time in fabrication requires close coordination of the expected nuclear energy production with the rest of the system components.

In the short-range time frame, in which the nuclear reactor has been charged with its fuel, the system problem becomes that of scheduling generation of the electrical potential available from the fuel. The operating environment is known much more precisely in the short-range than in the other time frames. Moreover, all the nuclear

parameters are frozen in the short-range due to its batch nature. Thus the system analysis problem is that of optimizing scheduling of the generation of the nuclear plant's limited energy potential over the short-range time horizon in a fairly known environment.

Previous studies in the long-range and mid-range system analysis have been more extensive than in the short-range analysis. The TVA Brown's Ferry study (2) comparing the economics of nuclear power plants to a fossil power plant showed conclusively the advantage of nuclear power. The mid-range system analysis problem studied at MIT (3) and Oak Ridge (4) have led to automated procedures for calculating a power reactor's batch size and enrichment over the mid-range time horizon.

In the short-range operations time frame, the published studies have been mainly limited to case studies illustrating advantages of coast-down under certain circumstances (5). This thesis study investigates the optimization in the short-range of the nuclear reactor generation schedule such to minimize system cost. The resource-limited case is studied in particular since this is where the principal planning problem lies. In the non-limited resource case, the answer is trivial, schedule the reactor at its full capacity and/or revise the refueling date. In the resource-limited case, the scheduling of when and at what capacity the nuclear plant should be operated is not so obvious.

## 2.2 Motivation for Resource-Limited Case

The resource-limited case, the one studied in this thesis, is the situation where the nuclear reactor doesn't have enough reactivity to run at full power continuously until its scheduled refueling date and for any of a number of reasons, early refueling is not possible. The amount of thermal nuclear energy to be extracted from the reactor is assumed fixed, limited to full-power reactivity limited burnup. The date of refueling is fixed, and the customer demand function can be forecast. Hence, the resource limited case is a straight-forward optimization problem. Much of the theoretical foundation for the resource-limited case was presented in Hans Widmer's thesis(6). Widmer noted that in short-range system analysis, "the value to the system of the given nuclear energy potential should be used (the system opportunity cost)" in finding the optimal distribution of nuclear energy.

The optimization technique used is a version of Dantzig and Wolfe's Decomposition Principle(7). Once the resource-limited case is solved, it can be extended to include the more complex features of short-range system analysis situations. The operational benefits of moving the refueling date can be quantitatively weighted against the inventory charges and other penalties. The importance of refueling during low seasonal demands can be more accurately calculated; and the significance of stretch-out and the timing of its use can also be studied in more detail. Thus,

the study of the resource-limited case in this thesis will develop the tools and procedures and provide a reference case to make possible the study of the more complex short-range situations.



### 2.3 Goals of Thesis

The objectives of this thesis are to:

- (1) Develop a calculational model for the resource-limited case to optimize the short-range production schedule of the nuclear power plants.

Corollary: Develop a calculation model from which more complex short-range problems can be considered.

- (2) Define the parameters that have significant influence on system cost and the Opportunity Cost of Nuclear Power, locating areas of greatest sensitivity.

- (3) Develop generalized rules of thumb for the utility dispatcher on the optimal use of nuclear power reactors.

Corollary: Develop a model that will present the dispatcher with a budget of nuclear energy to be expended over the short-range time horizon.

#### 2.4 Perspective on Short-Range Nuclear Power System Analysis

In the early days of nuclear power, the economic justification for nuclear power plants was the main topic of study among system planners (whether to buy nuclear or to buy fossil?). Some consider the publication of TVA's Brown's Ferry Study (2) the turning point in the utility industry's acceptance of nuclear power. Long-range system analysis deals with the question of how best to meet the future growth in customer demand. The parameters are the types of plants, size of plants, and location of plants. All these parameters are closely related to the forecasted composition of the utility's future customer demand. If the demand is industrial rather than residential, then base load plants will be preferred over cycling plants. Further, to keep transmission losses to a minimum, future plants should be located as close to future load centers as possible. Hence the utility must anticipate movement of load centers, and/or creation of new ones. The sizes of new plants must be in proportion to service demanded, otherwise either capital is wasted or service requested can not be met. The economics of power production is a consideration in choosing the type of power plant (but by no means the only one). The TVA study showed that nuclear was the economically preferred choice for the Brown's Ferry site. TVA's (a system located near the Appalachian coal mines) move toward nuclear was convincing to the rest of the utility industry in overcoming the industry reluctance to try a new technology. The time

scale in long-range system planning is from 10-30 years.

Once the decision to build a nuclear plant is made, the long lead times in the nuclear fuel cycle require mid-range planning to provide for the fuel services when needed. The mining industry practice is to open new mines only when demand is assured for the life of the mine (in the form of a long term contract). In most instances, money is advanced by the customer to the mining company to provide initial capital to start up the mine. The AEC presently requires a ten year notice on enrichment services. Fabrication of fuel takes about a year's time. The financial consequences of long lead times is considerable. The core of a 1000 MWe power reactor is valued at \$30,000,000. Thus, the inventory carrying charges would be in the millions of dollars. This places a premium on careful planning and scheduling of fuel services (and in turn, cash flow). The optimization of the nuclear fuel cycle in this time scale is called the mid-range system analysis problem. It deals with optimizing the power production from nuclear power reactors so as to minimize system cost over the mid-range time horizon. Studies in this field at MIT and Oak Ridge (4) have developed procedures for calculating a power reactor's enrichment and batch size over a 3 to 5 year time horizon. At MIT, Paul Deaton (3) developed a System Integration Model (SIM) and a System Optimization Model (SOM). The SIM generates an optimal production schedule for a particular utility system configuration (using the Booth Baleriaux

probabilistic simulation technique). The SOM searches for the optimal schedule of nuclear reactor's enrichment and batch size to meet the nuclear production schedule set by SIM.

The SOM relies on a reactor core physics model to provide the intermediate nuclear incremental cost values to perform its optimization analysis. At MIT, core simulation and optimization models (CORSOM) which simulate core physics calculations to find a minimum cost assignment of refuel enrichments and batch size for a given reactor production schedule were developed by J. Kearney (8) and H.Y. Watt (9).

Once the nuclear reactor has been charged with fuel, the system problem becomes one of scheduling the generation of the electricity potentially available from the fuel. This is the basic short-range (less than one year) nuclear power system analysis problem, which is the field of this thesis.

Short-range power system analysis is concerned with the operational aspect of producing and delivering the demanded power for the least cost (under certain rigid constraints). Given the existing network of power plants, the dispatcher must figure out which of his units to make available for the immediate future and the economical distributional dispatch of power generation from each unit.

The demand for electricity fluctuates greatly with geographical location, season and the time of day. For example, the minimum weekly demand at nights and weekends on a system may be only 35% of the corresponding weekly

maximum, while the annual minimum demand may represent only 20% of the demand peak. Thus, for the system as a whole, the annual load factor may be only 50%.

To meet this type of demand requirement, the utilities have at their disposal a wide assortment of different types of power plants with different operating characteristics. The basic operating strategy of nuclear power plants coming on line today is that of base loading them because of their low fuel cost. But as nuclear plants continue to make up an increasing share of the power system capacity, there will be times when demand will be less than a system's nuclear power capacity. Therefore, the optimization of day-to-day operations of nuclear power plants and their interaction with the rest of the power pool is a problem worth investigating.

Economic dispatch is concerned with meeting the hour-by-hour load requirements from the units on the line, at least cost. The guiding optimality rule is the "equal incremental production cost criterion". The main operating cost variables are fuel costs, the transmission line losses and the operating efficiencies of generators. To a first-order approximation, the incremental operating cost is that of the fuel. Since fossil-fuel power plants are continuous processors, the cost of an extra unit of power is equal to cost of an extra unit of fuel. For a nuclear power plant, the calculations of incremental cost of power is not so simple. Nuclear fueling is a batch process whose cost is

fixed in the short-range time frame.

There are a number of short-range nuclear options at the disposal of the utility to handle short-range deviations just before the scheduled refueling of a nuclear power reactor, for a variety of situations:

- (1) Coast-Down: The nuclear reactor has a negative power reactivity coefficient, thus by reducing the power level of the reactor, it can be kept critical.
- (2) Lower Feed Water Temperature: The nuclear reactor has a negative temperature reactivity coefficient, thus by reducing the water temperature, the reactor can be kept critical, though at lower thermal efficiency.
- (3) Alter Refuel Batch Size: If availability was below that expected, one can compensate by refueling a smaller batch. However, if availability was higher than expected and one of above methods was used to extend the burnup of the fuel, increasing the refuel batch size at the last minute is not a simple task, because of the long lead times involved in fuel preparation. But if the utility has a number of reactors using the same fuel design and enrichment or belongs to a nuclear fuel swapping pool, larger refuel batch size may be feasible.
- (4) Alter Enrichment: Because of the long lead times in enrichment and fabrication of fuel, this alternative is not usually possible except in cases where the utility could borrow the fuel from another reactor of its

utility system, with the same fuel design, or from a swapping pool.

(5) Move Refueling Date: With advance notice, refueling may be rescheduled for the revised date when the desired burnup is expected to be reached.

(6) Optimize Production Schedule: To refuel on schedule, optimize the fixed amount of energy available in the fuel until the scheduled refueling date.

Not all of the above options may be feasible, depending upon circumstances. Each option will involve an economic penalty of different size. Lower feed water temperatures will lower the thermodynamic efficiency of the plant. Extending burnup during the present cycle will shorten the next cycle's life time and increase its fuel cost. Refueling before desired burnup is achieved will increase fuel cost of the present cycle. Reducing batch size incurs carrying inventory charges on the unused batch. Swapping arrangements are presently unknown but can be expected to entail some service surcharge. Rationing involves the substitution of additional fossil energy to meet customer demand. Obviously, the short-range situation is a very complex and involved problem. Besides the nuclear economic considerations, system reliability considerations(\*) are

-----

(\*) The major system reliability constraints are:

- 1 system reserve
- 2 system security
- 3 voltage stability
- 4 current stability

also involved to pose additional constraints. The refueling date may be difficult to change because (1) system reserve would be dangerously low at some other time, or (2) refueling personnel may not be available, having been scheduled elsewhere.

And finally, most short-range options would affect later fuel cycles, which may make necessary a redevelopment of the mid-range plan. Generally, mid-range plans are best adhered to, despite short-range deviations as long as their underlying assumptions are still true. This would imply, that in the case of a nuclear reactor being resource limited, rationing might be the most appropriate option to use. Rationing would have the least disturbing effect on later fuel cycles, and the utility would be able to stay on schedule. As the first step at MIT toward the study of the complex short-range problem, this thesis study concentrated on optimizing the production schedule for a fixed amount of nuclear energy, option (6), to be called the Resource-Limited Case.



### 3.0 Resource-Limited Case

#### 3.1 Introduction

The average production cost of nuclear generated electricity has been found to be significantly lower than that of electricity generated from fossil fuels (10,11), such that electric utilities would desire to operate the nuclear units at capacity at all times. This is not feasible when the amount of available energy from the reactor is insufficient to operate the reactor at full capacity continuously until scheduled refueling. A shortage of energy is possible considering the large number of factors that are related to the original decision on the energy content in the reactor (i.e., long lead times involved in the nuclear fuel cycle, poor forecasting judgement, or forced outages). Examples of changes in the original planning assumptions which could lead to an energy-short situation are:

- (1) The fuel is required to be removed from the reactor after burnup reaches 20,000 MWD/T instead of the originally planned 30,000 MWD/T.
- (2) The plant availability has matured faster than anticipated.

In such cases, available energy of the reactor must be rationed until the next scheduled refueling (if the refueling can not be advanced).

This batch-energy-limited generation characteristic of nuclear units requires modification of the techniques of

dispatching and unit commitment conventionally used ("Equal Incremental Cost Rule") by the electric utility industry to handle the above case. The conventional concept of incremental cost of energy is not applicable to nuclear power plants on the time scale used by the electric utility dispatcher (i.e. one hour), because all the major costs associated the nuclear fuel cycle costs are contracted for in advance and fixed before the time of power generation. In the short-range time frame, nuclear energy has no unambiguously definable incremental cost. In fact, nuclear fuel is capitalized and depreciated in service whereas fossil fuel is expensed. The purpose of this research is to develop methods of specifying the optimum dispatching of nuclear generating units in the short-range when each nuclear unit has a fixed refueling date and a fixed amount of thermal energy potential for production by that date.

### 3.1.1 Method of Solution

The formulation of this problem as a single Linear Programming (L.P.) problem would involve too many variables to solve in a reasonable amount of time. The deterministic problem of solving the detailed hourly generation schedule for minimum system cost of a utility system composed of 50 units, each of four valve points, and over a one-year time horizon is of an order of magnitude of 1.6 million variables. Hence, to solve the short-range system analysis problem efficiently, the method of solution must take advantage of the special structure of the problem.

The resource-limited case is viewed by the economist as a "Resource Allocation Problem", deciding how to allocate a resource (nuclear energy) among many consumers (individual time intervals). The "economic optimal" solution is found by using the "free enterprise" method, letting the open market place decide which consumer receive a portion of the resource and the amount each receives. The free market determines allocation by the forces of supply and demand. Figure 3.1 shows a typical set of supply and demand curves. The supply curve is monotonically decreasing, as the price increases, the quantity demanded decreases. The intersection of these two curves determines an equilibrium trading price, that balances the supply with the demand for the resource. The equilibrium trading price is a mechanism that determines the allocation of the resource among many potential consumers. Each consumer is allocated just the amount that it is willing to pay for.

In the short-range nuclear allocation problem, where the "actual" market price of nuclear power is ambiguous, the economist uses "shadow prices" (26) in the analysis. In the resource-limited case, the supply is "inelastic"; the quantity of resource is fixed. Figure 3.2 shows the supply and demand curves for the short-range nuclear allocation problem. The gross resource demand curve is the summation of the resource demanded from all the possible individual consumers. The gross nuclear energy demand curve is the summation of the nuclear energy demanded from all the time




Figure 3.1 TYPICAL SUPPLY AND DEMAND CURVES




Figure 3.2 SUPPLY AND DEMAND CURVES FOR NUCLEAR ENERGY

intervals in the short-range time horizon, see Figure 3.3. Matching the gross supply curve with the gross demand curve determines an equilibrium price. Where this price intersects the individual demand curve of each time interval determines how much nuclear energy each time interval will receive, as illustrated in Figure 3.4.

A time interval's individual demand curve for nuclear energy is proportional to the "benefit" (to the system) derived from various quantities of nuclear energy. The "benefit" of nuclear energy (to the system) can be measured in terms of savings in operating costs of the other alternative source of energy. This "benefit" is termed the Opportunity Cost of Nuclear Energy (OCNP). The individual demand curve in question is a measure of OCNP for an individual time interval as a function of nuclear energy.

An individual demand curve can be calculated as follows: (1) In a single time interval, calculate the optimal system generation cost for a number of values of nuclear energy, as in Figure 3.5; (2) find an analytic fit of optimal system as a function of nuclear energy; (3) the negative derivative of that function is the OCNP curve in question, see Figure 3.6. OCNP is the incremental savings in system operating cost for an incremental change in nuclear energy.

In summary, the method of solution is as follows: (1) calculate a OCNP curve for each individual time interval in the planning horizon; (2) determine the equilibrium OCNP for




Figure 3.3 FORMATION OF MARKET DEMAND CURVE FOR NUCLEAR ENERGY




Figure 3.4 ALLOCATION OF ENERGY BY EQUILIBRIUM PRICE METHOD




Figure 3.5 DETERMINATION OF SYSTEM COST FUNCTION




Figure 3.6 DETERMINATION OF OCNP



the planning horizon by matching the gross demand curve for nuclear energy with the supply; (3) the individual allotments of nuclear energy are those quantities read off the individual OCNP curves at the equilibrium OCNP price.

### 3.1.2 Implementation

The solution of the one-year time horizon problem has been shown to be a combination of the solutions of many weekly problems. Though the exact combination is not known beforehand, it is distinguished by the fact that each week in the time horizon has the same OCNP. It can be easily shown that this is a stable optimal condition.

The weekly OCNP is calculated from the viewpoint that OCNP is the cost of the displaced energy when optimally distributed nuclear energy is marginally increased. In economics, the price of the next best substitutional commodity is also called the opportunity price.

Figure 3.7 shows a simple graphical illustration of determining OCNP. Suppose a hypothetical system of two components, one nuclear unit and one fossil, and a two-hour customer demand function, 1900 MW for the first hour and 900 MW for the second hour, as shown in Figure 3.7a. The fossil unit has 1300 MWe generating capacity and the nuclear unit has 600 MWe generating capacity but only 900 MWhe of energy. The fossil unit has a typically monotonically increasing incremental generation cost curve, a portion of which is shown in Figure 3.7b. What is the OCNP for this set of system parameters? The OCNP is that cost of the alternative




Figure 3.7A  
CUSTOMER DEMAND  
FUNCTION




Figure 3.7B  
A PORTION OF THE FOSSIL INCREMENTAL  
COST CURVE




Figure 3.7C  
OPTIMAL DISTRIBUTION  
OF NUCLEAR ENERGY

Figure 3.7 EXAMPLE OF DETERMINATION OF OCNP

energy displaced by a marginal increase in the optimally assigned nuclear energy. If the nuclear unit had 1 MWh more energy, what would be the cost of the 1 MWh of displaced fossil energy? The optimal distribution of nuclear energy is displayed in Figure 3.7c; 600 MWh in the first hour and 300 MWh in the second (\*). Since the nuclear unit is already operating at its full capacity (600 MW) in the first hour, the marginal unit of nuclear energy would be assigned to the second hour. Hence, the fossil generation scheduled for the second hour would decrease marginally from 600 MWh to 599 MWh. What is the generation cost of that one unit of fossil energy? The fossil incremental heat rate curve, Figure 3.1b indicates 4.6 mills/KWh. Hence, the OCNP of the system is 4.6 mills/KWh. The important condition prior to measuring the displaced energy cost is first to optimally assign all the nuclear energy.

The OCNP is that cost of alternative energy above which the nuclear reactor would seek to displace all other energy sources (limited by its own generating capacity) in expending all its fixed amount of energy. In this way, the nuclear energy has been distributed to minimize system generation cost, by replacing the most expensive energy alternatives. The OCNP calculated is associated with the

-----

(\*) In this simple example, the optimal distribution of nuclear energy is the condition where the fossil unit's production in the two time intervals is as equal to each other as possible, within the capacity limitations of the units.

particular amount of weekly nuclear energy distributed, the customer demand function and the system configuration used. But weekly OCNP functions are required to describe system cost sensitivity over a range of nuclear energy values. The weekly OCNP function is found by calculating explicitly OCNP values for a number of values of nuclear energy.

The condition for optimal inter-weekly dispatching of nuclear energy is that the weekly OCNP functions for all weeks be equal, subject to the constraint that the total amount of nuclear energy used equal the amount available(\*).

The OCNP optimization results in the assignment of a specific portion of total nuclear energy to be used each week so to minimize system cost over the short-range time horizon. The dispatcher would be free to utilize that and only that amount of nuclear energy budgeted to meet the weekly system demand. The dispatcher should be cautioned that any sales of nuclear energy across the connected interchange be sold at the optimized OCNP price for the planning period because the OCNP represents the short-range system substitutional cost for the nuclear energy.

The implementation of the above optimization scheme defines the time interval used for comparison of system costs and defining customer demand as one week. The

-----

(\*) This optimization problem is analogous to the classical dispatching problem of minimizing system cost of a system of all fossil units. That solution is when all units operate at equal incremental production cost, while constrained to satisfy the total system demand.

production cost program, PROCOST, solves for the minimal system cost (\$/wk) for specific values of:

- (1) the system configuration and its operating parameters, such as fuel costs and heat rates;
- (2) customer demand; and
- (3) a set of nuclear energies for the nuclear reactors.

The minimal cost solution is obtained from the optimal weekly nuclear assignment, which in turn, leads to a determination of OCNP. The minimum production cost is obtained by running the must-run (base load) units first, and then the hydro(\*) and peaking units(\*\*) are dispatched. Next, the optimal distribution of nuclear energy for the week is determined by the LP. model. As the last step, the pumped storage and fossil units interactions are calculated analytically.

The PROCOST program is run repeatedly (in the load-duration mode) for a variety of system parameters to generate the large number of data points necessary to define OCNP behavior as a function of weekly nuclear capacity factors(\*\*\*) for each week in the planning horizon. For

-----

- (\*) The hydro generation schedule is calculated externally of PROCOST. PROCOST reads in the hydro schedule and subtracts it from the demand function to be fulfilled.
- (\*\*) Because of the deterministic nature of this study, usage of peaking units must be assigned, details in Section 4.2.1. Input parameters for peakers includes simulated capacity factors, fuel costs and start-up and shut-down costs.
- (\*\*\*) For convenience, the normalized parameter, weekly nuclear capacity factor is used in place of nuclear energy.

example, the weekly OCNP function may be sufficiently characterized by calculating OCNP values at five values of the weekly nuclear capacity factor (i.e., 0.55, 0.65, 0.75, 0.85, 0.95). Thus, for a 26 week planning horizon, 130 OCNP values need be calculated (for a single reactor optimization study). The weekly OCNP values are input to a sorting program, ALLOCAT, which determines for an overall planning period nuclear capacity factor, the optimal weekly nuclear capacity factor distribution. These optimal capacity factors are re-entered in PROCOST (in chronologic load model mode) to determine the optimal detailed hourly generation schedule for all the units being simulated in the entire short-range time horizon.

### 3.2 Assumptions and Idealizations

#### 3.2.1 Deterministic Production Cost Model

The economic dispatch optimization model is a simple power flow problem where the basic time interval is one hour. Electrical circuit stability constraints and transmission loss are not considered. More detailed models concerned with load frequency control and transformer taps are described in Ref. (12,13). PROCOST, the production cost optimization model, calculates only the power distribution from several generators.

A deterministic approach was used to treat both load forecasts and forced outages in the system production cost model, PROCOST. The forecasted customer demand is assumed known with certainty as well as the time horizon (fixed fueling rate). To include the effect of the probabilistic distribution of the customer demand would require the use of Stochastic Programming (27) and be quite involved. Alternatively using Risk Decision Analysis, Ref. (33), would involve less computations than Stochastic Programming but still more than the deterministic approach. Rees and Larson (23) developed a short-range optimal scheduling program using dynamic programming, but without the capability of simulating nuclear plants. The deterministic method seems to be the quickest and simplest method available.

The deterministic approach also assumes that the system configuration of available power plants is known and fixed throughout each of the week(s) simulated. This implies 100%

availability. An alternative to the deterministic approach would be to use the Booth-Balerieux probabilistic utility model (17,18,19). The probabilistic utility model incorporates individual forced outage rates in the system calculation of economically satisfying the system load. This latter model would provide a more realistic set of plant capacity factors and system production costs. The deterministic approach favors the base load units and ignores the peaking units, because of the assumed perfect availability of the thermal units. Therefore, to compensate for this bias, peaking units and hydro units are simulated explicitly to peak shave the demand curve and to meet estimated (input) capacity factors for these units. The fossil units are optimized by determining the purely economic loading order and always loading the lowest cost increments first. The nuclear and pumped-storage generation schedules are optimized to peak-shave the resulting demand function.

The peak-shaving operations of the nuclear and pumped-storage are done in series (separately) to reduce the calculational costs involved in a single larger model. The fossil fuel costs of both the two-step and single step methods are identical. The explanation is that the amount of pumped-storage energy is the same in both cases. Since the amount of nuclear is fixed, the resulting fossil generating schedule is the same. Hence, the fossil fuel costs should be the same.



In short, the deterministic approach was chosen because it was the simplest case that could be studied while retaining most of the factors significant in the short-range optimization problem.

### 3.2.2 Load Models

A chronological load model was used to approximate the 168 hour per week customer demand function. The chronologic nature is required to include the effects of fossil plant start-up and shut-down, and also to simulate peaking units and their start-up and shut-down costs. And the modelling of pumped-storage and hydro units (with pondage) required the chronologic model so that it was possible to check that the reservoir level remained within permitted limits. Eventually, the large size of the L.P. optimization model precluded the modelling of the fossil start-up and shut-down costs, which would have required Integer Programming (a very expensive option). The consequence of this omission was believed small, since the system configurations used in the system simulations (modelling the AEP system) had little overnight shutdown.

A chronologic load model sensitivity study concluded that a 40-interval load model was sufficiently accurate in reproducing the fossil incremental capacity factors of a 168-interval model so that the former may be used in optimization studies in place of the latter to save computation costs; the details of this study is discussed in Appendix A along with the computer programs associated with the load models.

In reproducing OCNP, load-duration load models of six intervals were fairly accurate in comparison with the more detailed models. The sensitivity study with load-duration

load models are discussed in Section 5.2 and Appendix A.6. The exact number of intervals to use in few-interval models is dependent on the utility's customer demand function, its system configuration, and the accuracy desired in reproducing the results of detailed load models. The principle proven by the sensitivity studies is that a large reduction in the number of intervals will substantially reduce computation costs, without impairing accuracy.

The maximum reduction possible in the number of time intervals will depend on the feature of the model to be reproduced with accuracy. Each feature will have a different sensitivity to the number of time intervals in the load model. As discussed above, a greater reduction in intervals is possible when the feature of model of interest is OCNP rather than the fossil incremental capacity factors.

As a matter of convenience, holidays were omitted in developing the load models for the simulation studies. A low forecasted energy consumption for a week (due to a holiday) would result in a poor prediction of the week's demand function because the effect of the decreased energy consumption is spread over the entire week. The immediate effect would be a poor prediction of the weekly peaks. It has been assumed that utilities would have their own load models that would correct for this deficiency. Since writing sophisticated load models was beyond the range of this thesis, simple load models were used in the simulations, just to generate customer demand numbers. The

nuclear reactor optimization procedures presented in this thesis are independent of the load models used. A summary of current industrial methods in forecasting demand is given in Ref. (20).

### 3.2.3 Nuclear

There are a number of nuclear assumptions in the derivation of the production cost code, PROCOST. This code places no constraints on the rate of change of the nuclear power production from one time interval to the next. Physically, the reactor is adaptable to large and quick load changes, but the fuel presently used in reactors may be constrained in its ability to meet large or rapid changes (21).

Large changes in power are also difficult late in the core life due to the Xenon-135 (Xe) problem. After a prolonged operation at full power, a large power decrease or shut down will result in a substantial build up of Xe. Late in core life, there is not enough excess reactivity to override the Xe. Thus, if allowed to build up before resuming full power operation, a power reactor must wait until the Xe decays away (40-60 hours). Schultz (14) has a very good discussion on this Xe control problem. The Xe problem rules out rapid changes in the electrical production of a reactor during its coast-down phase since its excess reactivity is then practically nil. Weekend shutdown would still be possible, however.

Furthermore the codes, as written, allow for no constraint on the minimum power level of the nuclear reactors during load-following maneuvers.

The L.P. thermal energy model is based upon the assumption that the total amount of thermal energy

obtainable from a given reactor before refueling is constant, when limited to full-power reactivity-limited burnup.

### 3.2.4 Financial

The financial assumptions are very crucial in understanding how the system production cost is derived and applied in the optimization process. The basic financial assumption (under the short-range resource-limited condition) is that the production schedule (power history) of a power reactor has no effect on the cost of the nuclear fuel cycle. Head-end services can not be affected since they have been completed before energy is generated. Since the same end state, the full-power reactivity-limited burnup state, is reached in all cases, the tail-end services also will be unchanged. Thus the total cash outlay of the nuclear fuel cycle is undisturbed by the generation schedule.

However, more subtle effects result from the time value of money. The timing of (nuclear fuel) depreciation credits (or lease payments), and the timing of fossil fuel cost expenses do have a real financial impact on a utility earnings report, especially in times of high interest rates; see Appendix E. This effect favors use of nuclear fuel as early as possible, and defers buying fossil fuel as late as possible. In the mid-range time scale, the time value of money plays an important role in the decision process, but in the short-range time scale of interest in this thesis, the system reliability considerations outweigh the small economic benefit of distorting the system reserve capabilities. Thus, interest rates have been left out of

the system cost calculations for this thesis. Even if the fuel is rented on a heat-delivered basis, the total charge is assumed paid in one lump sum so that the time element can be ignored. Hence, the basic assumption is that there is no variable cost component in the nuclear fuel cycle. The system production cost will be exclusively the fossil fuel cost (plus start-up and shut-down costs of simulated peaking units), expensed as consumed. Operation and maintenance costs are disregarded, as these are assumed to be independent of the mode of operation of the system.



## 4.0 OPTIMIZATION MODELS

### 4.1 Introduction

The optimization procedure presented here is a series of separate programs that perform separate tasks. This method insures maximum flexibility and minimum duplication of calculational efforts when performing sensitivity studies, such as changing (i) the number of weeks optimized, (ii) a week's system configuration, (iii) the planning horizon resource, or (iv) a week's demand level. The study of a system's nuclear resource is not finished with the completion of a single optimization run, but is a continuing process. The result of one run provides management insight which suggests study of new parameters for another closer examination of where the greatest sensitivities lie.

The optimization programs are as follows:

- (1) PROCOST, the major program which calculates the minimal weekly system cost and the OCNP for a given set of parameters;
- (2) ALLOCAT, a program which finds the optimal distribution between weeks for nuclear energy from sets of OCNP values.
- (3) FOSSIL, a program that calculates the weekly system cost and OCNP for a nuclear-fossil system where the power level of the nuclear unit is held constant throughout the week.

PROCOST takes a series of assumed nuclear energy allotments for a particular week and assigns its generation to various

times in the week to determine the minimal system cost for each allotment of nuclear power and from this OCNP. ALLOCAT takes a set of weekly OCNP values over a longer period of time and determines how much nuclear energy to allocate to each week by using the criterion that the OCNP for all weeks shall be the same.

PROCOST is the system production cost program that calculates the optimal generation schedule from the following input data (i) fossil plant parameters, (ii) peaking unit parameters, (iii) hydro generation schedule, (iv) nuclear unit parameters, (v) pumped-storage parameters, and (vi) customer demand function. The user has a choice of specifying whether the nuclear optimization L.P. model use a load-duration model or a true chronologic or modified chronologic load model, the choice depending on the application of the result. The pumped-storage generation schedule can be either optimized for economic operation (least operating cost) or for security operation (maximum pumped-storage reserve capacity).

ALLOCAT is a sorting program that receives as input the collection of weekly OCNP functions, with an overall nuclear capacity factor. ALLOCAT finds the optimal distribution of weekly nuclear capacity factors by using the equal opportunity cost rule.

PROCOST is usually run many times in load-duration mode to generate OCNP numbers. When the optimal inter-weekly nuclear capacity factor distribution has been solved by

ALLOCAT, the values are fed back to PROCOST (in chronologic mode) to generate the detailed hourly generation schedule of all the units. The algorithm of PROCOST is discussed in Section 4.2 and of ALLOCAT in Section 4.3.

FOSSIL is used to calculate system cost for the reference situation when there is no nuclear optimization (constant power level through the week). This simpler program can be used in place of PROCOST in generating OCNP values for the case of constant weekly nuclear power level. FOSSIL also is used to calculate OCNP values for an alternate and more direct, but approximate, optimization procedure discussed in detail in Section 4.4.

#### 4.2 PROCOST Algorithm

The PROCOST algorithm presented here consists principally of two parts, the optimal generation schedule of nuclear units and the optimal generation schedule of pumped-storage unit. The original reason for dividing the computation was to reduce the computational costs of a single large L.P. model that included both the nuclear and pumped-storage units. Later, a number of other constraints(\*) on the pumped-storage unit precluded its inclusion in an L.P. model. Figure 4.1 shows the general flow chart of the PROCOST algorithm. The nuclear

---

(\*) These constraints included keeping the reservoir level within bounds, the formulation of a security mode schedule, and difficulty in modelling a pumped-storage unit adequately in a load-duration environment.




Figure 4.1 PROCOST ALGORITHM

optimization is composed of two parts, and MPSX. The L.P. formulation program, NUC\_OPT, writes the L.P. formulation of the nuclear optimization problem. MPSX, an IBM program product, reads the formulation and performs a variety of L.P. optimization and parametric studies. The L.P. solution is read by the pumped-storage scheduling program, called PUMP\_ST, which performs either economic or security mode scheduling.

Before NUC\_OPT formulates the nuclear optimization, it also performs a simulation of the hydro and peaking units. These subprograms are described in detail in the following sections.

#### 4.2.1 Nuclear L.P. Formulation

The nuclear scheduling problem is solved by linear programming (L.P.). To include the important feature of variable nuclear heat rates, a special version of L.P. called "separable programming" is used. IBM provides a program product called MPSX (Mathematical Programming Systems Extended) that solves separable programming problems. Thus a preprocessor is required to reformulate the utility system input parameters into the input format required for MPSX, the L.P. formulation of the nuclear scheduling problem. The input to the preprocessor, NUC\_OPT, consist of a customer demand function (output from a load model program, MODEL), nuclear, fossil, and peaking units plant data and the hydro generation schedule. The hydro generation schedule may vary a great deal depending on

seasonal, geographic, and climatic factors. Thus, the operation of such hydro units are calculated externally and input to the preprocessor. The preprocessor deducts the hydro schedule from the input customer demand function, resulting in a new modified customer demand function which the rest of the system units must satisfy.

The deterministic approach to a demand problem would normally under-utilize higher cost fossil and peaking units (due to the exclusion of forced outages). To partially compensate for this effect, the operation of the system peakers are simulated and forced outages of all fossil units are programmed (scheduled) into the monthly system configurations. Each peaking unit is scheduled to peak-shave the customer demand until its input capacity factor is achieved. Peaking units are called successively, the largest units first, to maximize their effect in flattening the demand function. The rationale for this method of scheduling peaking units is that peakers are observed to be utilized only during peak periods when system reserve is at its lowest point and operated at their full rated capacity. Thus peakers are modelled as single step functions, either on, or off. When needed, peaking units are turned on regardless of cost.

After the peaking unit generation schedule has been determined, the number of start-up and shut-downs for each unit is counted and total operating costs for the peakers calculated. The peaking units' schedule is then deducted

from the customer demand function, resulting in a lower modified demand function which the rest of the system units must satisfy. The peaking unit simulator, PEAKERS, operates on each different weekly customer demand function. The required parameters of a peaking unit are: rated capacity (MW), estimated capacity factor, average heat rate, fuel cost, and cost of each start-up and shut-down.

The fossil plant parameters are sorted by subroutine PECK\_OR that determines the economic incremental fossil loading order and also the fossil must-run level of operation. The latter is then deducted from the customer demand function, resulting in a lower modified demand function which the rest of the system facilities must satisfy. This modified demand function is the one passed to the nuclear scheduling program, MPSX. The L.P. formulation of the nuclear scheduling problem is presented as follows:

Objective function: minimize

$$\sum_j \sum_i (C_i) (F H_i) (F X_i^j) (T_j) \quad (4.1)$$

subject to the following constraints:

(customer demand constraint)

$$\left\{ \sum_i F X_i^j + \sum_n \sum_i^{I_n} X_i^j = D^j \right\} \quad (4.2)$$

j=1, ..., J

(limited thermal nuclear resource constraint)

$$\left\{ \sum_j \sum_i (X_i^j) (H_i) (T_j) = K_n \right\} \quad (4.3)$$

n=1, ..., N

(bounds, separable programming constraint)

$$\left\{ \begin{array}{l} \text{if and only if } F_{,n} X_{i-1}^j = F_{,n} B_{i-1} \\ \text{then } 0 \leq F_{,n} X_i^j \leq F_{,n} B_i \\ \text{else } F_{,n} X_i^j = 0 \end{array} \right\} \quad (4.4)$$

n=1, ..., N  
j=1, ..., J  
i=2, ..., I\_n

where:

$F X_i^j$  = fossil power level of the i-th increment and the j-th time period (MW)



- $X_i^j$  = power level of the  $i$ -th increment and the  $j$ -th time period of the  $n$ -th nuclear reactor (MW)  
 $F, n X_i^j$  = either  $F X_i^j$  or  $n X_i^j$   
 $F H_i$  = incremental fossil heat rate of the  $i$ -th increment of the loading order (million BTU/MWht)  
 $n H_i$  = incremental nuclear heat rate of the  $i$ -th nuclear increment of the  $n$ -th nuclear reactor (million BTU/MWht)  
 $C_i$  = fossil fuel cost (\$/million BTU) of the  $i$ -th increment  
 $D^j$  = modified customer demand of the  $j$ -th period (MW)  
 $K_n$  = full-power reactivity-limited thermal energy available in the  $n$ -th reactor (million BTU)  
 $F, n B_i$  = upper bound of the  $i$ -th increment (MW)  
 $J$  = total number of time periods  
 $N$  = total number of nuclear reactors  
 $I_n$  = total number of increments in a nuclear reactor  
 $T_j$  = duration of  $j$ -th time interval (Hours)

The objective function, Eq. (4.1), to be minimized is a summation of the incremental production cost over all the increments in the fossil loading order (index  $i$ ) and over the one-week time horizon (index  $j$ ). The incremental production cost is a product of the fuel cost (\$/million BTU), the incremental heat rate (million BTU/MWH) and the energy production (MWH) of that time period. The constraints to be met are: (1) the summation of the power levels of the individual nuclear and fossil units in each time period must satisfy the modified customer demand, Eq. (4.2), while (2) limiting the total nuclear production to

the available resources, Eq. (4.3). In addition, each variable is bounded, Eq. (4.4). This is where the separable programming aspect is featured. All increments are fixed at the lower bound of zero until all the preceding increments have been set to their upper bound. For example, the third increment of the loading order can not be started until the second (and the first) increments are fully loaded. Without this feature, variable heat rates could not be modelled.

To examine this problem more closely, notice that many of the fossil increments will always be loaded independently of the amount of nuclear energy to be distributed. For example, assume a fossil incremental loading order of 100 increments of 100 MWe each. The nuclear unit has a capacity rating of 1000 MWe. In a single time interval, suppose that the customer demand function specifies 8050 MWe to be met by the system. Then, irrespective of the optimal amount of nuclear energy assigned to this time interval a priori the first seventy fossil increments must always be fully loaded. Unfortunately, MPSX does not know this a priori. Starting from scratch, MPSX will laborously load each of the fossil increments one by one. A significant amount of computer time and storage cost is saved by having MPSX solve the following equivalent problem instead. For the time interval in question, the fossil incremental loading order is of only thirty increments of 100 MWe each. The nuclear unit is still of 1000 MWe, but the demand to be met is only 50 MWe. 7000 MWe has been subtracted from both the load demand and

the fossil generating capacity. Hence (in this example), the number of variables has been reduced by two-thirds, and the solution computation time cut by an order of magnitude, just by formulating the same problem from another viewpoint. This improvement of calculating minimum fossil operating levels and subtracting them from the system problem before nuclear optimization has significantly reduced MPSX computer CPU time by almost an order of magnitude. Specific programming details of NUC\_OPT are given in Appendix C.

The preprocessor, NUC\_OPT, formats (writes) this information (L.P. formulation) to meet MPSX input specifications on a transfer medium (such as a scratch disk) as its final product. Execution is transferred to MPSX to solve the nuclear scheduling problem (by the revised simplex method) and write the solution on a scratch disk. Execution is then turned over to the pumped-storage program. The programming aspects of MPSX are discussed in Appendix C.3.

#### 4.2.2 Pumped-Storage Scheduling Program

The pumped-storage scheduling program, PUMP\_ST, has three modes of operation: (1) security mode to maximize pumped reserve capacity; (2) economic mode to minimize operating costs, (3) pumped-storage by-passed completely(\*).

-----

(\*) If a pumped-storage unit does not exist, or is an insignificant portion of the system, or is not important in the OCNP calculational phase, then the pumped-storage scheduling routine can be skipped altogether. PUMP\_ST would then be used just to interpret (and print) the nuclear L.P. solution. See Appendix C for details on this option.

The latter choice will be ignored for the remainder of this section. The pumped-storage program first reads and interprets the nuclear L.P. solution. Then control is passed to the economic subroutine, ECO, to determine the economic pumped-storage generation schedule. If the desired mode of pumping is 'security', then the security subroutine, SECURIT is called to calculate the pumping schedule that would keep the reservoir filled as much as possible. Otherwise, the economic pumping schedule is calculated. The reservoir is then checked for water overflowing or running dry. Any necessary corrections are then made and control is returned to the main program, PUMP\_ST. PUMP\_ST then calculates and prints the capacity factors of both the various fossil increments in the economic loading order, and of all the fossil units themselves. It also calculates total system production cost, and the OCNP. Detailed programming specifics are given in Appendix C.

This section is further divided in four subsections:

- (1) Economic Pumped-Storage Theory
- (2) Economic Pumped-Storage Scheduling Algorithm
- (3) Pumped-Storage Security Theory
- (4) Pumped-Storage Security Scheduling Algorithm

#### 4.2.2.1 Economic Pumped-Storage Theory

The economic pumped-storage scheduling problem is an amply documented case (22). Originally, an L.P. formulation for the pumped-storage problem was devised. But since the solution is well known, this section of the

program was rewritten to solve for the solution analytically. With a pumped-storage facility, a utility would pump into the storage facility at times of low customer demand and low incremental cost of power. Stored energy would be discharged at times of peak customer demand and high incremental cost of power. Thus the utility would have lowered production costs by the difference between the cost of pumping the water, and the displaced cost of generation at peak demand. If the pumped-storage facility were 100% efficient and the pump, generator and reservoir were of limitless size, the solution of the scheduling problem would be described (see Figure 4.3) by that power level,  $K$ , where: (1) if the customer demand was above  $K$ , the pumped-storage facility would generate that amount equal to difference between  $K$  and the customer demand, (2) if the customer demand was below  $K$ , the pumped-storage facility would pump that amount equal to the difference between  $K$  and the customer demand, and (3) the amount pumped and the amount generated were equal over a cycle of the demand function. This is illustrated graphically as follows: Figure 4.2 is a simple load-duration curve representing the customer demand curve for a one-week time period. Power level  $K$  is that level where area  $A1$  equals area  $A2$  (Figures 4.3 and 4.4) so that the fossil power production is such




Figure 4.2  
ILLUSTRATIVE WEEKLY  
LOAD-DURATION CURVE




Figure 4.3  
OPERATION OF AN IDEALIZED  
PUMPED-STORAGE FACILITY




Figure 4.4  
PUMPED-STORAGE DURATION  
CURVE OF FIGURE 4.3




Figure 4.5  
FOSSIL DURATION CURVE  
OF FIGURE 4.3

that the fossil power production is levelized (Figure 4.5) and thus, fossil fuel cost is minimized (\*).

The fact is that the cycle efficiency is not 100%. Then the solution is graphically illustrated in Figure 4.6. Returning to the load duration curve, the pumped-storage facility generates power whenever the customer demand is above the power level  $K_1$  and pumps whenever the customer demand is below  $K_2$ , such that: (1) the incremental cost at  $K_1$  equals the incremental cost at  $K_2$  divided by the cycle efficiency, and (2) the energy generated  $A_1$  equals the energy stored,  $A_2$  times the cycle efficiency. The first condition is the economic minimal cost criterion and the second condition is the energy conservation principle.

The physical limitations of the generator and the pump also make the solution even more complex, as shown in Figure 4.9.  $G$  and  $P$  represent the capacity ratings of the generator and the pump, respectively, see Figure 4.10. When the customer demand is above the power level  $K_3$ , the pumped-storage generator is turned on until its capacity is reached or fossil generation is reduced to  $K_3$ . When the customer demand is below power level  $K_4$ , then the pump of the pumped-storage facility is turned on until its capacity is reached or fossil generation has increased to  $K_4$ . The economic cost criterion dictates that the incremental cost

-----  
(\* ) A major assumption used here is that the fossil loading order is strictly economical, the lowest cost increments loaded first, and without regard to start-up and shut-down cost.




Figure 4.6  
OPERATION OF AN INFINITELY  
 LARGE PUMPED-STORAGE FACILITY




Figure 4.7  
PUMPED-STORAGE DURATION  
 CURVE OF FIGURE 4.6




Figure 4.8  
FOSSIL DURATION CURVE  
 OF FIGURE 4.6






Figure 4.9  
OPERATION OF A FINITE  
 PUMPED-STORAGE FACILITY




Figure 4.10  
PUMPED-STORAGE DURATION  
 CURVE OF FIGURE 4.9




Figure 4.11  
FOSSIL DURATION CURVE  
 OF FIGURE 4.9

at K3 equals the incremental cost at K4 divided by the cycle efficiency. The energy conservation principle dictates that the generation energy, area A3 equal the pumping energy, area A4 times the cycle efficiency ( $\epsilon$ ).

The physical limitation of the reservoir size requires that the chronologic water level behavior be checked for overflowing and running dry. The chronologic water level behavior will be a function of generator and pump capacity and the customer demand function. Hence, for a properly designed pumped-storage facility where a utility knows its customer demand, it looks for a site for the pumped-storage facility of compatible reservoir size which in turn dictates generator and pumping capacity in the proper proportions. So in theory, for normal operations, reservoir size should not be expected to be an active constraint. Hence, the pumped-storage scheduling algorithm searches for the solution along the only two active constraints: cost criterion and energy conservation. The algorithm checks the water level after an optimal economic schedule has been calculated. After initially using only the cost criterion as a guide to find feasible pos of cost tradeoffs, the conservation principle is used to move toward maximum energy production by the pumped-storage unit. After an optimal schedule has been calculated, the water level is examined for overflows or running dry. If such a case is found, local correction measures are taken at times of violation. Greater details on the correction measures are

given in the next section. The pumped-storage facility is based on a weekly cycle, returning the water level at the end of the week to the level at the beginning of the week (an input specification). Free water inflow into the reservoir is allowed and is assumed to be uniform throughout the week.

#### 4.2.2.2 Economic Pumped-Storage Scheduling Algorithm

In the previous section, the distinguishing characteristics of the economic pumped-storage solution were discussed. In this section, the algorithm to reach the solution is discussed, but by a slightly different path than in the previous section. In brief, the algorithm systematically examines a limited number of points that satisfies both the energy conservation principle and the economic cost criterion until the optimal solution is reached. The algorithm locates the loci of points where the energy constraint is active and then proceeds systematically to where the cost constraint is active.

The flow chart of the pumped-storage economic algorithm is shown in Figure 4.12. The main program, PUMP\_ST, passes control to ECO, with all the pumped-storage operating parameters including the modified demand function that must be satisfied by the fossil increments and the pumped-storage facility. With the additional information of system variables passed from the preprocessor, the data base is formed from which the search for the solution is based. Graphically (see Figure 4.9), the solution is located where




Figure 4.12 ECO FLOW-CHART

the maximum area A3 (stored energy) satisfies both the cost criterion and energy conservation principle. The maximum area (stored energy) represents the largest utilization and hence the largest cost savings. An enumerative search is made since the number of points satisfying both constraints is small (less than the number of fossil increments), and a computer can search these points very quickly. The search is started by determining the lowest feasible value of K3 (Figure 4.12), and in turn, its associated feasible value of A3 (stored energy) is calculated(\*). The value of K3 is increased stepwise until the feasible value of A3 (stored energy) can no longer increase(\*\*). At this point the optimal solution has been reached.

The starting point of the search is K' (see Figure 4.13), the lowest feasible value of K3. K' is that power level which divides the load-duration curve so that the pumped-storage facility is always pumping or generating without regard for cost, see Figures 4.14 and 4.15. This is the case where the cost criterion is not active. From this starting point, the cost criterion is then introduced. Setting K3 to K' produces a value for K4 (see Figure 4.16). The associated value of A4 is calculated which is compared with A3. As illustrated in Figures 4.17 and 4.18, where

-----

- (\*) K4 by the cost criterion is calculated from K3, which determines area A4 (pumping energy), which in turn, determines the feasible value of A3 (stored energy).
- (\*\*) Increasing K3, increases K4 which increases A4 (pumping energy), which in turn, increases the feasible value of A4 (stored energy).




Figure 4.13  
FULL-UTILIZATION OF A PUMPED-STORAGE FACILITY WITHOUT REGARD TO COST




Figure 4.14  
PUMPED-STORAGE DURATION CURVE OF FIGURE 4.13




Figure 4.15  
FOSSIL DURATION CURVE OF FIGURE 4.13




Figure 4.16  
INITIAL STARTING SOLUTION OF  
THE PUMPED-STORAGE ALGORITHM




Figure 4.17  
PUMPED-STORAGE DURATION  
CURVE OF FIGURE 4.16




Figure 4.18  
FOSSIL DURATION CURVE  
OF FIGURE 4.16

energy A3 is out of balance with energy A4 because  $A3 \neq EA4$ , the value of K3 is increased to the next higher incremental loading order point. K4 is reset, A3 and EA4 are recalculated and compared. This is repeated until they are equal or the balance shifts to the other direction. If the shift occurs, A3 and A4 are interpolated to the point at which  $A3 = EA4$ , which determines the maximum feasible pumping. The next step is to re-sort the load duration curve of the pumped-storage facility back to a chronological load curve to check the water level. If the reservoir runs dry, generation is cut back to zero for the required number of intervals (and pumping is likewise adjusted); or if the reservoir overflows, pumping is cut back to zero for the required number of intervals (and generation is likewise adjusted). These corrective measures are not performed optimally (in a least-cost sense), but rather to correct the situation as immediately as possible (in as few time intervals as possible).

Finally, the pumped-storage schedule is complete and feasible and the incremental fossil production schedule by default is the residual load demand schedule. The detailed pumped-storage schedule is then printed (if desired), and control returned to the main program. The incremental fossil fuel costs are then calculated, and in turn, the total system production cost and the OCNP also. PUMP\_ST also prints the incremental and each fossil unit's average capacity factors.



As an option, the pumping schedule may be calculated by the Pumped-Storage Security Model described in the next section, instead of the economic model discussed in this section.


#### 4.2.2.3 Pumped-Storage Security Theory

Pumped-storage units have proven to be reliable and versatile in helping the utility dispatcher to cope with the statistical fluctuations in meeting customer demand. The pumped-storage facility is quick to adapt to changing load demands with a minimum of strain (24). In fact, utility practice is to assign a large portion of its pumped-storage generating capacity to spinning reserve. For example, AEP's Ludington pumped-storage facility has 460 MWe generating capacity but only 300 MWe is normally scheduled on a planned basis. The remaining 160 MWe capacity is set aside as spinning reserve to take care of equipment forced outages and unexpected load changes.

For the pumped-storage facility to meet this responsibility and to be capable of handling the severest problem, the reservoir must be kept as full as possible at all times. This means that whenever the pumped-storage facility is not generating power, it will be pumping water into the reservoir until it is filled. These operational procedures are probably not the least expensive mode of operation. To provide the system with maximum security, the pumped-storage facility has pumping scheduled until the reservoir is full, even though the generation schedule

Figure 4.19

TYPICAL ECONOMIC PUMPED-STORAGE SCHEDULE



Source: Reference (22), pp. 179

doesn't require it and economically, it would be cheaper to wait until the weekend to do the pumping. As an illustration, Figure 4.19 is an example of an economic pumped-storage schedule. The figure shows that there is large amounts of pumping on weekends and only a small amount of sub-capacity pumping during the week nights. The security model proposed would do the reverse, pump at rated capacity on week nights until the reservoir is filled, leaving little pumping to be done on weekends.

#### 4.2.2.4 Pumped-Storage Security Algorithm

The peak-shaving pumped-storage generation schedule for this security model is the same as in the economic model. It is characterized by the pumped-storage generation level (power level K3 in Figure 4.9), where if demand load is above that level, then the pumped-storage generators produced enough power to make up the difference or until its nominal capacity(\*) is reached.

The pumped-storage generation schedule is first calculated in ECO, next subroutine SECURIT is called to calculate the security mode pumping schedule. SECURIT first determines the allowable time periods to schedule pumping, which takes into account a transition interval before and after generation. For each allowable time period, pumping is scheduled for each time interval starting with the time

-----

(\*) Nominal capacity is not the rated capacity of the generators, but that capacity intended for scheduled usage, the remainder is for emergency usage.

interval of lowest demand until either the reservoir is filled, or all available intervals have been scheduled. The detailed algorithm is presented in Appendix C. When pumping for the last time period is scheduled, the final water level is set to return to the beginning-of-week level. Program control is then returned to ECO.

Three simplifying assumptions used in this model are:

- (i) a weekly water cycle is assumed, returning the end-of-week water level to beginning-of-week starting level;
- (ii) the cycle inefficiency is assumed to be all in the pumps. For example, for a 50% cycle efficient unit, the model requires a 2 MWH pumping requirement to produce 1 MWH generation resource, but produces a water level change of only 1 MWH.
- (iii) The (economic) scheduling method used was assumed sufficient. The pumping schedule could be further flattened by iterating over the lowest fossil increments, instead of the lowest demand levels. This would greatly increase the bookkeeping and complexity of the algorithm for a slightly smaller cost determination, hence it was not done.

The first two assumptions are also applicable to the economic pumped-storage model. These two assumptions are not fundamental to the successful execution of the program. These assumptions can be easily modified to fit the requirements of the user.

Appendix C contains the program listing of the security model and the I/O specification of the program.

#### 4.3 ALLOCAT Algorithm

The optimal allocation of the nuclear energy between weeks is performed by the ALLOCAT program. Each week is represented by a list of OCNP values. Maximum utilization of a limited resource dictates that the first nuclear energy increment go to the week having the highest value for nuclear power, OCNP. The first increment utilized, the second increment goes to the week having the second highest OCNP value. This process is analogous to selling to the highest bidders. Each week has a list of successive lower bids (as OCNP values). The central decision maker (the algorithm), one-by-one allocates increments of nuclear energy to the highest bidder first. After each allocation, the going price moves down, until all available nuclear energy has been allocated. In this condition some weeks may have a full supply of nuclear energy (all bids taken) while other weeks may have only the minimum supply (no bids taken). This describes the algorithm used by ALLOCAT. The program is told how much nuclear energy is available and by increments, allocates the energy to the individual weeks. It keeps track of the energy allocated each week to the unit being optimized, and when all the nuclear energy is allocated, the program lists the final capacity factor distribution. Appendix D lists the program along with the input and output from Case 4 (see Section 5.6).

#### 4.4 FOSSIL

FOSSIL is a program that calculates weekly system cost and OCNP for the case of no nuclear optimization. Thus, FOSSIL is principally used as a basis of comparison to measure the savings of the optimized nuclear dispatching schedule. Figuring the optimal fossil dispatching schedule for the case of base-loaded nuclear power (at constant power level throughout the week) is a trivial problem, since there is no nuclear optimization. The fossil algorithm is as follows: The constant nuclear power level is subtracted from the modified demand function, leaving the revised demand requirement that is to be fulfilled by the fossil units. The fossil units are represented by an economic loading order (output from NUC\_OPT), hence, it is a simple table look-up operation to figure the optimal fossil dispatching schedule and operating cost. The OCNP is the incremental fossil fuel cost of the weekly average fossil demand requirement.

The simplicity of FOSSIL (and its very quick method of calculating OCNP) also makes it convenient to use FOSSIL for developing initial guesses for multi-reactor problems. This alternate solution technique inverts the order of optimization steps discussed in Section 3.1. The exact optimization procedure (discussed in Section 3.1) is to first optimally peak-shave the nuclear energy within each week in the planning horizon (using PROCOST) and secondly calculate the optimal distribution of nuclear energy between

the weeks (using ALLOCAT). This procedure is referred to as the "Peak-Shave First" method. The alternate solution technique is to first calculate the optimal distribution of nuclear energy among all the weeks in the planning horizon, assuming a constant nuclear power level in each week, using FOSSIL and ALLOCAT. Secondly the optimal nuclear peak-shaved distribution is calculated (using PROCOST) for the optimized energies in the first step. This approach is referred to as the "Peak-Shave Second" method. A comparison of the two methodologies shows the "Peak-Shave Second" method to be a more direct (but approximate) method involving less computations. This method is especially useful in defining the neighborhood of the optimal solution of a multi-reactor problem where the calculation savings would be very large. Section 5.6 presents a numerical example of using the two solution techniques on the same system example.

## 5.0 System Optimization Studies

### 5.1 The System

To test the optimization procedures discussed earlier, three sample system optimization problems were solved. The first was a single-reactor optimization problem, and the second was a multi-reactor optimization problem. The multi-reactor optimization was performed under conditions more severe than "typical" operating conditions. The third optimization problem was a modification of the first in which the monthly configurations were adjusted to yield constant system reserves over the planning horizon.

American Electric Power Service Corporation (AEP) provided the basic data from which the utility system configuration (16) was constructed. The system, composed of 52 units of five power plant types, was simulated for a short-range planning period of six months, April through September. The system included two nuclear plants (of 1100 MWe each), one hydro plant (with limited pondage and 200 MWe peak generating capacity), one pumped-storage unit (of 300 MWe generating capacity), seven peaking units and 41 fossil units for a total generating capacity of 19,250 MWe. The fossil units were of three classes, large (1300-400MWe), medium (400-160 MWe) and small (below 160 MWe). The distinction between fossil classes was the shape of their average heat-rate curves. In PROCOST all fossil units are identified with one of three general shapes (or classes), with the amplitude of their average heat-rate curve being an



individual scalar multiple of one of the three standardized shapes. The 41 fossil units were composed of 15 large-sized fossil units, 15 medium-sized fossil units, and 11 small-sized fossil units. The three standardized fossil average heat-rate curves are presented in Appendix B. The standardized heat-rate curve of the large fossil class is flat between 0.7 and 1.0 of rated power and steeply rising below 0.7 of rated power. The medium fossil heat-rate curve is similar to the large fossil curve except that its slope is not so steep below 0.7 of rated power. The standardized heat-rate curve of the small fossil class is very different from the other two. The small fossil curve begins at 14,000 BTU/KWH at 0.4 rated power, slopes down to 12,500 BTU/KWH at 0.7 rated power and slopes up to 13,000 BTU/KWH at rated power.

The maintenance schedule (scheduled outage) of the individual fossil and peaking units proposed by AEP is displayed in Table 5.1. Most of the scheduled outage is placed in the spring and fall months. Since the model is deterministic, forced outage effects are simulated, treating them as scheduled outages also. Table 5.1 also displays the systematic treatment of forced outages. Essentially the same forced outage rate is displayed for each of the months. As mentioned earlier, peaking units are scheduled to peak-shave until their input estimated capacity factors are fulfilled. All the peakers had estimated capacity factors of 10% and start-up and shut-down cost of \$100/start-up, except for two

TABLE 5.1  
MAINTENANCE AND FORCED OUTAGE SCHEDULE  
OF PEAKING AND FOSSIL UNITS  
OF CASES 1 AND 2

Month	<u>Maintenance Schedule</u>												<u>Assumed Forced Outage Schedule</u>												
	<u>J</u>	<u>F</u>	<u>M</u>	<u>A</u>	<u>M</u>	<u>J</u>	<u>J</u>	<u>A</u>	<u>S</u>	<u>O</u>	<u>N</u>	<u>D</u>	<u>J</u>	<u>F</u>	<u>M</u>	<u>A</u>	<u>M</u>	<u>J</u>	<u>J</u>	<u>A</u>	<u>S</u>	<u>O</u>	<u>N</u>	<u>D</u>	
<u>Peakers</u>																									
1													X												
2														X	X										
3	X															X									
4			X																	X					
5						X														X	X				
6		X																						X	
7										X											X				
<u>Fossil</u>																									
1								X										X	X						
2									X														X	X	
3										X												X			
4				X																		X	X		
5							X												X						
6		X																		X	X				
7			X													X									
8					X								X	X											
9										X								X	X						
10		X												X											
11								X							X	X									
12						X											X								
13										X								X	X						
14	X																			X					
15						X														X	X				
16								X														X			
17			X																				X		
18				X																			X	X	X
19																					X				
20										X												X	X		
21	X																			X	X				
22						X										X	X								
23			X																						
24				X												X									
25										X			X	X											
26							X						X												
27				X										X	X										
28								X								X									
29										X									X	X					
30	X																	X	X						

TABLE 5.1 (CONT'D)

Month	<u>Maintenance Schedule</u>												<u>Assumed Forced Outage Schedule</u>											
	<u>J</u>	<u>F</u>	<u>M</u>	<u>A</u>	<u>M</u>	<u>J</u>	<u>J</u>	<u>A</u>	<u>S</u>	<u>O</u>	<u>N</u>	<u>D</u>	<u>J</u>	<u>F</u>	<u>M</u>	<u>A</u>	<u>M</u>	<u>J</u>	<u>J</u>	<u>A</u>	<u>S</u>	<u>O</u>	<u>N</u>	<u>D</u>
<u>Fossil (Cont'd)</u>																								
31	X																		X	X				
32				X																		X		
33	X	X	X	X	X	X	X	X	X														X	X
34											X												X	X
35									X														X	X
36											X										X			
37			X																					X
38				X															X	X				
39											X							X						
40					X									X	X									
41										X						X	X							

Note: An "X" represents a simulated outage for the entire month. The total time of scheduled outage for each plant corresponds to the actual observed outage rate for similar sized units. The specific forced outage schedule for each unit was chosen randomly. The maintenance schedule was chosen to lie mainly in the spring and fall months.

gas-turbine units (of 51 and 4 MWe) which had zero start-up and shut-down costs.

The individual plant parameters were supplied by AEP in 1973. The rated capacity, fuel costs and average heat-rate at rated capacity for the 41 fossil units and seven peaking units are tabulated in Table 5.2. The fuel costs do not reflect the sharp rise in fuel costs during 1974. The hydro unit with limited pondage was scheduled to generate 200 MWe for nine peak demand hours during each workday and 50 MWe at all other times. The pumped-storage unit's operating parameters were: 300 MWe capacity generator, 160 MWe capacity pump, 70% cycle efficiency, 9300 MWH reservoir capacity and 2300 MWH/week free water inflow into the reservoir. The operation of pumped-storage unit has been discussed in Section 4.3.

The system treated also had two nuclear units of 1100 MWe each. Nuclear Unit 1 was scheduled for refueling on October 1. In the six months prior to refueling which make up the planning period, Unit 1 was assumed to have 70% of the energy required to operate base loaded at full rated power. In the first simulation, Unit 2 was treated as a new unit just being introduced to service under a gradual programmed start-up: 20% of full rated power throughout April, 40% of full rated power throughout May, 60% during June, 80% during July, and 100% during August and September.

The forecasted weekly energy consumption during the six months (26 week) planning period is tabulated in Table 5.3.

TABLE 5.2

PLANT PARAMETERS OF PEAKING AND FOSSIL UNITS

<u>Peakers</u>	<u>Capacity Mw</u>	<u>Fuel Cost \$/10<sup>6</sup> Btu</u>	<u>Heat Rate 10<sup>6</sup> Btu/MWh</u>
1	4	1.70	15.0
2	51	1.70	15.0
3	95	1.70	12.5
4	95	1.05	12.0
5	95	1.05	12.0
6	90	0.55	12.9
7	90	0.55	12.9
<u>Fossil</u>			
1	145	1.70	9.8
2	105	0.40	12.0
3	110	0.40	12.0
4	100	0.55	10.8
5	105	1.0	11.8
6	150	0.95	9.4
7	150	0.95	9.4
8	150	0.95	9.4
9	150	0.95	9.4
10	150	0.55	9.7
11	150	0.55	9.7
12	215	0.55	9.5
13	240	1.0	9.1
14	205	0.55	9.8
15	205	0.55	9.8
16	215	0.55	9.8
17	215	0.55	9.8
18	225	0.50	10.0
19	225	0.50	10.0
20	225	0.50	10.0
21	215	0.55	9.2
22	210	0.55	9.2
23	240	0.80	9.1
24	240	0.80	9.1
25	240	0.80	9.1
26	280	1.05	9.3
27	400	0.55	9.0
28	450	0.95	9.0
29	525	0.35	9.1
30	580	0.55	9.0
31	600	0.50	9.1
32	600	0.50	9.1
33	615	0.50	9.0
34	800	1.05	9.4
35	800	0.40	9.5
36	800	0.40	9.5
37	800	1.10	9.0
38	800	1.10	9.0
39	1,300	1.25	8.4
40	1,300	0.80	8.5
41	1,300	0.80	8.5

Table 5.3

WEEKLY ENERGY FORECAST FOR PLANNING PERIOD

<u>Month</u>	<u>Week</u>	<u>Weekly Energy (MWH)</u>	<u>Monthly Total (MWH)</u>	<u>Demand Peak (MWH)</u>	<u>Average Power (MWH/H)</u>
April	1	1,860,288	7,238,361	13,577	11,073
	2	1,894,814		13,795	11,279
	3	1,801,320		13,207	10,722
	4	1,681,939		12,472	10,011
May	5	1,792,155	8,771,712	13,149	10,668
	6	1,728,221		12,747	10,287
	7	1,758,492		12,937	10,467
	8	1,801,151		13,207	10,721
	9	1,691,693		12,517	10,070
June	10	1,839,877	7,299,798	13,951	10,952
	11	1,883,604		14,227	11,212
	12	1,814,876		13,793	10,803
	13	1,761,441		13,456	10,485
July	14	1,681,810	9,122,626	12,954	10,011
	15	1,870,344		14,143	11,133
	16	1,826,914		13,869	10,874
	17	1,883,382		14,226	11,211
	18	1,860,176		14,079	11,072
August	19	1,833,500	7,589,101	13,911	10,914
	20	1,950,649		14,650	11,611
	21	1,895,024		14,299	11,280
	22	1,909,928		19,393	11,369
September	23	1,955,031	7,653,173	13,919	11,637
	24	1,868,715		13,034	11,123
	25	1,872,805		13,074	11,148
	26	1,956,622		13,939	11,647
<b>Total</b>		<b>47,674,771</b>			

These energy consumption numbers were supplied by AEP for simulation purposes. The six-month planning period spanned three seasons, Spring (April and May), Summer (June, July, and August) and Fall (September). The weekly energy consumption was input to a seasonal load model, MODEL, to generate the detailed hourly customer demand numbers. The weekly energy consumption was used as the independent variable of a seasonal customer demand correlation that determined the customer demand function for a week of a particular energy consumption and season. The load model is discussed in Appendix A and the detailed weekly customer demand functions generated from the energy forecasted are presented in Appendix A.4.3. The weekly peak demand of each week and the average power level inferred from the energy consumption are also tabulated in Table 5.3. The calculated peaks were obtained from MODEL; see Appendix A for details.

In the six-month period prior to refueling, a reactor with insufficient energy to run at full power until scheduled refueling can be considered a candidate for short-range resource-limited optimization. The second reactor, Nuclear Unit 2, coming on-line with a fully fueled core had an abundant supply of energy and an undetermined forced outage rate and would be undergoing a planned start-up program, so that the reactor's operation was

determinate over the short range. Only reactors with limited resource and a fairly certain availability (\*) over the short-range time horizon are amenable to short-range system analysis using PROCOST. Availability, at best, can only be fairly certain over a short-range time horizon.

The objective of the first system optimization (Case 1) was then to find the optimal distribution of weekly nuclear capacity factor of Nuclear Unit 1, whose overall thermal energy availability is 70% of rated capacity for the six months planning period prior to refueling. The second power reactor was operated at programmed steps in power levels.

Although the system contained two reactors, the first system simulation (Case 1) was a single-reactor optimization. The second system simulation (Case 2) was a complex two-reactor optimization. Case 2 used exactly the same system configuration as in Case 1, except for additional constraints on Nuclear Unit 2, which was limited to 80% of the energy used in the corresponding periods of Case 1, see Table 5.4. Nuclear Unit 2 was limited to 16% capacity factor on energy and 20% of power for April, 32% capacity factor on energy and 40% of power for May, 48% capacity factor on energy and 60% of power for June, 64%

-----

(\*) The deterministic approach (used in the PROCOST program) assumes the availability of the reactor is known with certainty. Hence, this assumption imposes certain restrictions on the use of this short-range optimization technique. This restriction can possibly be eliminated by the utilization of the Booth-Balerieux probabilistic technique, Ref. (16), for modelling forced outages in PROCOST.



TABLE 5.4

OPERATIONAL CONSTRAINTS ON NUCLEAR UNIT 2  
DURING THE TWO-REACTOR OPTIMIZATION, CASE 2

<u>Time Period</u>		<u>Limitation</u>	
<u>Weeks</u>	<u>Months</u>	<u>Energy</u> <u>(% Rated)</u>	<u>Power</u> <u>(% Rated)</u>
1-4	April	16	20
5-9	May	32	40
10-13	June	48	60
14-18	July	64	80
19-26	Aug.-Sept.	80	100

capacity factor on energy and 80% of power for July, and 80% capacity factor and 100% of power for August and September. The goal of Case 2 was find the optimal weekly nuclear capacity factor distribution of both nuclear reactors. Case 2 was admittedly a contrived case to illustrate: (1) a multi reactor optimization, and (2) the feasibility of the procedures to handle a complex and involved situation. Case 2 is not an ordinary straight-forward two-reactor optimization. Nuclear Unit 2 had five smaller separate planning periods, requiring a separate optimization in each period. Nuclear Unit 2 was analogous to a collection of five reactors, with each reactor operating for only one period and shut down for the other periods.

Case 3 is a single reactor optimization similar to Case 1. The only difference between Case 1 and 3 is that the monthly fossil configurations were adjusted in Case 3 to levelize the minimum monthly system reserves over the six-month planning horizon. The adjusted fossil monthly maintenance and forced outage schedule for Case 3 is tabulated in Table 5.5. All other system parameters of Case 3 are identical to Case 1.

This completes the description of the system environment and the three optimization problems. A complete listing of all the parameters used in Case 3 is tabulated in Appendix C.7. The solving of the optimization problem required a very fast method to calculate OCNP values. The next section describes the load model sensitivity studies



Table 5.5 (CONT'D)

Month:	MAINTENANCE SCHEDULE												ASSUMED FORCED OUTAGE SCHEDULE											
	J	F	M	A	M	J	J	A	S	O	N	D	J	F	M	A	M	J	J	A	S	O	N	D
<u>FOSSIL</u>																								
31	x																			x	x			
32				x																		x		
33	x	x	x	x	x	x	x	x	x	x														
34											x											x	x	
35									x														x	x
36											x										x			
37			x																					x
38							x										x	x						
39											x												x	
40					x									x	x									
41										x													x	x

Note: An "x" represents a simulated outage for the entire month. The total time of scheduled outage for each plant corresponds to the actual observed outage rate for similar sized units.

undertaken to meet this goal. The subsequent sections discuss the results and the conclusions of the three system optimization problems.

## 5.2 Load Model Sensitivity Study

The primary intent of this thesis study was to develop a calculational procedure to analyze short-range options of a nuclear utility system that is quick, efficient and accurate. The practical usefulness of such a survey program requires that execution to be low in cost. Developing such a program by necessity involves making some sacrifices in accuracy when analyzing a large complex problem. Hence a sensitivity study was undertaken to find the optimal cost-effective load models appropriate to use in the short-range optimization procedures. As discussed in Section 3.1.1, a detailed L.P. model to determine the optimal generation schedule for a large utility system would involve a problem with a million variables. This problem can be solved piecemeal by solving many smaller problems to lead to the solution of the original large problem.

OCNP is the concept used to relate smaller weekly optimization problems to the original optimal nuclear generation schedule problem. A detailed (hourly) weekly generation problem is an L.P. problem of 10,000 variables, which while manageable, is still too large a problem to solve 500 times to generate 500 OCNP values. The first phase of the optimal nuclear generation schedule problem is to find the optimal weekly nuclear capacity factor distribution, for which only the OCNP values of the weekly

optimization problem is required. Other information about the optimized solution such as system production cost, fossil incremental capacity factors, and the detailed generation scheduled are superfluous (at this stage of the optimization process).

Since only a single feature (OCNP) of the weekly optimization problem was deemed important (in the first phase), reproduction of that single feature in a much simpler calculational model was sought. For this purpose, load-duration load models were tested for their ability to reproduce OCNP values obtained from more detailed chronologic load models.

In parallel with this load-duration OCNP study, there were efforts to find a simpler chronologic load model to reduce computational costs where the chronologic demand pattern was important. The simple chronologic load model would retain the ability to reproduce the system production cost, OCNP, and fossil incremental capacity factors of a more detailed load model.

The simpler chronologic load model also provided a standard of comparison with which to judge the various load-duration load models.

The chronologic load model sensitivity study investigated a great many variations of the 168 hour weekly load model. The initial set of load models included 84 2-hour intervals, 54 3-hour intervals, and 42 4-hour intervals. Of the three, only the 84 2-hour interval load

model yielded satisfactory reproduction results. Further reduction of time intervals involved the use of non-uniform time intervals and combining the three average workdays together, aside from the peak workday and low workday. Thus, a modified chronologic 40-interval load model was developed, composed of a 10-interval peak workday, a 10-interval average workday, a 10-interval low workday, and a 10-interval weekend. This 40-interval modified chronologic model reproduced with sufficient accuracy the details of the 168-hour representation. Thus, it was chosen as the standard to judge the load-duration models. Further details of the chronologic sensitivity study are presented in Appendix A.5.

Preliminary work on the load-duration sensitivity studies showed that models of very few time intervals (between six to ten) were in surprisingly good agreement compared with the very detailed load-duration models in reproducing OCNP. The details of these preliminary studies are discussed in Appendix A.6.

Before choosing a six-interval load-duration load model for generating OCNP values (required for the three system optimization studies), a number of comparisons were made with more detailed load models. The study included the comparison of the weekly OCNP function of a typical summer week obtained from six load models: a 120-interval modified chronologic model (A), two 50-interval load-duration models (B and C), a 40-interval modified chronologic model (D), and

COMPARISON OF A TYPICAL SUMMER WEEKLY OCNF FUNCTION FROM SIX LOAD MODELS

<u>Model</u>	<u>Description</u>			<u>Weekly Nuclear Capacity Factor of Nuclear Unit 1</u>				
	<u>No. of Time Intervals</u>	<u>Nuclear Heat Rate</u>	<u>Type of Load Model</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	<u>0.95</u>
				<u>OCNF (Mills/KWh)</u>				
A	120	Variable	Hybrid	5.06	4.72	4.66	4.29	3.58
B	50	Constant	Load duration	5.06	4.77	4.66	4.29	3.58
C	50	Variable	Load duration	5.08	4.72	4.66	4.29	3.58
D	40	Variable	Hybrid	5.03	4.72	4.66	4.29	3.58
E	6	Constant	Load duration	5.03	4.72	4.66	4.29	3.58
F	6	Variable	Load duration	5.03	4.77	4.66	4.43	3.58

1  
110  
1



two six-interval load-duration models (E and F). The six models and their OCNP values are described in Table 5.6. The system environment for this comparison was the same as those conditions representing the first week in August of the first system simulation, Case 1, discussed in the previous section. The agreement in results of Model E compared with the more detailed models is very good. The difference in the weekly OCNP functions for Model E compared with the weekly OCNP function of Model A is by only one increment (at 0.55 nuclear capacity factor). Similarly, the deviation of Model E from the weekly OCNP function obtained from Model C is by only one increment at one nuclear capacity factor, and from Model B at a single increment each at two nuclear capacity factors. Model E agrees perfectly with the standard, Model D. The results of Model F (also listed in Table 5.6) are in poor agreement with the other models. Model F agrees at only two out of five points compared with Model A, and at only three out of five points compared with Model D, the standard of comparison. The fossil economic incremental loading order (derived from the August system configuration) used in this study is presented in Table 5.7.

The subtleties in calculating the correct OCNP value are illustrated from observing the differences between Model E, with a constant heat-rate and Model F, with a variable heat-rate. One model yields very accurate answers and the other contradictory values even though both models have the same number of time intervals. Since a variable nuclear

TABLE 5.7

AUGUST ECONOMIC FOSSIL LOADING ORDER

<u>Increment</u>	<u>Increment Size (MW)</u>	<u>Cumulative Increment Size (MW)</u>	<u>Increment Generation Cost (Mills/KWe)</u>	<u>Cumulative Generation Cost (\$/Hr)</u>
1	105	105	2.85	299
2	105	210	3.00	614
3	105	315	3.20	950
4	320	635	3.40	2,038
5	320	955	3.58	3,184
6	320	1,275	3.82	4,405
7	120	1,395	4.07	4,894
8	21	1,416	4.16	4,981
9	22	1,438	4.16	5,073
10	120	1,558	4.29	5,587
11	116	1,674	4.43	6,101
12	21	1,695	4.46	6,195
13	22	1,717	4.46	6,293
14	80	1,797	4.53	6,655
15	120	1,917	4.57	7,204
16	60	1,977	4.63	7,481
17	116	2,093	4.66	8,022
18	135	2,228	4.66	8,652
19	135	2,363	4.66	9,281
20	42	2,405	4.72	9,479
21	42	2,447	4.72	9,678
22	80	2,527	4.77	10,059
23	43	2,570	4.87	10,268
24	43	2,613	4.87	10,478
25	60	2,673	4.96	10,775
26	116	2,789	4.97	11,352
27	135	2,924	5.00	12,027
28	127	3,051	5.03	12,667
29	127	3,178	5.03	13,306
30	42	3,220	5.06	13,518
31	80	3,300	5.08	13,925
32	20	3,320	5.15	14,028
33	43	3,363	5.22	14,253
34	21	3,384	5.25	14,363
35	22	3,406	5.25	14,479
36	127	3,534	5.39	15,164
37	20	3,554	5.52	15,275
38	60	3,614	5.84	15,625
39	520	4,134	6.09	18,789
40	520	4,654	6.40	22,120
41	20	4,674	6.50	22,250
42	144	4,818	6.79	23,227
43	144	4,962	6.79	24,205
44	520	5,482	6.83	27,757
45	144	5,626	7.28	28,805
46	90	5,716	7.65	29,494
47	90	5,806	7.74	30,191
48	90	5,896	8.05	30,916

TABLE 5.7 (CONT'D)

<u>Increment</u>	<u>Increment Size (MW)</u>	<u>Cumulative Increment Size (MW)</u>	<u>Increment Generation Cost (Mills/KWe)</u>	<u>Cumulative Generation Cost (\$/Hr)</u>
49	90	5,986	8.30	31,663
50	48	6,034	8.49	32,070
51	48	6,082	8.49	32,478
52	90	6,172	8.59	33,251
53	160	6,332	8.83	34,664
54	160	6,492	8.86	36,081
55	48	6,540	9.10	36,518
56	56	6,596	9.11	37,028
57	56	6,652	9.11	37,538
58	160	6,812	9.30	39,026
59	160	6,972	9.32	40,518
60	260	7,232	9.40	42,961
61	56	7,288	9.77	43,508
62	90	7,378	9.77	44,387
63	260	7,638	9.89	46,958
64	160	7,798	9.91	48,544
65	160	7,958	9.94	50,136
66	260	8,218	10.55	52,878
67	29	8,247	14.45	53,297
68	29	8,276	15.49	53,746
69	29	8,305	18.22	54,274
70	1,500	9,805	25.00	91,774

heat-rate is the more realistic representation, it seems peculiar that the constant nuclear heat-rate model, E, gives more accurate results than the variable nuclear heat-rate model, F. The explanation lies in fact that a detailed representation of the nuclear heat-rate is incompatible in a coarse load model representation. In a six-interval model, each time interval represents about 20-40 hours. The nature of the L.P. model is such that the power level of each unit is constant for the duration of each time interval. This distortion effect is serious when the six-interval model schedules a reactor to generate power at a partial power level for only two time intervals, which in reality may represent 20-60 hours. In comparison, the detailed models would have scheduled the same reactor (under the same conditions) to a partial power level for only 10-30 hours. (The exact number depending on the customer demand function and the other system parameters.)

The principal reason for the smaller number of hours (in the detailed model) is that a variable nuclear heat-rate representation places a premium on operating at the most efficient power level as much as possible. Thus, a detailed model would schedule a reactor to operate at full rated power most of the time and operate at partial power as little as possible, i.e., about 20 hours a week. A six-interval model is handicapped in that each of its time interval represents 20-40 hours so that if it scheduled a reactor to be at a partial power level for only two time

intervals, that may represent as much as 60 hours. The overall effect of the differences in hours at partial power is that the overall average effective nuclear heat-rate is lower for the detailed load model than the six-interval model. This implies more nuclear electricity generated (from the same amount of thermal nuclear energy) for the detailed model than the six interval model, and in turn, a lower OCNP value. Therefore, the differences in OCNP values of a six interval model, with variable nuclear heat-rate (compared to a detailed load model) are inherent.

This difference in nuclear electricity also explains why using a constant nuclear heat-rate is necessary in a six-interval model. The nuclear heat-rate value in the constant heat-rate model equaled the 100% rated power value. A six-interval model that utilizes the same amount of nuclear electricity (that a detailed model would), is more likely to calculate the same OCNP value. This argument is illustrated by examining the optimal nuclear and fossil generation schedules calculated from three load models (F, D, E as described in Table 5.6) for the same sample problem, presented in Table 5.8.

Table 5.8 deals with a typical summer week, with Nuclear Unit 1 limited to 75% average capacity factor. The solution for Model F, Table 5.8a, shows that there are two time intervals equivalent to 60 hours when Nuclear Unit 1 is at partial power. By contrast, the solution for Model D, Table 5.8b, shows that its Nuclear Unit 1 is at partial

TABLE 5.8

NUCLEAR-FOSSIL GENERATION SCHEDULE OF  
THREE LOAD MODELS FOR A TYPICAL SUMMER WEEK  
AT 0.75 NUCLEAR CAPACITY FACTOR

Table 5.8a

Six Interval Load Duration  
with Variable Heat Rate

<u>Interval</u>	<u>Duration (Hr)</u>	<u>Fossil</u>	<u>Nuclear Unit 1</u>
1	50	5,086	1,100
2	24	4,202	1,100
3	19	3,055	1,100
4	24	2,363	815
5	36	1,937	395
6	15	1,375	0

Table 5.8c

Six Interval Load Duration with  
Constant Nuclear Heat Rate

<u>Interval</u>	<u>Duration (Hr)</u>	<u>Fossil</u>	<u>Nuclear Unit 1</u>
1	50	5,086	1,100
2	24	4,202	1,100
3	19	3,055	1,100
4	24	2,078	1,100
5	36	2,057	275
6	15	1,373	0

Table 5.8b

40-Interval Modified Chronologic  
with Variable Heat Rate

Only intervals when Nuclear Unit 1  
is at partial power are listed

<u>Interval</u>	<u>Duration (Hr)</u>	<u>Fossil</u>	<u>Nuclear Unit 1</u>
1	2	2,093	866
2	4	1,717	562
11	6	2,074	770
13	6	2,248	935
21	2	1,717	704
23	2	2,037	770
31	2	1,725	770
39	10	2,093	882
40	3	2,093	1,085

power for nine intervals for an equivalent of 37 hours. The solution of Model E, Table 5.8c, shows its Nuclear Unit 1 is scheduled for only one time interval at partial power for an equivalent of 36 hours, almost the same as Model D. Therefore, it is not surprising that Model E will yield a more consistent set of OCNP values than Model F.

A further verification for using Model E (for generating OCNP values) is the results of a study comparing the weekly OCNP functions of Model E with Model D under different system operating conditions. The four system operating conditions, taken from the first system optimization problem, included: (1) a typical spring week, the third week of April, (2) a typical summer week, the first week of August, (3) the peak summer week, the second week of August and (4) a typical fall week, the fourth week of September. The weekly OCNP functions are tabulated in Table 5.9.

The forty intervals in Model D were obtained from a reduction of the 120 interval modified chronologic load model (\*). This reduction is further explained in Appendix A. The six intervals in Model E were obtained from a

---

(\*) The 120-interval model was a simplification of the 168-hour representation where the three sets of hours representing the three average weekdays of the week have been combined into one set of intervals.

TABLE 5.9

COMPARISON OF WEEKLY OCNP FUNCTIONS  
BETWEEN A SIX INTERVAL LOAD DURATION (E)  
MODEL AND A 40 INTERVAL HYBRID MODEL (D)

<u>System Environment</u>	<u>Model</u>	<u>Weekly Nuclear Capacity Factor</u>				
		<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	<u>0.95</u>
Typical spring	D	8.30	6.40	6.09	5.25	5.00
	E	7.74	6.40	6.09	5.25	5.03
Typical summer	D	5.03	4.72	4.66	4.29	3.58
	E	5.03	4.72	4.66	4.43	3.58
Peak summer	D	6.09	5.03	4.77	4.66	4.29
	E	6.09	5.03	4.87	4.66	4.07
Typical fall	D	7.28	6.40	6.40	6.09	5.06
	E	7.28	6.40	6.40	6.09	5.25



reduction of the same forty intervals used in Model D (\*\*). A comparison of the 20 OCNP values from each load model (of Table 5.9) shows differences in only six OCNP values. Of the six OCNP off-values, four out of six show differences by only one fossil increment level. Hence, only two OCNP values (from Model E) out of twenty values deviate more than one fossil increment from the the reference values (from Model D). Three of the OCNP off-values, including the two severely off-values are located at the 0.95 nuclear capacity factor where there is inherent difficulty for a six interval model to reproduce OCNP values accurately. Excluding the 0.95 nuclear capacity factor region, the agreement between the Model D and Model E is almost perfect except for three points where the difference at each point is off by only one fossil increment.

The inherent difficulty at 0.95 nuclear capacity factor (and any nuclear capacity factor near unity) lies in the fact that a few-interval load-duration model does its poorest task of approximation at the extremities of the load-duration curve. The lower end of the load-duration curve is where the OCNP of 1.0 weekly nuclear capacity factor is determined. Hence, all OCNP values for weekly

---

(\*\*) Notice that the typical summer weekly OCNP function of the model of Table 5.9 is slightly different from the model of Table 5.6. The reason is that the six-interval model of Table 5.6 was obtained from a direct reduction of the 120-interval model whereas the six-interval model of Table 5.9 was obtained from a reduction of the forty-interval load model. Hence the two six-interval models were slightly different.

nuclear capacity factor near unity, obtained from a few-interval load-duration model, are of low-accuracy. This is not a serious drawback for the few-interval load-duration model since, in the resource-limited situation, the region of interest is far below unity. Only in the non-resource-limited situation is the region of interest near unity. In such a case, the optimization procedures discussed here would not be applicable.

There is an inherent reason why four out of six OCNP off-values are positive deviations. In a variable nuclear heat-rate model, there is a bias toward scheduling nuclear generation at high (more efficient) power levels over low power levels (\*). This bias effectively lowers the calculated OCNP value, because OCNP is calculated only from those intervals for which the nuclear unit is partially loaded. The average partial loading (of the nuclear power level) is higher in the many-interval model with variable heat-rate, and in turn, the critical fossil incremental power level(\*\*) is lower, and hence OCNP is lower.

This effect is amply illustrated by re-examining Table 5.8b and Table 5.8c, an optimal solution from Model D, with variable heat-rate compared with Model E, with constant

-----

- (\*) For reasons of economy, the variable nuclear heat-rate model tends to shut down generation during some intervals which otherwise would be lightly loaded, to raise the power levels of other partially loaded intervals to more efficient operating power levels.
- (\*\*) Critical fossil incremental power level is the power level used to determine the OCNP value. Refer to Section 3.1.1 for the determination of the OCNP value.

heat-rate. Model E had a partial nuclear power setting at 275 MWe and Model D had an average nuclear partial power setting of 832 MWe. Similarly, the critical fossil incremental power level for Model E was 2057 MWe; while for Model D, the (weighted average) critical incremental power level was 2031 MWe. It is expected for two models with the same average nuclear heat-rate that the critical fossil incremental power level will be lower for a variable heat-rate model than for a constant heat-rate model. Therefore, most OCNP deviations of Model E compared with Model D would be positive, which is confirmed by the experimental results.

It is possible to compensate for this effect by assuming a lower effective nuclear heat-rate for the constant nuclear heat-rate model than used in a detailed load model simulation. This is the justification for using an average nuclear heat-rate value equivalent to 100% rated capacity in the six-interval model for system optimization studies.

In conclusion, the satisfactory results of the six-interval load-duration model with constant nuclear heat-rate was used in obtaining the weekly OCNP functions for three system simulations. As mentioned earlier, further details on the load-duration sensitivity studies are supplied in Appendix A.6.

### 5.3 Single Reactor Optimization Study - Case\_1

The single reactor optimization study involved finding the optimal weekly nuclear capacity factor distribution over a 26-week time horizon for a 1100 MWe nuclear reactor in the system described in Section 5.1. First, the optimization procedure is to calculate a weekly OCNF function for each week in the time horizon using PROCOST. The 26 weekly OCNF functions are tabulated in Table 5.10 and plotted in Figure 5.1 by their respective months. The OCNF values have been calculated for values of weekly nuclear capacity factor between 0.55 and 0.95 at intervals of 0.10. The values for the weekly nuclear capacity factors were chosen arbitrarily. The density and spacing of data points is at the user's discretion. The criterion depends on which of the system conditions are being modeled. Secondly, the 26 weekly OCNF functions were fed to ALLOCAT to calculate the optimal weekly nuclear capacity factor distribution. The results are tabulated in Table 5.11. The weekly nuclear capacity factors were allowed to have a maximum value of 0.95, a minimum value of 0.55 and intermediate values at intervals of 0.10. Before discussing the optimization results further, some fundamental principles of OCNF must be stated first.

Examining Figure 5.1 or Table 5.10, these distinguishing characteristics of weekly OCNF functions are discernable: (1) The OCNF functions are monotonically decreasing functions with respect to an increasing nuclear capacity factor. (2) The weekly OCNF functions of different

TABLE 5.10

WEEKLY OCNP FUNCTIONS FROM THE SINGLE REACTOR OPTIMIZATION  
(CASE 1)

<u>Month</u>	<u>Week</u>	<u>Weekly Nuclear Capacity Factor</u>	<u>OCNP (Mills/KWHe)</u>				
			<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	<u>0.95</u>
April	1	8.86	6.83	6.79	6.09	5.03	
	2	9.10	7.74	6.83	6.09	5.08	
	3	8.49	6.79	6.09	5.25	5.03	
	4	6.40	5.39	5.03	4.97	4.66	
May	5	8.86	7.65	6.79	5.25	5.03	
	6	8.30	6.79	5.39	5.03	4.96	
	7	8.83	6.79	6.50	5.03	5.00	
	8	8.86	7.74	6.79	5.39	5.03	
	9	7.74	5.39	5.03	5.00	4.66	
June	10	6.40	5.39	5.03	4.71	4.56	
	11	6.40	6.09	5.06	4.98	4.63	
	12	6.09	5.08	5.00	4.66	4.52	
	13	6.09	5.03	4.96	4.66	4.28	
July	14	4.96	4.56	4.28	3.82	3.50	
	15	6.09	5.03	4.71	4.56	4.07	
	16	5.39	4.87	4.66	4.46	3.82	
	17	6.09	5.03	4.77	4.56	4.07	
	18	5.84	5.00	4.66	4.56	4.07	
August	19	5.03	4.71	4.66	4.28	3.58	
	20	6.09	5.03	4.87	4.66	4.07	
	21	5.39	5.00	4.66	4.56	3.82	
	22	5.39	5.03	4.71	4.56	3.82	
September	23	7.28	6.79	6.40	6.09	5.06	
	24	6.83	6.40	6.09	5.06	4.87	
	25	6.83	6.40	6.09	5.08	4.96	
	26	7.28	6.79	6.40	6.09	5.06	

Figure 5.1

WEEKLY OCNP FUNCTIONS FROM THE  
SINGLE REACTOR OPTIMIZATION STUDY, CASE 1








Figure 5.1 (CONT'D)



Note: Circled numbers refer to week numbers given in Table 5.10




TABLE 5.11

OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE SINGLE REACTOR OPTIMIZATION (CASE 1)

<u>Month</u>	<u>Week</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average Energy (10<sup>3</sup> MWH)</u>
April	1	0.85	157.08	609.84	152.46
	2	0.95	175.56		
	3	0.85	157.08		
	4	0.65	120.12		
May	5	0.85	157.08	711.48	142.29
	6	0.75	138.60		
	7	0.75	138.60		
	8	0.85	157.08		
	9	0.65	120.12		
June	10	0.65	120.12	480.48	120.12
	11	0.75	138.60		
	12	0.65	120.12		
	13	0.55	101.64		
July	14	0.55	101.64	508.20	101.64
	15	0.55	101.64		
	16	0.55	101.64		
	17	0.55	101.64		
	18	0.55	101.64		
August	19	0.55	101.64	406.56	101.64
	20	0.55	101.64		
	21	0.55	101.64		
	22	0.55	101.64		
September	23	0.95	175.56	646.80	161.70
	24	0.85	157.08		
	25	0.85	157.08		
	26	0.85	157.08		
<b>Total</b>			<b>3,363.36</b>		<b>129.36</b>



weeks (but the same monthly fossil configurations) never cross. (3) For weeks of increasing weekly energy consumption, the OCNP function likewise increases. (4) The larger the weekly energy consumption (with the same fossil configuration), the larger the slope of the OCNP function. (5) The weekly OCNP functions assumes a shape characteristic of their respective economic loading order. (6) The amplitude of the OCNP function varies inversely with the weekly system reserve. (7) The higher the average fossil fuel cost of the monthly system configuration, the higher the OCNP value.

The basis for the above characteristics of OCNP is the fact that the particular OCNP values are obtained indirectly from the economic loading order. It is the interactions of the system reserve and the demand function that determines the exact location on the economic loading order that an OCNP is read off. To clarify the latter two points (6 and 7), reference may be made to Table 5.12, a tabulation of the average fossil fuel cost of all the fossil components of the monthly system configurations, and Table 5.13, a tabulation of the system's weekly reserve.

The results of Case 1, the optimized weekly nuclear capacity factor distribution tabulated in Table 5.1 reflects many of the OCNP principles stated above. The overall nuclear capacity factor for the six-month planning period was 70%. The high weekly nuclear capacity factor for September reflects the unusually high fossil fuel cost for

TABLE 5.12

MONTHLY AVERAGE FOSSIL FUEL COSTS OF  
THE FOSSIL CONFIGURATION  
FOR CASES 1 AND 2

<u>Month</u>	<u>Fuel Costs</u> <u>Mills/KWH</u>
April	6.84
May	7.10
June	6.63
July	6.80
August	6.88
September	7.49

TABLE 5.13

WEEKLY SYSTEM RESERVE  
FOR CASES 1 AND 2

Month	April				May				
	1	2	3	4	5	6	7	8	9
Week									
Total gross generating capacity, MW	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750
Fossil maintenance outage, MW	2,505	2,505	2,505	2,505	2,690	2,690	2,690	3,690	2,690
Nuclear scheduled outage,* MW	880	880	880	880	660	660	660	660	660
Fossil forced outage, MW	2,420	2,420	2,420	2,420	2,570	2,570	2,570	2,570	2,570
Net generating capacity, MW	13,945	13,945	13,945	13,945	13,830	13,830	13,830	13,830	13,830
Weekly peak load, MW	13,577	13,795	13,207	12,472	13,149	12,747	12,937	13,206	12,517
Net reserve, MW	368	150	738	1,473	681	1,083	893	624	1,313
Month	June				July				
Week	10	11	12	13	14	15	16	17	18
Total gross generating capacity, MW	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750
Fossil maintenance outage, MW	1,340	1,340	1,340	1,340	895	895	895	895	895
Nuclear scheduled outage,* MW	440	440	440	440	220	220	220	220	220
Fossil forced outage, MW	2,555	2,555	2,555	2,555	2,045	2,045	2,045	2,045	2,045
Net generating capacity, MW	15,415	15,415	15,415	15,415	16,600	16,600	16,600	16,600	16,600
Weekly peak load, MW	13,951	14,227	13,793	13,456	12,954	14,143	13,869	14,226	14,079
Net reserve, MW	1,464	1,188	1,632	1,959	3,646	2,457	2,731	2,374	2,521
Month	August				September				
Week	19	20	21	22	23	24	25	26	
Total gross generating capacity, MW	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	
Fossil maintenance outage, MW	750	750	750	750	2,225	2,225	2,225	2,225	
Nuclear maintenance outage,* MW	0	0	0	0	0	0	0	0	
Fossil forced outage, MW	2,065	2,065	2,065	2,065	2,015	2,015	2,015	2,015	
Net generating capacity, MW	16,915	16,915	16,915	16,915	15,510	15,510	15,510	15,510	
Weekly peak load, MW	13,911	14,650	14,299	14,393	13,919	13,034	13,076	13,936	
Net reserve, MW	3,054	2,315	2,666	2,572	1,591	2,476	2,434	1,574	

\*Program startup limitation for Nuclear Unit 2.

- 157 -

that month. All the other months have about the same fossil fuel cost, as shown in Table 5.12. September, due to its significantly more expensive fossil fuel cost configuration is scheduled to generate at near full capacity, to displace as much of the expensive fossil fuel as possible. August and July have the lowest average weekly nuclear capacity factor, in fact, the lowest allowed, because of their large reserve capacity, Table 5.13. April has the lowest system reserve, hence the second largest set of weekly nuclear capacity factors. May is the second tightest month system reserve-wise, and also has the second highest fossil fuel configuration. May also has an above average monthly nuclear capacity factor. June has the lowest fossil fuel cost configuration and sufficient reserve such that its monthly nuclear capacity factor is below the average for the whole planning period. Within each monthly schedule, the weekly allotments of nuclear energy are proportional to the weekly energy consumption forecast, see Table 5.3. The low summer (June, July, and August) weekly nuclear capacity factors also reflect a seasonal influence. Demand peaks fluctuate a great deal more during the summer than during other seasons. Hence, the average capacity factor for the summer would be lower than during any other season with the same system reserve.

The overall impression from the results of this optimization study for the system simulated is that the maintenance scheduled was too unbalanced in excluding summer

maintenance. Gross generating capacity is large enough to handle the summer peaks while still scheduling more maintenance during August and July, and less during April and May. Also, a better mix of fossil plants should be scheduled for September to give a lower fossil fuel cost rate.

A total system cost calculation from the optimization results of Case 1 showed a very large dollar savings; see Table 5.14. Comparing the situation of no nuclear optimization, Case 1.A, (uniform hourly nuclear power generation for the entire six months), with the situation of constant weekly nuclear capacity factor, Case 1.B (optimized hourly generation), the saving was \$4.4 million in fossil fuel costs. By further optimizing the weekly nuclear capacity factor distribution over the six-month time horizon, Case 1.C, the saving increased by another \$340,000. For comparison, the total fossil fuel savings are equivalent to 66% of the nuclear fuel cost of Nuclear Unit 1, at 2.0 mills/KWH. The order of magnitude of the savings for Case 1 indicates that even for a single-reactor utility system, short-range optimization is worth-while in the resource-limited situations.

Table 5.14  
SYSTEM FOSSIL FUEL COSTS AND SAVINGS FOR CASE 1

Month	Week	Case 1.A	Case 1.B	Case 1.C
		No Nuclear Optimization (\$)	Hourly Optimization (\$)	Hourly and Weekly Optimization (\$)
April	1	10,897,641	10,703,601	10,524,562
	2	11,310,309	11,002,306	10,708,211
	3	10,401,792	10,220,996	10,056,930
	4	9,496,691	9,326,228	9,373,436
May	5	10,585,981	10,406,225	10,227,973
	6	10,078,719	9,886,612	9,830,631
	7	10,316,433	10,126,110	10,063,502
	8	10,660,648	10,482,397	10,300,385
	9	9,762,971	9,611,780	9,660,533
June	10	9,899,898	9,755,839	9,802,719
	11	10,210,651	10,063,304	10,013,456
	12	9,725,349	9,586,475	9,632,938
	13	9,369,029	9,242,724	9,387,855
July	14	8,847,012	8,746,190	8,873,310
	15	9,950,572	9,816,608	9,959,853
	16	9,670,594	9,555,670	9,692,954
	17	10,037,142	9,858,900	10,004,974
	18	9,883,377	9,753,496	9,894,948
August	19	9,623,066	9,517,456	9,652,246
	20	10,378,333	10,230,513	10,380,137
	21	10,002,896	9,877,511	10,016,482
	22	10,101,697	9,968,648	10,109,134
September	23	11,538,985	11,379,984	11,101,378
	24	10,879,069	10,716,938	10,559,049
	25	10,908,873	10,745,769	10,586,767
	26	11,551,409	11,390,192	11,216,616
Total		266,089,137	261,988,509	261,648,975
Comparison with Case 1.A		-	(4,100,628)	(4,440,162)

Case 1.A: Unit 1 is run at constant power (725 Mw), and Unit 2 is run at programmed power levels (Table 5.15) for all three cases.

Case 1.B: The weekly energy output of Unit 1 is the same as in Case 1.A, but the hourly power level within each week is optimized.

Case 1.C: Unit 1's power levels for each hour of each week are optimized for the entire six-month planning period.

Total energy output of Unit 1 is the same in all three cases.

TABLE 5.15

PROGRAMMED CONSTANT POWER LEVELS OF  
NUCLEAR UNIT 2 FOR CASES 1 AND 3

<u>Month</u>	<u>Power</u> <u>Level (MWe)</u>
April	220
May	440
June	660
July	880
August	1100
September	1100

#### 5.4 Multi-Reactor Optimization Study - Case\_2

In a multi-reactor resource-limited optimization, the optimal solution is approached iteratively. In the first iteration a weekly nuclear capacity factor distribution is assumed for all the reactors in the system except one, the first reactor to be optimized. The resulting weekly OCNF functions for that reactor (for the entire planning period) are input to ALLOCAT to calculate its optimal distribution. In the second iteration, the first reactor is assigned the capacity factor distribution obtained in the first iteration, and the second reactor is optimized (via ALLOCAT), with all the other reactors having the same weekly nuclear capacity factor distribution used in the first iteration. This process is repeated for each reactor in the system successively. The first cycle of optimization is complete when each reactor has been optimized once. A second cycle of optimization is initiated to improve on the first cycle since more complete information is then known about the operation of the system nuclear reactors. The cycles of optimization are repeated until there is a convergence of all the reactors' weekly capacity factors, or until improvement in system costs savings becomes insignificant. These optimization procedures are illustrated below.

The multi-reactor optimization problem considered in this thesis, Case 2, is an extension of the first simulation, with the added complication that Nuclear Unit 2 is also assumed to be limited in its production capacity.



The operating constraints of Unit 2 are given in Table 5.4. Nuclear Unit 1 has a 70% overall nuclear capacity factor for the same six month planning period. The remainder of the system is the same as Case 1, described in Section 5.1. The first step in finding the optimal weekly nuclear capacity factor distribution of both reactors was to calculate the weekly OCNP functions (using PROCOST). The weekly OCNP functions for Nuclear Unit 1 were calculated for weekly nuclear capacity factors from 0.55 to 0.95 at intervals of 0.10. The weekly OCNP function of Nuclear Unit 2 were calculated at four nuclear capacity factor values for April (8, 12, 16, 20%), four for May (16, 24, 32, 40%), five for June (36, 42, 48, 54, 60%), five for July (48, 56, 64, 72, 80%) and five for August and September (60, 70, 80, 90, 100%). The weekly OCNP functions for Case 2 are tabulated in Appendix B.3.

OCNP values are required for all the possible permutations of the weekly nuclear capacity factors of the two reactors to be pre-calculated because: (1) it is not known before hand which OCNP values are needed; (2) there is an economy of scale in computational efforts (and costs) in calculating all OCNP values at once, instead of by a piecemeal process. This procedure calculates many more OCNP than needed. However, OCNP calculations via six-interval load-duration models are fast enough that it is not a serious drawback. As experience (and insight) on the utility system responds is gained the system planner will be

able to specify a much narrower range in nuclear capacity factors (and hence need few OCNP data points calculated). This will greatly reduce computational costs by eliminating the calculation of most of the unnecessary OCNP values and will be especially desirable as the number of reactors increases.

In deciding which reactor (Unit 1 or 2) to optimize in the first iteration, Nuclear Unit 1 was noted to be relatively 'more' resource-limited, and that Unit 2 has strict limitations on shifting its energy from week to week. Thus, it seems that starting the optimization process with Unit 1 would lead to more rapid convergence. Hence, Nuclear Unit 1 was optimized in the first iteration where Nuclear Unit 2 is assumed to have a constant weekly nuclear capacity factor distribution. Table 5.16 tabulates the nuclear capacity factor distribution of each reactor at the end of each iteration. Under Column I of Table 5.16 are listed the results of the first multi-reactor iteration. The only difference in system conditions between the first iteration of the multi-reactor optimization and the the single reactor optimization problem is that Unit 2 has 20% less energy, across the entire 26 weeks. The difference in results comparing the solution of the first iteration (of the multi reactor case) with the solution of the single reactor optimization (Table 5.11) is a shift in energy from April and June to September. To a first approximation, all months should be equally affected. As stated earlier, the

TABLE 5.16  
OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE MULTIREACTOR SIMULATION  
(CASE 2)

Week	Month	Limitations on Unit 2 (% Power)	Iterations:	Weekly Nuclear Capacity Factor (%)					
				Unit 2			Unit 1		
				Initial	II	IV	Initial	I	III
1	April	20		16	20	20	70	85	85
2				16	16	16	70	95	95
3				16	16	16	70	85	75
4				16	12	12	70	55	65
5	May	40		32	32	32	70	85	85
6				32	32	32	70	75	75
7				32	32	32	70	75	75
8				32	32	32	70	85	85
9				32	32	32	70	65	65
10	June	60		48	48	48	70	65	65
11				48	54	54	70	65	65
12				48	48	48	70	55	55
13				48	42	42	70	55	55
14	July	80		64	48	48	70	55	55
15				64	72	72	70	55	55
16				64	64	64	70	55	55
17				64	72	72	70	55	55
18				64	64	64	70	55	55
19	August	100		80	70	70	70	55	55
20				80	80	80	70	55	55
21				80	80	80	70	55	55
22				80	70	70	70	55	55
23	September	100		80	90	90	70	95	95
24				80	80	80	70	95	95
25				80	80	80	70	95	95
26				80	90	90	70	95	95

reason for September's larger use of nuclear energy is its higher fossil fuel cost alternative. Hence, September has a relatively greater need for nuclear energy.

Nuclear Unit 2 has five separate planning periods in the six month planning horizon under consideration. In each of the smaller planning periods is associated a different operating capacity level and a different capacity factor objective. Hence, Unit 2 is be treated as if it is a collection of five separate reactors where only one reactor is on-line at a time.

In the second iteration, Unit 2 is optimized five times, in each of its separate planning periods. Nuclear Unit 1 is assumed to have the distribution calculated by the first iteration. The weekly DCNP functions of Unit 2 used in its optimization must be carefully matched to the proper weekly nuclear capacity factor of Nuclear Unit 1. The results of the second iteration are listed in Table 5.16 under Column II. The weekly distribution of Unit 2 (in each month) shows a correlation of nuclear capacity factors to the energy consumption pattern in each month.

For weeks of higher energy consumption, the weekly nuclear capacity factor is higher. The exception is May where most of correlation effect was already displayed in Unit 1's May weekly nuclear capacity factors. The step sizes in May's value of weekly nuclear capacity factors were large enough not to require any further changes in Unit 2's May weekly nuclear capacity factors. Optimizing each

reactor of the system once completes the first cycle of the optimization process. The second cycle starts (iteration III) with Unit 1 being optimized again, from the weekly nuclear capacity factor distribution for Unit 2 solved in iteration II. The results of iteration III compared with iteration I show that only the weekly nuclear capacity factors of April have been changed, indicating that absolute convergence is near. Iteration IV of Unit 2 shows identical results to iteration II indicating convergence has been reached. Technically, Unit 1 should be optimized again to compare iteration V with iteration III, to show Unit 1 also has reached convergence. But in a two-reactor system, this step is not necessary since iteration V is based on iteration IV, and iteration III is based on iteration II. It was shown that iteration II and IV are identical, hence, iteration III and V must also be identical. Thus only two complete cycles of iteration were necessary to find complete convergence in this multi reactor simulation.

The optimal nuclear energy distribution for Case 2 is given in Table 5.17. A detailed tabulation of the weekly system costs before and after optimization is given in Table 5.18A. A summary of changes in system cost with each iteration is given in Table 5.19. The complete two-reactor optimization, Case 2.C, results in a total savings of \$6.48 million compared with the situation of no nuclear optimization, Case 2.A. Of this, \$600,000 represents the improvement from the situation of optimal hourly generation,

TABLE 5.17

OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE TWO REACTOR OPTIMIZATION (CASE 2)

Month	Week	Unit 1				Unit 2			
		Capacity Factor	Weekly Energy (10 <sup>3</sup> MWH)	Monthly Total Energy (10 <sup>3</sup> MWH)	Monthly Average (10 <sup>3</sup> MWH)	Capacity Factor	Weekly Energy (10 <sup>3</sup> MWH)	Monthly Total Energy (10 <sup>3</sup> MWH)	Monthly Average (10 <sup>3</sup> MWH)
April	1	0.85	157.08	591.36	147.84	0.20	36.96	118.272	29.568
	2	0.95	175.56			0.16	29.568		
	3	0.75	138.60			0.16	29.568		
	4	0.65	120.12			0.12	22.176		
May	5	0.85	157.08	711.48	142.296	0.32	59.136	295.680	59.136
	6	0.75	138.60			0.32	59.136		
	7	0.75	138.60			0.32	59.136		
	8	0.85	157.08			0.32	59.136		
	9	0.65	120.12			0.32	59.136		
June	10	0.65	120.12	443.52	110.88	0.48	88.704	354.816	88.704
	11	0.65	120.12			0.54	99.792		
	12	0.55	101.64			0.48	88.704		
	13	0.55	101.64			0.42	77.616		
July	14	0.55	101.64	508.20	101.64	0.48	88.704	591.360	118.272
	15	0.55	101.64			0.72	133.056		
	16	0.55	101.64			0.64	118.272		
	17	0.55	101.64			0.72	133.056		
	18	0.55	101.64			0.64	118.272		

TABLE 5.17 (CONT'D)

<u>Month</u>	<u>Week</u>	<u>Unit 1</u>				<u>Unit 2</u>			
		<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average (10<sup>3</sup> MWH)</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average (10<sup>3</sup> MWH)</u>
August	19	0.55	101.64	406.56	101.64	0.70	129.36	554.40	138.60
	20	0.55	101.64			0.80	147.84		
	21	0.55	101.64			0.80	147.84		
	22	0.55	101.64			0.70	129.36		
September	23	0.95	175.56	702.24	175.56	0.90	166.32	628.32	157.08
	24	0.95	175.56			0.80	147.84		
	25	0.95	175.56			0.80	147.84		
	26	0.95	175.56			0.90	166.32		
<b>Total</b>			<b>3,363.36</b>		<b>129.36</b>		<b>2,542.848</b>		<b>97.80</b>

**TABLE 5.18A**

**SYSTEM FOSSIL FUEL COSTS AND SAVINGS  
FOR TWO-REACTOR OPTIMIZATION**

		<u>(CASE 2)</u>		
		Case*: <u>2. A</u>	<u>2. B</u>	<u>2. C</u>
<u>Month</u>	<u>Week</u>	<u>No Nuclear Optimization Cost (\$)</u>	<u>Hourly Optimization Cost (\$)</u>	<u>Hourly and Weekly Optimization Cost (\$)</u>
April	1	10,984,873	10,751,527	10,524,562
	2	11,436,858	11,052,846	10,749,480
	3	10,472,818	10,265,793	10,205,833
	4	9,561,435	9,364,134	9,453,621
May	5	10,735,700	10,507,216	10,310,620
	6	10,222,590	9,972,556	9,910,359
	7	10,462,552	10,220,627	10,155,671
	8	10,811,841	10,585,440	10,280,708
	9	9,902,855	9,691,986	9,745,326
June	10	10,086,561	9,868,042	9,917,193
	11	10,415,368	10,180,886	10,168,957
	12	9,905,807	9,696,814	9,852,382
	13	9,541,326	9,350,635	9,557,760
July	14	9,032,621	8,874,746	9,148,500
	15	10,176,826	9,959,049	10,029,367
	16	9,887,665	9,694,897	9,834,490
	17	10,265,846	10,042,109	10,114,799
	18	10,107,604	9,895,235	10,038,452
August	19	9,862,243	9,689,701	9,920,240
	20	10,648,551	10,411,466	10,562,431
	21	10,262,717	10,054,863	10,195,603
	22	10,364,649	10,147,153	10,390,699
September	23	11,871,600	11,615,127	11,204,110
	24	11,185,083	10,939,281	10,655,633
	25	11,217,640	10,968,761	10,684,321
	26	11,884,316	11,627,532	11,216,240
<b>Total</b>		271,307,945	265,428,422	264,827,357
<b>Relative Savings compared to Case A</b>		0	5,879,523	6,480,588

\*In Case A, Unit 1 is run at constant power of 725 Mw. Unit 2 is run at predetermined power level shown in Table 5.18B.

In Case B, the weekly energy output of both units is the same as in Case A, but the hourly power level within each week is optimized.

In Case C, power levels for each hour of each week are optimized within the constraints shown in Table 5.4. Total energy output from each reactor is the same in all cases.



TABLE 5.18B

PROGRAMMED CONSTANT POWER LEVELS OF NUCLEAR UNIT 2  
FOR CASE 2.A

<u>Month</u>	<u>Power Level (MW)</u>
April	167
May	330
June	497
July	667
August	853
September	853

TABLE 5.19

SUMMARY OF TWO-REACTOR OPTIMIZATION COST SAVINGS  
AS A FUNCTION OF NUMBER OF ITERATIONS

Case Iterations on Weekly Energy Allocations	<u>2.A</u>	<u>2.B</u>	<u>2.C</u>			
			<u>I</u>	<u>II</u>	<u>III</u>	<u>IV</u>
Total Cost, \$	271,307,945	265,428,422				264,827,357
Savings Relative to Case 2.B, \$	-5,879,523	0	555,334	593,897	601,065	601,065

Case 2.B, compared with the total optimization results, Case 2.C.

Table 5.19 indicates that most of the savings were realized after only one complete cycle of iterations in this two-reactor system. Other simulations have confirmed the hypothesis that the multi-reactor iteration process is a rapidly convergent one.

The major conclusions of this multi reactor simulation are that: (1) the short-range resource-limited optimization process described in this thesis has been shown adaptable to a two-reactor situation, (2) convergence takes only a few complete cycles of iterations, (3) most of the cost savings is realized after one or two complete cycles of iterations, (4) substantial savings in fossil fuel cost are possible with short-range optimization, and (5) potential cost savings increase as the amount of nuclear capacity and energy that are optimized are increased.

### 5.5 Single Reactor Optimization Study-Case 3

The purpose of Case 3 was to examine the effect of system reserves on OCNP, and on the optimal weekly nuclear capacity factor distribution. Case 3 is a modification of Case 1 where the fossil outage schedule (Table 5.1) has been adjusted to obtain a (nearly) constant minimum monthly system reserve, see Table 5.5. The original outage schedule (Table 5.1) was altered by moving the outage of as few units as possible within the six-month planning horizon. Most of the alteration occurred in the maintenance outage schedule. The few changes made in the forced outage schedule were aimed at achieving a better balance in the monthly forced outage total compared with the monthly net generating capacity.

The 26-week OCNP values for Case 3 are listed in Table 5.20. The weekly system reserves are listed in Table 5.21. The average fossil generation costs of the monthly fossil configurations are listed in Table 5.22. The optimal weekly nuclear capacity factor distribution is listed in Table 5.23.

A comparison of the optimal nuclear capacity factor distribution for Case 1 and Case 3 (Tables 5.11 and 5.23) shows a decrease of allocated energy for April and May, and an increase for July, August, and September. The June allotment is the same for both cases. The change in monthly allocation of nuclear energy is consistent with the change in the monthly minimum system reserve, both in direction and

TABLE 5.20

WEEKLY OCNP FUNCTIONS FROM THE SINGLE REACTOR OPTIMIZATION  
(Case 3)

<u>Month</u>	<u>Week</u>	<u>Weekly Nuclear Capacity Factors:</u>	<u>OCNP (Mills/KWhe)</u>				
			<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	<u>0.95</u>
April	1		6.40	6.09	5.83	5.03	4.96
	2		6.79	6.40	6.09	5.08	5.00
	3		6.40	5.83	5.03	5.00	4.66
	4		5.39	5.00	4.77	4.66	4.46
May	5		6.79	6.09	5.25	5.03	4.87
	6		6.09	5.06	5.03	4.87	4.66
	7		6.40	5.39	5.03	4.97	4.66
	8		6.79	6.09	5.39	5.03	4.87
	9		6.09	5.03	4.97	4.66	4.63
June	10		6.09	5.39	5.03	4.96	4.63
	11		6.40	6.09	5.08	5.00	4.66
	12		6.09	5.08	5.03	4.72	4.57
	13		6.09	5.03	4.97	4.66	4.53
July	14		5.00	4.66	4.57	4.16	3.58
	15		6.09	5.08	5.00	4.66	4.29
	16		6.09	5.03	4.87	4.63	4.16
	17		6.40	5.08	5.00	4.66	4.29
	18		6.09	5.03	4.96	4.66	4.29
August	19		5.39	5.00	4.77	4.57	3.82
	20		6.79	5.39	5.03	4.77	4.46
	21		6.09	5.03	4.97	4.66	4.29
	22		6.40	5.08	5.00	4.66	4.43
September	23		7.28	6.79	6.40	6.09	5.25
	24		6.83	6.40	6.09	5.25	4.97
	25		6.83	6.40	6.09	5.39	5.00
	26		7.28	6.79	6.40	6.09	5.25

TABLE 5.21

WEEKLY SYSTEM RESERVE FOR CASE 3

Month	April				May					
	Week	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>
Total gross generating capacity, Mw		19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750
Fossil maintenance outage, Mw		1,705	1,705	1,705	1,705	2,465	2,465	2,465	2,465	2,465
Nuclear scheduled outage,* Mw		880	880	880	880	660	660	660	660	660
Fossil forced outage, Mw		1,920	1,920	1,920	1,920	2,070	2,070	2,070	2,070	2,070
Net generating capacity, Mw		15,245	15,245	15,245	15,245	14,555	14,555	14,555	14,555	14,555
Weekly peak load, Mw		13,577	13,795	13,207	12,472	13,149	12,747	12,937	13,206	12,517
Net reserve, Mw		1,668	1,450	2,038	2,773	1,406	1,708	1,618	1,349	2,038
Month		June				July				
Week		<u>10</u>	<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>
Total gross generating capacity, Mw		19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750
Fossil maintenance outage, Mw		1,130	1,130	1,130	1,130	1,415	1,415	1,415	1,415	1,415
Nuclear scheduled outage,* Mw		440	440	440	440	220	220	220	220	220
Fossil forced outage, Mw		2,555	2,555	2,555	2,555	2,545	2,545	2,545	2,545	2,545
Net generating capacity, Mw		15,625	15,625	15,625	15,625	15,580	15,580	15,580	15,580	15,580
Weekly peak load, Mw		13,951	14,227	13,793	13,456	12,954	14,143	13,869	14,226	14,079
Net reserve, Mw		1,674	1,398	1,842	2,169	2,626	1,437	1,711	1,354	1,501
Month		August				September				
Week		<u>19</u>	<u>20</u>	<u>21</u>	<u>22</u>	<u>23</u>	<u>24</u>	<u>25</u>	<u>26</u>	
Total gross generating capacity, Mw		19,750	19,750	19,750	19,750	19,750	19,750	19,750	19,750	
Fossil maintenance outage, Mw		1,240	1,240	1,240	1,240	2,500	2,500	2,500	2,500	
Nuclear maintenance outage,* Mw		0	0	0	0	0	0	0	0	
Fossil forced outage, Mw		2,565	2,565	2,565	2,565	2,015	2,015	2,015	2,015	
Net generating capacity, Mw		15,925	15,925	15,925	19,925	15,285	15,285	15,285	15,285	
Weekly peak load, Mw		13,911	14,650	14,299	14,393	13,919	13,034	13,076	13,936	
Net reserve, Mw		2,064	1,325	1,676	1,582	1,366	2,251	2,209	1,349	

\*Program startup limitation for Nuclear Unit 2.

- 186 -

TABLE 5.22

MONTHLY AVERAGE FOSSIL GENERATION COSTS OF  
THE FOSSIL CONFIGURATION FOR CASE 3

<u>Month</u>	<u>Generation Costs</u> <u>(Mills/KWH)</u>
April	6.84
May	6.85
June	6.39
July	6.90
August	7.04
September	7.54

**TABLE 5.23**

**OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION  
FOR THE SINGLE REACTOR OPTIMIZATION (CASE 3)**

<u>Month</u>	<u>Week</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average Energy (10<sup>3</sup> MWH)</u>
April	1	0.85	157.08	554.40	138.60
	2	0.85	157.08		
	3	0.75	138.60		
	4	0.55	101.64		
May	5	0.85	157.08	674.52	134.90
	6	0.75	138.60		
	7	0.75	138.60		
	8	0.75	138.60		
	9	0.55	101.64		
June	10	0.65	120.12	480.48	120.12
	11	0.75	138.60		
	12	0.65	120.12		
	13	0.55	101.64		
July	14	0.55	101.64	545.16	109.03
	15	0.65	120.12		
	16	0.55	101.64		
	17	0.65	120.12		
	18	0.55	101.64		
August	19	0.55	101.64	443.51	110.88
	20	0.65	120.12		
	21	0.55	101.64		
	22	0.65	120.12		
September	23	0.95	175.56	665.28	166.32
	24	0.85	157.08		
	25	0.85	157.08		
	26	0.95	175.56		
<b>Total</b>			<b>3,363.36</b>		<b>129.36</b>



magnitude. April and May had large increases in reserves, hence significant decreases in nuclear energy allotments. July and August had large decreases in system reserve, hence significant increases in nuclear energy allotments. June had the smallest monthly change in system reserves (210 MW), not enough to change its nuclear energy allocation. September had a slight decrease in system reserves (225 MW), hence a slight increase the nuclear energy allotment. The comparison of the solution of Case 1 with Case 3 shows conclusively the significant effect an unequal system reserve has on the optimal distribution of nuclear energy.

Table 5.24 shows the cost savings in Case 3 made possible by successively optimizing the hourly use of nuclear energy while holding weekly allocation fixed (Case 3.B) and then optimizing both hourly and weekly use of nuclear energy (Case 3.C). Hourly optimization saves \$4.4 million and both hourly and weekly save \$4.7 million, about 70% of Nuclear Unit 1's fuel cycle cost at 2.0 mills/KWhe.

Comparison of Table 5.24 for Case 3 with Table 5.14 for Case 1 show that the total system fossil fuel costs for the changed maintenance and forced-outage schedule of Case 3 was a little more than \$2 million lower than Case 1. Comparing Cases B to Cases C, hourly optimization to weekly optimization, the savings are \$160,000 for Case 3 and \$340,000 for Case 1. It is to be expected that as the system reserves becomes equalized, the optimal distribution of capacity factors becomes narrower and hence the

**TABLE 5.24**  
**SYSTEM FOSSIL FUEL COSTS AND SAVINGS**  
**FOR CASE 3**

<u>Month</u>	<u>Week</u>	<u>Case 3.A</u>	<u>Case 3.B</u>	<u>Case 3.C</u>
April	1	10,629,018	10,452,025	10,309,019
	2	10,886,122	10,707,502	10,557,379
	3	10,204,452	10,039,148	9,993,321
	4	9,421,808	9,303,841	9,435,075
May	5	10,084,300	9,898,125	9,762,328
	6	9,624,926	9,454,683	9,411,099
	7	9,839,201	9,659,938	9,614,924
	8	10,151,039	9,964,469	9,915,509
	9	9,377,179	9,212,606	9,347,943
June	10	9,632,264	9,466,427	9,613,347
	11	9,963,262	9,781,430	9,734,177
	12	9,451,599	9,295,217	9,338,910
	13	9,081,760	8,945,116	9,079,552
July	14	8,848,790	8,715,163	9,837,240
	15	10,131,453	9,943,949	9,987,474
	16	9,811,395	9,632,603	9,766,925
	17	10,229,689	10,039,813	9,996,213
	18	10,055,654	9,870,064	10,009,600
August	19	11,455,317	9,641,892	9,773,228
	20	10,770,796	10,491,448	10,535,539
	21	10,803,244	10,075,964	10,216,792
	22	11,468,438	10,185,716	10,229,252
September	23	10,011,848	11,468,807	11,199,903
	24	10,884,673	10,795,505	10,640,491
	25	10,461,200	10,825,555	10,669,462
	26	10,572,132	11,481,658	11,212,542
<b>Total</b>				
<b>System Costs (\$)</b>		263,857,559	259,348,663	259,187,244
<b>Comparison with Case 3.A</b>		-	(4,508,896)	(4,670,315)

**Case 3.A:** Unit 1 is run at constant power (725 Mw), and Unit 2 is run at programmed power levels (Table 5.15) for all three cases.

**Case 3.B:** The weekly energy output of Unit 1 is the same as in Case 3.A, but the hourly power level within each week is optimized.

**Case 3.C:** Unit 1's power levels for each hour of each week are optimized for the entire six-month planning period.

Total energy output of Unit 1 is the same in all three cases.

difference in savings between hourly optimization and weekly optimization diminishes. As mentioned earlier, the low capacity factor of the summer months is partially due to a seasonal influence on the shape of their customer demand function. Both spring and summer have about the same average weekly energy consumption. However summer has much higher demand peaks than the spring, hence summer also has lower demand minimums than spring. Since the lower part of the load-duration curve plays an active role in determining OCNP, it is no surprise that summer months should have lower average nuclear capacity factors (with all other parameters equal).

A major determining system parameter for OCNP is the economic loading order. The economic loading order is made up of several system parameters such as fuel cost, maintenance schedule, heat-rate, etc. The slope of the OCNP curve is a reflection of the slope of the economic loading order from which OCNP is derived. A utility in the short-range has very few system parameters to manipulate. The customer demand is beyond real short term control. A large portion of fuel costs may be fixed by long-term contracts. Heat-rates are built into the physical equipment. The maintenance schedule is the only tool left which the system planner can use to manipulate system reserves and the economic loading order, and in turn OCNP. Because of changing economic conditions, fossil fuel costs show a great amount of variance from station to station.

Hence, the monthly economic loading order will show different patterns for different maintenance schedules. The main conclusion from the system simulations performed is that equal consideration must be given to fossil fuel arrangements as to system reserves when determining the monthly maintenance schedule.

## 5.6 Applicability

The optimization procedure used in the previous system simulations (Cases 1, 2, 3) has been to optimally peak-shave the nuclear energy within the week, and then find the optimal distribution of nuclear energy among the weeks. This procedure is referred to as the "Peak-Shave First" method. Another optimization procedure would be to optimally distribute the nuclear energy among all the weeks in the planning horizon first, then optimally peak-shave each week's energy within the week. This approach is referred to as the "Peak-Shave Second" method. As an illustration, the single-reactor optimization problem, Case 3, is repeated using the "Peak-Shave Second" method, which is referred to as Case 4.

In Case 4, the optimal weekly distribution of nuclear capacity factors was found by using FOSSIL (instead of PROCOST) to calculate the weekly OCNF functions. FOSSIL modeled the nuclear units operating at fixed power level throughout the entire week. The OCNF values were then fed to ALLOCAT to calculate the optimal weekly nuclear capacity factor distribution. This case is labelled 4.D to signify the difference in optimization procedures as compared to the previous cases. Table 5.25 tabulates the resulting optimal distribution of capacity factors and energies for Case 4.D. Notice that there is some similarity between the optimal distribution for Case 4 and the optimal distribution for Case 3. The peak-shaving of each week's nuclear energy was

TABLE 5.25  
OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR  
DISTRIBUTION FOR CASE 4

<u>Month</u>	<u>Week</u>	<u>Capacity Factor</u>	<u>Weekly Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Total Energy (10<sup>3</sup> MWH)</u>	<u>Monthly Average Energy (10<sup>3</sup> MWH)</u>
April	1	0.80	147.84	526.68	131.67
	2	0.95	175.56		
	3	0.55	101.64		
	4	0.55	101.64		
May	5	0.95	175.56	702.24	140.45
	6	0.70	129.36		
	7	0.80	147.84		
	8	0.80	147.84		
	9	0.55	101.64		
June	10	0.55	101.64	415.80	103.95
	11	0.60	110.88		
	12	0.55	101.64		
	13	0.55	101.64		
July	14	0.55	101.64	535.92	107.18
	15	0.60	110.88		
	16	0.55	101.64		
	17	0.65	120.12		
	18	0.55	101.64		
August	19	0.55	101.64	480.48	120.12
	20	0.85	157.08		
	21	0.55	101.64		
	22	0.65	120.12		
September	23	0.95	175.56	702.24	175.56
	24	0.95	175.56		
	25	0.95	175.56		
	26	0.95	175.56		
<b>Total</b>			3,363.36		129.36

performed by PROCOST, Case 4.E. Table 5.26 tabulates the weekly system cost and savings (compared to Case 3.A) for Case 4. The system problem for Case 3 and 4 was exactly the same, only the optimization procedures applied were different. A comparison of the final results of Case 3.C with 4.E shows that the "Peak-Shave First" method is a better procedure, by \$60,000. The cost comparison of Case 4.D with Case 3.A shows a savings of \$200,000, about the same savings as the in Case 3 derived from optimally distributing the nuclear energy between the weeks. Comparing Case 4.E with Case 4.D shows that the savings from peak-shaving is \$4.4 million, about the same as in Case 3. This comparison shows that the order of magnitude of the savings derived from optimally peak-shaving within the week, and optimally distributing the energy among all the weeks in the planning horizon is roughly independent of the order in which these steps are performed.

The results for Case 4 further document the conclusions of the previous cases that most of the potential savings (millions of dollars per reactor) of short-range nuclear system analysis lies in peak-shaving the operation of the nuclear reactors within a week. Lesser savings (approximately \$200,000) are derived from optimally distributing the limited amount of nuclear energy among the weeks. The main reason is that the energy consumption in different weeks throughout a year are more similar to each other than the energy consumption levels for the different

TABLE 5.26

SYSTEM FOSSIL FUEL COSTS AND SAVINGS FOR CASE 4

<u>Month</u>	<u>Week</u>	<u>Case 4.D* (\$/Wk)</u>	<u>Case 4.E* (\$/Wk)</u>
April	1	10,476,943	10,354,228
	2	10,505,168	10,470,144
	3	10,429,517	10,189,852
	4	9,621,231	9,435,075
May	5	9,710,526	9,676,013
	6	9,627,279	9,454,683
	7	9,690,351	9,571,481
	8	9,997,943	9,871,356
	9	9,594,694	9,347,943
June	10	9,857,137	9,613,347
	11	10,122,781	9,882,328
	12	9,669,964	9,438,299
	13	9,291,620	9,079,552
July	14	9,037,960	8,837,240
	15	10,282,809	10,036,407
	16	10,028,797	9,766,925
	17	10,308,590	10,083,413
	18	10,278,442	10,009,600
August	19	11,238,865	9,773,228
	20	10,587,558	10,361,515
	21	10,616,646	10,216,792
	22	11,251,572	10,229,252
September	23	10,029,392	11,199,903
	24	10,461,847	10,552,515
	25	10,486,044	10,581,086
	26	<u>10,453,215</u>	<u>11,212,542</u>
<b>Total</b>		263,656,891	259,244,719

Comparison with Case 3.A: (200,674) (4,612,840)

(\* Case 4.D: The power level of Unit 1 (constant throughout each week) is optimally assigned for each week in the planning period.

(\* Case 4.E: The weekly energy is the same as in Case 4.D, but the hourly power level within each week is optimized (peak shaved).

The total energy output from Unit 1 is the same as in Case 3.



hours of a week. The maximum difference in weekly energy consumption is about 20% whereas the maximum difference in hourly energy consumption is about 250%.

Consideration of the two optimization procedures indicates that the "Peak-Shave First" method is the more logical optimization method. However since peak-shaving calculation are time consuming, the "Peak-Shave Second" method, which solves for the weekly distribution of energy prior to peak-shaving each week, saves computer time (with some loss in precision of the final result). This saving would be of particular importance in multi-reactor optimizations where several iterative calculational cycles are required for each reactor. The "Peak-Shaving Second" method is a more direct but approximate method of calculating the optimal dispatching schedule and hence is useful in narrowing the range in which the more accurate method may be applied, thus conserving calculational effort.

For convenience, the resource-limited case assumed a fixed refueling date in the framework of the problem. However, the date chosen is an independent variable. The study of a variable refueling date problem can be viewed as a study of a series of (related) fixed refueling date problems. There is a potential for computational savings since the utility system configuration is the same for the entire series of fixed refueling date problems. The results of many of the system calculations once performed, can be used repeatedly in each of separate fixed refueling date

problems.

The "stretch-out" case can also be viewed as another version of the resource-limited problem. During the coast-down period, the power level of the nuclear power reactor is already programmed; but for the time period before coast-down has started, the problem is a resource-limited problem.

A sample of the weekly nuclear optimization recommended by PROCOST is given in Figure 5.2. As shown, the nuclear unit should be operated essentially in an on-off mode. It is turned on at full rated power during high demand time periods, and turned off (to the minimum power level) during low demand time periods, thus the optimal peak-shaving of nuclear reactor is a simple daily cycling (high-low) of the power level. A complex detailed following of the customer demand pattern is not necessary. Nuclear reactors under construction are projected to be capable of some degree of load-following cycling such as recommended by PROCOST. In the event that an on-off mode is not physically feasible for the reactors, PROCOST should be modified so as to include a minimum, or must-run, power level for each nuclear reactor involved in the optimization. See Appendix C.1 for details of suggested changes to accomplish this.




Figure 5.2 SAMPLE OPTIMAL WEEKLY NUCLEAR DISPATCHING SCHEDULE

## 6.0 Conclusions and Recommendations

### 6.1 Conclusions

(1) The system simulations performed showed the short-range optimization procedure developed to be flexible and reliable in handling a wide range of system conditions including an adaptability to multi-reactor problems as well as to single reactor optimizations.

(2) The system simulations showed that very large savings in fossil fuel costs, on the order of millions of dollars per reactor per optimization cycle, are possible from short-range nuclear system analysis. Thus use of these short-range system optimization technique by the utility industry would be a worthwhile undertaking.

(3) All short-range options can be viewed as expending a certain amount of nuclear energy in a certain time period. Thus a basis has been established for comparisons of other complex and involved short-range options.

(4) Procedural guidelines for optimal dispatching of nuclear generation (under resource-limited conditions) are to (a) peak shave the dispatching of nuclear energy by operating at peak power during peak demand time intervals and shutting down (or operating at minimum power) during low demand intervals, (b) follow a weekly budget of nuclear energy rationing until the next scheduled refueling date. The system simulations show that independent of the order of optimization most of short-range optimization savings (millions of dollars per reactor per optimization cycle)

comes from peak-shaving the nuclear energy within each week. Hence, peak-shaving should receive the primary attention. The savings from the weekly redistribution of energy were lower, on the order of hundreds of thousands of dollars per reactor per optimization cycle.

(5) The system parameters having greatest effect on total system operating costs are (a) system reserves, (b) seasonal customer demand shape, and (c) the economic loading order (in turn comprised of the system configuration and its basic parameters such as heat rates, and fuel costs). These are the system parameters that must be considered by the system planner in devising the allocation budget of nuclear energy over the short-range planning horizon.

(6) The sample system simulations have shown that the economic loading order is principally determined by the station's fuel cost (under today's economic conditions). Hence, the utility's determination of the maintenance schedule should aim at achieving a balanced fuel cost configuration in addition to a balanced system reserve configuration.

(7) Using the optimization techniques discussed in this thesis, an unambiguous and logical method has been developed to calculate the short-range substitutional cost of nuclear power, the OCNP. This is the trading price that should be used when transferring nuclear power by utilities.

(8) The system simulation studies have shown the optimal solution to be sensitive to the accuracy of the

input variables (i.e. fossil fuel costs and maintenance schedule). Hence, great care is necessary in determination of system parameters. Because of the introduction of new technology (i.e. nuclear power) in the utility industry coupled with a changing economic environment, many of the old "rules of thumb" and intuition may no longer valid. The new operating environment requires a reassessment of old operating practices.

(9) The scope and complexity of the system interactions illustrated in the sample system simulation demonstrate the usefulness and need for the computer as a tool in system dispatching.

## 6.2 Recommendations

The sample system simulations studied in this thesis showed that potential operating savings derived from short-range nuclear system analysis to be in the millions of dollars. Relatively simple models were used in the computer programs to pattern the operations of a modern utility system. The models identified the system parameters of greatest sensitivity on system cost and provided an upper limit on the potential savings that may be achievable through short-range nuclear system analysis. How much of this potential savings that can be realized depends on the operating constraints not included in the programs and validity of the assumptions used. The following is a list of recommendations to improve and define the accuracy of the

computer programs and calculational technique used.

(1) The range of applicability of the deterministic approach used in PROCOST should be assessed. This may be accomplished using risk-decision analysis, Ref. (33), to measure the severity for assuming 100% availability of the nuclear reactors, see Sections 3.2.1 and 5.1. The usefulness of the Booth-Balerieux probabilistic utility model in determining OCNP should be investigated in overcoming the difficulty mentioned above. Probability theory is most accurate in dealing with a large sample or large time periods. Thus, the applicability of the probabilistic model for a one-week time period should be considered.

(2) Future load models should include the modeling of holidays in the week to study the optimal generation schedule for these periods, see Sections 3.2.2 and A.1.

(3) Minimum operating load levels should be included in the nuclear unit representation in PROCOST. The procedure for implementing this feature is discussed in Appendix C.1.

(4) Start-up and shut-down costs should be included in future simulations studies. This may require use of (a) Integer Programming or (b) multi load-duration curves in PROCOST, see Appendix C.1.

(5) PROCOST, in its present form is a general program offering a number of options. Specialized users of PROCOST should modify the program to fit their own individual requirements and achieve improved computational efficiency

and lower execution time and storage requirements. The performance of the pumped storage subroutine, ECO, especially can be improved upon. Separate chronologic and load-duration versions of PROCOST should also improve computational efficiency. Details on these changes are given in Appendix C.1.

(6) From the sample system simulation studied in Section 5.6, it was found that the "Peak-Shave Second" method yielded within 2 %, the same system cost savings as the "Peak-Shave First" method. Since the "Peak-Shave Second" method is more computationally efficient, it is recommended that further tests should be made comparing the two solution techniques under several different system environments. If the two methods continue to show nearly the same system cost savings, then the simpler and quicker "Peak-Shave Second" method can be used in place of the "Peak-Shave First" method.



Appendix A: LOAD MODELS

A.1 Introduction

The weekly customer demand function is a necessary system input parameter for PROCOST, the production cost program. This demand function may be a set of actual demand numbers or it may be derived from a set of coefficients describing a seasonal demand function as dependent on one or two (or more) independent variables. For the case of performing sensitivity analysis, changing a single independent variable is more convenient than changing 168 numbers individually. The basic hypothesis for such a load model was that the customer demand for each hour of the week was linearly dependent on the weekly average power level. A least squares fit correlation was made for each hour of the week to the weekly average power level for each season. General utility practice has been to use the weekly peak power level as the independent variable. A comparison of the two methods (using 1971 Commonwealth Edison's customer demand) revealed that during the summer and a part of the fall seasons, the weekly peak is a better independent variable (in terms of a higher correlation coefficient) than the weekly average power level. However, the latter was used as the independent variable in the simulations discussed in this thesis, because of its overall higher correlation coefficient during the entire one year sample. Statistically, the peak fluctuates more than the mean, thus, the mean (weekly average power level) provides the higher

correlation coefficient. The form of the regression is:

customer demand = coeff(1)+coeff(2)\*independent variable,  
where coeff is a two element array containing the regression coefficients.

A 168-interval load model was found to be computationally burdensome. Several studies were performed to find simplified load models that would yield the same system results as the 168-interval load model. Appendix A.5 reports on a chronologic load model study that found a forty-interval model that duplicated most system results very well. Appendix A.6 reports on a load-duration study that found a six-interval model that duplicated OCNP values very well. The forty-interval model is a modified chronologic load model. The three average weekdays (excluding the peak weekday and the low weekday) were found to be very similar to each other. Table A.1 shows the distribution of daily energy consumption in a work week. Thus, the three average workdays were combined to form one day in the load model. The forty-interval model consisted of a 10-interval peak weekday, a 10-interval average weekday, a 10-interval low weekday, and a 10-interval weekend. Combining weekdays together rather than combining consecutive hours together retains a greater amount of accuracy in the load model. This can be illustrated by Figure A.1. Choosing the customer demand at 3 o'clock on Monday, Tuesday and Friday (three average weekdays, excluding the high and the low), the range in values is 398

TABLE A.1


RELATIVE DAILY (WEEKDAY) ENERGY CONSUMPTION\*

<u>Week</u>	<u>Low Weekday</u>	<u>Average Weekdays</u>			<u>Peak Weekday</u>
1	0.83	1.13	1.13	1.12	1.15
2	1.00	1.04	1.07	1.07	1.08
3	1.01	1.03	1.03	1.04	1.06
4	1.01	1.06	1.08	1.06	1.10
5	0.97	1.01	1.05	1.08	1.09
6	0.99	1.03	1.06	1.10	1.11
7	0.99	1.02	1.04	1.08	1.08
8	1.02	1.05	1.06	1.07	1.08
9	1.02	1.05	1.08	1.05	1.09
10	1.04	1.04	1.05	1.06	1.07
11	1.03	1.06	1.06	1.06	1.08
12	1.00	1.01	1.01	1.05	1.05
13	0.88	1.12	1.13	1.13	1.15

Note: Each number shown is the ratio of the day's energy consumption divided by 1/7 of the week's energy consumption.

The data are from the winter season of AEP's 1971 Customer Demand.

FIGURE A.1 168-HOUR REPRESENTATION OF THE  
WINTER CUSTOMER DEMAND FOR  
THE WEEK OF JAN. 11, 1971



MWH, whereas the smallest range in values on the same weekdays for 2,3,4 o'clock is 688 MWH.

The logical extension of combining weekdays together is toward load-duration curves. A six-interval load-duration model with constant nuclear heat-rate was found to yield accurate OCNP values. The demand levels of the six-intervals were chosen to be approximately equidistant from each other. The range in demand in the load-duration curve was divided into six equal intervals. Within each interval, the average demand level was calculated, yielding six demand levels.

Use of several computer programs aided formulating the different load models.

(1) PROFILE, listed in Appendix A.2 is a program that plots the contour of the average weekly demand function for a season.

(2) REGRESS, listed in Appendix A.3 is a program that calculates the weekly regression coefficients for particular combination of time intervals.

(3) MODEL, listed in Appendix A.4 is a program that calculates the individual demand function values from the forecasted weekly energy consumption and the regression coefficients.

PROFILE is a visual aid to help the system planner in deciding which of the hours of the week to combine to form the simplified load model. When a particular combination has been chosen REGRESS will calculate the regression

coefficients. MODEL will use the regression coefficients to calculate the projected demand function.

The interesting feature about REGRESS is that it performs a sorting of the weekday by energy consumption. For example, the disadvantage of grouping all Mondays (or any weekday) together (to form a correlation of Monday's hours with the weekly average power) is that some Mondays are the week's lowest demand day and other times, Monday is the highest demand day. The same is true for all the weekdays. A comparison of the ratio of the daily energy consumption to the weekly average for an entire season is tabulated in Table A.1. Interestingly, it shows that the weekly low weekday deviates more from the weekly norm than the weekly high weekday. There is a random distribution of which days are the high and low weekdays. But it shows that the other three weekdays usually show very similar energy consumption. Thus, higher correlation coefficients are obtained for developing correlation parameters for high weekdays, low days, average weekdays, and weekends rather than Mondays, Tuesdays, Wednesdays, etc. The former load model would be more representative than a week composed of 5 average weekdays.

MODEL is a computer program that calculates customer demand functions for energy consumption levels beyond the validity of the correlation the parameters were based on. Using only 1971 customer demand numbers, four seasonal sets of demand parameters were developed, However, to simulate a

1977 system demand function (for the system simulations), required a a 50% jump in power level which was as beyond the validity of the correlation. Thus, the independent variable was normalized by the average 1977 seasonal power level.

It is recommended that more accurate load models be used in the future which would include (1) provisions for holiday, and (2) stochastic demand levels.

## A.2 PROFILE

### A.2.1 Input Specifications

The File Structure:

COPY: file on which DEMAND resides

Input Variable Name:

DEMAND(168): the array which contains the chronologic weekly customer demand numbers. Thirteen weeks of data are required for each season.

Note: PROFILE uses the Fortran subroutine, PRTPLT (34), to do the printing of the average demand function. It is important that the JCL is in the correct order to establish the proper linkage.



```

//TEST EXFC PLIXCGO
//C.SYSIN DD *,DCB=BLKSIZE=2000
PROFILE: PROC OPTIONS(MAIN);
DCL DEMAND(168) FIXED DEC, (MASTER(168),DAY(24)) FLOAT DEC;
ON ENDFILE(COPY) GO TO BOTTOM;
MASTER,DEMAND=0;
DAY=0;
DO I=1 TO 13;
READ FILE(COPY) INTO(DEMAND);
MASTER=DEMAND+MASTER;
END;
MASTER=MASTER/13;
TOP:
DO I=1 TO 24;
DAY(I)=(MASTER(I)+MASTER(I+24)+MASTER(I+48)+MASTER(I+72)+MASTER(I+96))
/5;
END;
PUT PAGE EDIT (DAY  )(12 F(10),SKIP);
PUT EDIT (SUM(MASTER)/168)(F(20))SKIP;
PUT FILE(PUNCH) EDIT(MASTER)(8 F(10),SKIP);
PUT FILE(PUNCH) EDIT(DAY  )(8 F(10),SKIP);
NORDER=0;
NPLLOT=1;
NLINES,IDIM,NVALS=168;
JDIM,NVARS=2;

DCL PRTPLT EXTERNAL ENTRY(FIXED BIN(31),(*,*) FLOAT REAL,
FIXED BIN(31), FIXED BIN(31), FIXED BIN(31), FIXED BIN(31),
FIXED BIN(31), FIXED BIN(31)) OPTIONS(FORTRAN INTER);
DCL (NPLLOT,NVALS,NVARS,NLINES,NORDER,IDIM,JDIM) FIXED BIN(31);

BEGIN;
DCL ARRAY(IDIM,JDIM) FLOAT REAL;
DO I=1 TO 168;
ARRAY(I,1)=I; ARRAY(I,2)=MASTER(I); END;
CALL PRTPLT(NPLLOT,ARRAY,NVALS,NVARS,NLINES,NORDER,IDIM,JDIM);

```


A.2.2 Program Listing and JCL

PROF0001  
PROF0002  
PROF0003  
PROF0004  
PROF0005  
PROF0006  
PROF0007  
PROF0008  
PROF0009  
PROF0010  
PROF0011  
PROF0012  
PROF0013  
PROF0014  
PROF0015  
PROF0016  
PROF0017  
PROF0018  
PROF0019  
PROF0020  
PROF0021  
PROF0022  
PROF0023  
PROF0024  
PROF0025  
PROF0026  
PROF0027  
PROF0028  
PROF0029  
PROF0030  
PROF0031  
PROF0032  
PROF0033  
PROF0034  
PROF0035  
PROF0036

```
END;
NPL0T=2;
NLINES, IDIM, NVALS=24;
BEGIN;
DCL ARRAY(IDIM, JDIM) FLOAT REAL;
DO I=1 TO 24;
ARRAY(I, 1)=I;   ARRAY(I, 2)= DAY(I);   END;
CALL PRTPLT(NPLOT, ARRAY, NVALS, NVAR, NLINES, NORDER, IDIM, JDIM);
END;
BOTTCM:
END PROFILE;
//G.SYSLIB DD
// DD
// DD
// DD
// DD      DSN=SYS5.MATHLIB.SUBR, DISP=SHR
// DD      DSN=SYS1.FORTLIB, DISP=SHR
// DD      DSN=SYS2.SSP.SUBR, DISP=SHR
//G.FT06F001 DD SYSJUT=A, DCB=(RECFM=VA, BLKSIZE=133, BUFNO=1)
//G.SYSPRINT DD SYSOUT=A, DCB=(RECFM=VBA, LRECL=137, BLKSIZE=141)
//G.COPY DD DSN=U.M9960.8981.AEP.SUMMER.ONE13, DISP=SHR
```

```
PROF0037
PROF0038
PROF0039
PROF0040
PROF0041
PROF0042
PROF0043
PROF0044
PROF0045
PROF0046
PROF0047
PROF0048
PROF0049
PROF0050
PROF0051
PROF0052
PROF0053
PROF0054
PROF0055
PROF0056
PROF0057
```

CHART 2



APPENDIX A.2.3 SAMPLE OUTPUT FROM PROFILE

### A.3 REGRESS

#### A.3.1 Input Specifications

##### The File Structure:

**COPY:** file on which DEMAND resides (as in PROFILE, Appendix A.2.1)

**SYIN:** file on which the load model parameters are inputted.

Input Variable Names by order of input on file

##### SYIN:

**I:** number of weekly DEMAND values to skip before processing.

**X:** number of time intervals used in representing a weekday in the load model.

**Y:** number of time intervals used in representing a weekend in the load model.

**P:** number of weeks to a season.

**LEN(X):** array containing the number of hours represented by each time interval in the weekday portion of the load model. If X=24, then omit LEN.

**END(Y):** array containing the number of hours represented by each time interval in the weekend portion of the load model. If Y=48, then omit END.

Note: REGRESS calls the Fortran subroutine, LSFIT(25) to do the least squares fit analysis. It is important that the JCL is in the correct order to establish proper linkage.

```

//TEST EXEC PLIXCGO,LIBRARY='U.C7920.10712.PLIX21.PLIBASE'
//C.SYSIN DD *,DCB=BLKSIZE=2000
REGRESS: PROC OPTIONS(MAIN);
DCL (X,Y,I,P,Q,S) FIXED BIN;
GET LIST(I);
READ FILE(COPY) IGNORE(I );
ON ENDFILE(SYSIN) GO TO BOTTOM;
ON ENDFILE(COPY) CLOSE FILE(COPY);
TOP:
GET LIST (X,Y,P);
PUT DATA (X,Y,P);
S=3*X+Y;
Q=S+1;
BEGIN;
DCL WEEK( P, Q) FLOAT DEC;
DCL ( END(Y),LEN(X),HIGH(2),LOW(2)) FIXED BIN,
STRING BIT(5) VARYING, DEMAND(168) FIXED DEC,
(B, K,I,E,F,G,J) FIXED BIN,
A(5) FIXED BIN(31);

WEEK=0;
ON ERROR PUT DATA(E,K,KK,I,WEEK(KK,I),DEMAND(E+K));
IF X=24 THEN LEN=1;ELSE GET LIST(LEN);
IF Y=48 THEN END=1;ELSE GET LIST(END);
DO I=2 TO X;
LEN(I)=LEN(I)+LEN(I-1);
END;
DO I=2 TO Y;
END(I)=END(I)+END(I-1);
END;
PUT DATA(I,LEN,END);
PUT PAGE LIST(' HIGH, LOW, E, F, G, AND THEIR RELATIVE SIZES');
DO KK=1 TO P;
READ FILE(COPY) INTO (DEMAND);
A=0;
DO J=1 TO 5;

```

```

REGRO001 A.3.2 Program Listing and Sample Input
REGRO002
REGRO003
REGRO004
REGRO005
REGRO006
REGRO007
REGRO008
REGRO009
REGRO010
REGRO011
REGRO012
REGRO013
REGRO014
REGRO015
REGRO016
REGRO017
REGRO018
REGRO019
REGRO020
REGRO021
REGRO022
REGRO023
REGRO024
REGRO025
REGRO026
REGRO027
REGRO028
REGRO029
REGRO030
REGRO031
REGRO032
REGRO033
REGRO034
REGRO035
REGRO036

```

DO I=1 TO 24;	REGR0037
A(J)=A(J)+DEMAND((J-1)*24+I);	REGR0038
END;	REGR0039
END;	REGR0040
A=A/24;	REGR0041
PUT SKIP EDIT(A)(5 F(8));	REGR0042
HIGH(1)=A(1); HIGH(2)=1;	REGR0043
LOW(1)=A(1); LOW(2)=1;	REGR0044
DO I=2 TO 5;	REGR0045
IF LOW(1) > A(I) THEN DO;LOW(1)=A(I);LOW(2)=I; END;	REGR0046
IF HIGH(1) < A(I) THEN DO; HIGH(1)=A(I); HIGH(2)=I; END;	REGR0047
END;	REGR0048
WEEK(KK, Q )=SUM(DEMAND)/168;	REGR0049
E=(HIGH(2)-1)*24;	REGR0050
DO I=1 TO X;	REGR0051
IF I=1 THEN B=1; ELSE B=LEN(I-1)+1;	REGR0052
DO K=B TO LEN(I);	REGR0053
WEEK(KK, I)=WEEK(KK, I)+DEMAND(E+K);	REGR0054
END;	REGR0055
WEEK(KK, I)=WEEK(KK, I)/(LEN(I)-B+1);	REGR0056
END;	REGR0057
E=( LOW(2)-1)*24;	REGR0058
DO I=1 TO X;	REGR0059
IF I=1 THEN B=1; ELSE B=LEN(I-1)+1;	REGR0060
DO K=B TO LEN(I);	REGR0061
WEEK(KK, I+2*X)= WEEK(KK, I+2*X)+DEMAND(E+K);	REGR0062
END;	REGR0063
WEEK(KK, I+2*X)= WEEK(KK, I+2*X)/(LEN(I)-B+1);	REGR0064
END;	REGR0065
STRING='00000'B;	REGR0066
SUBSTR(STRING, HIGH(2), 1)='1'B;	REGR0067
SUBSTR(STRING, LOW(2), 1)='1'B;	REGR0068
E=INDEX(STRING, '0'B);	REGR0069
STRING=SUBSTR(STRING, E+1);	REGR0070
F=INDEX(STRING, '0'B);	REGR0071
STRING=SUBSTR(STRING, F+1);	REGR0072

```

G=INDEX(STRING,'0'B);
F=F+E;
G=G+F;

PUT      EDIT(HIGH(2),LOW(2),E,F,G,HIGH(1)/WEEK(KK,Q ),
LOW(1)/WEEK(KK,Q ),A(E)/WEEK(KK,Q ),A(F)/WEEK(KK,Q ),A(G)/WEEK(KK,Q ))
(5 F(5) , X(5), 5 F(10,2));

E=(E-1)*24;
F=(F-1)*24;
G=(G-1)*24;

DO I=1 TO X;
IF I=1 THEN B=1; ELSE B=LEN(I-1)+1;
DO K=B TO LEN(I);
WEEK(KK, X+I)=WEEK(KK, X+I)+(DEMAND(E+K)+DEMAND(F+K)+DEMAND(G+K))/3;
END;
WEEK(KK, X+I)=WEEK(KK, X+I)/(LEN(I)-B+1);
END;
DO I=1 TO Y;
IF I=1 THEN B=1; ELSE B=END(I-1) +1;
DO K= B TO END(I);
WEEK(KK,3*X+I)=WEEK(KK,3*X+I)+DEMAND(120+K);
END;
WEEK(KK,3*X+I)=WEEK(KK,3*X+I)/(END(I)-B+1);
END;
END;

DCI(NPTS,NCOEFF) FIXED BIN(31);
NCOEFF=2;
NPTS=P;
PUT EDIT((WEEK(I,1) DO I=1 TO 13))(13 F(10))SKIP(2);
BEGIN;
DCI LSFIT EXTERNAL ENTRY(FIXED BIN(31), FIXED BIN(31),(*) REAL FLOAT,
(*) REAL FLOAT, (*) REAL FLOAT) OPTIONS(FORTRAN INTER),
(X(NPTS),Y(NPTS) ,COEFF(NCOEFF)) FLOAT REAL ;

```

```

REGR0073
REGR0074
REGR0075
REGR0076
REGR0077
REGR0078
REGR0079
REGR0080
REGR0081
REGR0082
REGR0083
REGR0084
REGR0085
REGR0086
REGR0087
REGR0088
REGR0089
REGR0090
REGR0091
REGR0092
REGR0093
REGR0094
REGR0095
REGR0096
REGR0097
REGR0098
REGR0099
REGR0100
REGR0101
REGR0102
REGR0103
REGR0104
REGR0105
REGR0106
REGR0107
REGR0108

```

```

DO N=1 TO NPTS;
X(N)=WEEK(N,Q );
END;
PUT FILE(PUNCH) EDIT(X)(8 F(10),SKIP)SKIP;
PUT SKIP EDIT(' SEASONAL REGRESSION COEFFICIENTS FOLLOWS')(A);
DO I=1 TO S;
DO N=1 TO NPTS;
Y(N)=WEEK(N,I);
END;
CALL LSFIT(NPTS,NCOEFF,X,Y,COEFF);
PUT SKIP EDIT(I,COEFF)(F(5) , F(10,1), F(10,5));
WRITE FILE(COEF) FROM(COEFF);
END;
END;

END;
GO TO TOP;
BOTTOM:
END REGRESS;
//G.SYSLIB DD
// DD
// DD
// DD
// DD DSN=SYS5.MATHLIB.SUBR,DISP=SHR
// DD DSN=SYS1.FORTLIB,DISP=SHR
// DD DSN=SYS2.SSP.SUBR,DISP=SHR
//G.FT06FU01 DD SYSOUT=A,DCB=(RECFM=VA,BLKSIZE=133,BUFNO=1)
//G.SYSPRINT DD SYSOUT=A,DCB=(RECFM=VBA,LRECL=137,BLKSIZE=141)
//G.COPY DD DSN=U.M9960.8981.AEP.SUMMER.ONE13,DISP=SHR
//G.SYSIN DD *
9 24 48 13
24 48 13
24 48 12
24 48 13
//G.COEF DD DSN=U.M9960.8981.REGRESS.COEFF.PTS120,DISP=OLD

```

```

REGRO109
REGRO110
REGRO111
REGRO112
REGRO113
REGRO114
REGRO115
REGRO116
REGRO117
REGRO118
REGRO119
REGRO120
REGRO121
REGRO122
REGRO123
REGRO124
REGRO125
REGRO126
REGRO127
REGRO128
REGRO129
REGRO130
REGRO131
REGRO132
REGRO133
REGRO134
REGRO135
REGRO136
REGRO137
REGRO138
REGRO139
REGRO140
REGRO141
REGRO142
REGRO143
REGRO144

```



X=	24	Y=	48	F=	131	LEN(1)=	1	LEN(2)=	2
LEN(3)=	3	LEN(4)=	4	LEN(5)=	5	LEN(6)=	6	LEN(7)=	7
LEN(8)=	8	LEN(9)=	9	LEN(10)=	10	LEN(11)=	11	LEN(12)=	12
LEN(13)=	13	LEN(14)=	14	LEN(15)=	15	LEN(16)=	16	LEN(17)=	17
LEN(18)=	18	LEN(19)=	19	LEN(20)=	20	LEN(21)=	21	LEN(22)=	22
LEN(23)=	23	LEN(24)=	24	END(1)=	1	END(2)=	2	END(3)=	3
END(4)=	4	END(5)=	5	END(6)=	6	END(7)=	7	END(8)=	8
END(9)=	9	END(10)=	10	END(11)=	11	END(12)=	12	END(13)=	13
END(14)=	14	END(15)=	15	END(16)=	16	END(17)=	17	END(18)=	18
END(19)=	19	END(20)=	20	END(21)=	21	END(22)=	22	END(23)=	23
END(24)=	24	END(25)=	25	END(26)=	26	END(27)=	27	END(28)=	28
END(29)=	29	END(30)=	30	END(31)=	31	END(32)=	32	END(33)=	33
END(34)=	34	END(35)=	35	END(36)=	36	END(37)=	37	END(38)=	38
END(39)=	39	END(40)=	40	END(41)=	41	END(42)=	42	END(43)=	43
END(44)=	44	END(45)=	45	END(46)=	46	END(47)=	47	END(48)=	48

APPENDIX A.3.3 SAMPLE OUTPUT FROM RDBRESS  
(Spring, Summer, Autumn, Winter)

HIGH, LOW, E, F, G, AND THEIR RELATIVE SIZES

7812	7650	7479	7381	7135	1	5	2	3	4	1.12	1.02	1.09	1.07	1.06
6937	7289	7357	7410	7317	4	1	2	3	5	1.76	0.99	1.04	1.06	1.05
7256	7577	7632	7536	7390	3	1	2	4	5	1.98	1.03	1.08	1.07	1.05
7176	7257	7033	6761	7090	2	4	1	3	5	1.09	1.00	1.06	1.04	1.05
7174	7324	7103	6915	6226	2	5	1	3	4	1.13	0.96	1.10	1.09	1.06
6404	6741	6873	6528	6665	4	1	2	3	5	1.09	1.01	1.06	1.08	1.05
6636	6614	6695	6832	6657	5	2	1	3	4	1.07	1.04	1.04	1.05	1.07
6753	6927	6871	6888	6764	2	1	3	4	5	1.07	1.04	1.06	1.06	1.04
6993	6974	6830	6705	6785	1	4	2	3	5	1.08	1.04	1.08	1.06	1.05
6670	6712	6758	6836	6665	4	5	1	2	3	1.08	1.05	1.05	1.06	1.07
6565	6727	6680	6661	6552	2	5	1	3	4	1.08	1.05	1.05	1.07	1.07
6647	6755	6773	6733	6635	3	5	1	2	4	1.08	1.06	1.06	1.04	1.07
5224	6647	6707	6827	6590	5	1	2	3	4	1.11	0.83	1.05	1.04	1.08

6215 6435 6567 6073 6067 5977 5793 5894 5513 5939 5619 5768 5960  
 SEASONAL REGRESSION COEFFICIENTS FOLLOW

1	437.5	C.54712
2	-1393.9	1.05325
3	-1767.1	1.14320
4	-2047.3	1.17709
5	-2687.0	1.28218
6	-3431.5	1.43284
7	-5057.5	1.75313
8	-4459.8	1.77652
9	-980.1	1.22916
10	187.9	1.18959
11	1142.6	1.05685
12	1545.2	C.99072
13	2029.3	C.90117
14	3034.4	C.74546
15	3114.7	C.71440
16	3225.9	C.66236
17	2798.7	C.73655
18	1399.4	C.94151
19	-414.0	1.21380
20	-2513.6	1.60105
21	-1333.0	1.36628
22	2348.2	C.75911
23	2680.7	C.68899
24	1155.7	C.82332
25	-1316.3	1.09076
26	-2079.7	1.17910
27	-2359.6	1.20855
28	-2553.6	1.23235
29	-2582.9	1.30415
30	-3803.2	1.46430
31	-4839.9	1.65342
32	-4551.5	1.76886
33	-1363.8	1.36366
34	437.1	1.12303
35	1499.5	C.57620
36	2441.0	0.82372
37	2766.5	C.76160
38	3100.8	C.71275
39	3823.0	C.58451
40	3685.2	C.57241
41	2873.6	0.70270
42	2265.7	C.79468
43	-73.3	1.14643

44	-1818.1	1.41771
45	59.4	1.13212
46	3355.3	C.62566
47	3455.5	C.54820
48	1810.6	C.65558
49	2630.1	C.44712
50	1600.2	C.57135
51	1083.5	C.64215
52	1036.1	C.64805
53	649.5	C.70556
54	130.5	C.51726
55	-2081.0	1.21944
56	-3190.9	1.50222
57	-2135.8	1.42733
58	-1330.5	1.23542
59	-1440.0	1.36507
60	-502.0	1.71591
61	290.3	1.07666
62	-111.5	1.13958
63	150.5	1.07987
64	-140.6	1.10125
65	-1253.4	1.27168
66	-1600.7	1.32352
67	-3454.5	1.60531
68	-4700.6	1.79528
69	-2837.0	1.51553
70	231.3	C.95155
71	1708.5	C.76160
72	1426.4	C.71400
73	832.5	C.73735
74	-443.6	C.56826
75	-1042.1	C.56006
76	-1127.0	C.56571
77	-2013.4	1.05923
78	-2402.5	1.17144
79	-3110.5	1.25572
80	-3407.1	1.38527
81	-2206.7	1.27027
82	-937.8	1.12545
83	-209.2	1.03465
84	182.5	C.97701
85	772.1	C.86688
86	1179.7	C.78620
87	1632.0	C.69700
88	1521.2	C.63534
89	1615.4	C.68616
90	766.6	C.92261
91	-680.3	1.05083
92	-2534.3	1.40586
93	-717.9	1.07624
94	2317.8	C.60831
95	2482.5	C.54417
96	1315.6	C.66317
97	343.3	C.74825
98	-523.2	C.84717
99	-6349.9	1.73734
100	-1482.0	C.56873
101	-1314.0	C.53503
102	-1627.8	C.98558
103	-2421.6	1.11000

104 -2663.3 1.17749  
 105 -1856.0 1.12246  
 106 -223.8 0.67374  
 107 1107.7 0.67033  
 108 1256.4 0.65268  
 109 1922.7 0.57362  
 110 3009.2 0.37112  
 111 3440.7 0.28076  
 112 3909.6 0.26059  
 113 3217.4 0.30779  
 114 2415.2 0.44211  
 115 306.7 0.78177  
 116 -2458.2 1.23033  
 117 -769.4 0.59839  
 118 3338.0 0.39371  
 119 4104.6 0.24405  
 120 2950.6 0.37434

LEN(1)=	1	LEN(21)=	2	X=	24	Y=	48	D=	13:
LEN(6)=	6	LEN(7)=	7	LEN(3)=	3	LEN(4)=	4	LEN(7)=	5
LEN(11)=	11	LEN(12)=	12	LEN(8)=	8	LEN(9)=	9	LEN(17)=	17
LEN(16)=	16	LEN(17)=	17	LEN(13)=	13	LEN(14)=	14	LEN(15)=	15
LEN(21)=	21	LEN(22)=	22	LEN(18)=	18	LEN(19)=	19	LEN(20)=	20
END(2)=	2	END(3)=	3	LEN(23)=	23	LEN(24)=	24	END(1)=	1
END(7)=	7	END(8)=	8	END(4)=	4	END(5)=	5	END(6)=	6
END(12)=	12	END(13)=	13	END(9)=	9	END(10)=	10	END(11)=	11
END(17)=	17	END(18)=	18	END(14)=	14	END(15)=	15	END(16)=	16
END(22)=	22	END(23)=	23	END(19)=	19	END(20)=	20	END(21)=	21
END(27)=	27	END(28)=	28	END(24)=	24	END(25)=	25	END(26)=	26
END(32)=	32	END(33)=	33	END(29)=	29	END(30)=	30	END(31)=	31
END(37)=	37	END(38)=	38	END(34)=	34	END(35)=	35	END(36)=	36
END(42)=	42	END(43)=	43	END(39)=	39	END(40)=	40	END(41)=	41
END(47)=	47	END(48)=	48:	END(44)=	44	END(45)=	45	END(46)=	46

HIGH, LOW, E, F, G, AND THEIR RELATIVE SIZES

6976	6338	6428	6642	6837	1	2	2	4	5	1.08	1.02	1.06	1.07	1.05
6911	6759	6585	6724	6885	1	2	2	4	5	1.06	1.01	1.04	1.07	1.06
6995	6957	6985	7219	7158	4	2	1	3	5	1.07	1.03	1.04	1.09	1.06
7284	7111	7108	6834	6371	1	5	2	3	4	1.13	0.99	1.10	1.17	1.06
5185	6337	6545	6872	6883	5	1	2	3	4	1.17	0.85	1.04	1.08	1.10
6825	6943	6835	6731	6734	2	1	3	4	5	1.08	1.03	1.07	1.05	1.05
6533	6491	6583	6755	6771	4	2	1	3	5	1.08	1.03	1.04	1.04	1.07
6692	6513	6473	6504	6340	1	5	2	3	4	1.05	1.04	1.07	1.06	1.06
6320	6523	6484	6376	6412	2	1	3	4	5	1.07	1.03	1.06	1.04	1.05
6819	7102	6861	6591	6556	2	4	1	3	5	1.11	1.03	1.06	1.07	1.03
6714	6828	6866	7012	7077	5	1	2	3	4	1.08	1.02	1.04	1.05	1.07
6682	6604	6741	6770	6843	4	2	1	3	5	1.07	1.05	1.06	1.07	1.05
6876	6508	6543	6555	6853	4	5	1	2	3	1.09	1.05	1.06	1.06	1.07

SEASONAL REGRESSION COEFFICIENTS FOLLOWS

	5364	5411	6116	5982	5585	5825	5725	5427	5552	5984	6070	5724	5831
1	2941.5	C.44231											
2	2450.5	C.47379											
3	2584.4	C.42355											
4	2637.4	C.39860											
5	1955.4	C.51355											
6	2617.8	C.41521											
7	2144.3	C.52757											
8	1937.4	C.65556											
9	1063.8	C.91958											
10	1231.5	C.77490											
11	1154.1	1.74633											
12	857.8	1.11538											
13	1930.0	C.55892											
14	1359.2	1.06031											
15	514.2	1.18981											
16	641.9	1.14860											
17	121.9	1.22465											
18	-500.6	1.32430											
19	-1134.3	1.38545											
20	-1768.2	1.45105											
21	-2245.2	1.51486											
22	-2265.2	1.54321											
23	-2150.8	1.47552											
24	-537.8	1.17227											
25	1685.5	C.63024											
26	1384.5	C.62199											
27	1279.7	C.62063											
28	1430.5	C.58304											
29	1299.4	C.59878											
30	557.4	C.67133											
31	762.0	C.74039											
32	175.4	C.92045											
33	659.1	C.95575											
34	572.6	1.05245											
35	814.9	1.06294											
36	1074.0	1.04458											
37	774.8	1.09441											
38	473.9	1.15647											
39	503.6	1.15035											
40	1146.9	1.02710											
41	616.3	1.10577											
42	731.1	1.07555											
43	683.1	1.06731											

44	364.8	1.07780
45	199.4	1.09615
46	1244.0	0.95455
47	1292.8	0.90210
48	1586.2	0.75000
49	-2250.6	1.21066
50	-2029.6	1.13374
51	-1584.2	1.10489
52	-2591.2	1.18236
53	-2266.4	1.12997
54	-2377.0	1.16793
55	-2533.8	1.22559
56	-5371.1	1.75659
57	-7115.1	2.13859
58	-6656.8	2.14072
59	-6490.5	2.15956
60	-5059.7	1.96154
61	-4344.4	1.84266
62	-5505.9	2.02846
63	-6036.9	2.12063
64	-5747.2	2.05157
65	-5236.7	1.98941
66	-4275.0	1.81206
67	-3910.4	1.72815
68	-4043.4	1.71941
69	-3631.0	1.64777
70	-3238.7	1.61364
71	-3205.8	1.56643
72	-1736.5	1.23514
73	1660.8	0.60664
74	694.7	0.70105
75	445.8	0.71662
76	190.4	0.72645
77	1717.6	0.47546
78	1249.4	0.55272
79	744.3	0.67859
80	1606.3	0.53737
81	1910.2	0.55857
82	2149.3	0.55353
83	1561.6	0.73427
84	1891.9	0.71154
85	1604.9	0.76224
86	2348.8	0.64510
87	1644.7	0.74476
88	758.6	0.87587
89	230.7	0.56329
90	307.4	0.95455
91	-41.1	0.55825
92	167.8	0.94143
93	71.8	0.95105
94	220.3	0.94843
95	-418.2	1.01573
96	-33.2	0.86374
97	312.5	0.75350
98	488.6	0.87556
99	1241.8	0.52950
100	1287.4	0.50255
101	663.4	0.55156
102	1438.4	0.46760
103	1609.9	0.43521

104	1443.1	C.47744
105	1216.0	C.56124
106	745.5	C.68357
107	-255.4	C.66576
108	-408.8	C.92657
109	-1582.2	1.13636
110	-2256.1	1.21551
111	-1775.8	1.16255
112	-2712.0	1.19668
113	-1542.1	1.17355
114	-1927.6	1.18007
115	-1528.8	1.15543
116	-1785.8	1.16971
117	-1695.3	1.16255
118	63.7	C.92483
119	-589.6	1.00874
120	-702.5	C.57203

			X=	24		Y=	48		P=	12:
LEN(1)=	1	LEN(21)=	2	LEN(3)=	3	LEN(4)=	4	LEN(5)=	5	
LEN(6)=	6	LEN(7)=	7	LEN(8)=	8	LEN(9)=	9	LEN(10)=	10	
LEN(11)=	11	LEN(12)=	12	LEN(13)=	13	LEN(14)=	14	LEN(15)=	15	
LEN(16)=	16	LEN(17)=	17	LEN(18)=	18	LEN(19)=	19	LEN(20)=	20	
LEN(21)=	21	LEN(22)=	22	LEN(23)=	23	LEN(24)=	24	END(1)=	1	
END(2)=	2	END(3)=	3	END(4)=	4	END(5)=	5	END(6)=	6	
END(7)=	7	END(8)=	8	END(9)=	9	END(10)=	10	END(11)=	11	
END(12)=	12	END(13)=	13	END(14)=	14	END(15)=	15	END(16)=	16	
END(17)=	17	END(18)=	18	END(19)=	19	END(20)=	20	END(21)=	21	
END(22)=	22	END(23)=	23	END(24)=	24	END(25)=	25	END(26)=	26	
END(27)=	27	END(28)=	28	END(29)=	29	END(30)=	30	END(31)=	31	
END(32)=	32	END(33)=	33	END(34)=	34	END(35)=	35	END(36)=	36	
END(37)=	37	END(38)=	38	END(39)=	39	END(40)=	40	END(41)=	41	
END(42)=	42	END(43)=	43	END(44)=	44	END(45)=	45	END(46)=	46	
END(47)=	47	END(48)=	48;							

HIGH, LOW, E, F, G, AND THEIR RELATIVE SIZES

5390	6816	7085	712P	7017	4	1	2	3	5	1.13	0.85	1.08	1.17	1.11
6619	6682	6752	6728	6611	3	5	1	2	4	1.07	1.05	1.05	1.05	1.07
6659	6614	6615	664P	6553	1	5	2	3	4	1.06	1.05	1.06	1.06	1.06
6729	6942	6573	6936	6537	3	5	1	2	4	1.09	1.02	1.05	1.09	1.09
6243	6181	6162	6203	6251	5	3	1	2	4	1.06	1.04	1.05	1.04	1.05
6243	6245	6272	6245	61F6	3	5	1	2	4	1.06	1.05	1.06	1.06	1.06
6192	6313	6308	6375	6357	4	1	2	2	5	1.06	1.03	1.05	1.05	1.06
6285	6412	6458	6432	6334	3	1	2	4	5	1.07	1.04	1.06	1.06	1.05
6322	6334	6519	6738	6665	4	1	2	2	5	1.07	1.00	1.00	1.03	1.06
7073	7186	6992	6864	6652	2	5	1	3	4	1.10	1.02	1.08	1.07	1.05
6509	6687	6739	6669	6792	5	1	2	2	4	1.05	1.00	1.03	1.04	1.03
7440	7691	7595	6007	6670	2	4	1	2	5	1.14	0.89	1.10	1.12	0.95

5903 5615 5056 5782 5343 5343 5317 5450 5583 6383 5433 6464 0

SEASONAL REGRESSION COEFFICIENTS FOLLOWS

1	-1218.0	1.08897
2	-2251.3	1.22175
3	-2625.8	1.25988
4	-2987.6	1.31178
5	-3037.1	1.32115
6	-3470.6	1.42352
7	-4284.5	1.63622
8	-3636.5	1.66337
9	-2204.1	1.51457
10	-2109.3	1.53954
11	-2305.6	1.58325
12	-2139.0	1.55775
13	-2701.5	1.63371
14	-3190.8	1.72320
15	-1935.1	1.50468
16	-1587.4	1.45668
17	-4709.9	1.35900
18	-5955.9	2.14152
19	-6167.9	2.17274
20	-2202.0	1.54214
21	-1818.5	1.48023
22	-1876.6	1.45265
23	-1037.8	1.24350
24	-878.7	1.12270
25	330.7	0.81958
26	-876.5	0.97766
27	-1255.3	1.02523
28	-1511.2	1.05835
29	-1738.5	1.09632
30	-1868.2	1.14554
31	-2741.2	1.37045
32	-2160.9	1.40735
33	-605.5	1.24246
34	-353.6	1.24737
35	-236.6	1.23777
36	386.5	1.13788
37	376.5	1.12487
38	367.1	1.13163
39	1000.0	1.01821
40	1588.5	0.90271
41	-51.6	1.16857
42	-3224.0	1.68054
43	-4104.6	1.81656
44	-169.5	1.19563



45	773.5	1.04527
46	785.3	1.00832
47	681.1	0.95317
48	655.1	0.85552
49	356.8	0.77579
50	370.9	0.74389
51	207.3	0.75221
52	147.6	0.75442
53	2.8	0.77579
54	396.7	0.74493
55	1568.0	0.63111
56	4441.7	0.28668
57	6358.5	0.10822
58	6619.9	0.26039
59	7225.9	0.02081
60	7513.0	-0.05723
61	7861.0	-0.12351
62	9820.3	-0.41155
63	10210.9	-0.51525
64	10133.5	-0.52653
65	9508.2	-0.42144
66	6258.2	0.10354
67	5151.1	0.28044
68	8342.2	-0.22633
69	8512.9	-0.25754
70	7773.7	-0.17430
71	6687.2	-0.10054
72	4769.0	0.15349
73	1659.9	0.59001
74	-152.1	0.82687
75	-475.3	0.85172
76	-905.0	0.90921
77	-835.0	0.89412
78	-1216.3	0.96345
79	-1127.7	0.97269
80	-1055.5	1.01340
81	-890.3	1.05619
82	-52.3	0.93887
83	382.6	0.94329
84	1163.5	0.82934
85	1076.1	0.82518
86	1279.5	0.77784
87	1024.7	0.80281
88	602.6	0.85640
89	-444.6	1.03330
90	-2734.9	1.42248
91	-1871.2	1.29396
92	790.8	0.87045
93	1107.7	0.80801
94	1050.2	0.79876
95	982.4	0.75130
96	776.0	0.72451
97	82.7	0.77354
98	41.9	0.74389
99	-690.6	0.83455
100	-1038.8	0.87734
101	-983.0	0.86420
102	-1372.0	0.93210
103	-1450.8	0.95421
104	-1386.8	0.97607

105	-1500.4	1.54757
106	-499.3	C.92560
107	-581.9	C.94732
108	-228.2	C.90947
109	-92.5	C.90271
110	351.0	C.87122
111	211.1	C.81891
112	-514.7	C.92532
113	-1685.6	1.11902
114	-694.2	1.53746
115	-3770.8	1.51093
116	-924.2	1.58117
117	-158.6	C.96774
118	-236.7	C.96618
119	-147.3	C.90947
120	-546.0	C.92755

			X=	24		Y=	48		P=	13:
LEN(1)=	1	LEN(2)=	2	LEN(3)=	3	LEN(4)=	4	LEN(5)=	5	
LEN(6)=	6	LEN(7)=	7	LEN(8)=	8	LEN(9)=	9	LEN(10)=	10	
LEN(11)=	11	LEN(12)=	12	LEN(13)=	13	LEN(14)=	14	LEN(15)=	15	
LEN(16)=	16	LEN(17)=	17	LEN(18)=	18	LEN(19)=	19	LEN(20)=	20	
LEN(21)=	21	LEN(22)=	22	LEN(23)=	23	LEN(24)=	24	END(1)=	1	
END(2)=	2	END(3)=	3	END(4)=	4	END(5)=	5	END(6)=	6	
END(7)=	7	END(8)=	8	END(9)=	9	END(10)=	10	END(11)=	11	
END(12)=	12	END(13)=	13	END(14)=	14	END(15)=	15	END(16)=	16	
END(17)=	17	END(18)=	18	END(19)=	19	END(20)=	20	END(21)=	21	
END(22)=	22	END(23)=	23	END(24)=	24	END(25)=	25	END(26)=	26	
END(27)=	27	END(28)=	28	END(29)=	29	END(30)=	30	END(31)=	31	
END(32)=	32	END(33)=	33	END(34)=	34	END(35)=	35	END(36)=	36	
END(37)=	37	END(38)=	38	END(39)=	39	END(40)=	40	END(41)=	41	
END(42)=	42	END(43)=	43	END(44)=	44	END(45)=	45	END(46)=	46	
END(47)=	47	END(48)=	48:							

HIGH, LOW, E. F. G. AND THEIR RELATIVE SIZES

7409	7553	7516	7654	7616	5	1	2	3	4	1.07	1.04	1.06	1.05	1.06
7257	7137	7111	7122	6525	1	5	2	3	4	1.38	1.03	1.06	1.26	1.06
7158	7446	7041	7164	7417	2	3	1	4	5	1.75	1.00	1.01	1.01	1.75
7449	7358	7526	7337	5866	3	5	1	2	4	1.15	0.88	1.13	1.13	1.12
7449	7358	7526	7337	5866	3	5	1	2	4	1.15	0.88	1.13	1.13	1.12
7275	7615	7778	7876	7807	4	1	2	3	5	1.08	1.00	1.04	1.07	1.07
7415	7416	7574	7256	7478	3	4	1	2	5	1.06	1.01	1.03	1.03	1.04
7804	8050	7960	7785	7350	2	5	1	3	4	1.10	1.00	1.06	1.08	1.06
7310	7666	8249	8154	7530	3	1	2	4	5	1.09	0.97	1.01	1.08	1.05
8365	8278	7548	7720	7457	1	5	2	3	4	1.11	0.99	1.10	1.04	1.03
7837	8119	8140	7705	7418	3	5	1	2	4	1.08	0.99	1.04	1.08	1.02
7550	7502	7421	7213	7103	1	5	2	3	4	1.08	1.02	1.07	1.06	1.05
7289	7518	7459	7278	7062	2	5	1	3	4	1.09	1.02	1.05	1.08	1.05

	6373	5600	6055	6255	6295	6713	6264	6747	7059	6816	7192	6170	6151
SEASONAL	REGRESSION COEFFICIENTS FOLLOW												
1	-709.9	1.00654											
2	-745.0	0.98572											
3	-1314.3	1.05734											
4	-1292.0	1.05173											
5	-1406.7	1.07666											
6	-949.1	1.05079											
7	-416.6	1.05983											
8	625.8	1.04861											
9	3042.0	0.76557											
10	3537.8	0.71758											
11	3672.4	0.70926											
12	3285.4	0.74577											
13	2738.3	0.80867											
14	2570.8	0.83355											
15	2396.4	0.83733											
16	2000.3	0.85983											
17	2448.4	0.81964											
18	4244.0	0.40330											
19	3617.1	0.70438											
20	3688.8	0.67653											
21	3791.5	0.64726											
22	2595.6	0.71862											
23	1921.2	0.80430											
24	-975.3	1.10938											
25	776.5	0.77719											
26	345.0	0.81427											
27	226.1	0.81968											
28	-74.8	0.85656											
29	3.0	0.85416											
30	158.3	0.86849											
31	594.3	0.89000											
32	1888.4	0.84014											
33	3429.1	0.69183											
34	4432.1	0.56778											
35	4500.4	0.56217											
36	4691.9	0.52135											
37	3934.1	0.61350											
38	3570.2	0.80555											
39	3675.5	0.62730											
40	3217.1	0.65815											
41	3156.0	0.68620											
42	4814.3	0.48925											
43	4404.8	0.56747											

44	4103.6	0.59364
45	3679.4	0.63322
46	3702.5	C.55489
47	2927.5	C.64035
48	1473.6	C.75315
49	2144.1	C.53194
50	840.5	0.68562
51	166.2	0.77127
52	-70.7	0.79950
53	-426.2	0.85323
54	-1372.9	1.01456
55	-2968.3	1.21474
56	-5505.1	1.70526
57	-4465.5	1.71112
58	-4056.5	1.68090
59	-3750.7	1.65375
60	-3195.6	1.55500
61	-3649.9	1.60737
62	-4491.6	1.71860
63	-4300.9	1.68874
64	-3687.1	1.55375
65	-3605.1	1.56123
66	-2165.1	1.39855
67	-3745.0	1.62445
68	-4541.6	1.71611
69	-4286.3	1.65557
70	-3760.5	1.54006
71	-2910.4	1.36304
72	-2034.6	1.17255
73	-2199.4	1.14146
74	-2399.6	1.13462
75	-3016.5	1.20131
76	-3111.2	1.20692
77	-3226.7	1.22343
78	-3302.5	1.24616
79	-3056.0	1.23559
80	-2521.2	1.21315
81	-2494.8	1.27267
82	-2912.7	1.37270
83	-3814.4	1.51895
84	-4782.3	1.65375
85	-5121.0	1.67872
86	-6101.2	1.79620
87	-5979.2	1.75725
88	-5853.5	1.72355
89	-6143.2	1.78030
90	-4654.8	1.61888
91	-5108.8	1.71331
92	-4643.7	1.63602
93	-3935.8	1.51855
94	-3133.6	1.33174
95	-3058.3	1.33406
96	-3448.0	1.33718
97	-3750.1	1.32533
98	-4173.6	1.35338
99	-4365.4	1.36211
100	-4529.9	1.37456
101	-4550.2	1.37987
102	-4205.7	1.33531
103	-4223.5	1.34933

104	-3281.1	1.33022
105	-3469.3	1.37693
106	-3468.4	1.45120
107	-4004.8	1.29106
108	-3168.6	1.32284
109	-2568.4	1.28576
110	-2956.5	1.28108
111	-3057.2	1.27703
112	-2550.7	1.25552
113	-2235.0	1.16578
114	-381.4	0.95108
115	-1327.9	1.11566
116	-1353.7	1.12532
117	-1619.4	1.15612
118	-1727.1	1.15768
119	-1417.3	1.07354
120	-2075.2	1.12652

#### A.4 MODEL

##### A.4.1 Input Requirements

###### The File Structure:

LDMDL: File where the customer demand function is to be printed.

COEF: File name of dataset where the seasonal regression coefficients A and B reside.

SYSIN: File where the load model input parameters are located.

###### Variable Names by Order of Input in File SYSIN:

I: The number of seasons sets of A and B to be skipped on file COEF before beginning processing.

SEASON: The number of sets of seasonal parameters (A and B) to be processed in calculating all the demand function desired.

PTS: The number of time intervals used in the load model to represent a weekly customer demand function.

TIME: Array containing the number of hours represented by each time interval in the load model.

WEEKS: The number of weeks a set of seasonal parameters is used.

MEAN\_POWER: The mean power level of the season for which a seasonal set of regression parameters is valid.

MEAN\_ENERGY: The average weekly energy consumption value for the season being simulated.

ENERGY: The weekly energy consumption of the week for which the demand function is desired.

The last four variables are repeated for each season output desired.

Example Problem Number One:

The weekly demand function for two summer weeks and one winter week are desired. The summer weekly energy consumption values are 1,000,001 and 1,000,002 and the winter weekly energy consumption value is 1,000,100. The seasonal average summer energy is 1,000,500 and the seasonal average winter energy is 1,000,050. The seasonal power level for which the regression coefficients are valid are 6,000 and 5,000 for winter and summer, respectively.

The seasonal regression coefficients lie in the order of spring, summer, fall, and winter on file COEF. The load model is represented by four time intervals. The time duration of each interval is 41, 42, 43, 42 hours respectively.

The resulting input SYSIN file would read as follows:

```
1 3 120
41 42 43 42
2 5000 1,000,500 1,000,001 1,000,002
0 0 0
1 6000 1,000,050 1,000,100
```

Example Problem Number Two:

The input required for the weekly demand functions used in the system simulations (in Section 5.0) is listed below the program listing, in Appendix A.4.2. Appendix A.4.3 is the resulting computer output.

```

// 'PAY ENG',CLASS=A,REGION=128K
// EXEC PLIXCGO,
//C.SYSIN DD *,DCB=BLKSIZE=2000
MODEL: PROC OPTIONS(MAIN);
DCL      (I,SEASONS,PTS,WEEKS,K) FIXED BIN;

GET LIST(I,SEASONS,PTS );
PUT DATA(I,SEASONS,PTS )SKIP;
READ FILE(COFF) IGNORE(PTS*I);
BLOCK: BEGIN;
  DCL (A(PTS),B(PTS), C(PTS),COEFF(2)) FLOAT DEC,TIME(PTS) FIXED BIN,
      (POWER,ENERGY,MEAN_POWER, MEAN_ENERGY, TOTAL)      FLOAT DEC(16);
  GET LIST(TIME)COPY;
  LOOP: DO K=1 TO SEASONS;
  DO I=1 TO PTS;
  READ FILE(COFF) INTO(COEFF);
  A(I)=COEFF(1);
  B(I)=COEFF(2);
  END;
  A(99)=A(100);
  B(99)=B(100);
  GET LIST(WEEKS, MEAN_POWER, MEAN_ENERGY);
  PUT DATA(WEEKS, MEAN_POWER, MEAN_ENERGY)SKIP;
  DO I=1 TO WEEKS;
  GET LIST(ENERGY);
  PUT DATA(ENERGY)SKIP(2);
  POWER=MEAN_POWER*ENERGY/MEAN_ENERGY;
  C=A+B*POWER;
  TOTAL=SUM(C*TIME);
  C=C*ENERGY/TOTAL;

  PUT FILE(LDMDL) EDIT(C)(168 F(8));
  PUT EDIT(C)(8 F(10),SKIP)SKIP;
  END;
END LOOP;
END BLOCK;

```

```

MODE0001 A.4.2 Program Listing and Sample Input
MODE0002
MODE0003
MODE0004
MODE0005
MODE0006
MODE0007
MODE0008
MODE0009
MODE0010
MODE0011
MODE0012
MODE0013
MODE0014
MODE0015
MODE0016
MODE0017
MODE0018
MODE0019
MODE0020
MODE0021
MODE0022
MODE0023
MODE0024
MODE0025
MODE0026
MODE0027
MODE0028
MODE0029
MODE0030
MODE0031
MODE0032
MODE0033
MODE0034
MODE0035
MODE0036

```



```

PUT EDIT(' NORMAL END OF PROGRAM')(A)SKIP(2);
END MODEL;
//G.CJEF DD DSN=U.M9960.8981.REGRESS.COEFF.PTS120,DISP=OLD
//G.LDMCL DD DSN=U.M9960.8981.AEP.APR.MAY,DISP=OLD
//G.SYSIN DD *
0 3 120
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
9 6550 1806500
1860288 1894814 1801320 1681939
1792155 1728221 1758492 1801151 1691693
13 6385 1847000 1839877 1883604 1814876 1761441
1681810 1870344 1826914 1883382 1860176 1833500 1950649
1895024 1909928
4 6269 2024100
1955031 1868715 1872805 1956622

```

```

MODE0037
MODE0038
MODE0039
MODE0040
MODE0041
MODE0042
MODE0043
MODE0044
MODE0045
MODE0046
MODE0047
MODE0048
MODE0049
MODE0050
MODE0051
MODE0052
MODE0053
MODE0054
MODE0055

```

T= J SEASONS= 3 PTS= 123;  
 1  
 3  
 1  
 1  
 1

WEEKS= 9 MEAN\_POWER= 6.55000000000000E+03

MEAN\_ENERGY= 1.80650000000000E+06;

ENERGY= 1.86028800000000E+06;

10096	9864	9755	9671	9795	10229	11107	12347
13106	13478	13575	13504	13307	13233	13021	12627
12749	12720	12758	12942	12937	12700	12027	11011
9915	9640	9506	9451	9542	9968	10803	12111
12960	13150	13269	13125	12972	12980	12745	12385
12495	12516	12571	12713	12641	12433	11740	10720
9189	8941	8888	8881	8976	9252	10084	11393
12218	12595	12748	12636	12437	12437	12278	11960
12023	12025	12069	12151	12126	11999	11235	10245
9530	9105	8918	8837	8864	9025	9273	9794
10441	10920	11111	11115	10864	10640	10395	10187
10247	10368	10516	10791	10736	10538	10099	9501
8847	8520	8288	8268	8195	8239	8314	8664
9159	9305	9244	9353	9342	9047	8755	8645
8698	8858	9158	9566	9790	9837	9439	8987

ENERGY= 1.89481400000000E+06;

10271	10082	9991	9913	10060	10525	11468	12713
13380	13723	13794	13708	13493	13387	13169	12764
12900	12914	13008	13272	13219	12866	12170	11181
10140	9883	9755	9705	9811	10270	11152	12475
13141	13382	13470	13296	13130	13128	12866	12504
12641	12680	12808	13005	12875	12543	11854	10864
9280	9059	9020	9015	9072	9430	10336	11703
12511	12871	13030	12886	12640	12672	12501	12188
12295	12298	12401	12570	12438	12095	11393	10393
9582	9289	9116	9036	9091	9267	9541	10091
10702	11152	11325	11317	11043	10802	10539	10318
10389	10538	10733	11082	10958	10664	10211	9638
9002	8694	8487	8487	8387	8442	8542	8907
9386	9496	9383	9489	9460	9124	8814	8700
8752	8950	9319	9839	9996	9919	9489	9064

ENERGY= 1.80132000000000E+06;

9797	9493	9353	9256	9343	9725	10490	11722
12637	13058	13203	13154	12989	12969	12768	12393
12487	12387	12330	12379	12456	12418	11784	10721
9531	9225	9081	9018	9093	9453	10207	11489
12380	12754	12924	12834	12703	12728	12538	12183
12247	12235	12167	12213	12242	12212	11546	10472
9033	8739	8661	8652	8675	8974	9655	10864
11718	12125	12268	12207	12037	12035	11897	11572
11575	11559	11503	11519	11592	11563	10966	9993
9270	8792	8580	8497	8477	8613	8816	9305
9993	10524	10746	10771	10558	10362	10149	9962
10005	10078	10146	10295	10357	10323	9906	9267
8593	8221	7947	7947	7865	7892	7923	8250
8770	8997	9008	9123	9139	8916	8655	8553
8579	8702	8982	9153	9438	9697	9351	8854

SAMPLE OUTPUT FROM MODEL

Appendix A.4.3

ENERGY= 1.681939000000000E+06:

9193	8742	8539	8417	8429	8704	9242	10457
11689	12209	12448	12446	12345	12436	12257	11919
11960	11715	11454	11238	11482	11847	11230	10133
8753	8384	8220	8140	8154	8410	9032	10229
11407	11952	12227	12245	12158	12218	12119	11772
11744	11667	11349	11203	11433	11764	11153	9972
8717	8331	8202	8199	8168	8390	8786	9794
10706	11173	11294	11346	11267	11222	11126	10786
10668	10615	10357	10241	10512	10884	10422	9483
8743	8159	7895	7838	7694	7778	7890	8316
9088	9721	10009	10074	9939	9801	9651	9508
9515	9490	9397	9291	9599	9888	9517	8793
8049	7617	7256	7256	7199	7190	7132	7411
7985	8374	8528	8656	8729	8649	8453	8365
9357	8385	8324	8276	8726	9415	9175	8585

ENERGY= 1.792155000000000E+06:

9751	9436	9290	9192	9273	9647	10394	11625
12565	12993	13145	13100	12939	12978	12729	12356
12447	12336	12253	12291	12391	12374	11746	10676
9471	9160	9015	8950	9011	9373	10115	11392
12305	12692	12871	12799	12661	12689	12536	12151
12208	12192	12104	12136	12180	12177	11516	10434
9009	8708	8626	8617	8636	8929	9588	10782
11640	12052	12193	12140	11978	11973	11838	11512
11505	11486	11415	11421	11509	11511	10925	9954
9229	8744	8527	8444	8417	8549	8744	9229
9324	10462	10690	10717	10511	10319	10111	9927
9967	10033	10089	10218	10298	10790	9876	9230
8542	8175	7894	7894	7814	7838	7862	8185
8710	8950	8971	9087	9108	8895	8640	8538
8562	8678	8839	9085	9383	9676	9338	8834

ENERGY= 1.728221000000000E+06:

9427	9034	8854	8743	8784	9100	9726	10947
12057	12538	12740	12721	12594	12643	12455	12102
12165	11976	11900	11680	11840	12068	11482	10361
9054	8710	8554	8480	8514	8814	9469	10717
11784	12263	12497	12474	12370	12416	12242	11931
11939	11887	11666	11594	11747	11937	11305	10166
8940	8490	8380	8369	8365	8616	9123	10209
11098	11542	11672	11676	11566	11537	11425	11091
11020	10981	10801	10736	10931	11147	10633	9691
8947	8404	8161	8075	7998	8102	8249	8699
9439	10032	10294	10344	10179	10018	9844	9684
9705	9719	9657	9680	9387	10057	9658	8977
8256	7851	7524	7524	7457	7462	7439	7736
8289	8616	8714	8837	9888	9753	8532	8438
8443	8508	8540	8616	9002	9524	9244	8690

ENERGY= 1.758492000000000E+06:

9590	9224	9061	8955	9015	9359	10042	11268
12297	12754	12932	12900	12758	12778	12585	12223
12298	12146	12019	11969	12107	12213	11607	10510
9252	8923	8772	8703	8749	9079	9775	11037
12031	12466	12674	12623	12508	12545	12388	12035
12067	12032	11874	11851	11952	12051	11405	10293
8920	8593	8496	8486	8493	8764	9343	10480
11355	11783	11918	11896	11761	11743	11621	11290

11250	11220	11097	11060	11204	11319	10771	9810
9081	8565	8334	8250	8196	8313	8484	8950
9669	10236	10491	10521	10336	10161	9970	9799
9829	9867	9677	9935	10082	10167	9766	9097
8392	8004	7699	7699	7626	7640	7639	7949
8488	8774	8836	8955	8992	8820	8583	8485
8499	8589	8682	8838	9182	9596	9288	8758

ENERGY= 1.801151000000000E+06;

9796	9492	9352	9255	9342	9724	10489	11720
12636	13057	13201	13153	12988	12969	12767	12392
12487	12387	12329	12377	12455	12417	11783	10720
9530	9224	9080	9016	9091	9452	10206	11487
12378	12753	12923	12833	12703	12727	12538	12182
12246	12235	12166	12212	12241	12211	11546	10472
9032	8739	8650	8652	8674	8973	9654	10863
11717	12124	12266	12206	12036	12034	11896	11571
11574	11557	11501	11517	11590	11562	10966	9993
9269	8791	8579	8496	8476	8612	8815	9304
9992	10522	10745	10770	10557	10362	10148	9961
10004	10077	10145	10294	10356	10323	9906	9266
8583	8220	7946	7946	7864	7891	7922	8249
8769	8997	9007	9122	9139	8915	8655	8552
8578	8701	8881	9151	9437	9697	9351	8854

ENERGY= 1.691693000000000E+06;

9242	8804	8695	8486	8504	9788	9344	10540
11767	12279	12509	12504	12397	12479	12298	11957
12003	11770	11535	11331	11562	11893	11331	10181
8917	8453	8290	8211	8230	8495	9100	10332
11497	12019	12284	12293	12203	12259	12153	11806
11755	11714	11416	11285	11500	11800	11185	10013
8743	8365	8240	8227	8210	8439	8857	9881
10759	11250	11374	11411	11330	11288	11189	10851
10742	10692	10451	10345	10600	10939	10466	9525
8785	8211	7951	7865	7758	7846	7966	8397
9162	9786	10068	10131	9990	9847	9692	9545
9555	9538	9458	9373	9652	9924	9548	8832
8093	7656	7313	7313	7253	7247	7197	7479
8049	8425	8565	8694	8762	8671	8470	8380
9375	8411	8370	8348	8784	9438	9190	8607

WEEKS= 13

MEAN\_POWER= 6.385000000000000E+03

MEAN\_ENERGY= 1.847000000000000E+06;

ENERGY= 1.339877000000000E+06;

9900	9410	9203	8907	8975	9055	9543	10544
11903	12853	13446	13692	13835	13953	13905	13685
13522	13539	13270	12847	12774	12916	12387	11146
9804	9305	9100	8849	8795	9001	9421	10383
11646	12512	13044	13289	13320	13481	13466	13223
13171	13062	12739	12432	12348	12596	12106	10945
9334	8922	8694	8487	8473	8697	9107	9994
11174	11993	12497	12703	12700	12944	12830	12572
12552	12484	12193	11869	11793	12096	11628	10537
9538	8874	8506	8284	8208	8205	8290	8651
9406	10201	10730	11050	11111	11109	10988	10899
10947	10983	10862	10599	10539	10766	10404	9621
8790	8289	7725	7725	7621	7598	7540	7714
8240	8771	9079	9444	9721	9776	9678	9641
9685	9777	9804	9724	9813	10238	10033	9436

ENERGY= 1.88360400000000E+04;

10024	9542	9203	9010	9009	9163	9681	10735
12142	13108	13719	13983	14085	14229	14214	13983
13040	13883	13581	13225	13119	13317	12771	11433
9968	9470	9162	9000	8951	9175	9613	10622
11896	12786	13371	13561	13605	13782	13765	13491
13459	13363	13064	12712	12633	12844	12340	11140
9599	9217	8972	8795	8767	9001	9427	10451
11731	12540	13059	13214	13179	13375	13382	13106
13064	12956	12643	12316	12227	12515	12036	10858
9696	9056	8690	8473	8333	8348	8446	8791
9552	10356	10971	11235	11310	11777	11142	11127
11193	11232	11122	10844	10787	11013	10668	9851
8986	8465	7856	7856	7775	7720	7653	7834
8386	8948	9305	9685	10017	10092	9991	9953
9990	10084	10116	10029	10116	10479	10296	9689

ENERGY= 1.81497600000000E+06;

9843	9348	9030	8847	8799	8993	9465	10465
11766	12707	13291	13526	13693	13795	13728	13514
13440	13341	13014	12631	12499	12687	12164	10982
9711	9211	8908	8762	8706	8901	9310	10246
11504	12356	12986	13134	13157	13309	13295	13071
13007	12921	12631	12272	12185	12454	11971	10833
9203	8753	8520	8311	8305	8523	8924	9732
10856	11664	12175	12411	12476	12541	12514	12267
12259	12215	11936	11612	11548	11855	11335	10353
9444	8770	8401	8176	8137	8122	8195	8571
9323	10113	10621	10544	10998	11013	10878	10768
10304	10841	10713	10459	10398	10625	10253	9490
9578	8187	7650	7650	7533	7528	7475	7643
8157	8669	8949	9306	9552	9595	9505	9463
9510	9601	9625	9551	9640	10101	9883	9291

ENERGY= 1.76144100000000E+06;

9702	9197	8895	8721	8636	8861	9297	10256
11473	12395	12958	13172	13398	13458	13350	13148
13050	12920	12574	12170	12017	12197	11699	10631
9510	9010	8711	8576	8516	8647	9075	9953
11199	12021	12548	12802	12809	12942	12929	12744
12655	12578	12294	11929	11836	12150	11685	10595
8318	8392	8168	7935	7945	8152	8533	9174
10176	10983	11488	11787	11840	11893	11840	11615
11632	11638	11386	11066	11024	11342	10897	9960
9255	8547	8177	7945	7985	7947	7981	8400
9146	9924	10388	10718	10756	10808	10641	10490
10497	10538	10396	10160	10095	10324	9930	9209
8439	7971	7490	7490	7345	7380	7336	7491
7979	8452	8673	9011	9190	9208	9135	9083
9137	9226	9244	9179	9271	9807	9562	8982

ENERGY= 1.68181000000000E+06;

9493	8973	8694	8532	8392	8664	9047	9943
11038	11931	12462	12643	12933	12955	12787	12604
12470	12292	11917	11482	11299	11467	10999	10109
9212	8711	8417	8300	8232	8369	8724	9517
10744	11522	12044	12307	12290	12394	12384	12257
12131	12066	11791	11418	11317	11698	11257	10240
8245	7855	7645	7375	7410	7598	7950	8341
9162	9969	10465	10858	10966	10927	10835	10642

9952	9476	9144	8955	8937	9105	9607	10643
12314	12971	13574	13827	13951	14081	14049	13823
13770	13698	13398	13022	12907	13102	12566	11279
9881	9382	9075	8919	8867	9082	9510	10494
11762	12639	13173	13415	13452	13621	13605	13347
13305	13212	12917	12562	12480	12711	12215	11036
9530	9059	8818	8630	8609	8838	9255	10206
11433	12241	12758	12940	12922	13091	13086	12820
12789	12703	12402	12076	11992	12290	11818	10685
9511	8959	8592	8372	8266	8271	8357	8716
9474	10273	10819	11136	11203	11197	11078	11004
11063	11099	10982	10713	10654	10981	10527	9728
8881	8370	7786	7786	7692	7654	7592	7771
8308	8853	9184	9556	9858	9923	9819	9786
9827	9920	9949	9866	9954	10350	10155	9553

ENERGY= 1.833500C0J0J0J0E+06:

9992	9401	9077	8892	8856	9039	9523	10539
11868	12816	13407	13650	13799	13912	13860	13641
13575	13488	13168	12792	12667	12857	12331	11104
9781	9281	8977	8826	8772	8975	9392	10348
11510	12472	13004	13250	13278	13437	13422	13184
13129	13041	12748	12391	12306	12560	12071	10917
9333	8879	8642	8442	8430	8653	9060	9927
11093	11901	12415	12629	12630	12767	12749	12495
12477	12415	12127	11803	11731	12034	11569	10490
9515	8847	8493	8256	8190	8184	8255	8631
9385	10179	10702	11023	11082	11085	10960	10865
10910	10947	10824	10563	10503	10700	10365	9588
8762	8262	7706	7706	7598	7580	7523	7695
8219	8745	9046	9409	9678	9730	9634	9596
9640	9732	9758	9680	9769	10200	9995	9399

ENERGY= 1.95064900000000E+06:

10200	9731	9372	9169	9214	9328	9891	10990
12509	13499	14136	14428	14467	14652	14689	14442
14429	14411	14134	13803	13723	13931	13360	11872
10270	9722	9410	9233	9190	9443	9909	10989
12279	13206	13745	13978	14041	14244	14224	13900
13900	13793	13487	13142	13071	13225	12700	11439
10182	9669	9412	9267	9218	9467	9917	11152
12584	13394	13921	13996	13915	14188	14228	13925
13950	13679	13332	13002	12980	13159	12661	11351
9935	9336	8972	8763	8524	8569	8701	9005
9775	10592	11214	11519	11614	11535	11479	11476
11597	11613	11520	11220	11166	11391	11074	10204
9297	8736	8056	8056	8011	7906	7826	8028
8510	9221	9652	10054	10470	10578	10444	10430
10459	10555	10594	10495	10580	10848	10698	10077

ENERGY= 1.89502400000000E+06:

10054	9574	9232	9037	9044	9191	9717	10780
12204	13174	13790	14058	14150	14301	14295	14061
14074	13973	13675	13323	13222	13421	12972	11508
10011	9513	9204	9040	8992	9271	9664	10685
11961	12857	13393	13632	13679	13961	13843	13560
13534	13436	13136	12786	12708	12909	12402	11191
9781	9254	9047	8875	8844	9080	9510	10570
11976	12685	13206	13347	13305	13513	13526	13246
13198	13079	12760	12433	12334	12625	12142	10942

10699	10780	10567	10251	10243	10578	10155	9375
8967	8214	7842	7600	7758	7685	7679	8146
8841	9643	10040	10381	10394	10503	10288	10075
10041	10085	9923	9714	9645	9874	9449	8790
8081	7649	7252	7252	7065	7158	7130	7265
7713	8128	8261	8572	8652	8632	8584	8516
8581	8667	8676	8625	8720	9368	9084	8521

ENERGY= 1.97034400000000E+06;

9989	9504	9170	8979	8969	9130	9639	10683
12069	13030	13636	13895	14009	14145	14121	13893
13844	13778	13472	13110	12999	13195	12655	11346
9919	9420	9113	8954	8904	9122	9555	10549
11820	12703	13237	13479	13518	13691	13674	13410
13372	13278	12981	12627	12547	12769	12269	11091
9603	9127	8884	8702	8678	8909	9330	10312
11562	12371	12498	13059	13034	13214	13214	12944
12909	12813	12506	12180	12092	12388	11912	10761
9648	9001	8634	8415	8295	8305	8395	8748
9508	10309	10863	11179	11250	11226	11123	11057
11122	11156	11043	10770	10712	10938	10588	9782
8927	8411	7816	7816	7728	7683	7618	7800
8342	8895	9236	9612	9927	9996	9889	9858
9898	9991	10021	9936	10024	10406	10216	9612

ENERGY= 1.82691400000000E+06;

9975	9382	9050	8876	8836	9023	9503	10513
11832	12777	13366	13606	13761	13871	13813	13596
13527	13436	13113	12735	12608	12797	12274	11061
9756	9257	8953	8804	8749	8949	9363	10312
11572	12431	12962	13209	13235	13392	13377	13144
13086	12999	12707	12349	12264	12522	12036	10887
9240	8834	8599	8396	8386	8607	9012	9858
11009	11818	12330	12552	12558	12687	12666	12414
12400	12344	12060	11736	11656	11971	11507	10442
9491	8820	8452	8228	8171	8162	8230	8610
9363	10155	10674	10995	11053	11060	10931	10831
10873	10910	10785	10527	10466	10693	10376	9553
8732	8236	7686	7686	7575	7562	7506	7677
8197	8718	9012	9372	9633	9682	9588	9549
9594	9686	9711	9634	9724	10167	9955	9361

ENERGY= 1.98338200000000E+06;

10023	9541	9203	9010	9008	9162	9680	10734
12141	13106	13717	13981	14084	14227	14213	13992
13939	13881	13579	13223	13117	13315	12769	11431
9968	9469	9161	8999	8950	9175	9612	10621
11895	12785	13319	13560	13603	13781	13764	13489
13458	13361	13063	12711	12632	12843	12339	11139
9697	9215	8970	8793	8765	8999	9425	10449
11728	12537	13056	13211	13177	13372	13379	13104
13061	12953	12640	12313	12220	12513	12034	10857
9695	9055	8689	8472	8333	8348	8445	8790
9551	10355	10920	11234	11309	11276	11181	11125
11196	11230	11120	10843	10786	11012	10667	9850
8985	8464	7855	7855	7774	7719	7652	7837
8386	8948	9304	9684	10015	10091	9979	9951
9989	10082	10114	10027	10114	10478	10294	9687

ENERGY= 1.86017600000000E+06;

9737	9104	8738	8522	8366	8386	8489	8827
9590	10396	10971	11284	11361	11321	11233	11186
11263	11297	11189	10978	10851	11077	10737	9911
9037	8511	7890	7890	7815	7751	7682	7870
8425	8995	9364	9748	10794	10175	10060	10034
10370	10164	10197	10168	10195	10542	10364	9755

ENERGY= 1.90992800J000J00E+06;

10093	9616	9270	9073	9090	9229	9763	10939
12286	13261	13893	14157	14235	14395	14401	14163
14132	14090	13798	13452	13356	13558	13002	11605
10367	9569	9259	9092	9045	9281	9729	10766
12046	12951	13487	13725	13776	13963	13945	13651
13632	13532	13231	12991	12805	12994	12482	11258
9888	9394	9145	8990	8944	9184	9619	10726
12066	12875	13397	13521	13468	13694	13714	13428
13373	13240	12913	12585	12480	12768	12281	11052
9791	9166	8801	8587	8408	8435	8546	8875
9639	10449	11036	11347	11429	11378	11299	11264
11348	11381	11278	10992	10936	11162	10827	9990
9104	8572	7935	7935	7867	7793	7721	7913
8474	9056	9441	9830	10195	10283	10163	10140
10174	10269	10303	10212	10298	10624	10454	9841

WEEKS= 4

MEAN\_POWER= 6.2690000J00J00E+03

MEAN\_ENERGY= 2.0241000J00J00E+06;

ENERGY= 1.955031J0000000E+06;

10331	9885	9615	9523	9537	9895	10808	12368
13399	13862	13993	14016	13819	13920	13791	13599
13542	13474	13430	13714	13730	13298	12476	11377
10178	9692	9497	9389	9416	9791	10680	12225
13294	13754	13949	13984	13813	13874	13770	13558
13499	13360	13254	13587	13650	13243	12401	11261
9760	9369	9152	9063	9080	9431	10358	11872
12903	13425	13745	13773	13612	13699	13581	13348
13349	13232	13163	13399	13363	12911	12061	10951
10056	9330	8938	8841	8800	8874	9152	9764
10580	11349	11712	11987	11671	11511	11311	11124
11170	11297	11461	11649	11531	11197	10631	9922
9160	8737	8213	8213	8167	8210	8316	8693
9310	9811	9905	10145	10327	10227	9934	9776
9782	10023	10335	10805	10957	10788	10300	9744

ENERGY= 1.9687150000000E+06;

9772	9257	8957	8849	8858	9164	9967	11513
12511	13071	13180	13216	12980	13035	13018	12830
12597	12374	12314	12921	12970	12551	11837	10800
9756	9190	8958	8846	8852	9200	9975	11502
12655	13117	13313	13399	13235	13293	13247	13094
12899	12497	12321	12973	13113	12775	11911	10820
9359	8987	8765	8675	8679	9048	10033	11725
12847	13394	13734	13802	13678	13911	13848	13618
13585	13179	13019	13515	13496	13001	12113	10872
9753	8955	8560	8374	8341	8379	8652	9244
10037	10843	11278	11461	11247	11111	10899	10684
10539	10566	10797	11202	11116	10792	10245	9550
8763	8355	7762	7762	7723	7731	7826	8192
8772	9336	9419	9678	9863	9805	9513	9300
9207	9233	9559	10250	10459	10292	9833	9268

ENERGY= 1.9728050000000E+06;






#### A.5 Chronologic Load Model Sensitivity Study

The survey nature of the production cost program required a reduction of variables to improve its cost performance. A sensitivity study of load models was undertaken to find a configuration that would retain system accuracy for a minimum number of time intervals simulated. The criterion used for judging system accuracy was incremental capacity factors. Initially, simple averaging techniques were considered. The 168-hour-per-week representation (Figure A.2) were reduced to 84 2-hour intervals (Figure A.3) and 56 3-hour intervals (Figure A.4). Such arbitrary methods proved lacking, in sufficient detail. The use of non-uniform time intervals proved more satisfactory. Starting with the 168-hour representation (Figure A.1) the investigation's depth reached the extreme of a four-interval-per-week load model (Figure A.5) which represented the high and the low of the weekdays, and the high and the low of the weekend. For these two models, a comparison of the system cost of the four-interval load model was calculated very close to the reference 168-interval model, see Table A.2. This effect was due to a cancellation of errors. The closeness in system costs between the '4' and '168' is due to the very coarse time intervals used in the '4' load model. Averaging time intervals generally lowers system production cost due to the fact that peakers operate at higher cost than the base load increments, thus averaging substitutes lower cost energy for

Figure A.2

168-HOUR REPRESENTATIVE OF THE CUSTOMER  
DEMAND FOR THE WEEK OF JAN. 4, 1971



- 247 -




FIGURE A.3 84 INTERVAL REPRESENTATION OF THE CUSTOMER DEMAND FOR THE WEEK OF JAN. 4, 1971

Figure A.4

56-Interval Representation of the Customer Demand

for the Week of Jan. 4, 1971




FIGURE A.5 COMPARISON OF 4-INTERVAL  
LOAD MODEL WITH 168-INTERVAL  
LOAD MODEL ON WINTER DATA




Table A.2

Optimal System Cost Comparison of 6 Load Models  
(on Winter Load Data and Cost Plan 1)

<u>Load Model (Intervals/week)</u>	<u>Total System Cost (\$10<sup>3</sup>/wk)</u>
4	10,648
19	10,553
40	10,613
42	10,574
84	10,612
168	10,628

high cost energy. Table A.2 shows the trend in lower production cost with the decrease in the number of time intervals being simulated. However, the coarseness of the '4' model causes large amounts of nuclear energy to be used at inefficient (low) power levels, forcing the greater use of fossil fuel, thus offsetting the averaging effect. Of course, the capacity factors criterion for the four-interval model was not satisfied as shown in Figure A.6 .

As with the simple averaging technique, the next set of models preserved the seven-day representation explicitly. There was a 42-interval load model, (Figure A.7) consisting of 7 days/week and 6 intervals/day. Also an 84-interval load model (Figure A.8) consisting of 7 days/week and 12 intervals/day. Figures A.6 and A.9 shows how these models compare with the reference case. As expected the 84-interval load model did best in reproducing the incremental capacity factors. The next modeling simplification step was to combine the average weekdays together because of their strong similarity. A 19-interval load model (Figure A.10) representing one peak day of 6 intervals, and average day (composite of the four other week days) of 6 intervals and a weekend of 7 intervals was compared with the previous results. Figure A.11 shows that the 19-interval load model very closely reproduced the results of the 42-interval load model. Both models represented 6 time intervals per day. Thus the similarity in weekdays could be used effectively to reduce the number



FIGURE A.6 COMPARISON OF INCREMENTAL FOSSIL  
CAPACITY FACTORS ON WINTER  
LOAD DATA AND COST PLAN 1

- (X) 4-Interval Load Model
- (+) 42-Interval Load Model
- (Line) 168-Interval Load Model




FIGURE A.7 COMPARISON OF 42-INTERVAL LOAD MODEL WITH 168-INTERVAL LOAD MODEL ON WINTER DATA

(+) 42-Interval Load Model  
(Line) 168-Interval Load Model




FIGURE A.8 COMPARISON OF 84-INTERVAL LOAD MODEL  
WITH 168-INTERVAL LOAD MODEL  
ON WINTER DATA

Legend

(+) 84-Interval Load Model  
(Line) 168-Interval Load Model




FIGURE A.9 COMPARISON OF INCREMENTAL FOSSIL  
CAPACITY FACTORS ON WINTER  
LOAD DATA AND COST PLAN 1

Legend

- (+) 84-Interval Load Model
- (Line) 168-Interval Load Model




FIGURE A.10 COMPARISON OF 19-INTERVAL LOAD MODEL  
WITH 168-INTERVAL LOAD MODEL  
ON WINTER DATA

Legend

- (+) 19-Interval Load Model
- (Line) 168-Interval Load Model





FIGURE A.11 COMPARISON OF INCREMENTAL FOSSIL  
CAPACITY FACTORS ON WINTER  
LOAD DATA AND COST PLAN 1

Legend

- (X) 19-Interval Load Model
- (+) 42-Interval Load Model
- (Line) 168-Interval Load Model



of time intervals that had to be simulated. Table A.2 compares the weekly system production costs of the various load models using the same input parameters.

Accordingly, a 40-interval load model (Figure A.12) was formed, representing a peak weekday (10 intervals), a low weekday (10 intervals), an average weekday (composite of the three other weekdays, 10 intervals) and a weekend (10 intervals). The comparison of incremental capacity factors is shown in Figure A.13. To demonstrate that the good comparison was not coincidental, a comparison of the 40-interval load model with the 168-interval load model was made for summer load model data, instead of winter, see Figure A.14. The comparison of incremental capacity factors with the reference (168-hours) case was again favorable, shown in Figure A.15. The small aberrations at the high increments seem to be due to the pumped storage model.

As a further test, fossil fuel costs were changed from "Cost Plan 1" to "Cost Plan 2", Table A.3, so that the loading order of the fossil units was different. Figure A.16 shows that the incremental capacity factor distributions for the 40-interval load model and the 168-interval load model were very similar for "Cost Plan 2", also (see Figure A.13 for Cost Plan 1). The results justify using the 40-interval load model for future simulation studies in place of a 168-interval representation. Table A.4 compares the weekly system production cost of the 40-interval load model and the reference load model for the various tests referred to

FIGURE A.12 COMPARISON OF 40-INTERVAL LOAD MODEL WITH 168-INTERVAL LOAD MODEL ON WINTER DATA

Legend  
(+) 40-Interval Load Model  
(Line) 168-Interval Load Model






FIGURE A.13 COMPARISON OF INCREMENTAL FOSSIL  
CAPACITY FACTOR ON WINTER  
LOAD DATA AND COST PLAN 1

Legend

- (X) 40-Interval Load Model
- (+) 84-Interval Load Model
- (Line) 168-Interval Load Model




FIGURE A.14 COMPARISON OF 40-INTERVAL LOAD MODEL WITH 168-INTERVAL LOAD MODEL ON SUMMER DATA




FIGURE A.15 COMPARISON OF INCREMENTAL FOSSIL  
CAPACITY FACTORS ON SUMMER  
LOAD DATA AND COST PLAN 1

Legend

- (+) 40-Interval Load Model
- (Line) 168-Interval Load Model




TABLE A.3

FOSSIL PLANT DATA USED IN SENSITIVITY STUDY

1. Standardized Average Heat Data:

	<u>Power Level (% capacity)</u>	<u>Average Heat Rate (million Btu/MWhe)</u>
Large:	0.64	8.98
	1.00	8.92
Medium:	0.40	9.50
	0.80	8.90
	1.00	8.90
Small:	0.40	13.50
	0.60	12.70
	0.80	12.50
	1.00	12.80

2.	<u>Number of 'classes' of plants</u>	<u>Number of Valve Points</u>
Large:	6	2
Medium:	6	3
Small:	3	4

3. Information on each class of plants:

	<u>No. in Class</u>	<u>Rated Capacity(MW)</u>	<u>Avg Heat Rate (10<sup>6</sup>Btu/MWhe)</u>	<u>Cost 1 (¢/10<sup>6</sup>Btu)</u>	<u>Cost 2 (¢/10<sup>6</sup>Btu)</u>
Large:	4	1,300	8.5	40	60
	4	800	9.3	80	40
	2	600	9.1	80	40
	1	580	9.0	60	80
	1	525	9.1	40	60
	1	400	9.2	60	80
	Medium:	1	300	9.3	80
3		240	9.1	40	60
2		225	10.0	80	40
3		215	9.8	40	60
1		210	9.2	60	80
2		205	9.8	60	80
Small:		5	150	9.4	40
	1	105	10.2	80	40
	1	100	10.8	60	80

FIGURE A.16 COMPARISON OF INCREMENTAL FOSSIL  
CAPACITY FACTORS ON WINTER  
LOAD DATA AND COST PLAN 2

Legend

- (+) 40-Interval Load Model
- (Line) 168-Interval Load Model




Table 1.4

"Optimal System Cost Comparison of 40 Int/wk  
Load Model with 168 Int/wk  
Load Model (Units:  $\$10^3/\text{wk}$ )"

<u>Load Model (Intervals/wk)</u>	<u>Winter Load, Cost Plan 1</u>	<u>Winter Load Cost Plan 2</u>	<u>Summer Load, Cost Plan 1</u>
40	10,613	10,371	9,444
168	10,628	10,373	9,437

above. The agreement is favorable. Table A.3 also lists the plant parameters used in this study.

#### A.6 Load-Duration Sensitivity Study

The explicit simulation of 168 hours of the week is a costly calculation. It has been shown in the chronologic load model sensitivity study that little accuracy is lost in the prudent combination of time intervals to reduce the explicit number of intervals simulated. Depending on the particular feature of system the simulation model is trying to reproduce, the minimum number of time intervals will vary accordingly. In the previous section, the system feature to be reproduced was the incremental capacity factors, which allowed only a moderate reductions in the number of time intervals. In the reproduction of the OCNP, much less detail of the system need be reproduced. The chronologic pattern of the load model is not essential. The detailed simulation of high peaking demand intervals and low demand intervals is not so important. To find the correct value of OCNP, the model must locate the correct alternative cost to nuclear energy only at the time the nuclear energy is being exhausted. The difficulty of finding the correct alternative cost depends on the fine structure of the incremental fossil loading order. Table A.5 shows a typical fossil incremental loading order derived from a large 15,000 MWe capacity utility system. In the area of interest, the middle section of the loading order, the interval width vary from 100 MWe to 300 MWe. Some contiguous intervals have the same energy cost or only slight differences. Thus, it seems a great amount of latitude is available in reproducing the



Table A.5

TYPICAL ECONOMIC LOADING ORDER

INCREMENTAL STEP	STEP SIZE	CUMULATIVE SIZE	INCREM. FUEL COST	CUMULATIVE INCREM. FUEL COST
1	105	105	3.00	314.99
2	105	210	3.20	650.91
3	320	530	3.58	1796.26
4	320	850	3.82	3017.70
5	43	893	4.16	3196.68
6	120	1013	4.29	3710.96
7	43	1056	4.46	3902.85
8	120	1176	4.57	4451.29
9	60	1236	4.63	4728.87
10	116	1352	4.66	5269.71
11	135	1487	4.66	5899.21
12	135	1622	4.66	6528.70
13	43	1665	4.72	6731.61
14	43	1708	4.72	6934.52
15	80	1788	4.77	7315.81
16	60	1848	4.96	7613.40
17	116	1964	4.97	8190.16
18	135	2099	5.00	8865.16
19	168	2267	5.03	9709.64
20	168	2435	5.03	10554.11
21	43	2478	5.06	10771.69
22	80	2558	5.08	11178.30
23	43	2601	5.25	11404.05
24	168	2769	5.39	12309.57
25	60	2829	5.84	12659.68
26	260	3089	6.40	14324.95
27	96	3185	6.79	14976.72
28	96	3281	6.79	15628.48
29	260	3541	6.83	17404.38
30	96	3637	7.28	18103.26
31	60	3697	7.74	18567.90
32	60	3757	8.30	19066.03
33	48	3805	8.49	19473.38
34	48	3853	8.49	19880.73
35	48	3901	9.10	20317.53
36	56	3957	9.11	20827.51
37	56	4013	9.11	21337.48
38	160	4173	9.30	22824.93
39	160	4333	9.32	24316.90
40	56	4389	9.77	24863.74
41	60	4449	9.77	25449.77
42	260	4709	9.89	28021.15
43	160	4869	9.91	29607.41
44	160	5029	9.94	31198.49
45	21	5050	10.23	31413.38
46	260	5310	10.55	34155.58
47	21	5331	10.97	34385.95
48	21	5352	12.91	34656.99
49	29	5381	14.45	35075.96
50	29	5410	15.49	35525.13
51	29	5439	18.22	36053.56
52	1500	6939	25.00	73553.56

correct OCNP, as is shown by the experimental results.

Two system environments were used in the sensitivity study of load-duration models. An April load model with a non-nuclear system capacity of 12,000 MWe and an August load model with a non-nuclear system capacity of 13,000 MWe. The system parameters for the April and August system environments were the same as those used in the single reactor optimization study (Case 1) except for the modeling of the large fossil units. The large fossil units had a minimum operating level of 60% instead of 40% as used in the optimization studies.

Studying the situation of varying the capacity factor of a single reactor (1100 MWe, constant heat-rate), the April simulations were tested for load-duration models of 25, 12, 8, 6, 5, 4, 3, 2 time intervals. The list of resulting OCNP, system's cost, and incremental capacity factors are tabulated in Tables A.6, A.7, and A.8, respectively. As the number of time intervals decreases the OCNP values hardly change until the very end. The system cost numbers show only slight deterioration and even then, the changes are proportional for the various nuclear capacity factors (implying incremental system costs are the same for the various models, reinforcing the OCNP results). The incremental capacity factors, though, show marked deterioration with the reduction in the number of time intervals.

A similar single reactor case was repeated with the

TABLE A.6

OCNP COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(ONE REACTOR, APRIL LOAD DATA CASE)

<u>Weekly Nuclear Capacity Factor</u>	<u>Number of Time Intervals in Load-Duration Model:</u>	<u>OCNP (mills/10,000 Btut)</u>							
		<u>25</u>	<u>12</u>	<u>8</u>	<u>6</u>	<u>5</u>	<u>4</u>	<u>3</u>	<u>2</u>
0.2		23.81	23.81	23.81	23.81	23.81	23.81	23.81	23.81
0.3		23.81	23.81	23.81	23.81	23.81	23.81	23.81	10.04
0.4		10.04	10.04	10.04	10.04	10.04	10.04	10.04	10.04
0.5		8.88	8.88	8.88	8.88	8.85	8.88	8.67	9.47
0.6		6.51	6.51	6.51	6.51	6.51	6.51	6.51	6.10
0.7		6.10	6.10	6.10	6.10	6.10	6.10	6.10	5.13
0.8		4.84	4.84	4.84	4.84	4.84	4.84	4.82	4.84
0.9		4.76	4.76	4.76	4.76	4.79	4.76	4.76	4.79

TABLE A.7  
WEEKLY SYSTEM COST COMPARISON FOR LOAD-DURATION STUDY  
 (ONE REACTOR, APRIL LOAD DATA CASE)

<u>Weekly Nuclear Capacity Factor</u>	<u>System Production Costs (\$/wk)</u>			
	<u>Number of Time Intervals in Load Duration Model</u>			
	<u>25</u>	<u>12</u>	<u>8</u>	<u>6</u>
0.2	12,320,625	12,319,115	12,316,938	12,309,568
0.3	11,858,624	11,857,114	11,854,938	11,847,568
0.4	11,612,667	11,606,230	11,604,761	11,600,661
0.5	11,428,551	11,421,840	11,420,752	11,416,081
0.6	11,275,089	11,268,589	11,267,895	11,264,759
0.7	11,151,751	11,145,449	11,144,807	11,142,240
0.8	11,047,553	11,041,104	11,040,363	11,039,196
0.9	10,954,547	10,948,067	10,947,350	10,946,179
	<u>5</u>	<u>4</u>	<u>3</u>	<u>2</u>
0.2	12,305,089	12,311,116	12,296,722	12,060,314
0.3	11,843,089	11,849,116	11,834,722	11,772,658
0.4	11,603,239	11,598,939	11,587,959	11,577,751
0.5	11,417,442	11,412,132	11,400,531	11,391,234
0.6	11,268,732	11,250,882	11,252,150	11,222,610
0.7	11,140,423	11,135,831	11,127,149	11,107,190
0.8	11,035,965	10,030,987	11,026,651	11,009,242
0.9	10,942,978	10,937,927	10,933,787	10,916,154

TABLE A.8  
INCREMENTAL CAPACITY FACTOR COMPARISON FOR THE  
LOAD DURATION SENSITIVITY STUDY  
(Single Reactor, April Load Data Case)

The following tables are a comparison of the capacity factors of the 52 fossil increments in the April economic loading from eight load-duration models. The tables are arranged as follows:

The increments are labeled horizontally and the number of intervals in the load-duration models are labeled vertically. There is a separate table for each of eight values of the weekly nuclear capacity factor, ordered by descending values.

TABLE A.8A  
FOSSIL INCREMENTAL CAPACITY FACTOR COMPARISON FOR  
0.90 WEEKLY NUCLEAR CAPACITY FACTOR

INCRE:	1	2	3	4	5	6	7	8	9	10
N 25:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
T 12:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
E 8:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
R 6:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
V 5:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
A 4:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
L 3:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
S 2:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
INCRE:	11	12	13	14	15	16	17	18	19	20
N 25:	1.00	1.00	1.00	1.00	1.00	0.99	0.99	0.92	0.73	0.70
T 12:	1.00	1.00	1.00	1.00	1.00	1.00	0.98	0.94	0.71	0.71
E 8:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.96	0.72	0.67
R 6:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.92	0.71	0.71
V 5:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.74	0.64
A 4:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.95	0.84	0.71
L 3:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.92	0.71	0.71
S 2:	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.94	0.58
INCRE:	21	22	23	24	25	26	27	28	29	30
N 25:	0.69	0.66	0.64	0.63	0.61	0.59	0.57	0.57	0.52	0.50
T 12:	0.66	0.64	0.64	0.64	0.64	0.58	0.58	0.58	0.51	0.51
E 8:	0.67	0.67	0.67	0.64	0.58	0.58	0.58	0.58	0.53	0.48
R 6:	0.71	0.71	0.71	0.59	0.58	0.58	0.58	0.58	0.53	0.47
V 5:	0.64	0.64	0.64	0.64	0.64	0.64	0.53	0.50	0.50	0.50
A 4:	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.50
L 3:	0.71	0.71	0.71	0.71	0.71	0.61	0.47	0.47	0.47	0.47
S 2:	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58
INCRE:	31	32	33	34	35	36	37	38	39	40
N 25:	0.49	0.48	0.48	0.48	0.48	0.47	0.46	0.46	0.46	0.45
T 12:	0.49	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.46	0.45
E 8:	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.47	0.45	0.45
R 6:	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47
V 5:	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.47	0.43	0.43
A 4:	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
L 3:	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47
S 2:	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58	0.58
INCRE:	41	42	43	44	45	46	47	48	49	50
N 25:	0.45	0.42	0.37	0.35	0.33	0.20	0.02	0.02	0.02	0.02
T 12:	0.45	0.42	0.37	0.37	0.37	0.20	0.00	0.00	0.00	0.00
E 8:	0.45	0.44	0.35	0.35	0.35	0.21	0.00	0.00	0.00	0.00
R 6:	0.47	0.40	0.37	0.37	0.37	0.20	0.00	0.00	0.00	0.00
V 5:	0.43	0.43	0.43	0.43	0.43	0.11	0.00	0.00	0.00	0.00
A 4:	0.45	0.45	0.45	0.45	0.45	0.07	0.00	0.00	0.00	0.00
L 3:	0.47	0.47	0.47	0.47	0.47	0.00	0.00	0.00	0.00	0.00
S 2:	0.58	0.58	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
INCRE:	51	52								
N 25:	0.02	0.00								
T 12:	0.00	0.00								
E 8:	0.00	0.00								
R 6:	0.00	0.00								
V 5:	0.00	0.00								
A 4:	0.00	0.00								
L 3:	0.00	0.00								
S 2:	0.00	0.00								

















August system environment. Tables A.9, A.10, and A.11 show the resulting comparison of OCNP, system costs, and incremental capacity factors for six load-duration models, (20, 12, 10, 8, 6, and 4 time intervals per week). The August simulations verify the results of the April simulations.

Two-reactor simulations were also tested in the April and August environments. The April system tested two reactors (constant heat-rate) of 1100 MWe and 220 MWe rated capacity for 12 load-duration models. The resulting OCNP and system costs are tabulated in Tables A.12 and A.13, respectively. The OCNP results (Table A.12) continued to be reproduced faithfully, even at a very small number of time intervals.

In the August environment, two reactors of 1100 MWe each were simulated for 6 load models, but for a wider range of capacity factors. The resulting comparison of OCNP and system costs are shown in Tables A.14 and A.15, respectively. The results of these comparisons confirm the hypothesis that OCNP (and changes in system costs) are reproducible by load-duration models of only 6 time intervals. See Section 5.2 for more details on the load-duration study.

TABLE A.9

THE OCNP COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(ONE REACTOR, AUGUST LOAD DATA CASE)

<u>Weekly Nuclear Capacity Factor</u>	<u>Number of Time Intervals in Load-Duration Model:</u>	<u>OCNP (mills/10,000 Btu-th)</u>					
		<u>20</u>	<u>12</u>	<u>10</u>	<u>8</u>	<u>6</u>	<u>4</u>
0.2		8.88	8.88	8.88	8.88	8.88	8.88
0.3		8.67	8.67	8.67	8.67	8.67	8.67
0.4		6.93	6.93	6.93	6.93	6.93	8.08
0.5		6.10	6.10	6.10	6.10	6.10	6.10
0.6		4.79	4.79	4.79	4.82	4.79	4.79
0.7		4.54	4.54	4.64	4.64	4.54	4.64
0.8		4.44	4.44	4.44	4.44	4.44	4.44
0.9		3.64	3.64	3.64	3.64	3.64	3.64

TABLE A.10

THE WEEKLY PRODUCTION COST COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(ONE REACTOR, AUGUST LOAD DATA CASE)

Weekly Nuclear Capacity Factor	System Production Cost (\$/wk)		
	Number of Time Intervals in Load-Duration Model		
	<u>20</u>	<u>12</u>	<u>10</u>
0.2	12,126,049	12,125,590	12,124,706
0.3	11,955,110	11,954,576	11,953,615
0.4	11,801,502	11,801,444	11,799,836
0.5	11,677,486	11,677,295	11,675,563
0.6	11,571,443	11,571,240	11,569,983
0.7	11,479,508	11,479,297	11,477,874
0.8	11,392,916	11,392,719	11,391,287
0.9	11,312,014	11,311,172	11,310,365
	<u>8</u>	<u>6</u>	<u>4</u>
0.2	12,123,395	12,120,193	12,117,263
0.3	11,952,387	11,949,809	11,946,262
0.4	11,798,681	11,795,791	11,784,845
0.5	11,674,318	11,671,559	11,657,874
0.6	11,569,802	11,569,539	11,551,462
0.7	11,477,845	11,475,850	11,458,602
0.8	11,391,814	11,389,223	11,372,640
0.9	11,309,118	11,307,993	11,292,590



TABLE A.11  
INCREMENTAL CAPACITY FACTOR COMPARISON FOR THE  
LOAD DURATION SENSITIVITY STUDY  
(Single Reactor, August Load Data Case)

The following tables are a comparison of the capacity factors of the 60 fossil increments in the August economic loading from six load-duration models. The tables are arranged as follows:

The increments are labeled horizontally, and the number of intervals in the load-duration models are labeled vertically. There is a separate table for each of eight values of the weekly nuclear capacity factor, ordered by descending values.



















TABLE A.12

OCNP COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(TWO-REACTOR, APRIL LOAD DATA CASE)

Weekly Nuclear  
Capacity Factor  
of Two Reactors

	<u>OCNP (mills/10,000 Btut)</u>					
	<u>Number of Time Intervals in Load-Duration Model</u>					
	<u>50</u>	<u>30</u>	<u>20</u>	<u>15</u>	<u>10</u>	<u>9</u>
0.70/0.80	5.13/3.59	5.13/3.59	5.13/3.59	5.13/3.59	5.13/3.59	5.59/3.89
0.80/0.80	4.79/3.35	4.79/3.35	4.79/3.35	4.79/3.35	4.79/3.35	4.79/3.35
0.90/0.80	4.76/3.33	4.76/3.33	4.76/3.33	4.76/3.33	4.76/3.33	4.76/3.33
	<u>8</u>	<u>7</u>	<u>6</u>	<u>5</u>	<u>4</u>	<u>3</u>
0.70/0.80	5.13/3.59	5.13/3.59	5.13/3.59	5.56/3.59	5/13/3.59	5.56/3.59
0.80/0.80	4.79/3.35	4.79/3.35	4.79/3.35	4.79/3.35	4.79/3.35	4.79/3.35
0.90/0.80	4.76/3.33	4.76/3.33	4.76/3.33	4.76/3.33	4.76/3.35	4.76/3.33

TABLE A.13

SYSTEM COST COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(TWO REACTOR, APRIL LOAD DATA CASE)

<u>Weekly Nuclear Capacity Factor of Two Reactors</u>	<u>System Cost (\$/week)</u>					
	<u>Number of Time Intervals in Load-Duration Model</u>					
	<u>50</u>	<u>30</u>	<u>20</u>	<u>15</u>	<u>10</u>	<u>9</u>
0.70/0.80	10,891,033	10,890,930	10,890,610	10,890,670	10,889,568	10,888,652
0.80/0.80	10,794,546	10,794,461	10,794,133	10,794,234	10,793,073	10,792,347
0.90/0.80	10,701,758	10,701,672	10,701,346	10,701,446	10,700,240	10,699,562
	<u>8</u>	<u>7</u>	<u>6</u>	<u>5</u>	<u>4</u>	<u>3</u>
0.70/0.80	10,889,067	10,887,958	10,889,119	10,884,958	10,885,562	10,879,209
0.80/0.80	10,792,630	10,791,548	10,792,383	10,787,979	10,789,553	10,789,811
0.90/0.80	10,699,834	10,698,710	10,699,622	10,695,174	10,696,690	10,689,051

TABLE A.14

OCNP COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(TWO-REACTOR, AUGUST LOAD DATA CASE)

<u>Weekly Nuclear Capacity Factors of Two Reactors</u>	<u>OCNP (Mills/10,000 Btut)</u>			
	<u>Number of Time Intervals in Load-Duration Model</u>			
	<u>12</u>	<u>10</u>	<u>8</u>	<u>6</u>
0.50/0.80	4.76/4.44	4.76/4.44	4.76/4.44	4.76/4.44
0.60/0.80	4.44/4.44	4.44/4.44	4.44/4.44	4.44/4.44
0.70/0.80	4.25/4.25	4.08/4.08	4.25/4.25	4.25/4.25
0.80/0.80	3.64/3.64	3.64/3.64	3.64/3.64	3.64/3.64
0.90/0.80	3.41/3.41	3.41/3.41	3.41/3.41	3.41/3.41

TABLE A.15

SYSTEM COST COMPARISON FOR THE LOAD-DURATION SENSITIVITY STUDY  
(TWO-REACTOR, AUGUST LOAD DATA CASE)

<u>Weekly Nuclear Capacity Factors of Two Reactors</u>	<u>System Cost (\$/week)</u>			
	<u>Number of Time Intervals in Load-Duration Model</u>			
	<u>12</u>	<u>10</u>	<u>8</u>	<u>6</u>
0.50/0.80	10,752,167	10,752,579	10,751,793	10,749,149
0.60/0.80	10,663,824	10,664,374	10,663,790	10,661,248
0.70/0.80	10,578,992	10,579,644	10,579,004	10,576,414
0.80/0.80	10,503,629	10,504,303	10,503,708	10,501,378
0.90/0.80	10,434,784	10,435,423	10,434,828	10,432,045

Appendix B: SYSTEM PARAMETERS


B.1 Nuclear Heat-Rates

The nuclear heat-rate data used throughout this study are obtained from Figure B.1, a result of an analytic fit made by Prof. M. Benedict from points supplied by Commonwealth Edison. Individual data points are not shown to preserve the confidentiality of the material. Of particular interest, Figure B.1 shows that operating a nuclear reactor below 70% rated capacity results in high inefficiencies. Thus, a program to maximize nuclear utilization would avoid operation below 70% as much as possible, even to the extent of shutting down.

B.2 Fossil Heat Rates


Fossil heat-rates used in this report are obtained from a number of analytic fits derived by the author from plant data supplied by Commonwealth Edison. The plant data were measured in the years 1958-1962, and it seems to be utility practice not to update such data with the age of the plants. As such, a cause of significant deviations from optimal operations of a utility system may possibly lie in the outdated heat-rate statistics used(28). Considering the approximate nature of the statistics to the actual performance levels, standardized heat-rate curves were derived for the three types of fossil plants for which data was available: large fossil (300 - 600 MWe), medium fossil (150 - 300 MWe), and small fossil (150 - 50 MWe). The heat-rate used for individual plant would be obtained by

Figure B.1 NUCLEAR HEAT CURVE



multiplying the appropriate standardized heat-rate by an individual plant factor (average heat-rate at rated capacity) to lower or raise the standard curve to fit individual plant characteristics. During 1960, Commonwealth Edison had no data for the 1000 MWe class of fossil plants because none existed. Thus the heat-rates of plants used in this study are derived from the large fossil standardized heat-rate curve whereas if data were available, it would be more appropriate to use a separate standardized heat-rate curve for these extra large fossil units. Figures B.2, B.3, and B.4 show the analytically fitted standardized heat-rate curves derived for large, medium and small fossil units, respectively. The individual data points are not shown to preserve the confidentiality of the material.









Figure B.4  
SMALL FOSSIL HEAT CURVE



B.3 OCNP Values from Case 2

TABLE B.3.1

WEEKLY OCNP FUNCTIONS OF UNIT 1 FOR APRIL  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 2</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>0.95</u>
		<u>Unit 1:</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	
		<u>OCNP (mills/KWhe) of Unit 1</u>					
1	0.20	8.86	6.83	6.79	6.09	5.03	
	0.16	8.86	6.83	6.79	6.09	5.25	
	0.12	9.10	7.38	6.83	6.40	5.25	
	0.08	9.30	7.38	6.83	6.40	5.25	
2	0.20	9.10	7.74	6.83	6.09	5.08	
	0.16	9.10	8.30	6.83	6.40	5.39	
	0.12	9.30	8.83	6.83	6.40	5.39	
	0.08	9.32	8.83	7.28	6.40	5.39	
3	0.20	8.49	6.79	6.09	5.25	5.03	
	0.16	8.49	6.79	6.40	5.39	5.03	
	0.12	8.49	6.83	6.40	5.84	5.03	
	0.08	8.83	6.83	6.40	5.84	5.03	
4	0.20	6.40	5.39	5.03	4.97	4.66	
	0.16	6.40	5.39	5.03	5.00	4.72	
	0.12	6.79	5.84	5.08	5.03	4.77	
	0.08	6.79	6.09	5.08	5.03	4.77	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 1 FOR MAY  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 2</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>0.95</u>
		<u>Unit 1:</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	
							<u>OCNP (mills/KWHe) of Unit 1</u>
5	0.40	8.86	7.65	6.79	5.25	5.03	
	0.32	8.86	8.05	7.28	6.79	5.22	
	0.24	8.86	8.59	7.65	6.79	5.39	
	0.16	9.30	8.83	8.05	6.79	5.39	
6	0.40	8.30	6.79	5.39	5.03	4.96	
	0.32	8.30	6.79	5.84	5.15	5.03	
	0.24	8.83	7.65	6.79	5.39	5.03	
	0.16	8.86	7.74	6.79	5.39	5.03	
7	0.40	8.83	6.79	6.50	5.03	5.00	
	0.32	8.83	7.28	6.79	5.39	5.03	
	0.24	8.86	8.05	7.28	6.50	5.06	
	0.16	9.11	8.30	7.28	6.50	5.06	
8	0.40	8.86	7.74	6.79	5.39	4.79	
	0.32	8.86	8.05	7.28	6.79	5.25	
	0.24	9.11	8.83	8.05	6.79	5.39	
	0.16	9.32	8.83	8.05	6.79	5.39	
9	0.40	7.74	5.39	5.03	5.00	4.66	
	0.32	7.74	6.79	5.39	5.03	4.97	
	0.24	8.30	7.28	6.50	5.06	5.00	
	0.16	8.83	7.28	6.79	5.06	5.00	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 1 FOR JUNE  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 2</u>	<u>Weekly Nuclear Capacity Factors of</u>					
		<u>Unit 1:</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	<u>0.95</u>
		<u>OCNP (mills/KWHe) of Unit 1</u>					
10	0.60	6.40	5.39	5.03	4.71	4.56	
	0.54	6.40	5.39	5.03	4.96	4.66	
	0.48	6.40	5.84	5.08	5.00	4.71	
	0.42	6.40	6.09	5.39	5.03	4.71	
	0.36	6.40	6.09	6.09	5.03	4.71	
11	0.60	6.40	6.09	5.06	4.98	4.63	
	0.54	6.40	6.09	5.08	5.00	4.71	
	0.48	6.40	6.09	5.39	5.03	4.98	
	0.42	6.40	6.09	6.09	5.15	4.98	
	0.36	6.40	6.40	6.09	5.25	4.98	
12	0.60	6.09	5.08	5.00	4.66	4.52	
	0.54	6.09	5.08	5.00	4.71	4.66	
	0.48	6.09	5.39	5.03	4.98	4.66	
	0.42	6.09	6.09	5.08	5.03	4.66	
	0.36	6.40	6.09	5.39	5.03	4.66	
13	0.60	6.09	5.03	4.96	4.66	4.28	
	0.54	6.09	5.03	4.96	4.66	4.56	
	0.48	6.09	5.03	5.00	4.71	4.66	
	0.42	6.09	5.25	5.03	4.98	4.66	
	0.36	6.09	5.84	5.06	5.00	4.66	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 1 FOR JULY  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 2</u>	<u>Weekly Nuclear Capacity Factors of</u>				
		<u>Unit 1:</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>
		<u>OCNP (mills/KWHe) of Unit 1</u>				
14	0.80	4.96	4.56	4.28	3.82	3.50
	0.72	4.96	4.56	4.28	4.07	3.82
	0.64	4.96	4.63	4.56	4.28	4.07
	0.56	4.96	4.66	4.56	4.52	4.07
	0.48	5.03	4.87	4.66	4.56	4.07
15	0.80	6.09	5.03	4.71	4.56	4.07
	0.72	6.09	5.03	4.77	4.66	4.52
	0.64	6.09	5.03	5.00	4.71	4.63
	0.56	6.09	5.25	5.03	4.96	4.66
	0.48	6.09	5.84	5.15	5.00	4.66
16	0.80	5.39	4.87	4.66	4.46	3.82
	0.72	5.39	4.87	4.66	4.56	4.28
	0.64	5.39	5.03	4.77	4.66	4.56
	0.56	5.39	5.03	5.00	4.71	4.56
	0.48	6.09	5.25	5.03	4.87	4.56
17	0.80	6.09	5.03	4.77	4.56	4.07
	0.72	6.09	5.03	4.87	4.66	4.56
	0.64	6.09	5.06	5.00	4.77	4.66
	0.56	6.09	5.39	5.03	5.00	4.66
	0.48	6.09	6.09	5.25	5.03	4.66
18	0.80	5.84	5.00	4.66	4.56	4.07
	0.72	5.84	5.00	4.71	4.63	4.52
	0.64	5.84	5.03	5.00	4.71	4.56
	0.56	5.84	5.22	5.03	4.96	4.66
	0.48	6.09	5.52	5.08	5.00	4.66

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 1 FOR AUGUST  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 2</u>	<u>Weekly Nuclear Capacity Factors</u>						
		<u>Unit 1:</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	<u>0.95</u>	
			<u>OCNP (mills/KWHe) of Unit 1</u>					
19	1.00		5.03	4.71	4.66	4.28	3.58	
	0.90		5.03	4.71	4.66	4.56	4.28	
	0.80		5.03	4.98	4.71	4.66	4.56	
	0.70		5.08	5.03	4.98	4.71	4.63	
	0.60		5.84	5.08	5.03	4.96	4.63	
20	1.00		6.09	5.03	4.87	4.66	4.07	
	0.90		6.09	5.03	4.98	4.66	4.63	
	0.80		6.09	5.08	5.03	4.98	4.66	
	0.70		6.09	5.84	5.08	5.03	4.71	
	0.60		6.40	6.09	5.84	5.03	4.71	
21	1.00		5.39	5.00	4.66	4.56	3.82	
	0.90		5.39	5.00	4.77	4.66	4.52	
	0.80		5.39	5.03	4.98	4.77	4.66	
	0.70		5.84	5.23	5.03	4.98	4.66	
	0.60		6.09	5.84	5.23	5.00	4.66	
22	1.00		5.39	5.00	4.71	4.56	3.82	
	0.90		5.39	5.00	4.77	4.66	4.52	
	0.80		5.39	5.03	5.00	4.77	4.66	
	0.70		6.09	5.25	5.03	5.00	4.66	
	0.60		6.09	6.09	5.25	5.03	4.66	



TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 1 FOR SEPTEMBER  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 2</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>0.95</u>
		<u>Unit 1:</u>	<u>0.55</u>	<u>0.65</u>	<u>0.75</u>	<u>0.85</u>	
		<u>OCNP (mills/KWHe) of Unit 1</u>					
23	1.00	7.28	6.79	6.40	6.09	5.06	
	0.90	7.28	6.79	6.40	6.09	6.09	
	0.80	7.28	6.83	6.50	6.40	6.09	
	0.70	7.28	6.83	6.83	6.50	6.40	
	0.60	8.48	7.28	6.83	6.79	6.40	
24	1.00	6.83	6.40	6.09	5.06	4.87	
	0.90	6.83	6.40	6.09	5.84	5.06	
	0.80	6.83	6.40	6.40	6.09	5.84	
	0.70	6.83	6.79	6.40	6.40	6.09	
	0.60	6.83	6.83	6.79	6.40	6.09	
25	1.00	6.83	6.40	6.09	5.08	4.96	
	0.90	6.83	6.40	6.09	5.84	5.06	
	0.80	6.83	6.40	6.40	6.09	5.84	
	0.70	6.83	6.79	6.40	6.40	6.09	
	0.60	6.83	6.83	6.79	6.40	6.09	
26	1.00	7.28	6.79	6.40	6.09	5.06	
	0.90	7.28	6.79	6.40	6.09	6.09	
	0.80	7.28	6.83	6.50	6.40	6.09	
	0.70	7.28	6.83	6.83	6.50	6.40	
	0.60	8.48	7.28	6.83	6.79	6.40	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 2 FOR APRIL  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 1</u>	<u>Weekly Nuclear Capacity Factors of</u>				
		<u>Unit 2:</u>	<u>0.08</u>	<u>0.12</u>	<u>0.16</u>	<u>0.20</u>
		<u>OCNP (mills/KWHe) of Unit 2</u>				
1	0.95	9.89	6.79	5.39	5.03	
	0.85	9.89	6.79	6.09	6.09	
	0.75	9.89	6.83	6.79	6.09	
	0.65	9.89	7.74	6.83	6.09	
	0.55	9.89	9.11	7.28	6.09	
2	0.95	9.89	6.83	6.09	5.08	
	0.85	9.89	6.83	6.40	6.09	
	0.75	9.89	6.83	6.83	6.40	
	0.65	9.89	8.83	8.30	6.40	
	0.55	9.89	9.30	8.49	6.40	
3	0.95	9.32	6.40	5.03	5.03	
	0.85	9.32	6.40	5.39	5.25	
	0.75	9.32	6.40	6.40	5.39	
	0.65	9.32	6.83	6.79	5.39	
	0.55	9.32	8.49	6.79	5.39	
4	0.95	8.49	5.03	4.72	4.66	
	0.85	8.49	5.03	5.00	4.96	
	0.75	8.49	5.08	5.03	4.96	
	0.65	8.49	5.84	5.39	4.96	
	0.55	8.49	6.79	5.39	4.96	

TABLE B.3.1 (CONT'D)

WEEKLY OCNF FUNCTIONS OF UNIT 2 FOR MAY  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 1</u>	<u>Weekly Nuclear Capacity Factors of</u>				<u>0.40</u>
		<u>Unit 2:</u>	<u>0.16</u>	<u>0.24</u>	<u>0.32</u>	
		<u>OCNP (mills/KWHe) of Unit 2</u>				
5	0.95	9.40	7.65	5.23	5.03	
	0.85	9.40	7.65	6.79	5.25	
	0.75	9.40	7.74	7.28	5.39	
	0.65	9.40	8.59	8.05	5.39	
	0.55	9.40	8.86	8.30	5.39	
6	0.95	9.32	6.79	5.03	4.96	
	0.85	9.32	6.79	5.15	5.03	
	0.75	9.32	6.79	5.84	5.03	
	0.65	9.32	7.65	6.79	5.03	
	0.55	9.32	8.83	7.28	5.03	
7	0.95	9.32	6.79	5.03	5.00	
	0.85	9.32	6.79	5.39	5.03	
	0.75	9.32	7.28	6.79	5.03	
	0.65	9.32	8.05	7.28	5.03	
	0.55	9.32	8.86	7.74	5.03	
8	0.95	9.77	7.65	5.25	5.03	
	0.85	9.77	7.65	6.79	5.39	
	0.75	9.77	8.05	7.28	5.39	
	0.65	9.77	8.83	8.05	5.39	
	0.55	9.77	9.11	8.30	5.39	
9	0.95	4.66	4.97	5.39	9.11	
	0.85	4.97	5.03	5.39	9.11	
	0.75	4.97	5.39	6.50	9.11	
	0.65	4.97	6.79	7.28	9.11	
	0.55	4.97	6.79	8.30	9.11	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 2 FOR JUNE  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 1</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>0.60</u>
		<u>Unit 2:</u>	<u>0.36</u>	<u>0.42</u>	<u>0.48</u>	<u>0.54</u>	
		<u>OCNP (mills/KWHe) of Unit 2</u>					
10	0.95	5.39	5.00	4.72	4.66	4.57	
	0.85	5.39	5.03	5.00	4.96	4.66	
	0.75	6.09	5.39	5.08	5.03	4.66	
	0.65	6.09	6.09	5.84	5.15	4.66	
	0.55	6.40	6.09	6.09	5.15	4.66	
11	0.95	6.09	5.08	4.97	4.72	4.63	
	0.85	6.09	5.15	5.03	5.00	4.66	
	0.75	6.09	6.09	5.39	5.08	4.66	
	0.65	6.40	6.09	6.09	5.39	4.66	
	0.55	6.40	6.40	6.09	5.39	4.66	
12	0.95	5.25	4.97	4.66	4.66	4.53	
	0.85	5.25	5.03	4.97	4.77	4.66	
	0.75	5.39	5.08	5.03	5.00	4.66	
	0.65	6.09	6.09	5.39	5.06	4.66	
	0.55	6.40	6.09	5.84	5.06	4.66	
13	0.95	5.03	4.72	4.66	4.57	4.29	
	0.85	5.03	4.97	4.72	4.66	4.63	
	0.75	5.06	5.03	5.00	4.96	4.63	
	0.65	5.84	5.25	5.03	4.97	4.63	
	0.55	6.09	6.09	5.15	4.97	4.63	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 2 FOR JULY  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 1</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>0.80</u>
		<u>Unit 2:</u>	<u>0.48</u>	<u>0.56</u>	<u>0.64</u>	<u>0.72</u>	
							<u>OCNP (mills/KWHe) of Unit 2</u>
14	0.95	4.63	4.29	4.07	3.82	3.40	
	0.85	4.63	4.53	4.29	4.07	3.82	
	0.75	4.66	4.57	4.57	4.29	3.82	
	0.65	4.87	4.66	4.63	4.57	3.82	
	0.55	5.03	4.96	4.66	4.57	3.82	
15	0.95	5.06	4.77	4.63	4.53	4.07	
	0.85	5.06	4.96	4.72	4.66	4.29	
	0.75	5.15	5.03	5.00	4.77	4.29	
	0.65	5.84	5.25	5.03	5.00	4.29	
	0.55	6.09	6.09	5.08	5.00	4.29	
16	0.95	5.03	4.66	4.57	4.29	3.82	
	0.85	5.03	4.72	4.66	4.57	4.29	
	0.75	5.03	5.00	4.77	4.66	4.29	
	0.65	5.25	5.03	5.03	4.87	4.29	
	0.55	6.09	5.39	5.03	4.87	4.29	
17	0.95	5.08	4.87	4.66	4.57	4.07	
	0.85	5.08	5.00	4.77	4.66	4.29	
	0.75	5.25	5.03	5.00	4.87	4.29	
	0.65	6.09	5.39	5.06	5.00	4.29	
	0.55	6.09	6.09	5.15	5.00	4.29	
18	0.95	5.03	4.72	4.57	4.53	4.07	
	0.85	5.03	4.96	4.72	4.63	4.29	
	0.75	5.08	5.03	5.00	4.72	4.29	
	0.65	5.52	5.23	5.03	5.00	4.29	
	0.55	6.09	6.09	5.06	5.00	4.29	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 2 FOR AUGUST  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 1</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>1.00</u>
		<u>Unit 2:</u>	<u>0.60</u>	<u>0.70</u>	<u>0.80</u>	<u>0.90</u>	
		<u>OCNP (mills/KWHe) of Unit 2</u>					
19	0.95	5.00	4.66	4.56	4.28	3.58	
	0.85	5.00	4.71	4.66	4.56	4.07	
	0.75	5.03	4.98	4.71	4.66	4.07	
	0.65	5.08	5.03	4.98	4.71	4.07	
	0.55	5.84	5.08	5.00	4.71	4.07	
20	0.95	5.84	4.98	4.66	4.63	4.07	
	0.85	5.84	5.03	4.98	4.66	4.43	
	0.75	5.84	5.08	5.03	4.98	4.43	
	0.65	6.09	5.84	5.08	5.00	4.43	
	0.55	6.40	6.09	5.39	5.00	4.43	
21	0.95	5.03	4.77	4.66	4.52	3.82	
	0.85	5.03	4.98	4.77	4.66	4.28	
	0.75	5.22	5.03	4.98	4.77	4.28	
	0.65	5.84	5.22	5.03	4.96	4.28	
	0.55	6.09	5.84	5.06	4.96	4.28	
22	0.95	5.08	4.87	4.66	4.52	3.82	
	0.85	5.08	5.00	4.77	4.66	4.28	
	0.75	5.25	5.03	5.00	4.77	4.28	
	0.65	6.09	5.25	5.03	4.98	4.28	
	0.55	6.09	6.09	5.08	4.98	4.28	

TABLE B.3.1 (CONT'D)

WEEKLY OCNP FUNCTIONS OF UNIT 2 FOR SEPTEMBER  
FROM THE MULTI-REACTOR OPTIMIZATION (CASE 2)

<u>Week</u>	<u>Unit 1</u>	<u>Weekly Nuclear Capacity Factors of</u>					<u>1.00</u>
		<u>Unit 2:</u>	<u>0.60</u>	<u>0.70</u>	<u>0.80</u>	<u>0.90</u>	
		<u>OCNP (mills/KWHe) of Unit 2</u>					
23	0.95	6.83	6.40	6.09	6.09	5.06	
	0.85	6.83	6.50	6.40	6.09	5.39	
	0.75	6.83	6.83	6.50	6.40	5.39	
	0.65	7.28	6.83	6.83	6.40	5.39	
	0.55	8.48	7.28	6.83	6.40	5.39	
24	0.95	6.79	6.09	5.84	5.06	4.87	
	0.85	6.79	6.40	6.09	5.84	5.03	
	0.75	6.79	6.40	6.40	6.09	5.03	
	0.65	6.83	6.79	6.40	6.09	5.03	
	0.55	6.83	6.83	6.40	6.09	5.03	
25	0.95	6.79	6.09	5.84	5.06	4.96	
	0.85	6.79	6.40	6.09	5.84	5.03	
	0.75	6.79	6.40	6.40	6.09	5.03	
	0.65	6.83	6.79	6.40	6.40	5.03	
	0.55	6.83	6.83	6.40	6.40	5.03	
26	0.95	6.83	6.40	6.09	6.09	5.06	
	0.85	6.83	6.50	6.40	6.09	5.39	
	0.75	6.83	6.83	6.50	6.40	5.39	
	0.65	7.28	6.83	6.83	6.40	5.39	
	0.55	8.48	7.28	6.83	6.40	5.39	

Appendix C: PROCOST

C.1 Introduction

The organization of PROCOST and the algorithm of its main components were discussed in Section 4.0. A review of MPSX and the detailed algorithm of SECURIT are covered in later sections of this Appendix. The major topic remaining is the general operating philosophy for using PROCOST. The flowchart of PROCOST is given in Figure C.1. The component subprograms of PROCOST are:

NUC\_OPT: main program that writes the L.P. nuclear optimization formulation;

PEAKERS: subroutine that simulates the operation of peaking units;

PECK\_OR: subroutine that formulates the fossil economic loading order;

DURATN: subroutine that calculates the load-duration load model

MPSX: the program that solves the L.P. nuclear problem;

PUMP\_ST: main pumped-storage simulation program that also reads the L.P. nuclear solution, and calculates OCNP;

ECO: economic pumped-storage subroutine;

SECURIT: security pumped-storage subroutine.

The function of PROCOST is two-fold (1) to calculate OCNP values, and (2) to calculate the optimal dispatching schedule for the system's nuclear reactor(s). The latter step assumes that the modelling assumptions used in the other system components are reasonable in order to derive a






Figure C.1 PROCOST ALGORITHM

feasible and optimal nuclear dispatching schedule. Use of PROCOST is tied to the (method of) solution of the short-range problem, in as much as PROCOST attempts to supply the information (OCNP values and dispatching schedules) specified by the theory. Use of any other production cost code in place of PROCOST that supplied the same information would be also serve the purpose.

A great amount of effort has been directed toward making PROCOST a fast and efficient program. Compared with the early version, very substantial improvement in computational performance had been made. To calculate OCNP values, the current version of NUC\_OPT consumes about 0.2 CPU-Sec./value, MPSX consumes about 0.2 CPU-sec/value, while PUMP\_ST consumes about 1.1 CPU-sec./value. Most of the developmental effort had been toward improving the L.P. calculations, so that it is no longer the constricting job step (in terms of CPU time).

PUMP\_ST was originally designed for a detailed pumped-storage optimization based on the 168-hour load model. Hence, a great deal of calculational effort is wasted when PUMP\_ST is used with a six-interval load model. Therefore, it is recommended that: (1) the present pumped-storage version of PUMP\_ST not be used for the OCNP calculations but reserved for use when the detailed optimization schedule is desired; (2) a simpler model of pumped-storage operation be written for OCNP (six-interval models) calculations; (3) PUMP\_ST be examined to reduce the

large number of calculations it performs.

PROCOST has a core-storage requirement of 230 K. The determining step is in NUC\_OPT which is due to the overhead required to provide the dual capability of formulating L.P. problems with two types of load models (chronologic and load-duration) and accepting the original input (customer demand) data in any of three forms of load models. To achieve a large reduction in the storage requirement and improve CPU time, it is recommended that NUC\_OPT should be divided into two versions, one for load-duration models, and other for chronologic models.

In the present version of PROCOST, there is no constraint on the minimum operating level of the reactor. To make this option available, a new input variable, referred to as MINIMUM would be read in with the rated capacity (CAPACITY) of the reactor. MINIMUM would be considered the must-run portion of the nuclear unit, and have its capacity subtracted from the demand function prior to the L.P. formulation. In the L.P. model, the operating range of the reactor would be from zero to CAPACITY-MINIMUM. The nuclear resource constraint in the L.P. model must also be modified, to subtract out the portion of energy already allocated to the must-run portion of the reactor. It is important that the nuclear heat-rate curve be use to calculate the correct value of this must-run energy. In addition, the nuclear heat-rate curve itself must be adjusted for use in the L.P. model due to the revised

operating range of the reactor. Finally, MINIMUM should be added back to the nuclear optimized solution before the L.P. solution is to be printed.

The recommendations discussed above are related only to improving the numerical techniques without changing any of the modelling assumptions involved. Many of the simple assumptions and concepts in PROCOST can be improved upon. Start-up and shut-down effects can be included by allowing use of several loading orders and load-duration curves, each appropriate for only certain hours of the day. Incorporating error bands on the customer demand function should be easily implemented by MPSX parametric procedures. Other possibilities are suggested in Sections 6.2, 5.5, and 3.2.

Even though PROCOST is not perfect, it is a very flexible program. The flexibility is derived from the many options available in NUC\_OPT and MPSX especially. MPSX is extensively used by the oil and gas industry. MPSX was designed as a production code where intermediate results can be saved, old L.P. problems can be saved, solutions transferred, and many other useful features intended for users with a permanent interest in L.P. models. MPSX also has a great variety of parametric analysis routines and editing capability for L.P. models. Thus, once the basic L.P. model is formulated, NUC\_OPT need not be used again to alter the model. The editing facilities of MPSX have sufficient capability to perform any required adjustments to

the L.P. model. The potential flexibility of MPSX makes it well suited for the type of analysis desired by the system planner, to study a variety of related and complex situations.

To facilitate manipulation of the L.P. model, a detailed description of the L.P. nuclear model is given next, in Appendix C.2. Following is a review of the MPSX control language program which dictates the optimization routines to be used on the L.P. model.

Appendix C.4 contains a detailed description of the pumped-storage security algorithm. The remaining sections of Appendix C are: description of the input specification to PROCOST; listing of PROCOST; a complete listing of the PROCOST input file SYSIN for Case 3; and a representative selection of computer output from Case 3.

## C.2 L.P. MODEL

Efficient use of PROCOST requires agile manipulation of the L.P. model, in the MPSX control language program. The following is a detailed description of the L.P. model (its row and column names), to facilitate its use. The equations governing the L.P. model were given in Section 4.2.1.

The L.P. model is as follows (describing the rows from top to bottom, and the columns from left to right). The first row is the objective function, named COST, which is the summation of the incremental fossil fuel cost for the week, see Eqn. (4.1). Each time interval in the load model is simulated by a customer demand constraint equation, see Eqn. (4.2). The row name of each of these equations is of the form DEMANxxx where xxx is a three digit representation of the time interval being simulated. Each nuclear power reactor is represented by thermal nuclear resource constraint equation, see Eqn. (4.3). The row name of each of these equations is of the form NUCLRxxx where xxx is a three digit number assigned to each reactor. The constraints on each column variable is expressed by a BOUND row, see Eqn. (4.4). The BOUND row is named "BOUND1".

There is a separate column variable for each fossil and nuclear increment in each distinct time interval. The name of the fossil variables is of the form FFxxxyyy and the name of the nuclear variables is of the form Nxxxxzzw where xxx is a three digit representation of the time interval number, yyy is a three digit representation of the fossil increment

number,  $zz$  is a two digit representation of the reactor number, and  $w$  is a single digit representation of the nuclear increment number. The RHS column lists the values of the demand function and the nuclear resource constraints. The name of this column is RHS001. There are also RHS change columns which are used to modify RHS columns to form new (temporary) RHS columns on which RHS parametric analysis is based. The change column named CHC000, is used to modify the customer demand function. For each nuclear resource row, there are two RHS change columns, one for positive changes, and one for negative changes. The name of these columns are of the form CHCxxx where xxx is a three digit representation of  $(2n-1)$  for positive changes, and  $(2n)$  for negative changes and where  $n$  is the reactor number.

The above description is valid for either a load-duration or a chronologic load representation in a one-week L.P. model. To represent several weeks using a load-duration model, one L.P. model is required for each week. To represent several weeks using a chronologic load model, only one L.P. model is required for each different fossil configuration. The variation in the time duration of each time interval (for different weeks in the load-duration mode) requires a new L.P. model for each week. In the chronologic load model situation, the body of L.P. model is the same for different weeks (with the same fossil configuration). The only difference is an extra RHS column for each additional week. The name of this RHS column is of

the form RHSxxx where xxx is a three digit representation of the week number. This difference in the number of L.P. models generated by NUC\_OPT must not be overlooked when specifying the MPSX control language program or in the PUMP\_ST input parameters.

### C.3 MPSX

#### C.3.1 Control Language Program

MPSX (IBM program product) is a general purpose linear programming package. This section is not an introduction to MPSX, but rather a technical review of some useful MPSX programming procedures developed for the PROCOST operating environment. The prospective user of MPSX is referred to References (29,30) for introductions to linear programming and MPSX. An explanation of the keywords (commands) used in the MPSX control language program is given in Reference (31). An explanation of the role of the many subroutines available in MPSX, their abilities and their restrictions is covered in Reference (32).

MPSX is composed of two job steps: a compilation step and an execution step. The first step is the compiling of the MPSX control language program, which is the specification of the optimization procedures and parametric analysis used in solving the L.P. problem. The second step is the solving of the L.P. problem by the algorithm dictated in the MPSX control language program. Control is passed to the second step automatically upon completion of the first step. This section is a review of two sample MPSX control



language programs. It is assumed that the reader is familiar with MPSX, L.P., PL1, and general computer programming terminology.

The procedure for solving a simple L.P. problem is a straight-forward one. Sample 1, listed in Appendix C.3.2 is a simple example of a basic MPSX control language program solving a single L.P. problem. However, to efficiently solve a large number of related problems (as in calculating OCNP values), parametric techniques should be used. Instead of solving each problem from scratch, parametric analysis searches for a solution starting from the solution of a previously solved problem. Since the problems are related, their solutions are also similar. Thus a large amount of computations can be avoided by starting the calculations for solutions from an optimal solution of a related problem. Such an algorithm is illustrated in Sample 2. Sample 2, listed in Appendix C.3.3, is an example of a MPSX control language problem applicable to a single reactor optimization problem.

Sample 1 illustrate the basic steps in a control language problem: (1) identity the input data, "SYSTEBO1"; (2) provide (or identify) the problem name, "MINIMIZE"; (3) convert the input data (located on file IN) to machine code; (4) identify the objective function, "COST"; (5) setup the problem with the appropriate bounds for solving; (6) identify the RHS, "RHS 001"; (7) solve the problem; (8) write the solution (or a portion thereof). Each of the

above functions corresponds with a command in the MPSX control language. The exact sequence of commands depends on the specific problem being solved as does the parameters used with commands. The PROGRAM statement denotes the beginning of the control program and PEND denotes the end. An asterisk in column 1 denotes a comment card. A TITLE statement provides a title on every page of MPSX output. The INITIALZ command initializes all MPSX variables to default values. The first MOVE statement informs the computer, the name of the input data to be read (important, since several input models may reside in the same device). The name, SYSTEBO1, is formed from the concatenation of the character variable, SYSTE, with the week number (2 digits) of the problem in NUC\_OPT. The second MOVE statement identifies the name to be associated with the L.P. problem when residing in the computer's storage devices. The name, "MINIMIZE" is arbitrary, but must not duplicate a name already on the PROFILE. The CONVERT instruction reads the data named SYSTEBO1 on file IN, and converts the data to machine code. The third MOVE statement identifies the name of the L.P. row to be used as the objective function (several may be available). The SETUP command prepares the problem in matrix format ready for solving. "BOUND1" is the name of the row of bounds to be used in the present optimization. Minimization is the default mode. The fourth MOVE statement identifies the name of the RHS column to be used in the optimization (several may be available). The

OPTIMIZE instruction performs the actual problem solving. The SOLUTION instruction writes the solution on the user file SOLN. Only selected information from the solution is written: columns 2, 4, and 8 of the row variables and columns 2 and 4 of those column variables beginning with the letter N (the nuclear variables). The EXIT command terminates execution of the program. The entire solution is not written since the fossil schedule must complement the nuclear schedule to fulfill the demand function (conserving space and computer operations).

Sample 1 solves a single model without performing any parametric analysis. Sample 2, listed in Appendix D.2 is a more elaborate program that solves a large number of similar problems through repetitive use of subroutine call statements and parametric analysis. The subroutine structure is basically similar to Sample 1 with the addition of the parametric analysis statements. The parametric analysis solves for the solution of the same basic L.P. problem for different increments of nuclear energy. Sample 2 is a typical example of how to program MPSX to obtain the values of 22 weekly OCNF functions.

The following discussion of Sample 2 will cover only those statements not explained above. The function of the MVADR statement is to change the program branch for XDOPRINT from the default procedure to the user procedure labelled SET. XDOPRINT is explained below. The XFREQLOG=0 and XFREQLOGA=0 statements sets the printing of the iteration log

to a minimum (which is still quite voluminous). The XPARDELT=2 statement is related to XDOPRINT and will be discussed later. The EXEC(TIP) statement is a subroutine call to TIP. Subroutine TIP is called repeatedly to solve 22 different weekly L.P. models, and perform parametric analyses. The length of the control language program is limited. Hence, when groups of commands are used repeatedly, subroutines and loops should be incorporated in the program to conserve the number of statements.

Subroutine TIP is established by using the name, TIP, as the label to the first command of the subroutine. TIP is the label to a CONVERT command. The end of subroutine is denoted by a STEP or CONTINUE command. The difference between STEP and CONTINUE is that execution is returned to the calling routine when CONTINUE is encountered, whereas STEP implies execution should go to the statement following the calling statement. Other entry points may be established in the subroutine by placing labels such as PARRR and S2 on the relevant statements. The XPARAM=0 resets the system increment variable to its initial value.

An initial optimal solution to a L.P. model is required before the program can perform parametric analysis. Parametric RHS analysis also requires knowledge of how the RHS is to be varied and at what increments to write the solution. MOVE(XCHCOL,'CHC002') identifies the column named 'CHC002' as the Change Column that is to be combined with the RHS column to form the new RHS. One unit of 'CHC002'

will decrease the nuclear resource constraint by 5%, in the present version of NUC\_OPT. The new parametric RHS is a combination the old RHS plus a multiple of 'CHCOO2'. XPARAM, the multiplier of 'CHCOO2', is increased continuously. XPARAM=0 sets its initial value to zero and XPARAMAX=8, sets the final value of XPARAM to eight. PARARHS is the command which performs the parametric analysis. There is a pause each time XPARAM is a multiple of XPARADELT, which is set by the statement XPARADELT=2. When the pause occurs, XDOPRINT is signaled, which has been set to call subroutine SET, which specifies that the current solution is to be written on file SOLN.

In other words, for each of the 22 L.P. models, the solution of the basic weekly L.P. problem was solved with the initial amount of nuclear resource, along with four other values of the nuclear resource, at 10% decreasing intervals in nuclear energy. A total of 110 L.P. solutions will reside on user file SOLN.

A programming note: user files with large BLOCKSIZES will overload the buffers and result in SCC=80A. Unlimited increases in the REGION parameter on the JOB card will not alleviate the problem. The MPSX buffer core size parameter should be changed.

C.3.2: SAMPLE1, MPSX CONTROL LANGUAGE PROGRAM

SAM10001  
SAM10002  
SAM10003  
SAM10004  
SAM10005  
SAM10006  
SAM10007  
SAM10008  
SAM10009  
SAM10010  
SAM10011  
SAM10012  
SAM10013  
SAM10014  
SAM10015  
SAM10016  
SAM10017  
SAM10018  
SAM10019  
SAM10020

```
PROGRAM
*
* THIS PROGRAM PREFORMS THE NUCLEAR ENERGY OPTIMIZATION
*
TITLE (' ELECTRIC POWER DISPATCHING SIMULATION')
INITIALZ
MOVE(XDATA, 'SYSTEM01')
MOVE(XPBNAME, 'MINIMIZE')
CONVERT('FILE', 'IN')
MOVE(XOBJ, 'COST')
SETUP('BOUND', 'BOUND1')
MOVE(XRHS, 'RHS001')
OPTIMIZE
SOLUTION('FILE', 'SOLN', 'RSECTION', '2/4/8', 'CSECTION', '2/4/', X
'CMASKS', 'N*****', ' ')
EXIT
PEND
```

C.3.3: SAMPLE2, MPSX CONTROL LANGUAGE PROGRAM

SAM20001  
SAM20002  
SAM20003  
SAM20004  
SAM20005  
SAM20006  
SAM20007  
SAM20008  
SAM20009  
SAM20010  
SAM20011  
SAM20012  
SAM20013  
SAM20014  
SAM20015  
SAM20016  
SAM20017  
SAM20018  
SAM20019  
SAM20020  
SAM20021  
SAM20022  
SAM20023  
SAM20024  
SAM20025  
SAM20026  
SAM20027  
SAM20028  
SAM20029  
SAM20030  
SAM20031  
SAM20032  
SAM20033  
SAM20034  
SAM20035  
SAM20036

```
PROGRAM
*
* THIS PROGRAM PREFORMS THE NUCLEAR ENERGY OPTIMIZATION
*
TITLE (' ELECTRIC POWER DISPATCHING SIMULATION')
INITIALZ
MVADR(XDOPRINT,SET)
XSETLB=-1
XFREQLGO=0
XFREQLGA=0
XPARDELT=2.
MOVE(XPBNAME,'MINIMIZE')
MOVE(XOBJ,'COST')
MOVE(XRHS,'RHS001')
MOVE(XDATA,'SYSTEAO1')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO2')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO3')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO4')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO5')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO6')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO7')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO8')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO9')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO10')
```

	EXEC(TIP)	SAM20037
	MOVE(XDATA,'SYSTE11')	SAM20038
	EXEC(TIP)	SAM20039
	MOVE(XDATA,'SYSTE12')	SAM20040
	EXEC(TIP)	SAM20041
	MOVE(XDATA,'SYSTE13')	SAM20042
	EXEC(TIP)	SAM20043
	MOVE(XDATA,'SYSTEB01')	SAM20044
	EXEC(TIP)	SAM20045
	MOVE(XDATA,'SYSTEB02')	SAM20046
	EXEC(TIP)	SAM20047
	MOVE(XDATA,'SYSTEB03')	SAM20048
	EXEC(TIP)	SAM20049
	MOVE(XDATA,'SYSTEB04')	SAM20050
	EXEC(TIP)	SAM20051
	MOVE(XDATA,'SYSTEB05')	SAM20052
	EXEC(TIP)	SAM20053
	MOVE(XDATA,'SYSTEC01')	SAM20054
	EXEC(TIP)	SAM20055
	MOVE(XDATA,'SYSTEC02')	SAM20056
	EXEC(TIP)	SAM20057
	MOVE(XDATA,'SYSTEC03')	SAM20058
	EXEC(TIP)	SAM20059
	MOVE(XDATA,'SYSTEC04')	SAM20060
	EXEC(TIP)	SAM20061
	EXIT	SAM20062
TIP	CONVERT('FILE','IN')	SAM20063
	SETUP('BOUND','BOUND1')	SAM20064
PARR	XPARAM=0.	SAM20065
S2	OPTIMIZE	SAM20066
	SOLUTION('FILE','SOLN','RSECTION','2/4/8','CSECTION','2/4/',' X	SAM20067
	'CMASKS','N*****','')	SAM20068
	MOVE(XCHCOL,'CHC002')	SAM20069
	XPARAM=0.	SAM20070
	XPARAMAX=8.	SAM20071
	PARARHS('CONT')	SAM20072



SOLUTION('FILE','SCLN','RSECTION','2/4/8','CSECTION','2/4/',' X  
'CMASKS','N\*\*\*\*\*',' ' )  
STEP  
SET SOLUTION('FILE','SCLN','RSECTION','2/4/8','CSECTION','2/4/',' X  
'CMASKS','N\*\*\*\*\*',' ' )  
CONTINUE  
PEND

SAM20073  
SAM20074  
SAM20075  
SAM20076  
SAM20077  
SAM20078  
SAM20079

#### C.4 Pumped-Storage Security Algorithm

The peak-shaving pumped-storage generation schedule for this security model is the same as in the economic model. It is characterized by the pumped-storage generation level (power level K3 in Figure 4.9), where if demand load is above that level, then the pumped-storage generators produced enough power to make up the difference or until its nominal capacity(\*) is reached.

The pumping schedule flowchart is shown in Figure C.2. The pump scheduling algorithm is determined as follows:

- (1) Define the periods when pumping is allowed and where it is not allowed. A bit string representing the number of time intervals in a week can serve this purpose where a '1' bit means no pumping is allowed and a '0' bit means pumping is allowed. The string is initially all '0's. The generation periods are then denoted by '1' bits from an examination of the generation schedule. The bye periods (an input specification) before and after generation periods are also denoted by '1' bits. The remaining '0' bit substrings define periods when pumping is allowable.
- (2) Set pointers to the beginning and end of the next allowable pumping period.
- (3) Calculate the minimum amount of pumping that can be

-----

(\*) Nominal capacity is not the rated capacity of the generators, but that capacity intended for scheduled usage, the remainder is for emergency usage.




Figure C.2 SECURIT ALGORITHM

scheduled during this period before overflowing occurs. Hence, water-usage-to-date must be calculated for the present pumping period. The chronologic water level pattern is calculated by considering the generation schedule, free inflow (assumed uniform), pumping to date, and the starting water level (an input specification). The water level pattern is needed to determine the requirement of water to fill the reservoir during the present pumping period. That amount is the difference between the reservoir size and the calculated water level at the end of the period in question.

- (4) Search for the lowest demand interval during the pumping period. Scheduling pumping for this interval first is the most economic choice available. The timing of the pumping schedule is determined by this step.
- (5) The amount of pumping scheduled in an interval is subject to three constraints: (i) when capacity of the pump is reached, (ii) when the reservoir is filled, and (iii) when fossil load level reaches the turnaround level (\*). Whichever constraint becomes active first stops the pumping and hence determines the amount scheduled.

-----

(\*) Turnaround level is that load level, above which no pumping is allowed (K4 of Figure 4.9). It would be too expensive to pump. It's determined as a certain amount (an input specification) of MW below the pumped storage generation level (K3 of Figure 4.9).

(6) If constraints (i) or (iii) becomes active repeat step 4, search for the lowest demand interval. If constraint (ii) becomes active, or time has run out (pumping has been scheduled for all allowable time intervals and reservoir is not full) then repeat step 2, defining the next pumping period. The subroutine returns to ECO when the end of the string has been reached.

### C.5 Input Specification

PROCOST is composed of three program steps: (1) NUC\_OPT, the preprocessor to MPSX which formulates the L.P. model; (2) MPSX, the program that solves the L.P. model; (3) PUMP\_ST, the pumped-storage program. The data input to MPSX are automatically written by NUC\_OPT, hence, there are no input parameters directly fed to MPSX. Control of MPSX is derived from the input data to NUC\_OPT (which in turn inputs to MPSX) and the MPSX control language program (which was discussed in the previous section). The input specifications to NUC\_OPT and PUMP\_ST are given below.

#### C.5.1 NUC-OPT Input Specifications

The file structure is:

- (1) DATA: a transfer medium to MPSX,
- (2) HYDRO: contains the hydro generation schedule,
- (3) LDMDL: contains the customer demand function,
- (4) PEAKS: contains peaking unit parameters,
- (5) PECK: contains fossil loading order parameters,
- (6) SYSIN: contains modelling parameters,
- (7) TRANSFR: transfer medium to PUMP\_ST.

The DATA file is the one on which NUC\_OPT writes the MPSX input L.P. data. The record format should be card image, i.e., DCB=(RECFM=FB,LRECL=80,BLKSIZE=12880).

The HYDRO file contains the values of the array variable HYD, which is the dispatching schedule of the hydro unit (calculated off line).

The LDMDL file contains the values of the array

variable DEMAND, the weekly (chronologic) customer demand function.

The PEAKS file contains all the variables associated with the peaking units. One set of peaking unit variables is required for each week being simulated. If 52 weeks are being simulated, 52 sets of peaking parameters are required. Thus, there is available a large amount of flexibility in varying the peaking units available each week. A complete input set consists of the following parameters:

P\_NUM: the number of peaking units for the week.

C\_FACTOR: the simulated capacity factor for a peaking unit.

RATING: the rated capacity of the peaking unit, MW.

HEAT: the average heat-rate of the peaking unit at rated capacity, (million BTU/MWH).

F\_COST: the fuel cost of the peaking unit, (\$/million BTU).

SUSD: the average cost of one start-up and shut-down, (\$).

CODE: if CODE=0, then the detailed peaking unit generation schedule is printed.

At the very least, the minimum input set consists of a zero value for P\_NUM, otherwise PROCOST will ABEND. When P\_NUM is not zero, the five peaking unit variables above are read successively (in the order listed above), P\_NUM number of times. CODE is the last variable listed in a single set of peaking unit data.

The PECK file contains all the variables associated with the fossil economic incremental loading order. The input variables (listed in order of input) are:

N1: The number of large fossil units.

VP1: The number of valve points modelled in the large fossil units.

N2: The number of medium fossil units.

VP2: The number of valve points modelled in the medium fossil units.

N3: The number of small fossil units.

VP3: The number of valve points modelled in the small fossil units.

LGE\_HEAT(VP1,2): Array containing the average heat-rate data for large fossil units.

MED\_HEAT(VP2,2): Array containing the average heat-rate data for medium fossil units.

SML\_HEAT(VP3,2): Array containing the average heat-rate data for small fossil units.

NLGE(N1,4): Array containing the station characteristics of large fossil units. The parameters of interest for each station are the number of units, MW capacity of each unit, the heat rate (million BTU/MWH), and the fuel cost (\$/million BTU).

NMED(2,4): Array containing the station characteristics of medium fossil units. The parameters of interest for each station are the number of units, MW capacity of each unit, the heat rate (million BTU/MWH), and the fuel cost (\$/million BTU).

NSML(N3,4): Array containing the station characteristics of small fossil units. The parameters of interest for each



station are the number of units, MW capacity of each unit, the heat rate (million BTU/MWH), and the fuel cost (\$/million BTU).

EMERG: The size (MW) of the last increment added to the economic loading order (as an insurance measure). This may represent emergency purchase capacity.

E\_COST: The cost (mills/KWH) of the last increment.

The SYSIN file contains the parameters associated with the structure of the L.P. model. The names of the variables (listed in the order of input) are:

SYSTE: The name to be associated with the L.P. model to be written on file DATA. A maximum of six characters is allowed in the name.

MODE: MODE='CHR' for chronologic load model mode, and MODE='DUR' for load-duration load model mode.

TRUE: The actual number of hours represented by the load model. TRUE=168 for a weekly load model.

N1: The number of time intervals in the input load model on file LDMDL.

N2: The number of time intervals desired in the load-duration model. If MODE='CHR', then set N2=N1.

VP: The number of valve points in the input nuclear heat rate curve.

NUMBER: the number of nuclear reactors in the L.P. model.

K: the number of increments in the fossil economic incremental loading order.

PARAMETER: If no parametric analysis on the modified demand function will be performed by MPSX, set PARAMETER=0, else chose '1' or '2'. When PARAMETER=1, the change column equals 1% of the modified demand function; if PARAMETER=2, then it equals 100 MW.

WEEKS: the number of weeks using the same economic loading order and hydro generation schedule.

PECKING: ='YES' if the fossil economic incremental loading order is desired to be punched out on cards, in a format usable in FOSSIL.

= 'NO' if punched cards not desired.

TIME(N1): The array describing the weight (in hours) assigned to each time interval in the input load model. If TRUE=N1 then all values in TIME are automatically set equal to 1. In such a case, TIME should be omitted.

CODE(TRUE): an array containing the correspondence in which the input load model can be expanded to the basic (168) hourly load model. If TRUE=N1, omit this variable, the program will substitute the correct values.

LOAD(NUMBER): the array containing the average weekly nuclear capacity factors used in calculating the nuclear resource constraint (and included in the RHS column vectors).

EFFIC(VP,2): the array containing the nuclear incremental heat rate data.

CAPACITY(NUMBER): the array containing the capacities(MW)

of the nuclear reactors.

BTU(NUMBER): the array containing the average heat rate at rated capacity for each of the nuclear reactors.

The TRANSFR file is the medium on which NUC\_OPT writes the values of several system variables to be transferred to the pumped storage routine, PUMP\_ST. An adequate DCB for TRANSFR is (RECFM=U,BLKSIZE=13030).

### C.5.2 PUMP\_ST Input Specifications

The file structure is:

- (1) SYSIN: contains pumped-storage modelling parameters;
- (2) TRANSFR: contains system parameters transferred from NUC\_OPT;
- (3) SOLN: contains the L.P. model solutions written by MPSX.

The input parameters (listed by order of input) on file SYSIN are:

MODE= 'QUCK' if only the nuclear L.P. solution is to be printed, no pumped-storage simulation,  
= 'NONE' if more detailed information about system is to be printed but still no pumped-storage simulation,  
= 'ECO' if the economic pumped-storage schedule is to be calculated,  
= 'SEC' if security pumped-storage schedule is to be calculated.

CODE=0 if printing the detailed dispatching schedule is desired.

=1 if printing the detailed dispatching schedule is

not desired.

CAPACITY= MW generation capacity of pumped-storage unit.

RATIO= cycle efficiency of pumped-storage unit (fraction).

CAP\_PUMP= MW pumping capacity of pumped-storage unit.

RESERIOR= MWH size of pumped-storage reservoir.

FREE= weekly stream inflow into pumped-storage unit (MWH).

START= starting water level of reservoir (MWH).

BYE= time (Hours) of transition (rest) interval before and after generation.

TOLERANCE= The buffer (MW) below the minimum pumped-storage generation (demand) level at which no pumping is allowed.

ALLOT(N)= array containing the number of L.P. solutions solved for a weekly L.P. model, where N=1 for a load-duration model and N= the number of weeks using the same L.P. model for a chronologic load model.

I= number of descriptive character strings immediately following, that are to printed on the computer output.

TITLE= a descriptive character string with maximum length of 80 characters, entered I times.

In the load-duration mode, the last three parameters are repeated for each week having the same fossil configuration, see sample input.

The whole sequence of parameters above is repeated for each fossil configuration in PROCOST. An example of a sample input is presented in Appendix C.7, the complete listing of the card input for Case 3. In Appendix C.8 is a

representative sampling of the computer output from Case 3.

Programming Notes: (1) All input parameters required on file SYSIN are format-free; (2) Caution, the use of a DUMMY file for the MPSX SYSPRINT should be reserved for those with an expert knowledge of MPSX; (3) Subroutine DURATN calls the Fortran subroutine, ISORT (35), to sort the elements of an array into ascending order. It is important that the JCL is in the correct order to establish the proper linkage.

```

// EXEC PLIXCL,
// PARM.L='LIST,MAP,DCBS'
//C.SYSIN DD *,DCB=BLKSIZE=2000
NUC_OPT : PROCEDURE OPTIONS(MAIN);
DCL (N1,N2,TRUE,VP,NUMBER,K,          PARAMETER,WEEKS) FIXED BIN,
      SYSTE CHAR(6) VARYING, MODE CHAR(3),PECKING CHAR(3);

ON ENDFILE(SYSIN) GO TO BOTTOM;
/* BASIC PARAMETER INPUT SECTION,
   PARAMETERS USED TO DIMENSION ARRAY VARIABLES */
TOP:
GET LIST(SYSTE,MODE, TRUE,N1,N2,VP,NUMBER,K,PARAMETER,WEEKS,PECKING);
PUT LIST(' INPUT VARIABLES FOLLOWS:')PAGE;
PUT DATA(SYSTE,MODE, TRUE,N1,N2,VP,NUMBER,K,PARAMETER,WEEKS,PECKING);

BEGIN;

DCL B_T_U FLOAT BIN, (NN,I,J,JJ,JJJ,KK,KKK,P, COD(TRUE)) FIXED BIN,
DUPATN EXTERNAL ENTRY((*) FIXED BIN(31,10),(*) FIXED BIN,(*) FIXED BIN,
(*) FIXED BIN,(*) FIXED BIN(31,10),FIXED BIN,FIXED BIN);
DCL PEAKERS EXTERNAL ENTRY((*) FIXED BIN(31,10), FIXED BIN,FIXED BIN,
(*) FIXED BIN, FIXED BIN(31));
DCL (LOAD(NUMBER)          ,EFFIC(VP,2)) FLOAT BIN,
     CAPACITY(NUMBER) FIXED DEC;
DCL (TIME(N1),TIM(N2),TRANSFORM(K,2) )FIXED BIN, BTU(NUMBER) FLOAT BIN,
(WORK(N1),CODE(TRUE)) FIXED BIN,(MONEY,HYD(N1)) FIXED BIN(31), (FOSSIL,
ORDER(K),FUEL(K),CUM_ORDER(K),CUM_FUEL(K))FLOAT DEC(16),
BASE FLOAT DEC, (DEMAN(N2),DEMAND(N1)) FIXED BIN(31,10),
PECK_OR EXTERNAL ENTRY(FLOAT DEC,(*) FLOAT DEC(16), (*) FLOAT DEC(16),
FIXED BIN,FLDAT DEC(16),(*,2) FIXED BIN);
DCL INCRE FIXED BIN(31,5);

/* HYDRO GENERATION SCHEDULE INPUT SECTION */
GET FILE(HYDRO) LIST (HYD);
PUT LIST(' HYDRO DATA FOLLOWS:')SKIP;

```

```

PROC0001
PROC0002
PROC0003
PROC0004
PROC0005
PROC0006
PROC0007
PROC0008
PROC0009
PROC0010
PROC0011
PROC0012
PROC0013
PROC0014
PROC0015
PROC0016
PROC0017
PROC0018
PROC0019
PROC0020
PROC0021
PROC0022
PROC0023
PROC0024
PROC0025
PROC0026
PROC0027
PROC0028
PROC0029
PROC0030
PROC0031
PROC0032
PROC0033
PROC0034
PROC0035
PROC0036

```

C.6 Program Listing

```

PUT SKIP LIST(' WEEKLY HYDRG GENERATION SCHEDULE, INTERVAL BY INTERVAL
(MW)');
PUT EDIT(HYD)(8 F(10),SKIP)SKIP;
/* IF TRUE=N1, THEN THE VALUE OF TIME AND CODE ARE OBVIOUS
AND INPUT TO PROCOST IS NOT NECESSARY */
IF TRUE=N1 THEN DO;
TIME=1;
DO I=1 TO TRUE;
CODE(I)=I;
END; END;
ELSE GET LIST (TIME,CODE);
PUT SKIP(3) LIST(' THE TIME WEIGHING FUNCTION FOLLOWS (NUMBER OF HOURS
REPRESENTED BY EACH TIME INTERVAL):');
PUT EDIT (TIME) (8 F(10),SKIP)SKIP;
PUT SKIP(3) LIST(' *CODE* FOLLOWS(CORRESPONDENCE MAP FROM THE LOAD MO
DEL TO A 168 HOUR REPRESENTATION):');
PUT EDIT (CODE) (8 F(10),SKIP)SKIP;
GET LIST(LOAD,EFFIC,CAPACITY,BTU);
PUT SKIP(2) EDIT (' NUCLEAR INPUT PARAMETERS FOLLOWS:')(SKIP,A)
(' NUCLEAR INCREMENTAL HEAT RATES:',EFFIC)(SKIP,A,COL(40),12 F(8,2))
(' WEEKLY NUCLEAR CAPACITY FACTORS:',LOAD)(SKIP,A,COL(40),10 F(10,2))
(' RATED NUCLEAR CAPACITIES,MW:',CAPACITY)(SKIP,A,COL(40),10 F(10 ))
(' FULL POWER AVER HEAT RATES: ',BTU) (SKIP,A,COL(40),10 F(10,2));

B_T_U=0;
DO I=VP TO 2 BY -1;
EFFIC(I,1)=EFFIC(I,1)-EFFIC(I-1,1);
END;
DO I=1 TO VP;
B_T_U=B_T_U+EFFIC(I,1)*EFFIC(I,2);
END;

CALL PECK_OR(BASE,ORDER,FUEL,K,FOSSIL,TRANSFORM);
FOSSIL=FOSSIL*TRUE;
PUT SKIP(4) LIST(' ECONOMIC LOADING ORDER OF FOSSIL PLANTS');
PUT EDIT(' MUST RUN FOSSIL OPERATING LEVEL(MW) = ',BASE)(A,F(10))

```

```

PROC0037
PROC0038
PROC0039
PROC0040
PROC0041
PROC0042
PROC0043
PROC0044
PROC0045
PROC0046
PROC0047
PROC0048
PROC0049
PROC0050
PROC0051
PROC0052
PROC0053
PROC0054
PROC0055
PROC0056
PROC0057
PROC0058
PROC0059
PROC0060
PROC0061
PROC0062
PROC0063
PROC0064
PROC0065
PROC0066
PROC0067
PROC0068
PROC0069
PROC0070
PROC0071
PROC0072

```

```

SKIP;
PUT EDIT(' MINIMUM FOSSIL FUEL COST($/WK) =',FOSSIL)
(A,P'$$$$,999,999V.')SKIP;
CUM_ORDER=ORDER(1);
CUM_FUEL(1)=FUEL(1)*ORDER(1);
DO I=2 TO K;
CUM_ORDER(I)=CUM_ORDER(I-1)+ORDER(I);
CUM_FUEL(I)=CUM_FUEL(I-1)+FUEL(I)*ORDER(I);
END;
PUT EDIT(' INCREMENTAL STEP','STEP SIZE','CUMLATIVE SIZE','INCREM. GEN
ERATION', 'CUMLATIVE INCREM. GENERATION')(A, COL(24), A,COL(40),A,
COL(65),A,COL(90),A)SKIP(3);
PUT EDIT('(MW)', '(MW)', 'COST(MILLS/KWH)', 'COST($/HR)')
(COL(26), A(4), COL(46), A(4), COL(65), A(15), COL(95), A(10));

DO I=1 TO K;
PUT EDIT(I,ORDER(I),CUM_ORDER(I),FUEL(I),CUM_FUEL(I))(F(10),COL(20),
F(10),COL(40),F(10),COL(70),F(10,2),COL(95),F(10,2)) SKIP;
IF PECKING = 'YES' THEN
PUT FILE(PUNCH) EDIT(I,ORDER(I),CUM_ORDER(I),FUEL(I),CUM_FUEL(I))
(F(5), F(10), F(10), F(10,2), F(15)) SKIP;
END;
DCL TABLE(N2) FIXED BIN;
LOOP: DO JJJ=1 TO WEEKS;
GET FILE(LDMDL) LIST (DEMAND);
PUT LIST ('WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:')SKIP(3);
PUT LIST ('(INTERVAL BY INTERVAL, MW)')SKIP;
PUT EDIT(DEMAND) (8 F(10), SKIP) SKIP;
DEMAND=DEMAND-BASE;
DEMAND=DEMAND-HYD;
DO JJ=1 TO N1;
IF DEMAND(JJ) < 0 THEN DEMAND(JJ)=0;
END;
PUT SKIP(2);
CALL PEAKERS(DEMAND,TRUE,N1,TIME,MONEY);
IF MODE='DUR' THEN DO;

```

```

PROC0073
PROC0074
PROC0075
PROC0076
PROC0077
PROC0078
PROC0079
PROC0080
PROC0081
PROC0082
PROC0083
PROC0084
PROC0085
PROC0086
PROC0087
PROC0088
PROC0089
PROC0090
PROC0091
PROC0092
PROC0093
PROC0094
PROC0095
PROC0096
PROC0097
PROC0098
PROC0099
PROC0100
PROC0101
PROC0102
PROC0103
PROC0104
PROC0105
PROC0106
PROC0107
PROC0108

```



```

                CALL DURATN(DEMAND,WORK,TIME,TIM,DEMAN,N2,N1);
PUT SKIP(2) LIST(' OUTPUT FUNCTION FROM SUBROUTINE DURATION:');
PUT EDIT(DEMAN) (8 F(10),SKIP)SKIP;
DO I=1 TO TRUE;
  COD(I)=WORK(CODE(I));
END; END;

IF MODE='CHR' THEN DO;
TIM=TIME;
DEMAN =DEMAND;
END;
PUT FILE(TRANSFR) LIST(WEEKS,TRUE,K,N2,    NUMBER,VP,
TIM, FUEL, CUM_FUEL, ORDER,CUM_ORDER,TRANSFORM,COD ,MODE,BTU,
CAPACITY, DEMAN);
/* L. P. INPUT SPECIFICICATION SECTION
INCRE=0;
TABLE=0;
DEMAN=DEMAN -SUM(CAPACITY);
DO KK=1 TO N2;
DO KKK=1 TO K WHILE(CUM_ORDER(KKK) < DEMAN(KK));
END;
IF KKK=1 THEN GO TO BOT;
TABLE(KK)=KKK-1;
INCRE =INCRE +CUM_FUEL(KKK-1)*TIM(KK);
BOT: END;
MONEY=MONEY+FOSSIL;
PUT EDIT(' FOSSIL INCREMENTS, MUST RUN($/WK)', INCRE)
(SKIP(2), A, X(5), P'$$$ ,999,999V. ');
PUT FILE(TRANSFR) LIST(MONEY,INCRE);
DEMAN=DEMAN+SUM(CAPACITY);
DO JJ=1 TO N2;
IF TABLE(JJ) > 0 THEN
DEMAN(JJ)=DEMAN(JJ)-CUM_ORDER(TABLE(JJ));
IF DEMAN (JJ) < 0 THEN DEMAN (JJ)=0;
END;
PUT FILE(DATA) EDIT('NAME'    ,SYSTE,JJJ)

```

```

PROC0109
PROC0110
PROC0111
PROC0112
PROC0113
PROC0114
PROC0115
PROC0116
PROC0117
PROC0118
PROC0119
PROC0120
PROC0121
PROC0122
PROC0123
PROC0124
PROC0125
PROC0126
PROC0127
PROC0128
PROC0129
PROC0130
PROC0131
PROC0132
PROC0133
PROC0134
PROC0135
PROC0136
PROC0137
PROC0138
PROC0139
PROC0140
PROC0141
PROC0142
PROC0143
PROC0144

```

\*/

```

                (SKIP,COL(1),A,COL(15),A,P'99');
        PUT FILE(DATA) EDIT('ROWS')
                (SKIP,COL(1),A,COL(15),A);
        PUT FILE(DATA) EDIT('N','COST')
                (SKIP,COL(2),A,COL(5),A,P'999');
DO  I=1 TO N2;
        PUT FILE(DATA) EDIT('E','DEMAN',I)
                (SKIP,COL(2),A,COL(5),A,P'999');
END;
DO  I=1 TO NUMBER;
        PUT FILE(DATA) EDIT('L','NUCLR',I)
                (SKIP,COL(2),A,COL(5),A,P'999');
END;
        PUT FILE(DATA) EDIT('COLUMNS')
                (SKIP,COL(1),A,COL(15),A);
DO  J=1 TO N2;
        PUT FILE(DATA) EDIT('SEP',0,J, 'MARKER', 'SEPORG')
                (SKIP,COL(5),A,P'99',P'999',COL(15),A,COL(40),A);
        DO P=TABLE(J)+1 TO K;
                PUT FILE(DATA) EDIT('FF',J,P,'COST',FUEL(P)*TIM(J))
                        (SKIP,COL(5),A,P'999',P'999',COL(15),A,
COL(25),P'ZZZZZZZV.9999');
                PUT FILE(DATA) EDIT('FF',J,P,'DEMAN',J,+1.)
                        (SKIP,COL(5),A,P'999',P'999',COL(15),A,P'999',
COL(25),P'ZZZZZZZV.9999');
        END;
END;
                IF (VP=1) THEN
        PUT FILE(DATA) EDIT('ENDSEP','MARKER','SEPEND')
                (SKIP,COL(5),A(8),COL(15),A(8),COL(40),A(8));
DO  J=1 TO NUMBER;
DO  I=1 TO N2;
IF  VP=1 THEN
        PUT FILE(DATA) EDIT('SNC',J,I, 'MARKER', 'SEPORG')
                (SKIP,COL(5),A,P'99',P'999',COL(15),A,COL(40),A);
DO  NN=1 TO VP;

```

```

PROC0145
PROC0146
PROC0147
PROC0148
PROC0149
PROC0150
PROC0151
PROC0152
PROC0153
PROC0154
PROC0155
PROC0156
PROC0157
PROC0158
PROC0159
PROC0160
PROC0161
PROC0162
PROC0163
PROC0164
PROC0165
PROC0166
PROC0167
PROC0168
PROC0169
PROC0170
PROC0171
PROC0172
PROC0173
PROC0174
PROC0175
PROC0176
PROC0177
PROC0178
PROC0179
PROC0180

```

```

        PUT FILE(DATA) EDIT('N',I,J,NN, 'DEMAN',I,1.)
            (SKIP,COL(5),A,P'999',P'99',P'9',COL(15),A,P'999',
COL(25),P'ZZZZZZV.9999')
            ('N',I,J,NN, 'NUCLR',J,      EFFIC(NN,2)*
TIM(I)*BTU(J)/B_T_U)
            (SKIP,COL(5),A,P'999',P'99',P'9',COL(15),A,P'999',
COL(25),P'ZZZZZZV.9999');
END;

END;
END;
IF VP=1 THEN
    PUT FILE(DATA) EDIT('ENDSEP','MARKER','SEPEND')
        (SKIP,COL(5),A(8),COL(15),A(8),COL(40),A(8));
    PUT FILE(DATA) EDIT
        ('RHS') (SKIP,COL(1),A,COL(15),A);
DCL (CHANGE(NUMBER),N_RHS(NUMBER)) FLOAT DEC;
N_RHS= TRUE*CAPACITY*LOAD*BTU;
CHANGE = TRUE* CAPACITY      * .05 * BTU;

DO I=1 TO WEEKS;
IF I=1 THEN GO TO NET;
GET FILE(LDMDL) LIST (DEMAN );
PUT LIST (' INPUT CUSTOMER DEMAND FUNCTION FOLLOWS:') SKIP(2);
PUT  EDIT(DEMAN ) (8 F(10), SKIP) SKIP;
DEMAN =DEMAN -BASE-HYD;
CALL PEAKERS(DEMAN ,TRUE,N2, TIM, MONEY);
MONEY=MONEY+FOSSIL;
PUT FILE(TRANSFR) LIST(DEMAN,MONEY,INCR);
DO JJ=1 TO N2;
IF TABLE(JJ) > 0 THEN
DEMAN(JJ)=DEMAN(JJ)-CUM_ORDER(TABLE(JJ));
IF DEMAN (JJ) < 0 THEN DEMAN (JJ)=0;
END;

NET:

```

```

PROC0181
PROC0182
PROC0183
PROC0184
PROC0185
PROC0186
PROC0187
PROC0188
PROC0189
PROC0190
PROC0191
PROC0192
PROC0193
PROC0194
PROC0195
PROC0196
PROC0197
PROC0198
PROC0199
PROC0200
PROC0201
PROC0202
PROC0203
PROC0204
PROC0205
PROC0206
PROC0207
PROC0208
PROC0209
PROC0210
PROC0211
PROC0212
PROC0213
PROC0214
PROC0215
PROC0216

```

```

DO J=1 TO N2;
  PUT FILE(DATA) EDIT
  ('RHS', I , 'DEMAN', J, DEMAN (J) )
    (SKIP, COL(5), A, P'999', COL(15), A, P'999', COL(25),
    P'-----V.9999');
END;
DO J=1 TO NUMBER;
  PUT FILE(DATA) EDIT
  ('RHS', I, 'NUCLR', J, N_RHS(J))
    (SKIP, COL(5), A, P'999', COL(15), A, P'999', COL(25),
    P'-----V.9999');
END;
IF MODE='DUR' THEN I=WEEKS;
END;
IF PARAMETER=0 THEN GO TO SKIPP;
IF PARAMETER=1 THEN DO;
DO J=1 TO N2;
PUT FILE(DATA) EDIT('CHC', 0, 'DEMAN', J, DEMAN(J)/100)
  (SKIP, COL(5), A, P'999', COL(15), A, P'999', COL(25),
  P'-----V.9999');
END; END;
IF PARAMETER=2 THEN DO;
DO J=1 TO N2;
PUT FILE(DATA) EDIT('CHC', 0, 'DEMAN', J, 100)
  (SKIP, COL(5), A, P'999', COL(15), A, P'999', COL(25),
  P'-----V.9999');
END; END;
SKIPP:
DO I=1 TO NUMBER;
PUT FILE(DATA) EDIT('CHC', 2*I-1, 'NUCLR', I, CHANGE(I))
  (SKIP, COL(5), A, P'999', COL(15), A, P'999', COL(25),
  P'-----V.9999');
PUT FILE(DATA) EDIT('CHC', 2*I , 'NUCLR', I, -CHANGE(I))
  (SKIP, COL(5), A, P'999', COL(15), A, P'999', COL(25),
  P'-----V.9999');
END;

```

```

PROC0217
PROC0218
PROC0219
PROC0220
PROC0221
PROC0222
PROC0223
PROC0224
PROC0225
PROC0226
PROC0227
PROC0228
PROC0229
PROC0230
PROC0231
PROC0232
PROC0233
PROC0234
PROC0235
PROC0236
PROC0237
PROC0238
PROC0239
PROC0240
PROC0241
PROC0242
PROC0243
PROC0244
PROC0245
PROC0246
PROC0247
PROC0248
PROC0249
PROC0250
PROC0251
PROC0252

```

```

        PUT FILE(DATA) EDIT('BOUNDS')
          (SKIP,COL(1),A,COL(15),A);
DO I=1 TO N2;
  DO J=TABLE(I)+1 TO K;
    PUT FILE(DATA) EDIT('UP','BOUND1','FF' , I, J, ORDER(J))
      (SKIP,COL(2),A,COL(5),A,COL(15),A,P'999',P'999',
        COL(25),P'ZZZZZZV.9999');
  END;
END;
DO I=1 TO NUMBER;
DO J=i TO N2;

DO NN=1 TO VP;
  PUT FILE(DATA) EDIT('UP','BOUND1','N',J,I,NN,CAPACITY(I)*EFFIC
    (NN,1)) (SKIP,COL(2),A,COL(5),A,COL(15),A,P'999',P'99',P'9',
    COL(25),P'ZZZZZZV.9999');
  END;

END;
END;
        PUT FILE(DATA) EDIT('ENDATA')
          (SKIP,COL(1),A,COL(15),A);
IF MODE='CHR' THEN JJJ=WEEKS;
END LOOP;
END;
GO TO TOP;
BOTTOM:
END NUC_OPT;
* PROCESS ;
  DURATN: PROC(OLD,CODE,TIME,TIM,POINT,STEPS,N1);
DCL (N1,MARKER(STEPS),TIME(*),TIM(*),TEE,I,J,CODE(*)) FIXED BIN;
DCL (SORT(N1),A,B,SUM,WORK(N1,2))
FIXED BIN(31), (STEPS,FIRST) FIXED BIN,
(OLD(*), POINT(*)) FIXED BIN(31,10),
(INTERVAL, HIGH, LOW) FIXED BIN(31),

```

```

PROC0253
PROC0254
PROC0255
PROC0256
PROC0257
PROC0258
PROC0259
PRJC0260
PRJC0261
PROC0262
PRJC0263
PROC0264
PRJC0265
PROC0266
PROC0267
PROC0268
PROC0269
PROC0270
PROC0271
PROC0272
PROC0273
PROC0274
PROC0275
PROC0276
PROC0277
PROC0278
PROC0279
PROC0280
PROC0281
PROC0282
PROC0283
PROC0284
PROC0285
PROC0286
PROC0287
PROC0288

```

```
ISORT EXTERNAL ENTRY( (*) FIXED BIN(31),FIXED BIN(31), FIXED BIN(31))
OPTIONS(FORTRAN INTER);
```

```
      /* SET UP SORT      */
```

```
SORT=OLD;
DO I=1 TO N1;
SORT(I)=1000*SORT(I)+I;
END;
```

```
A=1;
B=N1;
CALL ISORT(SORT,A,B);
DO I=1 TO N1;
WORK(I,1)=SORT(N1+1-I)/1000;
WORK(I,2)=MOD(SORT(N1+1-I),1000);
END;
```

```
      /* BREAK INTO INTERVALS */
```

```
INTERVAL =(WORK(1,1)-WORK(N1,1))/STEPS;
J=0;
HIGH=WORK(1,1)+INTERVAL;
LOW=WORK(1,1); DO I=1 TO STEPS-1;
HIGH=HIGH -INTERVAL;
LOW = LOW - INTERVAL;
TOP: J=J+1;
IF (WORK(J,1) <= HIGH) & (WORK(J,1) > LOW ) THEN GO TO TOP;
ELSE J=J-1;
MARKER(I)=J;
END;
MARKER(STEPS)=N1;
```

```
      /* SET MARKER      */
```

```
FIRST=1;
DO I=1 TO STEPS;
TEE=0;
SUM=0 ;
DO J=FIRST TO MARKER(I);
SUM=SUM+WORK(J,1)*TIME(WORK(J,2));
```

```
PROC0289
PROC0290
PROC0291
PROC0292
PROC0293
PROC0294
PROC0295
PROC0296
PROC0297
PROC0298
PROC0299
PROC0300
PROC0301
PROC0302
PROC0303
PROC0304
PROC0305
PROC0306
PROC0307
PROC0308
PROC0309
PROC0310
PROC0311
PROC0312
PROC0313
PROC0314
PROC0315
PROC0316
PROC0317
PROC0318
PROC0319
PROC0320
PROC0321
PROC0322
PROC0323
PROC0324
```

```

TEE=TEE+TIME(WORK(J,2));
WORK(J,1)=I;
END;
IF TEE=0 THEN POINT(I)=0; ELSE
POINT(I)=SUM/TEE;
TIM (I)=TEE;
FIRST=MARKER(I)+1;
END;
DO I=1 TO N1;
SORT(I)=1000*WORK(I,2)+WORK(I,1);
END;
CALL ISORT(SORT,A,B);
DO I=1 TO N1;
CODE(I)=MOD(SORT(I),1000);
END;

RETURN;
END DURATN;
* PROCESS;
PEAKERS: PROC(DEMAND,TRUE,N1,TIME,OPERATIONS);
DCL ( TIME(*), N1,TRUE) FIXED BIN, DEMAND(*) FIXED BIN(31,10),
( DEM(N1),DEMM(N1),MAX(2),
C_FACTOR, RATING, HEAT, F_COST, SUSD, TIME_LEFT) FLOAT BIN;
DCL P_NUM FIXED BIN, OPERATIONS FIXED BIN(31) ;
OPERATIONS=0;
GET FILE(PEAKS) LIST(P_NUM);
IF P_NUM = 0 THEN DO ;
PUT EDIT( ' NO PEAKERS THIS WEEK')(A) SKIP(5);
GO TO NT;
END;
BEGIN;

DCL PEAK(N1,P_NUM) FLOAT BIN;
PEAK=0;
DEM=DEMAND;
DO K=1 TO P_NUM;

```

```

PROC0325
PROC0326
PROC0327
PROC0328
PROC0329
PROC0330
PROC0331
PROC0332
PROC0333
PROC0334
PROC0335
PROC0336
PROC0337
PROC0338
PROC0339
PROC0340
PROC0341
PROC0342
PROC0343
PROC0344
PROC0345
PROC0346
PROC0347
PROC0348
PROC0349
PROC0350
PROC0351
PROC0352
PROC0353
PROC0354
PROC0355
PROC0356
PROC0357
PROC0358
PROC0359
PROC0360

```

```

GET FILE(PEAKS) LIST(C_FACTOR, RATING, HEAT, F_COST, SUSD);
PUT EDIT( ' CAPACITY FACTOR=',C_FACTOR,'RATED CAPACITY(MW)=', RATING,
'HEAT RATE(MMBTU/MWH)=', HEAT, 'FUEL COST($/MMBTU)=', F_COST,'SUSD COST
($)= '
,SUSD)(A,F(5,2),X(3),A,F(4),X(3),A, F(6,2),X(3),A,F(6,2),X(3),A,F(5))
SKIP;
DEMM=DEM;
TIME_LEFT=C_FACTOR*TRUE;
OPERATIONS=OPERATIONS+TIME_LEFT*RATING*HEAT*F_COST;
TOP:
MAX(1)=DEMM(1);
MAX(2)=1;
DO I=2 TO N1;
IF MAX(1) < DEMM(I) THEN DO;
MAX(1)=DEMM(I);
MAX(2)=I;
END;
END;
IF TIME(MAX(2)) < TIME_LEFT THEN DO;
TIME_LEFT=TIME_LEFT-TIME(MAX(2));
PEAK(MAX(2),K)=RATING;
DEMM(MAX(2))=0;
GO TO TOP;
END;
IF TIME(MAX(2)) = TIME_LEFT THEN DO;
PEAK(MAX(2),K)=RATING;
GO TO BOTTOM;
END;
PEAK(MAX(2),K)=RATING*TIME_LEFT/TIME(MAX(2));
BOTTOM:
DO I=1 TO N1;
DEM(I)=DEM(I)-PEAK(I,K);
END;
CN=0;
DO I=2 TO N1;
IF ((PEAK(I,K) > 0) & ( PEAK(I-1,K) = 0) ) THEN ON=ON+TIME(I);

```

```

PROC0361
PROC0362
PROC0363
PROC0364
PROC0365
PROC0366
PROC0367
PROC0368
PROC0369
PROC0370
PROC0371
PROC0372
PROC0373
PROC0374
PROC0375
PROC0376
PROC0377
PROC0378
PROC0379
PROC0380
PROC0381
PROC0382
PROC0383
PROC0384
PROC0385
PROC0386
PROC0387
PROC0388
PROC0389
PROC0390
PROC0391
PROC0392
PROC0393
PROC0394
PROC0395
PROC0396

```



```

END;
OPERATIONS= OPERATIONS + ON*SUSD;
END;
PUT EDIT(' OPERATION COST OF PEAKERS= $',OPERATIONS)(COL(20),A,F(10,2))
SKIP(2);

GET FILE(PEAKS) LIST (CODE);
PUT DATA(CODE);
IF CODE=0 THEN DO;
PUT EDIT(' THE FOLLOWING DETAILS THE OPERATIONS MATRIX OF PEAKERS MAD
E AVAILABLE' )(COL(10),A)SKIP(5);
PUT EDIT('TIME','DEMAND','TOTAL PEAKERS','PEAKER 1','PEAKER 2')
(COL(5),A, COL(15),A, COL(25) , A, COL(40),A,COL(50),A,COL(60),A)
SKIP(3);
DO I=1 TO N1;
PUT EDIT (I, DEMAND(I), DEMAND(I)-DEM(I), (PEAK(I,J) DO J=1 TO P_NUM))
(COL(5),F(3), COL(15), F(7) , COL(25),F(8),10( X(6),F(4))) SKIP;
END;
END;

DEMAND=DEM;
END;
NT:
RETURN;
END PEAKERS;
* PROCESS;
PECK_OR: PROC(BASE,R_ORDER,R_FUEL,K,BTU,TRANSFORM);

DCL (ORDER(K),FUEL(K,2))FLOAT DEC(16), LOAD FLOAT DEC;
DCL (MATCH,LABEL,TRANSFORM(*,2),FLAG(K) ) FIXED BIN,MIN(2) FLOAT DEC;
DCL(N1,VP1,N2,VP2,N3,VP3)FIXED BIN;
DCL (R_ORDER(*),R_FUEL(*), BTU) FLOAT DEC(16);

GET FILE(PECK)
LIST(N1,VP1,N2,VP2,N3,VP3);

```

```

PROC0397
PROC0398
PROC0399
PROC0400
PROC0401
PROC0402
PROC0403
PROC0404
PROC0405
PROC0406
PROC0407
PROC0408
PROC0409
PROC0410
PROC0411
PROC0412
PROC0413
PROC0414
PROC0415
PROC0416
PROC0417
PROC0418
PROC0419
PROC0420
PROC0421
PROC0422
PROC0423
PROC0424
PROC0425
PROC0426
PROC0427
PROC0428
PROC0429
PROC0430
PROC0431
PROC0432

```

```

PUT LIST(' THE FOLLOWING IS THE PECK FILE INPUT FOR LARGE,MEDIUM, SMALL
FOSSIL PLANTS:'); PUT SKIP;
PUT DATA(N1,VP1,N2,VP2,N3,VP3);
PUT FILE(TRANSFER)
LIST(N1,VP1,N2,VP2,N3,VP3);
BEGIN;
TRANSFORM=0;
FLAG=0;
DCL
(NLGE(N1,4),NMED(N2,4),NSML(N3,4),L_HEAT(VP1),M_HEAT(VP2),S_HEAT(VP3)
,LGE_HEAT(VP1,2),MED_HEAT(VP2,2),SML_HEAT(VP3,2),COSTL(VP1),
COSTM(VP2),COSTS(VP3))FLOAT DEC;
GET FILE(PECK)
LIST(LGE_HEAT,MED_HEAT,SML_HEAT,NLGE,NMED,NSML);
PUT SKIP EDIT(' AVERAGE HEAT RATES FOR LARGE, MEDIUM AND SMALL FOSSIL P
LANTS: FRACTION OF RATED POWER, HEAT RATE(MMBTU/MWH)')(SKIP,A)
(LGE_HEAT)(SKIP,20 F(6,2))
(MED_HEAT)(SKIP,20 F(6,2))
(SML_HEAT)(SKIP,20 F(6,2)) ;
PUT EDIT(' PLANT PARAMETERS FOR LARGE, MEDIUM AND SMALL FOSSIL PLANTS:
')(SKIP(2),A);
PUT SKIP LIST(' NUMBER, CAPACITY(MW), HEAT RATE(MMBTU/MWH), FUEL COS
T($/MMBTU)');
PUT EDIT
(NLGE)(SKIP(2), 20( 4 F(10,2),SKIP))
(NMED)(SKIP(2), 20( 4 F(10,2),SKIP))
(NSML)(SKIP(2), 20( 4 F(10,2),SKIP)) ;
CALL INPUT_OUTPUT(LGE_HEAT,VP1,L_HEAT,COSTL);
CALL INPUT_OUTPUT(MED_HEAT,VP2,M_HEAT,COSTM);
CALL INPUT_OUTPUT(SML_HEAT,VP3,S_HEAT,COSTS);

INPUT_OUTPUT : PROC(START,VP,FINISH,COST);
DCL VP FIXED BIN,(START(* ,2), FINISH(*),COST(*) ) FLOAT DEC;
FINISH(1)=START(1,1);
DO I=2 TO VP;
FINISH(I)=START(I,1)-START(I-1,1);

```

```

PROC0433
PROC0434
PROC0435
PROC0436
PROC0437
PROC0438
PROC0439
PROC0440
PROC0441
PROC0442
PROC0443
PROC0444
PROC0445
PROC0446
PROC0447
PROC0448
PROC0449
PROC0450
PROC0451
PROC0452
PROC0453
PROC0454
PROC0455
PROC0456
PROC0457
PROC0458
PROC0459
PROC0460
PROC0461
PROC0462
PROC0463
PROC0464
PROC0465
PROC0466
PROC0467
PROC0468

```

```

END;
COST(1)=START(1,2);
DO I=2 TO VP;
COST(I)=(START(I,1)*START(I,2)-START(I-1,1)*START(I-1,2))/FINISH(I);
END;
END;

```

```

BASE=0;
K=0;
BTU=0;
DO I=1 TO N1;
LOAD=NLGE(I,2)*LGE_HEAT(1,1)*NLGE(I,1);
BTU=BTU+COSTL(1)*LOAD*NLGE(I,3)*NLGE(I,4)/LGE_HEAT(VP1,2);
BASE=BASE+LOAD;
END;
DO I=1 TO N2;
LOAD=NMED(I,2)*MED_HEAT(1,1)*NMED(I,1);
BTU=BTU+COSTM(1)*LOAD*NMED(I,3)*NMED(I,4)/MED_HEAT(VP2,2);
BASE=BASE+LOAD;
END;
DO I=1 TO N3;
LOAD=NSML(I,2)*SML_HEAT(1,1)*NSML(I,1);
BTU=BTU+COSTS(1)*LOAD*NSML(I,3)*NSML(I,4)/SML_HEAT(VP3,2);
BASE=BASE+LOAD;
END;

```

```

DO J=2 TO VP1;
DO I=1 TO N1;
K=K+1;
LOAD=NLGE(I,2)*L_HEAT(J)*NLGE(I,1);
ORDER(K)=LOAD;
FUEL(K,1)=
NLGE(I,4)*COSTL(J)*NLGE(I,3)/LGE_HEAT(VP1,2);
FUEL(K,2)=10* ( +I)+J-1;
END;

```

```

PROC0469
PROC0470
PROC0471
PROC0472
PROC0473
PROC0474
PROC0475
PROC0476
PROC0477
PROC0478
PROC0479
PROC0480
PROC0481
PROC0482
PROC0483
PROC0484
PROC0485
PROC0486
PROC0487
PROC0488
PROC0489
PROC0490
PROC0491
PROC0492
PROC0493
PROC0494
PROC0495
PROC0496
PROC0497
PROC0498
PROC0499
PROC0500
PROC0501
PROC0502
PROC0503
PROC0504

```

```

END;
DO J=2 TO VP2;
DO I=1 TO N2;
K=K+1;
ORDER(K)= NMED(I,2)*M_HEAT(J)*NMED(I,1);
FUEL(K,1)=
  NMED(I,4)*COSTM(J)*NMED(I,3)/MED_HEAT(VP2,2);
FUEL(K,2)=10*(N1 +I)+J-1;
END;
END;
DO J=2 TO VP3;
DO I=1 TO N3;
K=K+1;
ORDER(K)=NSML(I,2)*S_HEAT(J)*NSML(I,1);
FUEL(K,1)=
  NSML(I,4)*COSTS(J)*NSML(I,3)/SML_HEAT(VP3,2);
FUEL(K,2)=10*(N1+N2+I)+J-1;
END;
END;
GET FILE(PECK)
LIST(EMERG,E_COST);
K=K+1;
ORDER(K)=EMERG;
FUEL(K,1)=E_COST;
FUEL(K,2)=10*(N1+N2+N3+1)+1;

DO J=1 TO K;
AGAIN:
MIN(1)=FUEL(1,1);
MIN(2)=1;
DO I=2 TO K;
IF (MIN(1)>FUEL(I,1)) & FLAG(I)=0 THEN DO;
MIN(1)=FUEL(I,1);
MIN(2)=I;
END;
END;

```

```

PROC0505
PROC0506
PROC0507
PROC0508
PROC0509
PROC0510
PROC0511
PROC0512
PROC0513
PROC0514
PROC0515
PROC0516
PROC0517
PROC0518
PROC0519
PROC0520
PROC0521
PROC0522
PROC0523
PROC0524
PROC0525
PROC0526
PROC0527
PROC0528
PROC0529
PROC0530
PROC0531
PROC0532
PROC0533
PROC0534
PROC0535
PROC0536
PROC0537
PROC0538
PROC0539
PROC0540

```

```

LABEL=FUEL(MIN(2),2);
IF MOD(LABEL,10)=1 THEN GO TO PLACE;
MATCH=LABEL-1;
DO PP=1 TO J;
IF MATCH=TRANSFORM(PP,2) THEN GO TO PLACE;
END;
FLAG(MIN(2))=1;
GO TO AGAIN;
PLACE: FUEL(MIN(2) ,1)=1000.;
R_FUEL(J)=MIN(1);
TRANSFORM(J,1)=MIN(2);
TRANSFORM(J,2)=FUEL(MIN(2),2);
R_ORDER(J)=ORDER(MIN(2));
FLAG=0;
END;
RETURN;

```

```

END PECK_OR;
//L.SYSLIB DD DSN=SYS5.MATHLIB.SUBR,DISP=SHR
// DD
// DD
// DD
// DD DSN=SYS1.FORTLIB,DISP=SHR
// DD DSN=SYS2.SSP.SUBR,DISP=SHR
//SYSLMOD DD DSN=U.M9960.8981.TEST1.LIBRARY.LMOD(NUCLEAR),DISP=OLD,
// DCB=BLKSIZE=13030,SPACE=
PUMP_ST:
PROC OPTIONS(MAIN);
/* THIS PROGRAM REFORMATS THE NUCLEAR L.P. OPTIMIZATION SOLUTION AND
CALLS THE DESIRED P.S. SUBROUTINES TO CALCULATE THE P.S. GENERATION
SCHEDULE. THE INCREMENTAL FOSSIL CAPACITY FACTORS ARE ALSO CALCULATED
BELOW. THE ALGORITHM OF THIS PROGRAM IS DESCRIBED IN THE APPENDIX OF
RAY ENG'S PH.D THESIS, MIT DEPT. OF NUCLEAR ENGINEERING. *****/
DCL
MODE CHAR(4),
INCR FIXED BIN(31,5);

```

```

PROC0541
PROC0542
PROC0543
PROC0544
PROC0545
PROC0546
PROC0547
PROC0548
PROC0549
PROC0550
PROC0551
PROC0552
PROC0553
PROC0554
PROC0555
PROC0556
PROC0557
PROC0558
PROC0559
PROC0560
PROC0561
PROC0562
PROC0563
PROC0564
PROC0565
PROC0566
PROC0567
00000020 PROC0568
00000030 PROC0569
00000040 PROC0570
00000050 PROC0571
00000060 PROC0572
00000070 PROC0573
00000080 PROC0574
00000090 PROC0575
00000100 PROC0576

```

```

DCL
  (MONEY,
  Z) FIXED BIN(31);
DCL
  (M1,
  M2,
  M3(6),
  COUNT,
  I,
  J,
  K,
  WEEKS,
  N1,
  CUM,
  NN,
  NUMBER,
  VP,
  CODE) FIXED BIN;
DCL
  RATIO FIXED DEC(5,3);
DCL
  (RESERIOR,
  CAP_PUMP,
  CAPACITY,
  FREE,
  BYE,
  TOLERANCE,
  START) FIXED DEC;
  Z=0;
  ON ENDFILE(TRANSFER)
    GO TO BOTTOM;
  ON ENDFILE(SYSIN)
    GO TO BOTTOM;
PEAK:
  COUNT=0;
/*      FOSSIL PLANT PARAMETERS      */

```

```

00000110 PROC0577
00000120 PROC0578
00000130 PROC0579
00000140 PROC0580
00000150 PROC0581
00000160 PROC0582
00000170 PROC0583
00000180 PROC0584
00000190 PROC0585
00000200 PROC0586
00000210 PROC0587
00000220 PROC0588
00000230 PROC0589
00000240 PROC0590
00000250 PROC0591
00000260 PROC0592
00000270 PROC0593
00000280 PROC0594
00000290 PROC0595
00000300 PROC0596
00000310 PROC0597
00000320 PROC0598
00000330 PROC0599
00000340 PROC0600
00000350 PROC0601
00000360 PROC0602
00000370 PROC0603
00000380 PROC0604
00000390 PROC0605
00000400 PROC0606
00000410 PROC0607
00000420 PROC0608
00000430 PROC0609
00000440 PROC0610
00000450 PROC0611
00000460 PROC0612

```

GET FILE(TRANSFR) LIST(M3);	00000470	PROC0613
PUT SKIP LIST(' ENTER P.S. MODE AND P.S. CODE');	00000480	PROC0614
/* ENTER PUMPED STORAGE OPERATION MODE AND OUTPUT CODE */	00000490	PROC0615
GET FILE(SYSIN) LIST( MCDE, CODE)COPY;	00000500	PROC0616
PUT FILE(SYSPRINT) LIST(' ENTER PUMPED STORAGE PARAMETERS:')	00000510	PROC0617
SKIP;	00000520	PROC0618
PUT FILE(SYSPRINT)	00000530	PROC0619
LIST(	00000540	PROC0620
' CAPACITY, RATIO, CAP_PUMP, RESERIOR, FREE, START,BYE,TOLERANCE')	00000550	PROC0621
;	00000560	PROC0622
GET FILE(SYSIN) LIST (	00000570	PROC0623
CAPACITY,RATIO,CAP_PUMP,RESERIOR ,FREE,START,BYE,TOLERANCE)COPY;	00000580	PROC0624
TOP:	00000590	PROC0625
GET FILE(TRANSFR) LIST( WEEKS,N1,CUM,NN,NUMBER,VP);	00000600	PROC0626
BLOCK:	00000610	PROC0627
BEGIN;	00000620	PROC0628
DCL	00000630	PROC0629
BTU(NUMBER) FIXED DEC(5,4);	00000640	PROC0630
DCL	00000650	PROC0631
NUC_CAP(NUMBER) FIXED DEC,	00000660	PROC0632
LOAD(N1) FIXED DEC,	00000670	PROC0633
(TIME(NN),	00000680	PROC0634
TRANSFORM(CUM,2),	00000690	PROC0635
INCREMENT(CUM),	00000700	PROC0636
ORDER(N1)) FIXED BIN,	00000710	PROC0637
(CUM_FUEL(CUM) ,	00000720	PROC0638
STEP(CUM),	00000730	PROC0639
CUM_STEP(CUM)) FIXED DEC,	00000740	PROC0640
CHAR CHAR(3);	00000750	PROC0641
DCL	00000760	PROC0642
FUEL(CUM) FIXED DEC(5,3);	00000770	PROC0643
DCL	00000780	PROC0644
ALLOT(WEEKS) FIXED BIN,	00000790	PROC0645
(DEMAND(NN),	00000800	PROC0646
NUCLEAR(NN,NUMBER),	00000810	PROC0647
FOSSIL(NN)) FIXED BIN(31,5),	00000820	PROC0648

TEMP FLOAT DEC(8),	00000830	PROC0649
TEM FIXED BIN(31,5);	00000840	PROC0650
GET FILE(TRANSFR)	00000850	PROC0651
LIST(TIME,FUEL ,CUM_FUEL,STEP,CUM_STEP,TRANSFORM, ORDER,CHAR,	00000860	PROC0652
BTU, NUC_CAP,DEMAND,MONEY, INCRE);	00000870	PROC0653
PUT SKIP(3);	00000880	PROC0654
PUT SKIP LIST(' ENTER NUMBER OF WEEKLY PERMUTATIONS');	00000890	PROC0655
IF CHAR='CHR' THEN	00000900	PROC0656
GET FILE(SYSIN) LIST (ALLOT)COPY;	00000910	PROC0657
ELSE	00000920	PROC0658
GET FILE(SYSIN) LIST(ALLOT(1))COPY;	00000930	PROC0659
DCL	00000940	PROC0660
STRANG CHAR(80);	00000950	PROC0661
PUT SKIP LIST(' SIMULATION DESCRIPTION: ');	00000960	PROC0662
GET LIST(TEM);	00000970	PROC0663
DO I=1 TO TEM;	00000980	PROC0664
GET LIST(STRANG) COPY;	00000990	PROC0665
END;	00001000	PROC0666
LOOP:	00001010	PROC0667
DO M1=1 TO WEEKS;	00001020	PROC0668
IF M1>1 THEN	00001030	PROC0669
GET FILE(TRANSFR) LIST(DEMAND,MONEY, INCRE);	00001040	PROC0670
LOOP_TWO:	00001050	PROC0671
DO M2=1 TO ALLOT(M1);	00001060	PROC0672
PUT FILE(SYSPRINT) EDIT (	00001070	PROC0673
' OPTIMAL NUCLEAR GENERATION SCHEDULE')(A) SKIP(4);	00001080	PROC0674
PUT FILE(SYSPRINT) EDIT (	00001090	PROC0675
'FOR',COUNT+1,' WEEK;', M2,' ALLOCATION')(	00001100	PROC0676
SKIP,A,F(5),A,F(5),A);	00001110	PROC0677
Z=Z+1;	00001120	PROC0678
PUT FILE(SYSPRINT) EDIT('INDEX=',Z)(X(30),A(6), F(10));	00001130	PROC0679
/* ***** L. P. SOLUTION READER ***** */	00001140	PROC0680
/* THIS SECTION INTERPETS THE MPSX L.P. SOLUTION INTO A USABLE	00001150	PROC0681
FORMAT. THE L.P. SOLUTION FORMAT IS DEPENDENT UPON THE OUTPUT	00001160	PROC0682
INSTRUCTIONS USED IN THE MPSX CONTROL LANGUAGE PROGRAM, AND HENCE	00001170	PROC0683
UNDER USER CONTROL. THIS SECTION WILL READ THE OUTPUT PRODUCED BY THE	00001180	PROC0684



"SOLUTION" COMMAND SHOWN IN THE SAMPLE JOBS ILLUSTRATED IN THE  
 APPENDIX OF RAY ENG'S THESIS. \*/

DCL

```
1 SOL BASED(R),
  2 ACTIVE FLOAT DEC(8),
  2 DUAL FLOAT DEC(8),
  2 NAME CHAR(8);
```

DCL

```
1 SOLE BASED(Q),
  2 ACTIVITY FLOAT DEC(8),
  2 NAME CHAR(8);
```

DCL

```
1 ANS BASED (T),
  2 ALPHA (10) CHAR(8),
  2 REAL(3) FLOAT DEC(4),
  2 INTEGER(3) FIXED BIN(31),
  2 ALPH(4) CHAR(4),
  2 TITLE CHAR(80);
```

DCL

```
ECO EXTERNAL ENTRY(FIXED BIN, FIXED BIN, (*) FIXED DEC, FIXED BIN,
  (*) FIXED DEC, (*) FIXED DEC(5,3), CHAR(4), FIXED DEC,
FIXED DEC(5,3), FIXED DEC, FIXED DEC, FIXED DEC, FIXED DEC, FIXED DEC
, FIXED DEC);
READ FILE(SOLN) IGNORE(4);
READ FILE(SOLN) SET(T);
PUT FILE(SYSPRINT) EDIT(' L.P. PARAMETERS' ) (
  SKIP, COL(10), A) ( 'OBJECTIVE FUNCTION', ALPHA(3) ) (
  SKIP, COL(5), A, COL(30), A) ('RHS', ALPHA(4)) (
  SKIP, COL(5), A, COL(30), A) ('STATUS', ALPH(2)) (
  SKIP, COL(5), A, COL(30), A) (
  'NUMBER OF ITERATIONS', INTEGER(1)) (
  SKIP, COL(5), A, COL(30), A) ;
PUT FILE(SYSPRINT)
EDIT('FIXED FOSSIL FUEL COST($/WK)', MONEY + INCRE) (
  SKIP, COL(1), A, COL(35), P'$$$ ,999,999V.') (
  'VARIABLE FOSSIL FUEL COST($/WK)', REAL(1)) (
```

```
00001190 PROC0685
00001200 PROC0686
00001210 PROC0687
00001220 PROC0688
00001230 PROC0689
00001240 PROC0690
00001250 PROC0691
00001260 PROC0692
00001270 PROC0693
00001280 PROC0694
00001290 PROC0695
00001300 PROC0696
00001310 PROC0697
00001320 PROC0698
00001330 PROC0699
00001340 PROC0700
00001350 PROC0701
00001360 PROC0702
00001370 PROC0703
00001380 PROC0704
00001390 PROC0705
00001400 PROC0706
00001410 PROC0707
00001420 PROC0708
00001430 PROC0709
00001440 PROC0710
00001450 PROC0711
00001460 PROC0712
00001470 PROC0713
00001480 PROC0714
00001490 PROC0715
00001500 PROC0716
00001510 PROC0717
00001520 PROC0718
00001530 PROC0719
00001540 PROC0720
```

COL(50) , A, COL(85), P'\$\$\$,\$\$\$,999V.');	00001550	PROC0721
PUT FILE(SYSPRINT) EDIT (	00001560	PROC0722
' SYSTEM COST WITHOUT PUMPED STORAGE, ',	00001570	PROC0723
MONEY + INCRE+ REAL(1) ) (A,P'\$\$\$,\$\$\$,999,999V.')	00001580	PROC0724
SKIP;	00001590	PROC0725
READ FILE(SOLN) IGNORE(5+NN);	00001600	PROC0726
PUT FILE(SYSPRINT)	00001610	PROC0727
EDIT('REACTOR',	00001620	PROC0728
'NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)')	00001630	PROC0729
( COL(5),A,COL(20),A)SKIP(3);	00001640	PROC0730
IF VP=1 THEN	00001650	PROC0731
PUT FILE(SYSPRINT) EDIT('OCNP (MILLS/KWH)' ) (	00001660	PROC0732
COL(75), A);	00001670	PROC0733
DO J=1 TO NUMBER;	00001680	PROC0734
READ FILE(SCLN) SET(R);	00001690	PROC0735
PUT FILE(SYSPRINT) EDIT(J,DUAL/10.) (	00001700	PROC0736
SKIP,COL(5),F(5), COL(25),F(8,2));	00001710	PROC0737
IF VP=1 THEN	00001720	PROC0738
PUT FILE(SYSPRINT) EDIT(DUAL*BTU(J)) (	00001730	PROC0739
COL(80), F(8,2));	00001740	PROC0740
END;	00001750	PROC0741
READ FILE(SCLN) IGNORE(4);	00001760	PROC0742
FOSSIL=0;	00001770	PROC0743
DO J=1 TO NUMBER;	00001780	PROC0744
DO I=1 TO NN;	00001790	PROC0745
TEMP=0;	00001800	PROC0746
DC K=1 TO VP;	00001810	PROC0747
READ FILE(SCLN) SET(Q);	00001820	PROC0748
TEMP=TEMP+ACTIVITY;	00001830	PROC0749
END;	00001840	PROC0750
TEM=TEMP;	00001850	PROC0751
FOSSIL(I)=FOSSIL(I)+TEM;	00001860	PROC0752
NUCLEAR(I,J)=TEM;	00001870	PROC0753
END;	00001880	PROC0754
END;	00001890	PROC0755
FOSSIL=DEMAND-FOSSIL;	00001900	PROC0756
PUT FILE(SYSPRINT) SKIP(3)		

LIST('NUCLEAR UNIT DISPATCHING: ');	00001910	PROC0757
PUT FILE(SYSPRINT) SKIP	00001920	PROC0758
EDIT('INTERVAL WEIGHTING FACTOR')(A);	00001930	PROC0759
PUT FILE(SYSPRINT)	00001940	PROC0760
EDIT('DEMAND','FOSSIL','NUCLEAR 1','NUCLEAR 2',	00001950	PROC0761
'NUCLEAR 3','...')(X(5), 3(A,X(9)),3(A,X(9)));	00001960	PROC0762
PUT SKIP EDIT (	00001970	PROC0763
'(HOURS)', '(MW)', '(MW)', '(MW)', '(MW)', '(MW)')(	00001980	PROC0764
COL(14),A(7), COL(33), A(4), X(11), A(4),	00001990	PROC0765
3(X(13), A(4)));	00002000	PROC0766
DO I=1 TO NN;	00002010	PROC0767
PUT FILE(SYSPRINT)	00002020	PROC0768
EDIT( I, TIME(I), DEMAND(I), FOSSIL(I),(	00002030	PROC0769
NUCLEAR(I,J) DO J=1 TO NUMBER)) (	00002040	PROC0770
F(5),F(12),F(20), F(15), 4 F(17))SKIP;	00002050	PROC0771
END;	00002060	PROC0772
READ FILE(SOLN) IGNORE(2);	00002070	PROC0773
/*    END OF L.P. READER SECTION    */	00002080	PROC0774
/* MODE OF OPERATION OF PUMPED STORAGE UNIT IS CHOSEN: (1) IF "NONE",	00002090	PROC0775
THEN NO P.S. UNIT IS SCHEDULED, THE PROGRAM CONTINUES WITH	00002100	PROC0776
CALCULATING THE FOSSIL INCREMENTAL CAPACITY FACTORS; (2) IF "QUICK",	00002110	PROC0777
THEN NO FURTHER PROCESSING (NO P.S. SCHEDULING, AND NO INCREMENTAL	00002120	PROC0778
FOSSIL CAPACITY FACTOR CALCULATIONS); (3) IF "ECO", THEN THE ECONOMIC	00002130	PROC0779
PUMPED STORAGE ALGORITHM IS CALLED; (4) IF "SEC", THEN THE SECURITY	00002140	PROC0780
P.S. ALGORITHM IS CALLED. *****/	00002150	PROC0781
DO I=1 TO N1;	00002160	PROC0782
LOAD(I)= FOSSIL(ORDER(I));	00002170	PROC0783
END;	00002180	PROC0784
IF MODE='NONE' THEN	00002190	PROC0785
GO TO REPORT;	00002200	PROC0786
IF MODE='QUICK' THEN	00002210	PROC0787
GO TO SHORT_CUT;	00002220	PROC0788
PUT SKIP(2) LIST('PUMPED STORAGE STATISTICS:');	00002230	PROC0789
IF MODE='ECO'   MODE='SEC' THEN	00002240	PROC0790
CALL	00002250	PROC0791
ECO(N1,CUM, LOAD, CODE, CUM_STEP, FUEL, MODE, CAPACITY,	00002260	PROC0792

```

                RATIO, CAP_PUMP, RESERIOR, FREE, START, BYE,
                TOLERANCE);
/* PUMPED STORAGE GENERATION COST CALCULATIONS */
DCL
  INCREMENTAL_FOSSIL_FUEL_COST FIXED DEC(15,2);
DCL
  P FIXED BIN;
  INCREMENTAL_FOSSIL_FUEL_COST=0;
  DO I=1 TO N1;
    -DO P=1 TO CLM;
      IF LOAD(I) < CUM_STEP(P) THEN
        GO TO TT;
    END;
  IF P=1 THEN
    INCREMENTAL_FOSSIL_FUEL_COST=
    INCREMENTAL_FOSSIL_FUEL_COST +LOAD(I)*FUEL(P);
  ELSE
    INCREMENTAL_FOSSIL_FUEL_COST=
    INCREMENTAL_FOSSIL_FUEL_COST+CUM_FUEL(P-1) +(
    LOAD(I)-CUM_STEP(P-1))*FUEL(P);
  END;
  PUT SKIP(3) LIST('FOSSIL INCREMENTS RESULTS:');
  PUT FILE(SYSPRINT)
  EDIT( ' INCREMENTAL FOSSIL FUEL COST=',
  INCREMENTAL_FOSSIL_FUEL_COST)(A,P'$$$$,999,999V.' ) SKIP;
  PUT SKIP
  EDIT(' WEEKLY SYSTEM PRODUCTION COST=',
  MONEY + INCREMENTAL_FOSSIL_FUEL_COST) (
  A, P'$$$$,999,999V.' );
/* ***** REPORT GENERATOR ***** */
/* OF FOSSIL INCREMENTAL CAPACITY FACTORS * */
DCL
  P_FACTOR(CUM) FLOAT DEC;
DCL
  CAP_FACTOR(CUM) FLOAT DEC;

```

```

00002270 PROC0793
00002280 PROC0794
00002290 PROC0795
00002300 PROC0796
00002310 PROC0797
00002320 PROC0798
00002330 PROC0799
00002340 PROC0800
00002350 PROC0801
00002360 PROC0802
00002370 PROC0803
00002380 PROC0804
00002390 PROC0805
00002400 PROC0806
00002410 PROC0807
00002420 PROC0808
00002430 PROC0809
00002440 PROC0810
00002450 PROC0811
00002460 PROC0812
00002470 PROC0813
00002480 PROC0814
00002490 PROC0815
00002500 PROC0816
00002510 PROC0817
00002520 PROC0818
00002530 PROC0819
00002540 PROC0820
00002550 PROC0821
00002560 PROC0822
00002570 PROC0823
00002580 PROC0824
00002590 PROC0825
00002600 PROC0826
00002610 PROC0827
00002620 PROC0828

```

DCL		00002630	PROC0829
MATRIX (N1,CUM) FLOAT BIN;		00002640	PROC0830
REPORT:		00002650	PROC0831
PUT SKIP(4) LIST(' REACTORS	DCNP (MILLS/KWH)');	00002660	PROC0832
DO I=1 TO NUMBER;		00002670	PROC0833
TEMP=0;		00002680	PROC0834
TEMP=0;		00002690	PROC0835
DO J=1 TO N1;		00002700	PROC0836
IF (NUCLEAR(ORDER(J), I) < ( NUC_CAP(I) -1) ) & (		00002710	PROC0837
NUCLEAR(ORDER(J), I) > 0) THEN		00002720	PROC0838
DO;		00002730	PROC0839
TEMP=TEMP + LOAD(J) ;		00002740	PROC0840
TEM = TEM + 1;		00002750	PROC0841
END;		00002760	PROC0842
END;		00002770	PROC0843
IF TEM>0 THEN		00002780	PROC0844
TEMP=TEMP/TEM;		00002790	PROC0845
DO K=1 TO CUM WHILE(CUM_STEP(K) < TEMP);		00002800	PROC0846
END;		00002810	PROC0847
PUT SKIP EDIT(I, FUEL(K)) (F(5), X(10), F(5,2));		00002820	PROC0848
END;		00002830	PROC0849
MATRIX=0;		00002840	PROC0850
DO I=1 TO N1;		00002850	PROC0851
DO J=1 TO CUM;		00002860	PROC0852
IF LOAD(I)< CUM_STEP(J) THEN		00002870	PROC0853
GO TO NEXT;		00002880	PROC0854
END;		00002890	PROC0855
NEXT:		00002900	PROC0856
IF J=1 THEN		00002910	PROC0857
GO TO NXT;		00002920	PROC0858
DO K=1 TO J-1;		00002930	PROC0859
MATRIX(I,K)=1;		00002940	PROC0860
END;		00002950	PROC0861
IF LOAD(I)= CUM_STEP(J-1) THEN		00002960	PROC0862
GO TO XT;		00002970	PROC0863
NXT:		00002980	PROC0864

XT:

```
MATRIX(I,J)=1 * (
  1 - (CUM_STEP(J)-LOAD(I))/STEP(J));
END;
DO I=1 TO CUM;
  TEMP=0;
  DO J=1 TO N1;
    TEMP=TEMP+MATRIX(J,I);
  END;
  P_FACTOR(I)=TEMP;
END;
P_FACTOR= P_FACTOR/N1;
IF CODE=0 THEN
  PUT FILE(PUNCH) EDIT(P_FACTOR)(10 F(8,3),SKIP)SKIP;
  PUT FILE(SYSPRINT) DATA(CODE)SKIP(2);
  PUT FILE(SYSPRINT) SKIP
  LIST( ' ECONOMIC LOADING ORDER CAPACITY FACTORS FOLLOWS' )
  ;
  PUT FILE(SYSPRINT) EDIT( P_FACTOR)(10 F(8,3),SKIP)SKIP;
/* ABOVE, THE INCREMENTAL FOSSIL CAPACITY FACTORS OF THE ECONOMIC
LOADING ORDER IS CALCULATED AND PRINTED. BELOW, THE INCREMENTS ARE
ASSIGNED BACK TO THEIR ORIGINAL POWER STATIONS, AND THE AVERAGE
CAPACITY FACTOR OF A STATIONS UPPER INCREMENTS ARE CALCULATED AND
PRINTED. *****/
DO I=1 TO CUM;
  CAP_FACTOR(TRANSFORM(I,1))=P_FACTOR(I);
  INCREMENT(TRANSFORM(I,1))=STEP(I);
END;
PUT FILE(SYSPRINT) EDIT('LARGE FOSSIL PLANTS')(
COL(2),A) SKIP(2);
DO J=1 TO M3(1);
  TEMP=0;
  DO I=0 TO M3(2)-2;
    TEMP=TEMP+CAP_FACTOR(I*M3(1)+J)*
    INCREMENT(I*M3(1)+J);
  END;
```

```
00002990 PROC0865
00003000 PROC0866
00003010 PROC0867
00003020 PROC0868
00003030 PROC0869
00003040 PROC0870
00003050 PROC0871
00003060 PROC0872
00003070 PROC0873
00003080 PROC0874
00003090 PROC0875
00003100 PROC0876
00003110 PROC0877
00003120 PROC0878
00003130 PROC0879
00003140 PROC0880
00003150 PROC0881
00003160 PROC0882
00003170 PROC0883
00003180 PROC0884
00003190 PROC0885
00003200 PROC0886
00003210 PROC0887
00003220 PROC0888
00003230 PROC0889
00003240 PROC0890
00003250 PROC0891
00003260 PROC0892
00003270 PROC0893
00003280 PROC0894
00003290 PROC0895
00003300 PROC0896
00003310 PROC0897
00003320 PROC0898
00003330 PROC0899
00003340 PROC0900
```

TEM=0;	00003350	PROC0901
DO I=0 TO M3(2)-2;	00003360	PROC0902
TEM=TEM+INCREMENT(I*M3(1)+J);	00003370	PROC0903
END;	00003380	PROC0904
TEMP=TEMP/TEM;	00003390	PROC0905
PUT FILE(SYSPRINT)	00003400	PROC0906
EDIT('AVERAGE INCREMENTAL CAPACITY FACTOR OF UNIT ',J,	00003410	PROC0907
TEMP)(X(5),A,F(3),F(10,3))SKIP;	00003420	PROC0908
END;	00003430	PROC0909
K=M3(1)*(M3(2)-1);	00003440	PROC0910
PUT FILE(SYSPRINT) EDIT('MEDIUM FOSSIL PLANTS')(	00003450	PROC0911
COL(2),A) SKIP(2);	00003460	PROC0912
DO J=1 TO M3(3);	00003470	PROC0913
TEMP=0;	00003480	PROC0914
TEM=0;	00003490	PROC0915
DO I=0 TO M3(4)-2;	00003500	PROC0916
TEM=INCREMENT(I*M3(3)+J+K)+TEM;	00003510	PROC0917
END;	00003520	PROC0918
DO I=0 TO M3(4)-2;	00003530	PROC0919
TEMP=TEMP+CAP_FACTOR(I*M3(3)+J+K)*	00003540	PROC0920
INCREMENT(I*M3(3)+J+K);	00003550	PROC0921
END;	00003560	PROC0922
TEMP=TEMP/TEM ;	00003570	PROC0923
PUT FILE(SYSPRINT)	00003580	PROC0924
EDIT('AVERAGE INCREMENTAL CAPACITY FACTOR OF UNIT ',J,	00003590	PROC0925
TEMP)(X(5),A,F(3),F(10,3))SKIP;	00003600	PROC0926
END;	00003610	PROC0927
PUT FILE(SYSPRINT) EDIT('SMALL FOSSIL PLANTS')(	00003620	PROC0928
COL(2),A) SKIP(2);	00003630	PROC0929
K=M3(3)*(M3(4)-1)+K;	00003640	PROC0930
DO J=1 TO M3(5);	00003650	PROC0931
TEMP=0;	00003660	PROC0932
TEM=0;	00003670	PROC0933
DO I=0 TO M3(6)-2;	00003680	PROC0934
	00003690	PROC0935
	00003700	PROC0936

TEM=STEP(I*M3(5)+J+K)+TEM;	00003710	PROC0937
END;	00003720	PROC0938
DO I=0 TO M3(6)-2;	00003730	PROC0939
TEMP=TEMP+CAP_FACTOR(I*M3(5)+J+K)*	00003740	PROC0940
STEP(I*M3(5)+J+K);	00003750	PROC0941
END;	00003760	PROC0942
TEMP=TEMP/TEM ;	00003770	PROC0943
PUT FILE(SYSPRINT)	00003780	PROC0944
EDIT('AVERAGE INCREMENTAL CAPACITY FACTOR OF UNIT ',J,	00003790	PROC0945
TEMP)(X(5),A,F(3),F(10,3))SKIP;	00003800	PROC0946
END;	00003810	PROC0947
PUT FILE(SYSPRINT) SKIP(5);	00003820	PROC0948
/* THE ARRAY VARIABLE "MATRIX" CONTAINS THE DETAILED HOURLY	00003830	PROC0949
GENERATION SCHEDULE OF ALL THE FOSSIL INCREMENTS IF THIS SCHEDULE IS	00003840	PROC0950
DESIRED, THIS SECTION MAY BE ALTERED TO PRINT THE VALUES OF "MATRIX".	00003850	PROC0951
*****	00003860	PROC0952
PUT FILE(SYSPRINT) SKIP DATA(CODE);	00003870	PROC0953
IF CODE=0 THEN	00003880	PROC0954
DO;	00003890	PROC0955
PUT FILE(SYSPRINT)	00003900	PROC0956
EDIT(	00003910	PROC0957
'OPERATIONS MATRIX OF FOSSIL INCREMENTS FOLLOWS')	00003920	PROC0958
( COL(2),A);	00003930	PROC0959
PUT FILE(SYSPRINT)	00003940	PROC0960
EDIT(	00003950	PROC0961
' I-TH TIME PERIOD --> ROW I, J-TH INCREMENT --> COLUMN J'	00003960	PROC0962
) (	00003970	PROC0963
A);	00003980	PROC0964
PUT FILE(SYSPRINT) SKIP	00003990	PROC0965
LIST(	00004000	PROC0966
' ONLY NON TRIVIAL MATRIX ELEMENTS ARE LISTED');	00004010	PROC0967
PUT FILE(SYSPRINT) SKIP;	00004020	PROC0968
DO I=1 TO N1;	00004030	PROC0969
DO J=1 TO CUM WHILE(MATRIX(I,J)=1);	00004040	PROC0970
END;	00004050	PROC0971
	00004060	PROC0972



```

                PUT FILE(SYS PRINT) DATA(MATRIX(I,J));
                /*END*/
            /*END*/
SHORT_CUT:
                END LOOP_TWO;
                IF CHAR='DUR' THEN
                    M1=WEEKS;
                    COUNT=CCUNT+1;
                /*END*/
            END LOOP;
        END BLOCK;
/* READ NEXT SET OF PARAMETERS                               */
IF COUNT= WEEKS THEN
    GO TO PEAK;
    GO TO TOP;
BOTTOM:
    PUT FILE(SYS PRINT) EDIT(' NORMAL END')(A) SKIP;
/*END*/
END PUMP_ST;
ECO :
    PROC (
        N1, CUM, NEW, CODE, CUM_STEP, FUEL, MODE, CAPACITY, RATIO, CAP_PUMP,
        RESERIOR, FREE, START, BYE, TOLERANCE);
/* THIS SUBPROGRAM PERFORMS THE ECONOMIC PUMPED STORAGE SCHEDULING
ALGORITHM. THE DETAILED FLOW CHART IS PRESENTED IN RAY ENG'S THESIS.
THE ROLE OF THE VARIOUS VARIABLES USED ARE EXPLAINED BELOW
***** */
    DCL
        MODE CHAR(4);
    DCL
        (N1,
        CUM) FIXED BIN;
    DCL
        (P,
        N,
        M,

```

```

00004070 PROC0973
00004080 PROC0974
00004090 PROC0975
00004100 PROC0976
00004110 PROC0977
00004120 PROC0978
00004130 PROC0979
00004140 PROC0980
00004150 PROC0981
00004160 PROC0982
00004170 PROC0983
00004180 PROC0984
00004190 PROC0985
00004200 PROC0986
00004210 PROC0987
00004220 PROC0988
00004230 PROC0989
00004240 PROC0990
00004250 PROC0991
00000010 PROC0992
00000020 PROC0993
00000030 PROC0994
00000040 PROC0995
00000050 PROC0996
00000060 PROC0997
00000070 PROC0998
00000080 PROC0999
00000090 PROC1000
00000100 PROC1001
00000110 PROC1002
00000120 PROC1003
00000130 PROC1004
00000140 PROC1005
00000150 PROC1006
00000160 PROC1007
00000170 PROC1008

```

```

KK) FIXED BIN;
DCL
STORE(N1) FIXED DEC(15,2),
(MAX(2),
SUN(N1),
ACCUM,
MAKEUP,
MIN(2),
II_COST,
INDEX_COST,
SUN_VALUE) FIXED DEC(9,2);
DCL
(F(CUM),
A(CUM),
CODE,
PP) FIXED BIN;
DCL
(CUM_STEP(*),
A_CUM(CUM),
LOAD(N1),
NEW(*),
FOS(N1),
ORDER(N1)) FIXED DEC,
TEMP FIXED DEC(15),
(PATIO,
FUEL(*)) FIXED DEC(5,3);
DCL
(RESERIOR,
CAP_PUMP,
CAPACITY,
FREE,
BYE,
TOLERANCE,
START) FIXED DEC;
DCL
F_COST (CUM) FIXED DEC(15);

```

```

00000180 PROC1009
00000190 PROC1010
00000200 PROC1011
00000210 PROC1012
00000220 PROC1013
00000230 PROC1014
00000240 PROC1015
00000250 PROC1016
00000260 PROC1017
00000270 PROC1018
00000280 PROC1019
00000290 PROC1020
00000300 PROC1021
00000310 PROC1022
00000320 PROC1023
00000330 PROC1024
00000340 PROC1025
00000350 PROC1026
00000360 PROC1027
00000370 PROC1028
00000380 PROC1029
00000390 PROC1030
00000400 PROC1031
00000410 PROC1032
00000420 PROC1033
00000430 PROC1034
00000440 PROC1035
00000450 PROC1036
00000460 PROC1037
00000470 PROC1038
00000480 PROC1039
00000490 PROC1040
00000500 PROC1041
00000510 PROC1042
00000520 PROC1043
00000530 PROC1044

```

```

DCL
SECURIT EXTERNAL ENTRY( (*) FIXED DEC, (*) FIXED DEC, FIXED DEC(5,00000540 PROC1045
3), FIXED DEC, FIXED DEC, FIXED DEC, FIXED DEC, FIXED BIN, FIXED DEC,00000550 PROC1046
FIXED DEC);
00000560 PROC1047
00000570 PROC1048
/* THE FOLLOWING SECTION IS A SORTING PROCESS TO FORM A LOAD DUPATION 00000580 PROC1049
CURVE IN THE ARRAY VARIABLE "LOAD". "FOS" STORES THE ORIGINAL 00000590 PROC1050
CHRONOLOGIC DEMAND DATA AND "NEW" STORES THE NEW FOSSIL GENERATION 00000600 PROC1051
SCHEDULE, AFTER THE PUMPED STORAGE SCHEDULING. 00000610 PROC1052
*****/
00000620 PROC1053
FOS=NEW;
00000630 PROC1054
DO I=1 TO N1;
00000640 PROC1055
MAX(1)=FOS(1);
00000650 PROC1056
MAX(2)=1;
00000660 PROC1057
DO J=2 TO N1;
00000670 PROC1058
IF MAX(1) < FOS(J) THEN
00000680 PROC1059
DO;
00000690 PROC1060
MAX(1)=FOS(J);
00000700 PROC1061
MAX(2)=J;
00000710 PROC1062
END;
00000720 PROC1063
END;
00000730 PROC1064
LOAD(I)=MAX(1);
00000740 PROC1065
ORDER(I)=MAX(2);
00000750 PROC1066
FOS( MAX(2) ) = -I;
00000760 PROC1067
END;
00000770 PROC1068
FOS=NEW;
00000780 PROC1069
A,A_CUM=0;
00000790 PROC1070
DO II=1 TO CUM WHILE(CUM_STEP(II)<LOAD(N1));
00000800 PROC1071
END;
00000810 PROC1072
DO PP=II TO CUM;
00000820 PROC1073
DO J=1 TO N1 WHILE( LOAD(J) > CUM_STEP(PP));
00000830 PROC1074
END;
00000840 PROC1075
IF J=N1+1 THEN
00000850 PROC1076
GO TO TEN;
00000860 PROC1077
STORE=0;
00000870 PROC1078
A(PP)=J;
00000880 PROC1079
/* "A(PP)" STORES THE LOCATION OF THE LOAD DURATION INTERVAL JUST 00000890 PROC1080

```

```

UNDER THE PP-TH FOSSIL INCREMENT. *****/
  DJ K=J TO N1;
  STORE(K) = CUM_STEP(PP) - LOAD(K);
  IF STORE(K) > CAP_PUMP THEN
    STORE(K) = CAP_PUMP;
  END;
  A_CUM(PP) = SUM(STORE);
/* A_CUM(PP) RECORDS THE AMOUNT OF PUMPING ENERGY SCHEDULED WHEN THE
PP-TH INCREMENT IS THE HIGHEST COST OF THE PUMPING ENERGY SUPPLIED.
*****/
TEN:
  END;
/* "F(K)" RECORDS THE POSITION OF THE LOWEST LOAD DURATION INTERVAL
IN THE K-TH INCREMENT. *****/
  MAKEUP=1;
  SUN=0;
  F_COST=-FREE;
  DO K=CUM-1 TO 1 BY -1;
    DO I=1 TO N1 WHILE( CUM_STEP(K) < LOAD(I));
    END;
    IF I=1 THEN
      GO TO ED;
    STORE=0;
    F(K+1)=I-1;
    DO J=1 TO I-1;
      STORE(J)=-CUM_STEP(K)+LOAD(J);
      IF STORE(J) > CAPACITY THEN
        STORE(J)=CAPACITY;
      END;
    F_COST(K+1)=SUM(STORE)-FREE;
/* "F_COST(K)" RECORDS THE AMOUNT OF STORED ENERGY TO PEAK SHAVE UP
TO AND INCLUDING THE K-TH INCREMENT. */
ED:
  END;
/* BELOW, A SPECIAL SECTION TO CALCULATE "F_COST(1)" AND "F(1)". */
  DO I=1 TO N1;

```

```

00000900 PROC1081
00000910 PROC1082
00000920 PROC1083
00000930 PROC1084
00000940 PROC1085
00000950 PROC1086
00000960 PROC1087
00000970 PROC1088
00000980 PROC1089
00000990 PROC1090
00001000 PROC1091
00001010 PROC1092
00001020 PROC1093
00001030 PROC1094
00001040 PROC1095
00001050 PROC1096
00001060 PROC1097
00001070 PROC1098
00001080 PROC1099
00001090 PROC1100
00001100 PROC1101
00001110 PROC1102
00001120 PROC1103
00001130 PROC1104
00001140 PROC1105
00001150 PROC1106
00001160 PROC1107
00001170 PROC1108
00001180 PROC1109
00001190 PROC1110
00001200 PROC1111
00001210 PROC1112
00001220 PROC1113
00001230 PROC1114
00001240 PROC1115
00001250 PROC1116

```

```

        IF LOAD(I) > CAPACITY THEN
            STORE(I) = CAPACITY;
        ELSE
            STORE(I)=LOAD(I);
        END;
        F_COST(1)=SUM(STORE);
        F(1)=N1;
        DO KK=CUM TO 2 BY -1 WHILE ( F_COST(KK) <= 0);
        END;
        /* "KK" RECORDS THE INCREMENT LEVEL WHERE PUMPING COMES INTO PLAY,
        WHEREAS, THE FREE WATER INFLOW DID ALL THE PEAK SHAVING BEFORE THE
        KK-TH LEVEL WAS REACHED. */
        /* THE FOLLOWING SECTION CALCULATES THE INITIAL ITERATION POINT,
        LEVEL K AS SHOWN IN FIGURE 4.20 IN RAY ENG'S THESIS. "SUN(I)"
        REPRESENTS THE AMOUNT OF GENERATION REQUIRED TO PEAK SHAVE TO THE
        I-TH LOAD DURATION INTERVAL. "ACCUM" REPRESENTS THE COMPLEMENTARY
        PUMPING ENERGY. */
        DO I=1 TO N1;
            TEMP=0;
            IF I=1 THEN
                GO TO PASS;
            DO J=1 TO I-1;
                IF LOAD(J)-CAPACITY > LOAD(I) THEN
                    TEMP=TEMP+CAPACITY;
                ELSE
                    TEMP=TEMP+LOAD(J)-LOAD(I);
            END;
        PASS:
            SUN(I)=TEMP-FREE;
            STORE=C;
            DO J=I TO N1;
                STORE(J)=LOAD(I)-LOAD(J);
                IF STORE(J) > CAP_PUMP THEN
                    STORE(J)=CAP_PUMP;
            END;
            ACCUM=SUM(STORE);

```

```

00001260 PROC1117
00001270 PROC1118
00001280 PROC1119
00001290 PROC1120
00001300 PROC1121
00001310 PROC1122
00001320 PROC1123
00001330 PROC1124
00001340 PROC1125
00001350 PROC1126
00001360 PROC1127
00001370 PROC1128
00001380 PROC1129
00001390 PROC1130
00001400 PROC1131
00001410 PROC1132
00001420 PROC1133
00001430 PROC1134
00001440 PROC1135
00001450 PROC1136
00001460 PROC1137
00001470 PROC1138
00001480 PROC1139
00001490 PROC1140
00001500 PROC1141
00001510 PROC1142
00001520 PROC1143
00001530 PROC1144
00001540 PROC1145
00001550 PROC1146
00001560 PROC1147
00001570 PROC1148
00001580 PROC1149
00001590 PROC1150
00001600 PROC1151
00001610 PROC1152

```

```

        IF SUN(I) > RATIO*ACCUM THEN
            GO TO COST;
        END;
/* INTRODUCE COST CONSTRAINT *****/
COST:
    DO P=1 TO CUM WHILE( LOAD(I) > CUM_STEP(P));
    END;
    IF P=CUM+1 THEN
        P=CUM;
/* "INDEX_COST" IS THE COST OF ENERGY BEING REPLACED AND "II_COST" IS
THE COST OF THE ENERGY BEING SUPPLIED*/
NXT:
    INDEX_COST=FUEL(P);
    II_COST=INDEX_COST * RATIO;
    DO PP=CUM TO 1 BY -1;
        IF FUEL(PP) <= II_COST THEN
            GO TO NET;
        END;
TEST: /* COST CONSTRAINT SET AT THIS LEVEL INDICATES PUMPING MAY NOT
BE ECONOMIC *****/
    P=P+1;
    SUN_VALUE=0;
    IF P > KK THEN
        DO;
            PUT SKIP LIST(' PUMPING NOT ECONOMICAL');
            GO TO NO_PUMP;
        /* AFFIRMATIVE RESULT, PUMPING NOT ECONOMIC */
        END;
        GO TO NXT;
/* INCREASE LEVEL P, AND TEST AGAIN */
NET:
    ACCUM=A_CUM(PP);
    IF ACCUM=0 THEN
        GO TO TEST;
    SUN_VALUE=ACCUM*RATIO;
    DO K=CUM TO 2 BY -1 WHILE( F_COST(K) < SUN_VALUE);
00001620 PROC1153
00001630 PROC1154
00001640 PROC1155
00001650 PROC1156
00001660 PROC1157
00001670 PROC1158
00001680 PROC1159
00001690 PROC1160
00001700 PROC1161
00001710 PROC1162
00001720 PROC1163
00001730 PROC1164
00001740 PROC1165
00001750 PROC1166
00001760 PROC1167
00001770 PROC1168
00001780 PROC1169
00001790 PROC1170
00001800 PROC1171
00001810 PROC1172
00001820 PROC1173
00001830 PROC1174
00001840 PROC1175
00001850 PROC1176
00001860 PROC1177
00001870 PROC1178
00001880 PROC1179
00001890 PROC1180
00001900 PROC1181
00001910 PROC1182
00001920 PROC1183
00001930 PROC1184
00001940 PROC1185
00001950 PROC1186
00001960 PROC1187
00001970 PROC1188

```

```

END;
IF FUEL( K)= INDEX_COST THEN
  DO;
    KK=K;
    GO TO SOLUTION;
  END;
IF FUEL(K) > INDEX_COST THEN
  DO;
/* SLACK IN PUMPED STORAGE ENERGY UTILIZATION CALCULATED, TRY AGAIN
FOR HIGHER UTILIZATION. "MAKEUP" IS TEMPORARY STORAGE OF THE LAST
CALCULATED PUMPED STORAGE PUMPING LEVEL. *****/
    MAKEUP=PP;
    P=P+1;
    GO TO NXT;
  END;
/* IF FUEL(K) < INDEX_COST THEN DO */
/* MAXIMUM ECONOMIC PUMPED STORAGE ENERGY UTILIZATION */
/* COST CONSTRAINT VIOLATED, TOO MUCH ENERGY SCHEDULED.
***** FOR THE CASE OF
TOO MUCH WATER PUMPED, THE PEAK SHAVING SCHEDULE IS FIXED, AND THE
WATER PUMPED IS ADJUSTED FROM THE GENERATION SCHEDULE */
    IF F_COST(P) >= A_CUM(MAKEUP) * RATIO THEN
      DO;
        DO M=1 TO F(P);
          IF LOAD(M)-CUM_STEP(P-1) > CAPACITY THEN
            LOAD(M) = LOAD(M) -CAPACITY;
          ELSE
            LOAD(M) = CUM_STEP(P-1);
        END;
        IF MODE='SEC' THEN
          GO TO READY;
        ACCUM= F_COST(P)/RATIO;
        DO M=CUM TO 1 BY -1 WHILE(A_CUM(M) > ACCUM);
        END;
        DO N=A(M) TO N1;
          IF CUM_STEP(M) - LOAD(N) > CAP_PUMP THEN
00001980 PROC1189
00001990 PROC1190
00002000 PROC1191
00002010 PROC1192
00002020 PROC1193
00002030 PROC1194
00002040 PROC1195
00002050 PROC1196
00002060 PROC1197
00002070 PROC1198
00002080 PROC1199
00002090 PROC1200
00002100 PROC1201
00002110 PROC1202
00002120 PROC1203
00002130 PROC1204
00002140 PROC1205
00002150 PROC1206
00002160 PROC1207
00002170 PROC1208
00002180 PROC1209
00002190 PROC1210
00002200 PROC1211
00002210 PROC1212
00002220 PROC1213
00002230 PROC1214
00002240 PROC1215
00002250 PROC1216
00002260 PROC1217
00002270 PROC1218
00002280 PROC1219
00002290 PROC1220
00002300 PROC1221
00002310 PROC1222
00002320 PROC1223
00002330 PROC1224

```

```

        LOAD(N) = LOAD(N) + CAP_PUMP;
    ELSE
        LOAD(N) = CLM_STEP(M);
    END;
    MAKEUP= ACCUM - A_CUM(M);
    M=M+1;
    DO N= A(M) TO N1 WHILE ( MAKEUP > 0 );
        XX= (CUM_STEP(M)-LOAD(N));
        IF XX > (CAP_PUMP-(LOAD(N)-FOS(ORDER(N)))) THEN
            XX = (CAP_PUMP-(LOAD(N)-FOS(ORDER(N))));
        IF XX < MAKEUP THEN
            DO;
                MAKEUP=MAKEUP-XX;
                LOAD(N)=LOAD(N)+XX;
            END;
        ELSE
            DO;
                LOAD(N)=LOAD(N)+MAKEUP;
                MAKEUP=0;
            END;
        END;
    GO TO READY;
    END;
/* FOR THE CASE OF TOO MUCH PEAK SHAVING RELATIVE TO PUMPING, THE
SCHEDULE IS DETERMINED BELOW. */
    PP= MAKEUP;
    SUN_VALUE=A_CUM(PP)*RATIO;
    DO KK=CUM TO 2 BY -1;
        IF F_COST(KK) > SUN_VALUE THEN
            GO TO SOLUTION;
    END;
/* PUMPING INTERVALS ARE SCHEDULED BELOW */
SOLUTION:
    IF MODE='SEC' THEN
        GO TO NO_PUMP;
    DO K=A(PP) TO N1;

```

```

00002340 PROC1225
00002350 PROC1226
00002360 PROC1227
00002370 PROC1228
00002380 PROC1229
00002390 PROC1230
00002400 PROC1231
00002410 PROC1232
00002420 PROC1233
00002430 PROC1234
00002440 PROC1235
00002450 PROC1236
00002460 PROC1237
00002470 PROC1238
00002480 PROC1239
00002490 PROC1240
00002500 PROC1241
00002510 PROC1242
00002520 PROC1243
00002530 PROC1244
00002540 PROC1245
00002550 PROC1246
00002560 PROC1247
00002570 PROC1248
00002580 PROC1249
00002590 PROC1250
00002600 PROC1251
00002610 PROC1252
00002620 PROC1253
00002630 PROC1254
00002640 PROC1255
00002650 PROC1256
00002660 PROC1257
00002670 PROC1258
00002680 PROC1259
00002690 PROC1260

```



IF CUM_STEP(PP) - LOAD(K) > CAP_PUMP THEN	00002700	PROC1261
LOAD(K)=LOAD(K)+CAP_PUMP;	00002710	PROC1262
ELSE	00002720	PROC1263
LOAD(K)=CUM_STEP(PP);	00002730	PROC1264
END;	00002740	PROC1265
/* GENERATION INTERVALS ARE SCHEDULED BELOW, IF NO PUMPING NECESSARY,	00002750	PROC1266
THE PREVIOUS SECTION IS BY PASSED. */	00002760	PROC1267
NO_PUMP:	00002770	PROC1268
DO K=1 TO I WHILE ( SUN_VALUE > SUN(K));	00002780	PROC1269
END;	00002790	PROC1270
DO J=1 TO K-1;	00002800	PROC1271
IF LOAD(J) > CUM_STEP(KK) THEN	00002810	PROC1272
DO;	00002820	PROC1273
IF LOAD(J) -CAPACITY > CUM_STEP(KK) THEN	00002830	PROC1274
LOAD(J)=LOAD(J)-CAPACITY;	00002840	PROC1275
ELSE	00002850	PROC1276
LOAD(J)=CUM_STEP(KK);	00002860	PROC1277
END;	00002870	PROC1278
END;	00002880	PROC1279
MAKEUP=SUN_VALUE-F_COST(KK+1);	00002890	PROC1280
DO J=K-1 TO 1 BY -1 WHILE (MAKEUP > 0);	00002900	PROC1281
XX= (LOAD(J)-CUM_STEP(KK-1));	00002910	PROC1282
/* "XX" REPRESENTS THE UNUSEC PUMPED STORAGE GENERATION CAPACITY FOR	00002920	PROC1283
THE PRESENT TIME INTERVAL */	00002930	PROC1284
IF XX > (CAPACITY-FOS(ORDER(J))+LOAD(J)) THEN	00002940	PROC1285
XX = (CAPACITY-FOS(ORDER(J))+LOAD(J));	00002950	PROC1286
IF MAKEUP > XX THEN	00002960	PROC1287
DO;	00002970	PROC1288
MAKEUP=MAKEUP-XX;	00002980	PROC1289
LOAD(J)=LOAD(J)-XX;	00002990	PROC1290
END;	00003000	PROC1291
ELSE	00003010	PROC1292
DO;	00003020	PROC1293
LOAD(J)=LOAD(J)-MAKEUP;	00003030	PROC1294
MAKEUP=0;	00003040	PROC1295
END;	00003050	PROC1296

```

END;
/* THE BASIC ECONOMIC SCHEDULING ALGORITHM IS FINISHED. THE NEXT
SECTION CHECKS THE WATER LIMITS OF THE RESEROIR. FIRST, RESORT THE
LOAD DURATION CURVE BACK TO THE CHRONOLOGIC PATTERN, "NEW". */
READY:
  DO I=1 TO N1;
    NEW( ORDER(I) ) = LOAD(I);
  END;
  IF MODE='SEC' THEN
    CALL
    SECURIT(NEW, FOS, RATIO, START, FREE, CAP_PUMP, RESERIOR, N1,
    BYE, TOLERANCE);
REPEAT:
  STORE= FOS-NEW;
  DO I=1 TO N1;
    IF STORE(I) < 0 THEN
      STORE(I)= RATIO * STORE(I);
  END;
  STORE=STORE-(FREE/N1);
  DO I=2 TO N1;
    STORE(I)=STORE(I)+STORE(I-1);
  END;
/* "STORE" IS THE CUMULATIVE WATER LEVEL. THE SECTION BELOW
CALCULATES THE MAX AND MIN OF THE WATER LEVEL OVER A WEEK */
  STORE=START-STORE;
  MAX(1)=STORE(1);
  MAX(2)=1;
  MIN(1)=STORE(1);
  MIN(2)=1;
  DO I=2 TO N1;
    IF MAX(1) <= STORE(I) THEN
      DO;
        MAX(1)=STORE(I);
        MAX(2)=I;
      END;
    IF MIN(1) >= STORE(I) THEN

```

```

00003060 PROC1297
00003070 PROC1298
00003080 PROC1299
00003090 PROC1300
00003100 PROC1301
00003110 PROC1302
00003120 PROC1303
00003130 PROC1304
00003140 PROC1305
00003150 PROC1306
00003160 PROC1307
00003170 PROC1308
00003180 PROC1309
00003190 PROC1310
00003200 PROC1311
00003210 PROC1312
00003220 PROC1313
00003230 PROC1314
00003240 PROC1315
00003250 PROC1316
00003260 PROC1317
00003270 PROC1318
00003280 PROC1319
00003290 PROC1320
00003300 PROC1321
00003310 PROC1322
00003320 PROC1323
00003330 PROC1324
00003340 PROC1325
00003350 PROC1326
00003360 PROC1327
00003370 PROC1328
00003380 PROC1329
00003390 PROC1330
00003400 PROC1331
00003410 PROC1332

```

DO;	00003420	PROC1333
MIN(1)=STORE(I);	00003430	PROC1334
MIN(2)=I;	00003440	PROC1335
END;	00003450	PROC1336
END;	00003460	PROC1337
/* WHEN COMPARING BEGINNING-OF-THE-WEEK WATER LEVEL TO THE	00003470	PROC1338
END-OF-THE-WEEK WATER LEVEL, IF THERE IS NO MATCH, THEN A SERIOUS	00003480	PROC1339
ERROR HAS OCCURRED SOMEWHERE */	00003490	PROC1340
MAKEUP= START -STORE(N1);	00003500	PROC1341
IF ABS(MAKEUP) > RESERIOR/1000 THEN	00003510	PROC1342
DO;	00003520	PROC1343
PUT FILE(SYSPRINT) SKIP	00003530	PROC1344
LIST(	00003540	PROC1345
' ERROR IN PUMPED STORAGE ROUNTINE, PROCESSING CONTINUING');	00003550	PROC1346
GO TO LISTING;	00003560	PROC1347
END;	00003570	PROC1348
/* IF RESERVOIR IS OVERDRAWN, GENERATION IS FIRST CUT-BACK DURING THE	00003580	PROC1349
IMMEDIATE TIME PERIOD(WHEN OVERDRAWN). */	00003590	PROC1350
IF MIN(1) <0 THEN	00003600	PROC1351
DO;	00003610	PROC1352
MAKEUP=-MIN(1);	00003620	PROC1353
MAX(2)=MIN(2);	00003630	PROC1354
TOPP:	00003640	PROC1355
IF NEW(MAX(2))>=FCS(MAX(2)) THEN	00003650	PROC1356
DO;	00003660	PROC1357
MAX(2)=MAX(2)-1;	00003670	PROC1358
GO TO TOPP;	00003680	PROC1359
END;	00003690	PROC1360
IF MAKEUP > FOS(MAX(2)) - NEW(MAX(2)) THEN	00003700	PROC1361
DO;	00003710	PROC1362
MAKEUP=MAKEUP-FOS(MAX(2))+NEW(MAX(2));	00003720	PROC1363
NEW(MAX(2))=FOS(MAX(2));	00003730	PROC1364
MAX(2)=MAX(2)-1;	00003740	PROC1365
IF MAX(2)=0 THEN	00003750	PROC1366
DO;	00003760	PROC1367
PUT FILE(SYSPRINT) SKIP	00003770	PROC1368

```

LIST(
' * * * * * * * * * * MIN WATER LEVEL TOO LOW TO CORRECT, PROCEEDING TO NEXT STEP * * * * * * * * * * '
);
GO TO LISTING;
END;
GO TO TOPP;
END;
ELSE
NEW(MAX(2))=NEW(MAX(2))+MAKEUP;
/* COMPENSATING CUT-BACK IN PUMPING(TO BALANCE THE THE ABOVE CUT-BACK
IN GENERATION) IS ALSO SCHEDULED IN THE MOST IMMEDIATE TIME PERIOD. */
MAX(2)=MIN(2)+1;
MAKEUP=-MIN(1)/RATIO;
TIP:
IF FOS(MAX(2)) >= NEW(MAX(2)) THEN
DO;
MAX(2)=MAX(2)+1;
GO TO TIP;
END;
IF MAKEUP > NEW(MAX(2)) - FOS(MAX(2)) THEN
DO;
MAKEUP=MAKEUP-NEW(MAX(2))+FOS(MAX(2));
NEW(MAX(2))=FOS(MAX(2));
MAX(2)=MAX(2)+1;
IF MAX(2)=N1 THEN
DO;
PUT FILE(SYSPRINT) SKIP
LIST(
' * * * * * * * * * * CORRECTION TO MIN PROBLEM NOT POSSIBLE, PROCEEDING TO NEXT STEP * * * * * * * * * * '
);
GO TO LISTING;
END;
GO TO TIP;
END;

```

```

00003780 PROC1369
00003790 PROC1370
00003800 PROC1371
00003810 PROC1372
00003820 PROC1373
00003830 PROC1374
00003840 PROC1375
00003850 PROC1376
00003860 PROC1377
00003870 PROC1378
00003880 PROC1379
00003890 PROC1380
00003900 PROC1381
00003910 PROC1382
00003920 PROC1383
00003930 PROC1384
00003940 PROC1385
00003950 PROC1386
00003960 PROC1387
00003970 PROC1388
00003980 PROC1389
00003990 PROC1390
00004000 PROC1391
00004010 PROC1392
00004020 PROC1393
00004030 PROC1394
00004040 PROC1395
00004050 PROC1396
00004060 PROC1397
00004070 PROC1398
00004080 PROC1399
00004090 PROC1400
00004100 PROC1401
00004110 PROC1402
00004120 PROC1403
00004130 PROC1404

```



```

MAKEUP = (MAX(1)-RESERIOR);
UOPP:
IF FOS(MIN(2)) <= NEW(MIN(2)) THEN
DO;
MIN(2)=MIN(2)+1;
GO TO UOPP;
END;
IF MAKEUP > FOS(MIN(2)) - NEW(MIN(2)) THEN
DO;
MAKEUP=MAKEUP-FOS(MIN(2))+NEW(MIN(2));
NEW(MIN(2))=FOS(MIN(2));
MIN(2)=MIN(2)+1;
IF MIN(2)=N1 THEN
DO;
PUT FILE(SYSPRINT) SKIP
LIST(
' * * * * * CORRECTION TO MAX PROBLEM NOT POSSIBLE, PROCEEDING TO NEXT STEP * * * * * ');
GO TO LISTING;
END;
GO TO UOPP;
END;
ELSE
NEW(MIN(2))=NEW(MIN(2))+MAKEUP;
GO TO REPEAT;
/* RE-TEST WATER LEVEL */
END;
/* BELOW, IS THE PRINTING OF THE PUMPED STORAGE SCHEDULE */
LISTING: /* RETURN TO MAIN PROGRAM TO LIST RESULTS */
***** REPORT GENERATOR *****
PUMPED STORAGE GENERATION FIGURES */
PUT FILE(SYSPRINT)
EDIT('BOW WATER LEVEL=',STORE(1),'EOW WATER LEVEL=', STORE(N1),
'MAX=', MAX(1),'MIN=', MIN(1))(
COL(10),A,F(5),COL(50),A,F(5), X(5),A,F(5),X(5),A,F(5))SKIP(3);

```

```

00004500 PROC1441
00004510 PROC1442
00004520 PROC1443
00004530 PROC1444
00004540 PROC1445
00004550 PROC1446
00004560 PROC1447
00004570 PROC1448
00004580 PROC1449
00004590 PROC1450
00004600 PROC1451
00004610 PROC1452
00004620 PROC1453
00004630 PROC1454
00004640 PROC1455
00004650 PROC1456
00004660 PROC1457
00004670 PROC1458
00004680 PROC1459
00004690 PROC1460
00004700 PROC1461
00004710 PROC1462
00004720 PROC1463
00004730 PROC1464
00004740 PROC1465
00004750 PROC1466
00004760 PROC1467
00004770 PROC1468
00004780 PROC1469
00004790 PROC1470
00004800 PROC1471
00004810 PROC1472
00004820 PROC1473
00004830 PROC1474
00004840 PROC1475
00004850 PROC1476

```

PUT FILE(SYSPRINT) EDIT(' (IN UNITS OF MWHR)')(A);	00004860	PROC1477
PUT FILE(SYSPRINT) DATA(CODE) SKIP;	00004870	PROC1478
IF CODE=0 THEN	00004880	PROC1479
DD;	00004890	PROC1480
PUT FILE(SYSPRINT) EDIT (	00004900	PROC1481
'TIME','BASIC TIME','INCREMENTAL FOSSIL',	00004910	PROC1482
'GENERATION/-PUMPING','WATER LEVEL')(	00004920	PROC1483
CGL(5),A,COL(15),A, COL(30),A,COL(55),A,COL(80),A) SKIP(2);	00004930	PROC1484
PUT FILE(SYSPRINT) EDIT(' (IN UNITS OF MWHR)')(A);	00004940	PROC1485
DO I=1 TO N1;	00004950	PROC1486
PUT FILE(SYSPRINT)	00004960	PROC1487
EDIT( I,NEW(I),FOS(I)-NEW(I),STORE(I))(	00004970	PROC1488
X(8),F(12),6 F(23))SKIP(1);	00004980	PROC1489
END;	00004990	PROC1490
END;	00005000	PROC1491
;	00005010	PROC1492
RETURN;	00005020	PROC1493
END ECO ;	00005030	PROC1494
SECURIT :	00000010	PROC1495
PROC(NEW, OLD, EFFICIENCY, START, FREE, PUMP, RESERVIOR, N1, BYE,	00000020	PROC1496
TOLERANCE);	00000030	PROC1497
DCL	00000040	PROC1498
N1 FIXED BIN;	00000050	PROC1499
DCL	00000060	PROC1500
STRING VARYING BIT(N1),	00000070	PROC1501
(TOLERANCE,	00000080	PROC1502
TURNAROUND,	00000090	PROC1503
AMT,	00000100	PROC1504
LOWEST(2),	00000110	PROC1505
POINT,	00000120	PROC1506
FREE,	00000130	PROC1507
RESERVIOR ,	00000140	PROC1508
START,	00000150	PROC1509
PUMP,	00000160	PROC1510
BYE,	00000170	PROC1511
STORE(N1),	00000180	PROC1512

```

NEW( *),
OLD( *),
TEMP(N1)) FIXED DEC;
DCL
(MARGIN,
WATER(N1)) FLOAT DEC,
EFFICIENCY FIXED DEC(5,3);
/* LIGHT=1 WHEN '0' SUBSTRING IS LAST ONE IN PERIOD */
LIGHT=0;
POINT = 0;
STRING=(200)'0'B;
/* STRING FORMATION
STORE=NEW-OLD;
IF STORE(1) < 0 THEN
  SUBSTR(STRING,1,1)='1'B;
DO I=2 TO N1;
  IF STORE(I) < 0 THEN
    DO;
      SUBSTR(STRING,I,1)='1'B;
      IF STORE (I-1)=0 THEN
        DO;
          DO J=1 TO BYE;
            SUBSTR(STRING,I-J,1)='1'B;
          END;
        END;
      END;
    END;
  ELSE
    IF STORE (I-1) < 0 THEN
      DO;
        DO J=1 TO BYE;
          SUBSTR( STRING,I+J-1,1)='1'B;
        END;
      END;
    END;
/* CALCULATE TURNAROUND LEVEL */
TURNAROUND = 90000;

```

```

00000190 PROC1513
00000200 PROC1514
00000210 PROC1515
00000220 PROC1516
00000230 PROC1517
00000240 PROC1518
00000250 PROC1519
00000260 PROC1520
00000270 PROC1521
00000280 PROC1522
00000290 PROC1523
00000300 PROC1524
00000310 PROC1525
00000320 PROC1526
00000330 PROC1527
00000340 PROC1528
00000350 PROC1529
00000360 PROC1530
00000370 PROC1531
00000380 PROC1532
00000390 PROC1533
00000400 PROC1534
00000410 PROC1535
00000420 PROC1536
00000430 PROC1537
00000440 PROC1538
00000450 PROC1539
00000460 PROC1540
00000470 PROC1541
00000480 PROC1542
00000490 PROC1543
00000500 PROC1544
00000510 PROC1545
00000520 PROC1546
00000530 PROC1547
00000540 PROC1548

```



```

DO I=1 TO N1;
  IF STORE(I) < 0 THEN
    DO;
      IF TURNAROUND > OLD(I) THEN
        TURNAROUND=OLD(I);
      END;
    END;
  TURNAROUND = TURNAROUND - TOLERANCE;
/* CALC CHRONOLOGIC WATER LEVEL BEHAVIOR */
WATER_LEVEL:
  LENGT =INDEX(STRING,'1'B);
  IF LENGT =0 THEN
    DO;
      LENGT=LENGTH(STRING);
      IF LENGT =0 THEN
        RETURN;
      ELSE
        LENGT=LENGT+1;
        LIGHT=1;
      END;
    END;
  LENGT =LENGT -1;
  WATER= STORE;
  DO I=1 TO N1;
    IF WATER(I) >0 THEN
      WATER(I)=WATER(I)*EFFICIENCY;
    END;
  WATER= WATER+ FREE/N1;
  WATER(1)=START+WATER(1);
  DO I=2 TO N1;
    WATER(I)=WATER(I-1) + WATER(I);
  END;
/* CALC MARGIN BET RESERVIOR CAPACITY AND WATER LEVEL AT END OF
ACTIVE INTERVAL */
  MARGIN=(RESERVIOR - WATER(POINT+LENGT ))/EFFICIENCY;
  IF LIGHT=1 THEN
    DO;

```

```

00000550 PROC1549
00000560 PROC1550
00000570 PROC1551
00000580 PROC1552
00000590 PROC1553
00000600 PROC1554
00000610 PROC1555
00000620 PROC1556
00000630 PROC1557
00000640 PROC1558
00000650 PROC1559
00000660 PROC1560
00000670 PROC1561
00000680 PROC1562
00000690 PROC1563
00000700 PROC1564
00000710 PROC1565
00000720 PROC1566
00000730 PROC1567
00000740 PROC1568
00000750 PROC1569
00000760 PROC1570
00000770 PROC1571
00000780 PROC1572
00000790 PROC1573
00000800 PROC1574
00000810 PROC1575
00000820 PROC1576
00000830 PROC1577
00000840 PROC1578
00000850 PROC1579
00000860 PROC1580
00000870 PROC1581
00000880 PROC1582
00000890 PROC1583
00000900 PROC1584

```

```

MARGIN = (START - WATER(POINT+LENGT))/EFFICIENCY;
DO I=N1 TO 1 BY -1 WHILE (MARGIN<0);
  IF STORE(I) > 0 THEN
    DO;
      IF (-MARGIN) >= STORE(I) THEN
        DO;
          NEW(I) = OLD(I);
          MARGIN=MARGIN+STORE(I);
          STORE(I)=0;
        END;
      ELSE
        DO;
          NEW(I)=NEW(I)+MARGIN;
          STORE(I)=STORE(I)+MARGIN;
          MARGIN=0;
          RETURN;
        END;
      END;
    END;
  END;
  END;
  LOWEST(1)=90000;
  TEMP=NEW;
/* FIND LOWEST DEMAND PERIOD */
SORT:
DO I= POINT+1 TO POINT + LENGT ;
  IF LOWEST(1) >=TEMP(I) THEN
    DO;
      LOWEST(1)=TEMP(I);
      LOWEST(2)=I;
    END;
  END;
  END;
  IF LOWEST(1)=90000 THEN
    GO TO NEXT_LEVEL;
  AMT=TURNAROUND - NEW(LOWEST(2));
  IF (AMT<= 0) | (MARGIN <= 0) THEN
    GO TO NEXT_LEVEL;

```

```

00000910 PROC1585
00000920 PROC1586
00000930 PROC1587
00000940 PROC1588
00000950 PROC1589
00000960 PROC1590
00000970 PROC1591
00000980 PROC1592
00000990 PROC1593
00001000 PROC1594
00001010 PROC1595
00001020 PROC1596
00001030 PROC1597
00001040 PROC1598
00001050 PROC1599
00001060 PROC1600
00001070 PROC1601
00001080 PROC1602
00001090 PROC1603
00001100 PROC1604
00001110 PROC1605
00001120 PROC1606
00001130 PROC1607
00001140 PROC1608
00001150 PROC1609
00001160 PROC1610
00001170 PROC1611
00001180 PROC1612
00001190 PROC1613
00001200 PROC1614
00001210 PROC1615
00001220 PROC1616
00001230 PROC1617
00001240 PROC1618
00001250 PROC1619
00001260 PROC1620

```

```

    IF (AMT >= MARGIN) & (PUMP >= MARGIN) THEN
        DO;
/* RESERVIOR IS FILLED */
        NEW(LOWEST(2))=NEW(LOWEST(2))+MARGIN;
        STORE(LOWEST(2))=MARGIN;
        GO TO NEXT_LEVEL;
        END;
    ELSE
        DO;
/* SCHEDULE PUMPING CAPACITY OR TIL TURNAROUND LEVEL IS REACHED */
        IF AMT > PUMP THEN
            AMT=PUMP;
            MARGIN=MARGIN-AMT;
            STORE(LOWEST(2))=AMT;
            NEW(LOWEST(2))= NEW(LOWEST(2))+AMT;
/* FIND NEXT LOWEST DEMAND PERIOD */
            TEMP(LOWEST(2))=90000;
            LOWEST(1)=90000;
            GO TO SORT;
        END;
/* MOVE POINTER */
NEXT_LEVEL:
    IF LENGTH(STRING)=LENGT THEN
        RETURN;
    LENGT =LENGT +1;
    STRING=SUBSTR(STRING,LENGT );
    POINT=POINT+LENGT -1;
    LENGT =INDEX(STRING,'0'B);
    IF LENGT = 0 THEN
        RETURN;
    STRING=SUBSTR( STRING,LENGT );
    POINT=POINT+LENGT -1;
    GO TO WATER_LEVEL;
END SECURIT ;

```

```

00001270 PROC1621
00001280 PROC1622
00001290 PROC1623
00001300 PROC1624
00001310 PROC1625
00001320 PROC1626
00001330 PROC1627
00001340 PROC1628
00001350 PROC1629
00001360 PROC1630
00001370 PROC1631
00001380 PROC1632
00001390 PROC1633
00001400 PROC1634
00001410 PROC1635
00001420 PROC1636
00001430 PROC1637
00001440 PROC1638
00001450 PROC1639
00001460 PROC1640
00001470 PROC1641
00001480 PROC1642
00001490 PROC1643
00001500 PROC1644
00001510 PROC1645
00001520 PROC1646
00001530 PROC1647
00001540 PROC1648
00001550 PROC1649
00001560 PROC1650
00001570 PROC1651
00001580 PROC1652
00001590 PROC1653
00001600 PROC1654

```

```

// 'RAYMOND L. ENG',CLASS=A,REGION=230K
/*MAIN  LINES=3,CARDS=7
/*SRI  LOW
//A EXEC  PLIXG,PRDG='U.M9960.8981.TEST1.LIBRARY.LMOD(NUCLEAR)',
//  PARM.G='ISASIZE(27200),REPORT'
//G.PLIDUMP  DD  SYSOUT=A
//G.FT06F001  DD  SYSOUT=A
//G.LDMDL  DD  DSN=U.M9960.8981.AEP.APR.MAY,DISP=OLD
//G.HYDRO DD *,DCB=BLKSIZE=2000
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50

```

```

CAS30001
CAS30002
CAS30003
CAS30004
CAS30005
CAS30006
CAS30007
CAS30008
CAS30009
CAS30010
CAS30011
CAS30012
CAS30013
CAS30014
CAS30015
CAS30016
CAS30017
CAS30018
CAS30019
CAS30020
CAS30021
CAS30022
CAS30023
CAS30024
CAS30025
CAS30026
CAS30027
CAS30028
CAS30029
CAS30030
CAS30031
CAS30032
CAS30033
CAS30034
CAS30035
CAS30036

```

C.7 PROCOST Input for Case 3

```

50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30037
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30038
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30039
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30040
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30041
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30042
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30043
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30044
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30045
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30046
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30047
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30048
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30049
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30050
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30051
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30052
50 50 50 50 50 50 50 50 200 200 200 200 200 200 200 200 50 50 50 50 200 200 50 50 50 CAS30053
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30054
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30055
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30056
50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 50 CAS30057
//G.SYSIN DD *,DCB=BLKSIZE=2000 CAS30058
'SYSTEAS' 'DUR' 168 120 6 1 2 61 0 4 'YES' CAS30059
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 CAS30060
3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 CAS30061
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 CAS30062
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 CAS30063
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 CAS30064
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 CAS30065
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 CAS30066
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 CAS30067
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 CAS30068
49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 CAS30069
73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 CAS30070
100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 CAS30071
120 CAS30072

```

.95	.999					1.	1.05	1100	220	1.05	1.44	CAS30073
'SYSTEB'	'DUR'	168	120	6	1	2	58	0	5	'YES'		CAS30074
1	1	1	1	1	1	1	1	1	1	1	1	CAS30075
3	3	3	3	3	3	3	3	3	3	3	3	CAS30076
1	1	1	1	1	1	1	1	1	1	1	1	CAS30077
1	1	1	1	1	1	1	1	1	1	1	1	CAS30078
1	1	1	1	1	1	1	1	1	1	1	1	CAS30079
1	2	3	4	5	6	7	8	9	10	11	12	CAS30080
25	26	27	28	29	30	31	32	33	34	35	36	CAS30081
25	26	27	28	29	30	31	32	33	34	35	36	CAS30082
25	26	27	28	29	30	31	32	33	34	35	36	CAS30083
49	50	51	52	53	54	55	56	57	58	59	60	CAS30084
73	74	75	76	77	78	79	80	81	82	83	84	CAS30085
100	101	102	103	104	105	106	107	108	109	110	111	CAS30086
120												CAS30087
.95	.999	1.	1.05	1100	440	1.05	1.24					CAS30088
'SYSTEC'	'DUR'	168	120	6	1	2	52	0	4	'YES'		CAS30089
1	1	1	1	1	1	1	1	1	1	1	1	CAS30090
3	3	3	3	3	3	3	3	3	3	3	3	CAS30091
1	1	1	1	1	1	1	1	1	1	1	1	CAS30092
1	1	1	1	1	1	1	1	1	1	1	1	CAS30093
1	1	1	1	1	1	1	1	1	1	1	1	CAS30094
1	2	3	4	5	6	7	8	9	10	11	12	CAS30095
25	26	27	28	29	30	31	32	33	34	35	36	CAS30096
25	26	27	28	29	30	31	32	33	34	35	36	CAS30097
25	26	27	28	29	30	31	32	33	34	35	36	CAS30098
49	50	51	52	53	54	55	56	57	58	59	60	CAS30099
73	74	75	76	77	78	79	80	81	82	83	84	CAS30100
100	101	102	103	104	105	106	107	108	109	110	111	CAS30101
120												CAS30102
.95	.999	1.	1.05	1100	660	1.05	1.14					CAS30103
'SYSTED'	'DUR'	168	120	6	1	2	67	0	5	'YES'		CAS30104
1	1	1	1	1	1	1	1	1	1	1	1	CAS30105
3	3	3	3	3	3	3	3	3	3	3	3	CAS30106
1	1	1	1	1	1	1	1	1	1	1	1	CAS30107
1	1	1	1	1	1	1	1	1	1	1	1	CAS30108

1 1	CAS30109
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24	CAS30110
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30111
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30112
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30113
49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72	CAS30114
73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99	CAS30115
100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119	CAS30116
120	CAS30117
.95 .999 1. 1.05 1100 880 1.05 1.08	CAS30118
'SYSTEE' 'DUR' 168 120 6 1 2 61 0 4 'YES'	CAS30119
1 1	CAS30120
3 3	CAS30121
1 1	CAS30122
1 1	CAS30123
1 1	CAS30124
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24	CAS30125
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30126
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30127
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30128
49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72	CAS30129
73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99	CAS30130
100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119	CAS30131
120	CAS30132
.95 .999 1. 1.05 1100 1100 1.05 1.05	CAS30133
'SYSTEF' 'DUR' 168 120 6 1 2 64 0 4 'YES'	CAS30134
1 1	CAS30135
3 3	CAS30136
1 1	CAS30137
1 1	CAS30138
1 1	CAS30139
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24	CAS30140
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30141
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30142
25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48	CAS30143
49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72	CAS30144

73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	CAS30145	
100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119									CAS30146
120																												CAS30147
.95	.999									1.	1.05	1100	1100	1.05	1.05													CAS30148
//G.PECK DD *,DCB=BLKSIZE=2000																												
9	4	6	4	5	4																							CAS30149
.4	.966	.6	.911	.8	.894	1.	.895																					CAS30150
.4	.95	.6	.91	.8	.89	1.0	.89																					CAS30151
.40	1.35	.6	1.27	.8	1.25	1.	1.28																					CAS30152
1	400	9.2	.55																									CAS30153
1	525	9.1	.35																									CAS30154
1	580	9.0	.55																									CAS30155
1	600	9.1	.50																									CAS30156
1	800	9.4	1.05																									CAS30157
2	800	9.5	.40																									CAS30158
1	800	9.0	1.10																									CAS30159
1	1300	8.40	1.25																									CAS30160
2	1300	8.5	.80																									CAS30161
1	240	9.1	1.00																									CAS30162
4	210	9.8	.55																									CAS30163
3	225	10.	.50																									CAS30164
1	215	9.2	.55																									CAS30165
2	240	9.1	.80																									CAS30166
1	280	9.3	1.05																									CAS30167
1	145	9.8	1.70																									CAS30168
1	215	12.	.40																									CAS30169
1	105	11.8	1.0																									CAS30170
2	150	9.4	.95																									CAS30171
2	150	9.7	.55																									CAS30172
1500	25																											CAS30173
8	4	6	4	5	4																							CAS30174
.4	.966	.6	.911	.8	.894	1.	.895																					CAS30175
.4	.95	.6	.91	.8	.89	1.0	.89																					CAS30176
.40	1.35	.6	1.27	.8	1.25	1.	1.28																					CAS30177
1	450	9.0	.95																									CAS30178
1	580	9.0	.55																									CAS30179
																												CAS30180



2	600	9.1	.50
1	800	9.4	1.05
2	800	9.5	.40
1	800	9.0	1.10
1	1300	8.40	1.25
1	1300	8.5	.80
1	215	9.5	.55
4	210	9.8	.55
3	225	10.	.50
1	215	9.2	.55
3	240	9.1	.80
1	280	9.3	1.05
1	100	10.8	.55
1	215	12.	.40
1	105	11.8	1.0
3	150	9.4	.95
2	150	9.7	.55
	1500	25	
	8	4	5 4 4 4
.4	.966	.6	.911 .8 .894 1. .895
.4	.95	.6	.91 .8 .89 1.0 .89
.40	1.35	.6	1.27 .8 1.25 1. 1.28
1	400	9.2	.55
1	450	9.0	.95
1	580	9.0	.55
2	600	9.1	.50
1	800	9.4	1.05
2	800	9.5	.40
1	800	9.0	1.10
2	1300	8.5	.80
3	212	9.8	.55
3	225	10.	.50
1	425	9.2	.55
2	240	9.1	.80
1	280	9.3	1.05
1	215	12.	.40

CAS30181  
 CAS30182  
 CAS30183  
 CAS30184  
 CAS30185  
 CAS30186  
 CAS30187  
 CAS30188  
 CAS30189  
 CAS30190  
 CAS30191  
 CAS30192  
 CAS30193  
 CAS30194  
 CAS30195  
 CAS30196  
 CAS30197  
 CAS30198  
 CAS30199  
 CAS30200  
 CAS30201  
 CAS30202  
 CAS30203  
 CAS30204  
 CAS30205  
 CAS30206  
 CAS30207  
 CAS30208  
 CAS30209  
 CAS30210  
 CAS30211  
 CAS30212  
 CAS30213  
 CAS30214  
 CAS30215  
 CAS30216

1 100 10.8 .55  
 4 150 9.4 .95  
 2 150 9.7 .55  
 1500 25  
 9 4 7 4 6 4  
 .4 .966 .6 .911 .8 .894 1. .895  
 .4 .95 .6 .91 .8 .89 1.0 .89  
 .40 1.35 .6 1.27 .8 1.25 1. 1.28  
 1 400 9.2 .55  
 1 525 9.1 .35  
 1 450 9.0 .95  
 2 600 9.1 .50  
 1 800 9.4 1.05  
 2 800 9.5 .40  
 1 800 9.0 1.10  
 1 1300 8.40 1.25  
 1 1300 8.5 .80  
 1 240 9.1 1.00  
 3 212 9.8 .55  
 3 225 10. .50  
 1 210 9.2 .55  
 3 240 9.1 .80  
 1 215 9.5 .55  
 1 280 9.3 1.05  
 1 145 9.8 1.70  
 1 215 12. .40  
 1 100 10.8 .55  
 1 105 11.8 1.0  
 3 150 9.4 .95  
 2 150 9.7 .55  
 1500 25  
 10 4 5 4 5 4  
 .4 .966 .6 .911 .8 .894 1. .895  
 .4 .95 .6 .91 .8 .89 1.0 .89  
 .40 1.35 .6 1.27 .8 1.25 1. 1.28  
 1 400 9.2 .55

CAS30217  
 CAS30218  
 CAS30219  
 CAS30220  
 CAS30221  
 CAS30222  
 CAS30223  
 CAS30224  
 CAS30225  
 CAS30226  
 CAS30227  
 CAS30228  
 CAS30229  
 CAS30230  
 CAS30231  
 CAS30232  
 CAS30233  
 CAS30234  
 CAS30235  
 CAS30236  
 CAS30237  
 CAS30238  
 CAS30239  
 CAS30240  
 CAS30241  
 CAS30242  
 CAS30243  
 CAS30244  
 CAS30245  
 CAS30246  
 CAS30247  
 CAS30248  
 CAS30249  
 CAS30250  
 CAS30251  
 CAS30252

1 450 9.0 .95  
 1 525 9.1 .35  
 1 580 9.0 .55  
 1 600 9.1 .50  
 1 800 9.4 1.05  
 2 800 9.5 .40  
 2 800 9.0 1.10  
 1 1300 8.40 1.25  
 1 1300 8.5 .80  
 1 240 9.1 1.00  
 3 213 9.8 .55  
 3 225 10. .50  
 3 240 9.1 .80  
 1 215 9.5 .55  
 1 145 9.8 1.70  
 1 215 12. .40  
 1 100 10.8 .55  
 3 150 9.4 .95  
 2 150 9.7 .55  
 1500 25  
 8 4 7 4 6 4  
 .4 .966 .6 .911 .8 .894 1. .895  
 .4 .95 .6 .91 .8 .89 1.0 .89  
 .40 1.35 .6 1.27 .8 1.25 1. 1.28  
 1 400 9.2 .55  
 1 525 9.1 .35  
 1 580 9.0 .55  
 1 600 9.1 .50  
 1 800 9.4 1.05  
 2 800 9.0 1.10  
 1 1300 8.40 1.25  
 2 1300 8.5 .80  
 1 240 9.1 1.00  
 2 210 9.8 .55  
 1 225 10. .50  
 2 213 9.2 .55

CAS30253  
 CAS30254  
 CAS30255  
 CAS30256  
 CAS30257  
 CAS30258  
 CAS30259  
 CAS30260  
 CAS30261  
 CAS30262  
 CAS30263  
 CAS30264  
 CAS30265  
 CAS30266  
 CAS30267  
 CAS30268  
 CAS30269  
 CAS30270  
 CAS30271  
 CAS30272  
 CAS30273  
 CAS30274  
 CAS30275  
 CAS30276  
 CAS30277  
 CAS30278  
 CAS30279  
 CAS30280  
 CAS30281  
 CAS30282  
 CAS30283  
 CAS30284  
 CAS30285  
 CAS30286  
 CAS30287  
 CAS30288

3 240 9.1 .80  
 1 215 9.5 .55  
 1 280 9.3 1.05  
 1 145 9.8 1.70  
 1 215 12. .40  
 1 105 11.8 1.0  
 1 100 10.8 .55  
 4 150 9.4 .95  
 2 150 9.7 .55  
 1500 25

CAS30289  
 CAS30290  
 CAS30291  
 CAS30292  
 CAS30293  
 CAS30294  
 CAS30295  
 CAS30296  
 CAS30297  
 CAS30298  
 CAS30299

//G.PEAKS DD \*,DCB=BLKSIZE=2000

6	.10	95	12.5	1.05	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30300					
	.10	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1	CAS30301				
6	.10	95	12.5	1.05	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30302					
	.10	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1	CAS30303				
6	.10	95	12.5	1.05	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30304					
	.10	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1	CAS30305				
6	.10	95	12.5	1.05	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30306					
	.10	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1	CAS30307				
6	.10	95	12.5	1.05	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30308					
	.10	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1	CAS30309				
7	.10	95	12.	1.05	100	.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30310
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30311
7	.10	95	12.	1.05	100	.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30312
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30313
7	.10	95	12.	1.05	100	.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30314
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30315
7	.10	95	12.	1.05	100	.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30316
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30317
7	.10	95	12.	1.05	100	.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30318
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30319
6						.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30320
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30321
6						.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30322
	.1	90	12.9	.55	100	.1	51	15.	1.7	0	.10	4	15.	1.7	0	1					CAS30323
6						.10	95	12.5	1.7	100	.10	95	12.	1.05	100	.1	90	12.9	.55	100	CAS30324

```

.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30325
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30326
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30327
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30328
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30329
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30330
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30331
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30332
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30333
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30334
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30335
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30336
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30337
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30338
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30339
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30340
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30341
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30342
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30343
6 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 .1 90 12.9 .55 100 CAS30344
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30345
5 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 CAS30346
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30347
5 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 CAS30348
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30349
5 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 CAS30350
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30351
5 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 CAS30352
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30353
5 .10 95 12.5 1.7 100 .10 95 12. 1.05 100 CAS30354
.1 90 12.9 .55 100 .1 51 15. 1.7 0 .10 4 15. 1.7 0 1 CAS30355
//G.TRANSFR DD DSN=&TRANS,UNIT=SCRATCH,DISP=(NEW,PASS), CAS30356
// SPACE=(CYL,(1,1)), CAS30357
// DCB=(RECFM=U,BLKSIZE=13000) CAS30358
//G.DATA DD DSN=&DATA,UNIT=SCRATCH,SPACE=(CYL,(25,5)), CAS30359
// DISP=(NEW,PASS),DCB=(RECFM=FB,LRECL=80,BLKSIZE=12880) CAS30360
//B EXEC MPSX

```

```
//MPSCOMP.SYSIN DD *,DCB=(RECFM=FB,LRECL=80,BLKSIZE=2000)
PROGRAM
```

```
*
* THIS PROGRAM PREFORMS THE NUCLEAR ENERGY OPTIMIZATION
* FOR THE AEP CASE 3
TITLE (' ELECTRIC POWER DISPATCHING SIMULATION')
INITIALZ
MVADR(XDOPRINT,SET)
XSETLB=-1
XFREQLGA=0
XFREQLGO=0
XPARDELT=2.
MOVE(XOBJ,'COST')
MOVE(XPBNAME,'MINIMIZE')
MOVE(XDATA,'SYSTEAO1')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO2')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO3')
EXEC(TIP)
MOVE(XDATA,'SYSTEAO4')
EXEC(TIP)
MOVE(XDATA,'SYSTEB01')
EXEC(TIP)
MOVE(XDATA,'SYSTEB02')
EXEC(TIP)
MOVE(XDATA,'SYSTEB03')
EXEC(TIP)
MOVE(XDATA,'SYSTEB04')
EXEC(TIP)
MOVE(XDATA,'SYSTEB05')
EXEC(TIP)
MOVE(XDATA,'SYSTEC01')
EXEC(TIP)
MOVE(XDATA,'SYSTEC02')
EXEC(TIP)
```

```
CAS30361
CAS30362
CAS30363
CAS30364
CAS30365
CAS30366
CAS30367
CAS30368
CAS30369
CAS30370
CAS30371
CAS30372
CAS30373
CAS30374
CAS30375
CAS30376
CAS30377
CAS30378
CAS30379
CAS30380
CAS30381
CAS30382
CAS30383
CAS30384
CAS30385
CAS30386
CAS30387
CAS30388
CAS30389
CAS30390
CAS30391
CAS30392
CAS30393
CAS30394
CAS30395
CAS30396
```

MOVE(XDATA, 'SYSTEC03')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEC04')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEM01')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEM02')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEM03')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEM04')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEM05')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEE01')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEE02')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEE03')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEE04')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEMF01')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEMF02')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEMF03')  
EXEC(TIP)  
MOVE(XDATA, 'SYSTEMF04')  
EXEC(TIP)  
EXIT  
TIP CONVERT('FILE', 'IN')  
MOVE(XRHS, 'RHS001')  
SETUP('BOUND', 'BOUND1')  
A=0  
EXEC(PARRR)

CAS30397  
CAS30398  
CAS30399  
CAS30400  
CAS30401  
CAS30402  
CAS30403  
CAS30404  
CAS30405  
CAS30406  
CAS30407  
CAS30408  
CAS30409  
CAS30410  
CAS30411  
CAS30412  
CAS30413  
CAS30414  
CAS30415  
CAS30416  
CAS30417  
CAS30418  
CAS30419  
CAS30420  
CAS30421  
CAS30422  
CAS30423  
CAS30424  
CAS30425  
CAS30426  
CAS30427  
CAS30428  
CAS30429  
CAS30430  
CAS30431  
CAS30432

	STEP	CAS30433
PARRR	XPARAM=0.	CAS30434
	A=A+1	CAS30435
	IF(A.EQ.1,S2)	CAS30436
	MOVE('DPZSTART','CONTINUE')	CAS30437
	RESTORE('NAME','SA')	CAS30438
S2	OPTIMIZE	CAS30439
	SOLUTION('FILE','SOLN','RSECTION','2/4/8','CSECTION','2/4/',' X	CAS30440
	'CMASKS','N*****',' ')	CAS30441
	SAVE('NAME','SA')	CAS30442
	MOVE(XCHCOL,'CHC002')	CAS30443
	XPARAM=0.	CAS30444
	XPARAMAX=8.	CAS30445
	PARARHS('CONT')	CAS30446
	SOLUTION('FILE','SOLN','RSECTION','2/4/8','CSECTION','2/4/',' X	CAS30447
	'CMASKS','N*****',' ')	CAS30448
	STEP	CAS30449
SET	SOLUTION('FILE','SOLN','RSECTION','2/4/8','CSECTION','2/4/',' X	CAS30450
	'CMASKS','N*****',' ')	CAS30451
	CONTINUE	CAS30452
A	DC(0)	CAS30453
	PEND	CAS30454
	//MPSEXEC.SYSPRINT DD DUMMY	CAS30455
	//MPSEXEC.IN DD DSN=&DATA,VOL=REF=*.A.G.DATA,DISP=(OLD,DELETE)	CAS30456
	//MPSEXEC.SOLN DD DSN=&SOLN,DISP=(NEW,PASS),UNIT=SCRATCH,	CAS30457
	// SPACE=(CYL,(10,5)),DCB=(RECFM=VBS,BLKSIZE=7144,LRECL=204)	CAS30458
	// EXEC PLIXG,PROG='U.M9960.8981.TEST1.LIBRARY.LMOD(TEMPNAME)'	CAS30459
	// EXEC PLIXG,PROG='U.M9960.8981.TEST1.LIBRARY.LMOD(TEMPNAME)'	CAS30460
	//G.SYSIN DD *,DCB=BLKSIZE=2000	CAS30461
	'SEC' 1	CAS30462
300	.7 160 9300 2300 7600 1 200	CAS30463
	5 1 'APRIL CONFIGURATION, WEEK 1 , P.S. SECURITY MODE CALC'	CAS30464
	5 1 'APRIL CONFIGURATION, WEEK 2 , P.S. SECURITY MODE CALC'	CAS30465
	5 1 'APRIL CONFIGURATION, WEEK 3 , P.S. SECURITY MODE CALC'	CAS30466
	5 1 'APRIL CONFIGURATION, WEEK 4 , P.S. SECURITY MODE CALC'	CAS30467
	'SEC' 1	CAS30468



300	.7	160	9300	2300	7600	1	200		CAS30469
5	1	'MAY	CONFIGURATION,	WEEK 5,	P.S. SECURITY MODE	CALC'			CAS30470
5	1	'MAY	CONFIGURATION,	WEEK 6,	P.S. SECURITY MODE	CALC'			CAS30471
5	1	'MAY	CONFIGURATION,	WEEK 7,	P.S. SECURITY MODE	CALC'			CAS30472
5	1	'MAY	CONFIGURATION,	WEEK 8,	P.S. SECURITY MODE	CALC'			CAS30473
5	1	'MAY	CONFIGURATION,	WEEK 9,	P.S. SECURITY MODE	CALC'			CAS30474
		'SEC'	1						CAS30475
300	.7	160	9300	2300	7600	1	200		CAS30476
5	1	'JUNE	CONFIGURATION,	WEEK 10,	P.S. SECURITY MODE	CALC'			CAS30477
5	1	'JUNE	CONFIGURATION,	WEEK 11,	P.S. SECURITY MODE	CALC'			CAS30478
5	1	'JUNE	CONFIGURATION,	WEEK 12,	P.S. SECURITY MODE	CALC'			CAS30479
5	1	'JUNE	CONFIGURATION,	WEEK 13,	P.S. SECURITY MODE	CALC'			CAS30480
		'SEC'	1						CAS30481
300	.7	160	9300	2300	7600	1	200		CAS30482
5	1	'JULY	CONFIGURATION,	WEEK 14,	P.S. SECURITY MODE	CALC'			CAS30483
5	1	'JULY	CONFIGURATION,	WEEK 15,	P.S. SECURITY MODE	CALC'			CAS30484
5	1	'JULY	CONFIGURATION,	WEEK 16,	P.S. SECURITY MODE	CALC'			CAS30485
5	1	'JULY	CONFIGURATION,	WEEK 17,	P.S. SECURITY MODE	CALC'			CAS30486
5	1	'JULY	CONFIGURATION,	WEEK 18,	P.S. SECURITY MODE	CALC'			CAS30487
		'SEC'	1						CAS30488
300	.7	160	9300	2300	7600	1	200		CAS30489
5	1	'AUGUST	CONFIGURATION,	WEEK 19,	P.S. SECURITY MODE	CALC'			CAS30490
5	1	'AUGUST	CONFIGURATION,	WEEK 20,	P.S. SECURITY MODE	CALC'			CAS30491
5	1	'AUGUST	CONFIGURATION,	WEEK 21,	P.S. SECURITY MODE	CALC'			CAS30492
5	1	'AUGUST	CONFIGURATION,	WEEK 22,	P.S. SECURITY MODE	CALC'			CAS30493
		'SEC'	1						CAS30494
300	.7	160	9300	2300	7600	1	200		CAS30495
5	1	'SEPT.	CONFIGURATION,	WEEK 23,	P.S. SECURITY MODE	CALC'			CAS30496
5	1	'SEPT.	CONFIGURATION,	WEEK 24,	P.S. SECURITY MODE	CALC'			CAS30497
5	1	'SEPT.	CONFIGURATION,	WEEK 25,	P.S. SECURITY MODE	CALC'			CAS30498
5	1	'SEPT.	CONFIGURATION,	WEEK 26,	P.S. SECURITY MODE	CALC'			CAS30499
//G.TRANSFR	DD	DSN=&TRANS,	VOL=REF=*,	A.G.TRANSFR,	DISP=(OLD,DELETE)				CAS30500
//G.SGLN	DD	DSN=&SGLN,	DISP=(OLD,DELETE),	VOL=REF=*,	B.MPSEXEC.SGLN				CAS30501

INPUT VARIABLES FOLLOWS: N2= 6 SYSTF='SYSTE' MODE='DUR' TRUE= 168 NI= 120  
 PARAMETER= J WEEKS= 4 VP= 1 NUMHR= 2 K= 61  
 HYDRO DATA FOLLOWS: PECKING='N' :

WEEKLY HYDRO GENERATION SCHEDULE, INTERVAL BY INTERVAL (MW)

50	50	50	50	50	50	50	50
200	200	200	200	200	200	200	200
50	50	50	200	200	50	50	50
50	50	50	50	50	50	50	50
200	200	200	200	200	200	200	200
50	50	50	200	200	50	50	50
50	50	50	50	50	50	50	50
200	200	200	200	200	200	200	200
50	50	50	200	200	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50
50	50	50	50	50	50	50	50

THE TIME WEIGHING FUNCTION FOLLOWS (NUMBER OF HOURS REPRESENTED BY EACH TIME INTERVAL):

1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
3	3	3	3	3	3	3	3
3	3	3	3	3	3	3	3
3	3	3	3	3	3	3	3
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1

\*CODE\* FOLLOWS(CORRESPONDENCE MAP FROM THE LOAD MODEL TO A 168 HOUR REPRESENTATION):

1	2	3	4	5	6	7	8
9	10	11	12	13	14	15	16
17	18	19	20	21	22	23	24
25	26	27	28	29	30	31	32
33	34	35	36	37	38	39	40
41	42	43	44	45	46	47	48
25	26	27	28	29	30	31	32
33	34	35	36	37	38	39	40
41	42	43	44	45	46	47	48
25	26	27	28	29	30	31	32
33	34	35	36	37	38	39	40
41	42	43	44	45	46	47	48
49	50	51	52	53	54	55	56
57	58	59	60	61	62	63	64
65	66	67	68	69	70	71	72
73	74	75	76	77	78	79	80
81	82	83	84	85	86	87	88
89	90	91	92	93	94	95	96
97	98	99	100	101	102	103	104

APPENDIX C.8 SAMPLE OUTPUT FROM PROCOST

105	106	107	108	109	110	111	112
113	114	115	116	117	118	119	120

NUCLEAR INPUT PARAMETERS FOLLOWS:  
 NUCLEAR INCREMENTAL HEAT RATES:  
 WEEKLY NUCLEAR CAPACITY FACTORS:  
 RATED NUCLEAR CAPACITIES, MW:  
 FULL POWER AVER HEAT RATES:

1.00	1.05
0.95	1.00
1.00	2.00
1.05	1.94

THE FOLLOWING IS THE PECK FILE INPUT FOR LARGE, MEDIUM, SMALL

L FOSSIL PLANTS:

N1= 4 VPI= 4 N2= 6 VP2= 4 N3= 5  
 VP3= 4

AVERAGE HEAT RATES FOR LARGE, MEDIUM AND SMALL FOSSIL PLANTS: FRACTION OF RATED POWER, HEAT RATE (MMBTU/MMH)

0.40	0.97	0.60	0.91	0.80	0.89	1.00	0.89
0.40	0.95	0.60	0.91	0.80	0.89	1.00	0.99
0.40	1.35	0.60	1.27	0.80	1.25	1.00	1.28

PLANT PARAMETERS FOR LARGE, MEDIUM AND SMALL FOSSIL PLANTS:  
 NUMBER, CAPACITY (MW), HEAT RATE (MMBTU/MMH), FUEL COST (\$/MMBTU)

1.00	400.00	9.20	0.55
1.00	225.00	9.10	0.55
1.00	580.00	9.00	0.55
1.00	600.00	9.10	0.50
1.00	800.00	9.40	1.05
2.00	800.00	9.50	0.40
1.00	900.00	9.00	1.10
1.00	1300.00	8.40	1.25
2.00	1300.00	8.50	0.80
1.00	240.00	9.10	1.00
4.00	210.00	9.30	0.55
3.00	225.00	10.00	0.50
1.00	215.00	9.20	0.55
2.00	240.00	9.10	0.80
1.00	280.00	9.30	1.05
1.00	145.00	9.80	1.70
1.00	215.00	12.00	0.40
1.00	105.00	11.80	1.00
2.00	150.00	9.40	0.55
2.00	150.00	9.70	0.55

ECONOMIC LOADING ORDER OF FOSSIL PLANTS  
 MUST RUN FOSSIL OPERATING LEVEL (MW) = 5200  
 MINIMUM FOSSIL FUEL COST (\$/WK) = 26,418,661.

INCREMENTAL STEP	STEP SIZE (MW)	CUMULATIVE SIZE (MW)	INCREM. GENERATION COST (MILLS/KWH)	CUMULATIVE INCREM. GENERATION COST (\$/HR)
1	105	105	2.85	299.30
2	105	210	3.00	614.30
3	105	315	3.20	950.21
4	320	635	3.40	2339.50
5	320	955	3.58	3193.35
6	320	1275	3.82	4405.28
7	120	1395	4.07	4893.94

8	43	1438	4.16	5072.92
9	120	1558	4.29	5587.20
10	116	1674	4.43	6101.39
11	43	1717	4.46	6292.98
12	80	1757	4.53	6655.27
13	120	1917	4.57	7203.71
14	60	1577	4.63	7481.29
15	116	2093	4.66	8022.13
16	135	2278	4.66	8651.07
17	135	2363	4.66	9281.12
18	43	2406	4.72	9484.33
19	43	2449	4.72	9686.94
20	80	2529	4.77	10063.22
21	60	2589	4.96	10365.32
22	116	2705	4.97	10742.58
23	135	2840	5.00	11617.38
24	163	298	5.03	12467.35
25	163	3176	5.03	13306.53
26	43	3219	5.06	13524.11
27	80	3299	5.08	13930.72
28	43	3342	5.25	14156.47
29	163	3510	5.39	15061.99
30	60	3570	5.84	15617.10
31	520	4090	6.09	18576.71
32	520	4610	6.40	21907.27
33	96	4706	6.79	22559.03
34	96	4802	6.79	23210.79
35	520	5322	6.83	26767.60
36	54	5418	7.28	27461.48
37	60	5478	7.74	27920.11
38	60	5538	8.30	28424.74
39	49	5586	8.49	28831.59
40	44	5734	8.49	29233.95
41	160	5754	8.83	30652.28
42	160	5954	8.86	32069.92
43	43	6002	9.10	32505.72
44	56	6058	9.11	33016.69
45	56	6114	9.11	33526.57
46	160	6274	9.30	35014.11
47	160	6414	9.32	35500.38
48	260	6694	9.40	38949.35
49	56	6750	9.76	39496.19
50	60	6810	9.77	40082.27
51	260	7070	9.89	42653.60
52	160	7230	9.91	44237.36
53	160	7390	9.94	45830.94
54	21	7411	10.23	46345.83
55	260	7671	10.55	48789.33
56	21	7692	10.97	49313.40
57	21	7713	12.91	49289.43
58	29	7742	14.45	49704.41
59	29	7771	15.49	50157.58
60	29	7800	18.22	50686.01
61	1500	9300	25.00	88186.01

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

10096	9864	9755	9671	9795	10279	11107	12347
13106	13478	13575	13504	13307	13233	13071	12627

12748	12720	12758	12942	12937	12700	12027	11011
9915	9640	9506	9451	9542	9968	10803	12111
12860	13150	13769	13125	12972	12980	12745	12385
12495	12516	12571	12713	12641	12433	11740	10720
9189	8941	8988	8991	8926	9262	10084	11393
12218	12595	12748	12636	12418	12437	12278	11960
12023	12025	12069	12151	12126	11899	11235	10245
9230	8915	8918	8837	8864	9025	9273	9794
10441	10920	11111	11115	10864	10640	10395	10187
10247	10363	10516	10751	10736	10538	10099	9501
5847	3520	8288	8238	8195	8239	8314	8664
9159	9305	9244	9353	9342	9047	8755	8645
8088	8859	9158	8586	9790	9837	9439	8987

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 88071.00

CODE= 1.00000E+00

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

7348      0733      5661      4399      4196      3427

FOSSIL INCREMENTS, MUST RUN(\$/MWH)      \$3,606,484.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

10271	13082	4991	9913	10060	10525	11468	12713
13380	13723	13794	13739	13493	13387	13169	12764
12900	12914	13038	13272	13219	12866	12170	11191
10140	5883	9755	9705	9811	10770	11152	12475
13141	13332	13470	13296	13130	13126	12866	12504
12641	12680	12808	13005	12875	12563	11954	10864
9280	9059	9070	9015	9072	9430	10336	11703
12511	12871	13030	12886	12640	12672	12501	12188
12285	12298	12411	12520	12438	12095	11393	10393
9682	9289	9116	9036	9091	9267	9541	10081
10702	11152	11325	11317	11043	10802	10539	10318
10399	10538	10733	11082	10958	10664	10211	9638
9002	8694	8487	8447	8387	8442	8542	8907
9336	9486	9393	9438	9460	9124	8814	8700
8752	8950	9319	9839	9956	9919	9489	9064

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 88071.00

CODE= 1.00000E+00

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

7534      6898      5881      5137      4403      3595

FOSSIL INCREMENTS, MUST RUN(\$/WK) \$3,762,857.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, Mw)

9797	9493	9353	9256	9343	9725	10493	11727
12637	13058	13203	13154	12999	12969	12768	12393
12487	12397	12330	12379	12456	12418	11781	10721
9531	9225	9091	9018	9033	9453	10207	11489
12380	12754	12924	12834	12703	12728	12533	12133
12247	12235	12167	12213	12242	12212	11545	10472
9033	8739	8601	8652	8675	8974	9655	10864
11713	12125	12269	12207	12037	12035	11897	11572
11575	11559	11533	11519	11542	11563	10966	9993
9270	8792	8530	8497	8477	8613	8816	9305
9993	10524	10746	10771	10558	10362	10149	9962
10005	10078	10146	10295	10357	10323	9906	9267
9593	9221	7947	7947	7865	7892	7923	8250
8770	8997	9008	9123	9139	8916	8655	8553
8579	8722	8882	9153	9438	9697	9351	8854

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.35	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 98671.00

CODE= 1.00030E+00

OUTPUT FUNCTION FROM SUPRCUTINE DURATION:

7013	5309	5309	4634	3845	3096
------	------	------	------	------	------

FOSSIL INCREMENTS, MUST RUN(\$/WK) \$3,153,795.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, Mw)

9193	8742	8538	8417	8429	8704	9242	10457
11689	12209	12448	12446	12345	12436	12257	11919
11960	11715	11464	11238	11482	11847	11290	10133
8753	8384	8220	8140	8154	8410	9002	10229
11407	11952	12227	12245	12158	12218	12119	11772
11744	11007	11349	11203	11433	11764	11153	9972
8717	8331	8202	8189	8168	8390	8786	9794
10706	11173	11294	11340	11267	11222	11126	10786
10669	10615	10357	10241	10512	10984	10472	9493
8743	9159	7895	7408	7654	7778	7850	8316
9088	9721	10008	10074	9439	9801	9651	9508
9515	9440	9397	9291	9589	9888	9517	8793
8049	7617	7256	7256	7199	7190	7132	7411
7985	8374	8528	8456	8729	8649	8453	8365
8357	8385	8324	8276	8726	9415	9175	8585

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.35	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100

- 014 -

CAPACITY FACTOR= 0.10 RATED CAPACITY(MW)= 51 HEAT RATE(MMRTU/MWH)= 15.00 FUEL COST(\$/MMRTU)= 1.70 \$/SD COST(\$)= 0  
CAPACITY FACTOR= 0.10 RATED CAPACITY(MW)= 4 HEAT RATE(MMRTU/MWH)= 15.00 FUEL COST(\$/MMRTU)= 1.70 \$/SD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 88171.00

CODE= 1.00000E+00

OUTPUT FUNCTION FROM SUBROUTINE DURATION:  
6345 5505 4641 3762 3077 2260

FOSIL INCREMENTS, MUST RUN(\$/WK) \$2,423,449.





105 106 107 108 109 110 111 112  
 113 114 115 116 117 118 119 120

NUCLEAR INPUT PARAMETERS FOLLOWS:  
 NUCLEAR INCREMENTAL HEAT RATES: 1.00 1.05  
 WEEKLY NUCLEAR CAPACITY FACTORS: 0.95 1.00  
 RATED NUCLEAR CAPACITIES, MW: 1100 440  
 FULL POWER AVER HEAT RATES: 1.05 1.24

THE FOLLOWING IS THE PEEK FILE INPUT FOR LARGE, MEDIUM, SMALL

L FOSSIL PLANTS:  
 N1= 8 VP1= 4 N2= 6 VP2= 4 N3= 5  
 VP3= 4:

AVERAGE HEAT RATES FOR LARGE, MEDIUM AND SMALL FOSSIL PLANTS: FRACTION OF RATED POWER, HEAT RATE(MMRTU/MWH)  
 0.40 0.97 0.60 0.91 0.90 0.89 1.00 0.89  
 0.40 0.95 0.60 0.91 0.90 0.89 1.00 0.89  
 0.40 1.35 0.60 1.27 0.80 1.25 1.00 1.20

PLANT PARAMETERS FOR LARGE, MEDIUM AND SMALL FOSSIL PLANTS:  
 NUMBER, CAPACITY(MW), HEAT RATE(MMRTU/MWH), FUEL COST(\$/MMRTU)

1.00	450.00	9.00	0.95
1.00	580.00	9.00	0.55
2.00	600.00	9.10	0.50
1.00	800.00	9.40	1.05
2.00	800.00	9.50	0.40
1.00	800.00	9.00	1.10
1.00	1300.00	8.40	1.25
1.00	1300.00	8.50	0.90
1.00	215.00	9.50	0.55
4.00	210.00	9.80	0.55
3.00	225.00	10.00	0.50
1.00	215.00	9.20	0.55
3.00	240.00	9.10	0.80
1.00	280.00	9.30	1.05
1.00	150.00	10.00	0.55
1.00	215.00	12.00	0.40
1.00	105.00	11.80	1.00
3.00	150.00	9.40	0.95
2.00	150.00	9.70	0.55

ECONOMIC LOADING ORDER OF FOSSIL PLANTS  
 MUST RUN FOSSIL OPERATING LEVEL(MW) = 4858  
 MINIMUM FOSSIL FUEL COST(\$/WK) = \$6,001,549.

INCREMENTAL STEP	STEP SIZE (MW)	CUMULATIVE SIZE (MW)	INCREM. GENERATION COST(MILLS/KWH)	CUMULATIVE INCREM. GENERATION COST(\$/WK)
1	320	320	3.40	1089.28
2	320	640	3.58	2233.63
3	320	960	3.82	3455.07
4	240	1200	4.07	4432.38
5	43	1243	4.16	4611.36
6	240	1483	4.29	5639.92
7	115	1598	4.43	6153.81
8	43	1642	4.46	6345.70

9	240	1882	4.57	7442.58
10	60	1942	4.63	7720.16
11	116	2058	4.66	8261.00
12	135	2193	4.66	8900.50
13	135	2328	4.66	9519.99
14	43	2371	4.72	9722.90
15	43	2414	4.72	9925.81
16	43	2457	4.87	10135.34
17	43	2500	4.97	10346.87
18	60	2560	4.96	10542.46
19	116	2676	4.97	11219.23
20	135	2811	5.00	11394.23
21	163	2779	5.03	12739.70
22	163	3147	5.03	13584.18
23	43	3190	5.06	13502.76
24	20	3210	5.15	13903.78
25	43	3210	5.23	14129.45
26	43	3296	5.25	14354.20
27	163	3464	5.39	15259.72
28	20	3484	5.52	15370.17
29	60	3544	5.84	15720.28
30	260	3304	6.09	17307.59
31	260	4064	6.40	18967.86
32	20	4084	6.50	19197.30
33	144	4228	6.79	20075.45
34	144	4372	6.79	21051.09
35	260	4632	6.83	22821.99
36	144	4776	7.28	23877.31
37	90	4866	7.65	24565.99
38	90	4956	7.74	25262.75
39	90	5046	8.05	25987.74
40	90	5136	8.30	26734.93
41	90	5226	8.59	27507.87
42	160	5386	8.83	28321.21
43	160	5546	8.86	29338.95
44	56	5602	9.11	30349.32
45	56	5658	9.11	31358.79
46	160	5818	9.30	32846.24
47	160	5978	9.32	34339.21
48	260	6238	9.40	36781.58
49	56	6294	9.76	37323.32
50	90	6384	9.77	38207.36
51	260	6644	9.89	40778.74
52	160	5934	9.91	42365.00
53	160	6564	9.94	43956.08
54	21	6985	10.23	44170.97
55	260	7245	10.55	46913.17
56	21	7266	10.97	47143.54
57	21	7287	12.91	47414.58
58	1500	8787	25.00	84914.58

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

9751	9436	9290	9192	9273	9647	10394	11625
12565	12993	13145	13100	12939	12978	12729	12356
12447	12336	12263	12291	12381	12374	11746	10676
9471	9150	9015	8550	9011	9373	10115	11392
12305	12692	12871	12789	12661	12689	12506	12151
12209	12192	12104	12136	12180	12177	11516	10434

9009	8708	8626	8617	8636	8929	9588	10782
11640	12052	12193	12140	11978	11973	11838	11512
11505	11466	11415	11421	11509	11511	10925	9954
9224	8744	8527	8464	8417	8549	8745	9229
9924	10462	10690	10717	10511	10319	10111	9927
9967	10033	10089	10218	10298	10290	9876	9230
8542	8175	7894	7894	7614	7833	7862	8185
8710	9950	8971	9087	9108	8895	8640	8538
8562	8678	8839	9085	9383	9676	9338	8634

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 55	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 55	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 3.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 3.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 122647.00

CODE= 1.00000E+001

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

7269 6533 5567 4941 4065 3323

FOSSIL INCREMENTS, MUST RUN(\$/WK) \$3,428,042.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

9427	9034	8854	8743	8794	9100	9726	10947
12057	12533	12740	12721	12594	12643	12455	12102
12165	11976	11800	11680	11800	12068	11482	10361
9054	8710	8554	8430	8514	8814	9469	10717
11784	12253	12497	12474	12770	12416	12282	11931
11939	11037	11666	11594	11747	11937	11305	10166
8840	8490	8380	8369	8365	8616	9123	10209
11098	11542	11672	11676	11566	11537	11425	11091
11020	10981	10801	10736	10931	11147	10633	9681
9947	8434	8161	9075	7498	8102	8249	8699
9439	10032	10234	10344	10179	10018	9844	9684
9705	9718	9687	9690	9837	10057	9668	8977
8256	7851	7524	7524	7457	7462	7439	7736
8289	8616	8714	9837	8488	8753	8532	8438
8443	8503	8500	8610	9002	9524	9244	8690

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 55	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 3.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 3.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 122547.00

CODE= 1.00000E+001

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

6880 5974 5224 4501 3657 2849

FOSSIL INCREMENTS, MUST RUN(\$/WK) \$2,954,739.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

9580	9224	9061	8555	9015	9355	10042	11268
12297	12754	12937	12900	12758	12778	12585	12223
12298	12146	12019	11565	12107	12213	11607	10510
9252	8923	8772	8703	8749	9079	9775	11037
12331	12406	12674	12623	12508	12545	12398	12035
12067	12032	11674	11851	11952	12051	11405	10293
8970	8593	8496	8486	8493	8764	9343	10480
11355	11783	11918	11856	11761	11743	11621	11290
11250	11220	11092	11040	11204	11319	10771	9810
9031	8565	8334	8250	8196	8313	8484	6950
9089	10230	10431	10521	10336	10161	9970	9799
9829	9807	9877	9935	10092	10167	9766	9397
8392	8034	7499	7699	7626	7640	7639	7949
8488	8774	8836	8555	8992	8820	8583	8485
8499	8588	8632	8838	9192	9596	9289	8759

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 122147.00

CODE= 1.00000E+00

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

7.77	5278	5368	4673	3176	3070
------	------	------	------	------	------

FOSSIL INCREMENTS, MUST RUN(\$/WK) \$3,158,475.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

9796	9492	9352	9255	9342	9724	10489	11720
12635	13057	13201	13153	12998	12969	11767	12392
12487	12357	12329	12377	12455	12417	11783	11720
9530	9224	9090	9016	9041	9452	10206	11487
12378	12753	12923	12843	12703	12727	12538	12182
12246	12235	12156	12212	12241	12211	11546	10472
7132	7344	8800	8652	8674	8473	8654	10863
11717	12124	12265	12206	12036	12034	11896	11571
11574	11557	11501	11517	11590	11562	10966	9993
9269	8791	8579	8496	8476	8612	8815	9304
9992	10522	10745	10770	10557	10462	10148	9961
10004	10077	10145	10294	10356	10323	9906	9266
8583	8220	7945	7946	7964	7891	7922	8249
8769	8497	8007	8122	8139	8915	8655	8552
8578	8701	8831	9151	9437	9697	9351	8854

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 0.55	SUSD COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSD COST(\$)= 0

- 446 -

CAPACITY FACTOR= 0.10 RATED CAPACITY(MW)= 4 HEAT RATE(MMBTU/MWH)= 15.00 FUEL COST(\$/MMBTU)= 1.70 SUSO COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 122347.00

CODE= 1.00000E+00

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

7321 6636 5592 4840 4114 3371

FOSSIL INCREMENTS, MUST RUN(\$/WK) 63,451,832.

WEEKLY CUSTOMER DEMAND FUNCTION FOLLOWS:  
(INTERVAL BY INTERVAL, MW)

9242	8804	8605	8486	8504	8788	9344	10560
11767	12279	12509	12504	12397	12479	12298	11957
12103	11770	11535	11331	1582	11893	11331	10181
8317	8453	8290	8211	8230	8495	9100	10332
11437	12018	12284	12293	12203	12254	12153	11806
11785	11714	11416	11285	11500	11800	11185	10013
8743	8365	8240	8227	8210	8434	8857	9881
10735	11250	11374	11411	11330	11288	11189	10851
10742	10692	10451	10345	10600	10939	10466	9525
8780	8211	7951	7865	7758	7841	7966	8397
9102	8736	10058	10131	9990	9847	9692	9545
8545	9533	9458	9373	9652	9924	9548	8832
8043	7000	7313	7313	7253	7247	7197	7479
8449	8425	8568	8654	8762	8671	8470	8380
8375	8411	8370	8348	8784	9438	9190	8607

CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 55	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSO COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 55	HEAT RATE(MMBTU/MWH)= 12.50	FUEL COST(\$/MMBTU)= 1.70	SUSO COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 95	HEAT RATE(MMBTU/MWH)= 12.00	FUEL COST(\$/MMBTU)= 1.05	SUSO COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 3.55	SUSO COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 90	HEAT RATE(MMBTU/MWH)= 12.90	FUEL COST(\$/MMBTU)= 3.55	SUSO COST(\$)= 100
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 51	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSO COST(\$)= 0
CAPACITY FACTOR= 0.10	RATED CAPACITY(MW)= 4	HEAT RATE(MMBTU/MWH)= 15.00	FUEL COST(\$/MMBTU)= 1.70	SUSO COST(\$)= 0

OPERATION COST OF PEAKERS= \$ 122347.00

CODE= 1.00000E+00

OUTPUT FUNCTION FROM SUBROUTINE DURATION:

0075 5093 4939 4120 3474 2063

FOSSIL INCREMENTS, MUST RUN(\$/WK) 62,754,775.

```
0001          PROGRAM
0002          *
0003          * THIS PROGRAM PERFORMS THE NUCLEAR ENERGY OPTIMIZATION
0004          * FOR THE AEP CASE 3
0005          * TITLE (' ELECTRIC POWER DISPATCHING SIMULATION')
0006          INITIALZ
0100          MVADR(XCOPRINT,SFT)
0101          XSETLP=-1
0102          XFREQLGA=0
0103          XFRECLGC=0
0104          XPARDELT=2.
0105          MOVE(XCRJ,'CCST')
0106          MOVE(XPRNAME,'MINIMIZE')
0107          MOVE(XDATA,'SYSTEAO1')
0108          EXEC(TIP)
0109          MOVE(XDATA,'SYSTEAO2')
0110          EXEC(TIP)
0111          MOVE(XDATA,'SYSTEAO3')
0112          EXEC(TIP)
0113          MOVE(XDATA,'SYSTEAO4')
0114          EXEC(TIP)
0115          MOVE(XDATA,'SYTEBO1')
0116          EXEC(TIP)
0117          MOVE(XDATA,'SYSTEMC2')
0118          EXEC(TIP)
0119          MOVE(XDATA,'SYSTEMO3')
0120          EXEC(TIP)
0121          MOVE(XDATA,'SYSTEMO4')
0122          EXEC(TIP)
0123          MOVE(XDATA,'SYSTEMO5')
0124          EXEC(TIP)
0125          MOVE(XDATA,'SYSTEMC01')
0126          EXEC(TIP)
0127          MOVE(XDATA,'SYSTEMC02')
0128          EXEC(TIP)
0129          MOVE(XDATA,'SYSTEMC03')
0130          EXEC(TIP)
0131          MOVE(XDATA,'SYSTEMC04')
0132          EXEC(TIP)
0133          MOVE(XDATA,'SYSTEMD01')
0134          EXEC(TIP)
0135          MOVE(XDATA,'SYSTEMD02')
0136          EXEC(TIP)
0137          MOVE(XDATA,'SYSTEMD03')
0138          EXEC(TIP)
0139          MOVE(XDATA,'SYSTEMD04')
0140          EXEC(TIP)
0141          MOVE(XDATA,'SYSTEMD05')
0142          EXEC(TIP)
0143          MOVE(XDATA,'SYSTEME01')
0144          EXEC(TIP)
0145          MOVE(XDATA,'SYSTEME02')
0146          EXEC(TIP)
0147          MOVE(XDATA,'SYSTEME03')
```

```

0148 EXEC(TIP)
0149 MOVE(XCATA,'SYSTEE04')
0150 EXEC(TIP)
0151 MOVE(XCATA,'SYSTEF01')
0152 EXEC(TIP)
0153 MOVE(XCATA,'SYSTEF02')
0154 EXEC(TIP)
0155 MOVE(XCATA,'SYSTEF03')
0156 EXEC(TIP)
0157 MOVE(XCATA,'SYSTEF04')
0158 EXEC(TIP)
0159 EXIT
0160 TIP CONVERT('FILE','IA')
0161 MOVE(XRMS,'RHSJUL')
0162 SETUP('PCUAD','RDIIND1')
0163 A=0
0164 EXEC(PARPR)
0165 STEP
0166 PARPR XPARAM=0.
0167 A=A+1
0168 IF(A.EQ.1,S2)
0169 MOVE('OPZSTART','CONTINUE')
0170 RESTOPF('NAME','SA')
0171 S2 OPTIMIZE
0480 SOLUTION('FILE','SOLN','RSECTION','2/4/9','CSECTION','2/4/9',X
0481 'CMASKS','N*****',' ')
0482 SAVE('NAME','SA')
0483 MOVE(XCHCCL,'CHC002')
0484 XPARAM=0.
0485 XPARAMAX=B.
0486 PARARMS('CNT')
0487 SOLUTION('FILE','SOLN','RSECTION','2/4/8','CSECTION','2/4/8',X
0488 'CMASKS','N*****',' ')
0489 SET SOLUTION('FILE','SOLN','RSECTION','2/4/8','CSECTION','2/4/8',X
0490 'CMASKS','N*****',' ')
0491 A CONTINUE
DC(O)
PEND

```

ENTER P.S. MODE AND P.S. CODE  
'QUICK' 1

ENTER PUMPED STORAGE PARAMETERS:  
300 .7 160 9300 2300 7600 1 200

CAPACITY, RATIO, CAP\_PUMP, RESERIOR, FREE, START, BYE, TOLERANCE

ENTER NUMBER OF WEEKLY PERMUTATIONS  
5

SIMULATION DESCRIPTION:  
'APRIL CONFIGURATION, WEEK 1, NO P.S. CALC.'

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK; 1 ALLOCATION

INDEX= 1

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS01  
STATUS MIN  
NUMBER OF ITERATIONS 41  
FIXED FOSSIL FUEL COST(\$/WK) \$10,111,616. VARIABLE FOSSIL FUEL COST(\$/WK) \$110,538.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,222,155.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)	JCNP (MILLS/KWH)
1	4.72	4.96
2	3.44	4.96

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	62	7348	6029	1100	220		
2	16	6733	5413	1100	220		
3	17	5661	4341	1100	220		
4	20	4889	3569	1100	220		
5	33	4156	2676	1100	220		
6	20	3427	2571	633	219		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK; 2 ALLOCATION

INDEX= 2

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS01  
STATUS MIN  
NUMBER OF ITERATIONS 46  
FIXED FOSSIL FUEL COST(\$/WK) \$10,111,616. VARIABLE FOSSIL FUEL COST(\$/WK) \$197,407.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,309,019.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)	JCNP (MILLS/KWH)
1	4.79	5.03
2	3.49	5.03



NUCLEAR UNIT DISPATCHING:		DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
INTERVAL	WEIGHTING FACTOR (HOURS)						
1	62	7348	6028	1100	220		
2	16	6733	5413	1100	220		
3	17	5661	4341	1100	220		
4	20	4889	3569	1100	220		
5	33	4196	3176	800	220		
6	20	3427	2942	267	218		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK: 3 ALLOCATION

INDEX= 3

L.P. PARAMETERS

OBJECTIVE FUNCTION COST  
RHS RHS001  
STATUS MIN

NUMBER OF ITERATIONS

53

FIXED FOSSIL FUEL COST(\$/WK) \$10,111,616. VARIABLE FOSSIL FUEL COST(\$/WK) \$287,819.  
SYSTEM COST WITHOUT PUMPED STORAGE: \$10,399,436.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-YR)
1	5.56
2	3.51

OCNP (MILLS/KWH)
5.93
5.06

NUCLEAR UNIT DISPATCHING:		DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
INTERVAL	WEIGHTING FACTOR (HOURS)						
1	62	7348	6028	1100	220		
2	16	6733	5413	1100	220		
3	17	5661	4341	1100	220		
4	20	4989	3569	1100	220		
5	33	4196	3539	437	220		
6	20	3427	3209	0	218		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK: 4 ALLOCATION

INDEX= 4

L.P. PARAMETERS

OBJECTIVE FUNCTION COST  
RHS RHS001  
STATUS MIN

NUMBER OF ITERATIONS

56

FIXED FOSSIL FUEL COST(\$/WK) \$10,111,616. VARIABLE FOSSIL FUEL COST(\$/WK) \$392,997.  
SYSTEM COST WITHOUT PUMPED STORAGE: \$10,504,614.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-YR)
1	5.80
2	3.51

OCNP (MILLS/KWH)
6.09
5.06

NUCLEAR UNIT DISPATCHING:		DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
INTERVAL	WEIGHTING FACTOR (HOURS)						
1	62	7348	6028	1100	220		

2	16	6733	5413	1100	220
3	17	5661	4341	1100	220
4	20	4889	3715	954	220
5	33	4196	3976	0	220
6	20	3427	3209	0	218

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK: 5 ALLOCATION

INDEX= 5

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RMS RMSJ01  
STATUS MIN  
NUMBER OF ITERATIONS 57  
FIXED FOSSIL FUEL COST(\$/WK) \$10,111,616. VARIABLE FOSSIL FUEL COST(\$/WK) \$501,569.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,613,165.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	6.10	6.40
2	3.51	5.06

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	62	7343	6029	1100	220		
2	16	6733	5413	1100	220		
3	17	5661	4341	1100	220		
4	20	4889	4581	88	220		
5	33	4196	3976	0	220		
6	20	3427	3209	0	218		

ENTER NUMBER OF WEEKLY PERMUTATIONS  
5

SIMULATION DESCRIPTION:  
APRIL CONFIGURATION, WEEK 2, NO P.S. CALC.

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 2 WEEKS: 1 ALLOCATION

INDEX= 6

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RMS RMSJ01  
STATUS MIN  
NUMBER OF ITERATIONS 46  
FIXED FOSSIL FUEL COST(\$/WK) \$10,269,629. VARIABLE FOSSIL FUEL COST(\$/WK) \$200,515.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,470,144.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	4.76	5.00
2	3.47	5.00

NUCLEAR UNIT DISPATCHING:		DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
INTERVAL	WEIGHTING FACTOR (HOURS)						
1	05	7534	6214	1100	220		
2	14	6898	5578	1100	220		
3	15	5881	4561	1100	220		
4	22	5107	3787	1100	220		
5	31	4403	3083	1100	220		
6	21	3595	2717	660	218		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 2 WEEKS; 2 ALLOCATION

INDEX= 7

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS001  
STATUS MIN  
NUMBER OF ITERATIONS 53  
FIXED FOSSIL FUEL COST(\$/WK) \$10,269,629. VARIABLE FOSSIL FUEL COST(\$/WK) \$287,750.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,557,379.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	4.84	5.08
2	3.53	5.08

NUCLEAR UNIT DISPATCHING:		DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
INTERVAL	WEIGHTING FACTOR (HOURS)						
1	05	7534	6214	1100	220		
2	14	6898	5578	1100	220		
3	15	5881	4561	1100	220		
4	22	5107	3787	1100	220		
5	31	4403	3299	894	220		
6	21	3595	3223	154	218		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 2 WEEKS; 3 ALLOCATION

INDEX= 8

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS001  
STATUS MIN  
NUMBER OF ITERATIONS 59  
FIXED FOSSIL FUEL COST(\$/WK) \$10,269,629. VARIABLE FOSSIL FUEL COST(\$/WK) \$385,117.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,654,746.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	5.80	6.09
2	3.74	5.39

NUCLEAR UNIT DISPATCHING:		DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
INTERVAL	WEIGHTING FACTOR (HOURS)						
1	05	7534	6214	1100	220		

2	14	6898	5578	1100	220
3	15	5881	4561	1100	220
4	22	5107	3787	1100	220
5	31	4403	3754	429	220
6	21	3595	3377	0	218

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 2 WEEKS: 4 ALLOCATION

INDEX= 9

L.P. PARAMETERS  
 OBJECTIVE FUNCTION COST  
 RMS RMS001  
 STATUS MIN  
 NUMBER OF ITERATIONS 61  
 FIXED FOSSIL FUEL COST(\$/WK) \$10,269,629. VARIABLE FOSSIL FUEL COST(\$/WK) \$490,678.  
 SYSTEM COST WITHOUT PUMPED STORAGE, \$10,760,257.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	6.10	6.43
2	3.74	5.39

NUCLEAR UNIT DISPATCHING: INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
1	65	7534	6214	1100	220		
2	14	6898	5578	1100	220		
3	15	5881	4561	1100	220		
4	22	5107	4090	797	220		
5	31	4403	4098	86	220		
6	21	3595	3377	0	218		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 2 WEEKS: 5 ALLOCATION

INDEX= 10

L.P. PARAMETERS  
 OBJECTIVE FUNCTION COST  
 RMS RMS001  
 STATUS MIN  
 NUMBER OF ITERATIONS 65  
 FIXED FOSSIL FUEL COST(\$/WK) \$10,269,629. VARIABLE FOSSIL FUEL COST(\$/WK) \$602,553.  
 SYSTEM COST WITHOUT PUMPED STORAGE, \$10,872,183.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	6.47	6.79
2	3.74	5.39

NUCLEAR UNIT DISPATCHING: INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
1	65	7534	6214	1100	220		
2	14	6898	5578	1100	220		
3	15	5881	4610	1051	220		
4	22	5107	4724	163	220		
5	31	4403	4183	0	220		

6 21 3595 3377 0 219

ENTER NUMBER OF WEEKLY PERMUTATIONS  
5

SIMULATION DESCRIPTION:  
APRIL CONFIGURATION, WEEK 3, NO P.S. CALC.

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 3 WEEKS: 1 ALLOCATION

INDEX= 11

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS001  
STATUS MIN  
NUMBER OF ITERATIONS 45  
FIXED FOSSIL FUEL COST(\$/WK) \$9,666,127. VARIABLE FOSSIL FUEL COST(\$/WK) \$156,900.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,821,028.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)	OCNP (MILLS/KWH)
1	4.44	4.65
2	3.24	4.66

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)
1	61	7013	5693	1100	220	...
2	17	6309	4989	1100	220	...
3	15	5309	3989	1100	220	...
4	19	4634	3314	1100	220	...
5	39	3845	2525	1100	220	...
6	17	3096	2322	556	218	...

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 3 WEEKS: 2 ALLOCATION

INDEX= 12

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS001  
STATUS MIN  
NUMBER OF ITERATIONS 54  
FIXED FOSSIL FUEL COST(\$/WK) \$9,666,127. VARIABLE FOSSIL FUEL COST(\$/WK) \$240,297.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,906,335.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)	OCNP (MILLS/KWH)
1	4.76	5.00
2	3.47	5.00

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)
1	61	7013	5693	1100	220	...
2	17	6309	4989	1100	220	...
3	15	5309	3989	1100	220	...
4	19	4634	3314	1100	220	...
5	39	3845	2525	1100	220	...
6	17	3096	2322	556	218	...

- 425 -

1	61	7013	5693	1100	220
2	17	6309	4989	1100	220
3	15	5309	3989	1100	220
4	19	4634	3314	1100	220
5	39	3845	2802	823	220
6	17	3096	2705	173	218

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 3 WEEK: 3 ALLOCATION

INDEX= 13

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RMS001  
STATUS MIN  
NUMBER OF ITERATIONS 58  
FIXED FOSSIL FUEL COST(\$/WK) \$9,666,127. VARIABLE FOSSIL FUEL COST(\$/WK) 9327,193.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,993,321.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	4.79	5.03
2	3.49	5.03

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	61	7013	5693	1100	220		
2	17	6309	4989	1100	220		
3	15	5309	3989	1100	220		
4	19	4634	3314	1100	220		
5	39	3845	3176	449	220		
6	17	3096	2866	12	219		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 3 WEEK: 4 ALLOCATION

INDEX= 14

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RMS001  
STATUS MIN  
NUMBER OF ITERATIONS 65  
FIXED FOSSIL FUEL COST(\$/WK) \$9,666,127. VARIABLE FOSSIL FUEL COST(\$/WK) 9418,848.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,084,976.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	5.56	5.83
2	3.49	5.03

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	61	7013	5693	1100	220		
2	17	6309	4989	1100	220		
3	15	5309	3989	1100	220		
4	19	4634	3510	904	220		

5	39	3845	3920	105	220
6	17	3096	2878	0	218

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 3 WEEKS; 5 ALLOCATION

INDEX# 15

L.P. PARAMETERS  
 OBJECTIVE FUNCTION COST  
 RMS RMS001  
 STATUS MIN  
 NUMBER OF ITERATIONS 70  
 FIXED FOSSIL FUEL COST(\$/WK) \$9,466,127. VARIABLE FOSSIL FUEL COST(\$/WK) \$523,724.  
 SYSTEM COST WITHOUT PUMPED STORAGE, \$10,189,852.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	4.10	6.40
2	3.49	5.03

NUCLEAR UNIT DISPATCHING:						
INTERVAL	WEIGHTING FACTOR	DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3
	(HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)
1	61	7013	5693	1100	220	
2	17	6309	4984	1100	220	
3	15	5309	4090	999	220	
4	19	4634	4124	299	220	
5	39	3845	3625	0	220	
6	17	3096	2878	0	218	

ENTER NUMBER OF WEEKLY PERMUTATIONS  
5

SIMULATION DESCRIPTION:  
APRIL CONFIGURATION, WEEK 4, NO P.S. CALC.

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 4 WEEKS; 1 ALLOCATION

INDEX# 16

L.P. PARAMETERS  
 OBJECTIVE FUNCTION COST  
 RMS RMS001  
 STATUS MIN  
 NUMBER OF ITERATIONS 45  
 FIXED FOSSIL FUEL COST(\$/WK) \$8,935,281. VARIABLE FOSSIL FUEL COST(\$/WK) \$164,471.  
 SYSTEM COST WITHOUT PUMPED STORAGE, \$9,099,753.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	4.25	4.46
2	3.10	4.46

NUCLEAR UNIT DISPATCHING:						
INTERVAL	WEIGHTING FACTOR	DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3

	(HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)
1	60	6345	5025	1100	220	
2	15	5505	4185	1100	220	
3	20	4641	3321	1100	220	
4	22	3762	2442	1100	220	
5	39	3077	1757	1100	220	
6	12	2260	1713	330	217	

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 4 WEEKS; 2 ALLOCATION

INDEX= 17

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RMS001  
STATUS MIN  
NUMBER OF ITERATIONS 54  
FIXED FOSSIL FUEL COST(\$/WK) 88,935,281. VARIABLE FOSSIL FUEL COST(\$/WK) 244,227.  
SYSTEM COST WITHOUT PUMPED STORAGE, 89,179,509.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)	OCNP (MILLS/KWH)
1	4.44	4.66
2	3.24	4.66

NUCLEAR UNIT DISPATCHING:							
INTERVAL	WEIGHTING FACTOR	DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
	(HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	60	6345	5025	1100	220		
2	15	5505	4185	1100	220		
3	20	4641	3321	1100	220		
4	22	3762	2442	1100	220		
5	39	3077	2100	757	220		
6	12	2260	2043	0	217		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 4 WEEKS; 3 ALLOCATION

INDEX= 18

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RMS001  
STATUS MIN  
NUMBER OF ITERATIONS 60  
FIXED FOSSIL FUEL COST(\$/WK) 88,935,281. VARIABLE FOSSIL FUEL COST(\$/WK) 325,575.  
SYSTEM COST WITHOUT PUMPED STORAGE, 89,260,856.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TH)	OCNP (MILLS/KWH)
1	4.54	4.77
2	3.24	4.66

NUCLEAR UNIT DISPATCHING:							
INTERVAL	WEIGHTING FACTOR	DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
	(HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	60	6345	5025	1100	220		
2	15	5505	4185	1100	220		
3	20	4641	3321	1100	220		



4	22	3762	2469	1074	220
5	39	3077	2529	328	220
6	12	2260	2043	0	217

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 4 WEEKS: 4 ALLOCATION

INDEX= 19

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS01  
STATUS MIN  
NUMBER OF ITERATIONS 65  
FIXED FOSSIL FUEL COST(\$/WK) \$8,935,281. VARIABLE FOSSIL FUEL COST(\$/WK) \$411,544.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,346,825.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	4.76	5.33
2	3.24	4.66

INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
1	60	6345	5025	1100	220		
2	15	5505	4185	1100	220		
3	20	4641	3321	1100	220		
4	22	3762	2705	837	220		
5	39	3077	2840	17	220		
6	12	2260	2043	0	217		

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 4 WEEKS: 5 ALLOCATION

INDEX= 20

L.P. PARAMETERS  
OBJECTIVE FUNCTION COST  
RHS RHS01  
STATUS MIN  
NUMBER OF ITERATIONS 74  
FIXED FOSSIL FUEL COST(\$/WK) \$8,935,281. VARIABLE FOSSIL FUEL COST(\$/WK) \$499,793.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,435,075.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	5.13	5.39
2	3.24	4.66

INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
1	60	6345	5025	1100	220		
2	15	5505	4185	1100	220		
3	20	4641	3342	1079	220		
4	22	3762	3443	99	220		
5	39	3077	2857	0	220		
6	12	2260	2043	0	217		

ENTER P.S. MODE AND P.S. CODE

QUICK 1

ENTER PUMPED STORAGE PARAMETERS:  
300 .7 160 93.0 2300 7600 1 200

CAPACITY, RATIO, CAP\_PUMP, RESERVOIR, FPEE, START, BYE, TOLERANCE

ENTER NUMBER OF WEEKLY PERMUTATIONS  
5

SIMULATION DESCRIPTION:  
\*MAY CONFIGURATION, WEEK 5, NO P.S. CALC.\*

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK: 1 ALLOCATION

INDEX# 21

L.P. PARAMETERS

OBJECTIVE FUNCTION	COST
RHS	RHS001
STATUS	MIN
NUMBER OF ITERATIONS	43

FIXED FOSSIL FUEL COST(\$/WK) 39,552,238. VARIABLE FOSSIL FUEL COST(\$/WK) 9123,774.  
SYSTEM COST WITHOUT PUMPED STORAGE, 39,676,013.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	4.64	4.87
2	3.93	4.87

NUCLEAR UNIT DISPATCHING:		DEMAND	FOSSIL	NUCLEAR 1	NUCLEAR 2	NUCLEAR 3	...
INTERVAL	WEIGHTING FACTOR (HOURS)	(MW)	(MW)	(MW)	(MW)	(MW)	
1	62	7269	5729	1100	440		
2	17	6433	4993	1100	440		
3	14	5567	4027	1100	440		
4	23	4841	3301	1100	440		
5	39	4065	2525	1100	440		
6	14	3323	2448	140	435		

OPTIMAL NUCLEAR GENERATION SCHEDULE

FOR 1 WEEK: 2 ALLOCATION

INDEX# 22

L.P. PARAMETERS

OBJECTIVE FUNCTION	COST
RHS	RHS001
STATUS	MIN
NUMBER OF ITERATIONS	51

FIXED FOSSIL FUEL COST(\$/WK) 39,552,238. VARIABLE FOSSIL FUEL COST(\$/WK) 8210,689.  
SYSTEM COST WITHOUT PUMPED STORAGE, 39,762,328.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	4.79	5.03
2	4.05	5.03

- 130 -

NUCLEAR UNIT DISPATCHING:						
INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)
1	62	7269	5729	1100	440	
2	17	6533	4993	1100	440	
3	14	5567	4027	1100	440	
4	23	4841	3301	1100	440	
5	38	4065	2847	778	440	
6	14	3323	2811	77	435	

OPTIMAL NUCLEAR GENERATION SCHEDULE FOR 1 WEEK: 3 ALLOCATION INDEX= 23

L.P. PARAMETERS

OBJECTIVE FUNCTION COST  
RHS RMSC01  
STATUS MIN

NUMBER OF ITERATIONS 57

FIXED FOSSIL FUEL COST(\$/WK) \$9,552,238. VARIABLE FOSSIL FUEL COST(\$/WK) \$297,833.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,850,072.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	5.00	5.25
2	4.05	5.03

NUCLEAR UNIT DISPATCHING:						
INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)
1	62	7269	5729	1100	440	
2	17	6533	4993	1100	440	
3	14	5567	4027	1100	440	
4	23	4841	3301	1100	440	
5	38	4065	3275	350	440	
6	14	3323	2888	0	435	

OPTIMAL NUCLEAR GENERATION SCHEDULE FOR 1 WEEK: 4 ALLOCATION INDEX= 24

L.P. PARAMETERS

OBJECTIVE FUNCTION COST  
RHS RMSC01  
STATUS MIN

NUMBER OF ITERATIONS 64

FIXED FOSSIL FUEL COST(\$/WK) \$9,552,238. VARIABLE FOSSIL FUEL COST(\$/WK) \$393,939.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,946,178.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	OCNP (MILLS/KWH)
1	5.80	6.09
2	4.05	5.03

NUCLEAR UNIT DISPATCHING:						
INTERVAL	WEIGHTING FACTOR (HOURS)	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)
1	62	7269	5729	1100	440	

2	17	6533	4993	1100	440
3	14	5567	4027	1100	440
4	23	4841	3544	857	440
5	38	4065	3584	41	440
6	14	3323	2888	0	435

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 1 WEEK: 5 ALLOCATION  
L.P. PARAMETERS

INDEX= 25

OBJECTIVE FUNCTION COST  
RHS RMSC01  
STATUS MIN  
NUMBER OF ITERATIONS 70  
FIXED FOSSIL FUEL COST(\$/WK) \$9,552,235. VARIABLE FOSSIL FUEL COST(\$/WK) \$503,535.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$10,055,774.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	6.47	6.79
2	4.05	5.03

NUCLEAR UNIT DISPATCHING:  
INTERVAL WEIGHTING FACTOR (HOURS)

	DEMAND (MW)	FOSSIL (MW)	NUCLEAR 1 (MW)	NUCLEAR 2 (MW)	NUCLEAR 3 (MW)	...
1	62	5729	1100	440		
2	17	4553	1100	440		
3	14	5567	1043	440		
4	23	4841	207	440		
5	38	4065	0	440		
6	14	3323	0	435		

ENTER NUMBER OF WEEKLY PERMUTATIONS  
5

SIMULATION DESCRIPTION:  
MAY CONFIGURATION, WEEK 6, NO P.S. CALC.

OPTIMAL NUCLEAR GENERATION SCHEDULE  
FOR 2 WEEKS: 1 ALLOCATION  
L.P. PARAMETERS.

INDEX= 26

OBJECTIVE FUNCTION COST  
RHS RMSC01  
STATUS MIN  
NUMBER OF ITERATIONS 42  
FIXED FOSSIL FUEL COST(\$/WK) \$9,078,835. VARIABLE FOSSIL FUEL COST(\$/WK) \$164,254.  
SYSTEM COST WITHOUT PUMPED STORAGE, \$9,242,890.

REACTOR	NUCLEAR L.P. OPPORTUNITY COST (\$/MILLION BTU-TM)	JCNP (MILLS/KWH)
1	4.44	4.66
2	3.76	4.66

APPENDIX D: ALLOCAT

D.1 Input Specifications

Input Variable Names listed by order of input on file

SYSIN:

NCF: Overall nuclear capacity factor for the planning period.

WEEKS: Number of weeks in the planning period.

LENGTH: One more than the maximum number of OCNP data points in a weekly curve.

KEY= 'SAME', if all weekly sets of OCNP values are obtained from a single set of weekly nuclear capacity factors; else KEY=(any four characters).

N=number of OCNP values in weekly representation

INTERVALS(N)=interval spacing of OCNP values

OCNP(N)=OCNP data values

If KEY≠'SAME' then the last three variables are repeated WEEKS times. If KEY='SAME' then N and INTERVALS need be listed only once.

NOTES: The number of OCNP data points for each week need not be the same. The algorithm is given in Section 4.3.

```

// EXEC PLIXCLG,
// PARM.C='NAG,NOFSD,      NOP,NSTG,NX,NS,NA',
// PARM.L='LIST,MAP,DCBS',
// PARM.G='REPORT,ISASIZE(1)'
//C.SYSIN DD *,DCB=BLKSIZE=2000
  ALLOCAT : PROC OPTIONS(MAIN);
  DCL KEY CHAR(4);
  DCL (NCF) FIXED DEC(6,2), (WEEKS,LENGTH) FIXED DEC;
  ON ENDFILE(SYSIN) GO TO BOTTCM;
  TOP:
  GET LIST (NCF, WEEKS, LENGTH, KEY);
  PUT DATA (NCF, WEEKS, LENGTH, KEY);
  NCF=NCF*WEEKS;
  BLOCK: BEGIN;
  DCL ( INCR(WEEKS,LENGTH), OCNP(WEEKS,LENGTH),MASK1(WEEKS),
  MASK2(WEEKS), MASK3(WEEKS), MASK4(WEEKS), MAX) FIXED DEC(6,2),
  (INDEX(WEEKS) ,NUMBER, I, J, K ) FIXED BIN;
  OCNP,INCR=0;
  PUT EDIT(' OCNP TABLE FOLLOWS:')(A) SKIP(2);
  DO I=1 TO WEEKS;
  IF (I>1) & (KEY='SAME')      THEN DO;
  DO J=1 TO NUMBER;
  INCR(I,J)=INCR(I,J);
  END;
  GO TO READ;
  END;
  GET LIST(NUMBER);
  GET LIST((INCR(I,J) DO J=1 TC NUMBER));
  READ:
  GET LIST((OCNP(I,J) DO J=1 TC NUMBER));
  PUT EDIT((OCNP(I,J) DO J=1 TC NUMBER))( 18 F(7,2))SKIP;
  MASK1(I)=INCR(I,1);
  MASK2(I)=INCR(I,2);
  MASK3(I)=OCNP(I,1);
  MASK4(I)=OCNP(I,2);
  INDEX(I)=2;

```

```

ALLC0001
ALLC0002
ALLC0003
ALLC0004
ALLC0005
ALLC0006
ALLC0007
ALLC0008
ALLC0009
ALLC0010
ALLC0011
ALLC0012
ALLC0013
ALLC0014
ALLC0015
ALLC0016
ALLC0017
ALLC0018
ALLC0019
ALLC0020
ALLC0021
ALLC0022
ALLC0023
ALLC0024
ALLC0025
ALLC0026
ALLC0027
ALLC0028
ALLC0029
ALLC0030
ALLC0031
ALLC0032
ALLC0033
ALLC0034
ALLC0035
ALLC0036

```

D.2 Program Listing and Sample Input

```

END;
PUT EDIT(' INCREMENTAL STEP TABLE FOLLOWS:')(A) SKIP(2);
DO I=1 TO WEEKS;
PUT EDIT((INCR(I,J) DO J=1 TO LENGTH))( 18 F(7,2))SKIP;
END;
NCF=NCF-SUM(MASK1);
DO J=1 TO (LENGTH-1)*WEEKS;
MAX=MASK4(1);
NUMBER=1;
DO I=2 TO WEEKS;
IF MAX < MASK4(I) THEN DO;
  MAX=MASK4(I);
  NUMBER=I;
END;
END;
NCF=NCF-MASK2(NUMBER);
MASK1(NUMBER)=MASK1(NUMBER)+MASK2(NUMBER);
MASK3(NUMBER)=MAX;
IF NCF>0 THEN GO TO BOT;
IF NCF=0 THEN GO TO SOLN;
MASK1(NUMBER)=MASK1(NUMBER)+NCF;
GO TO SOLN;
BOT:
INDEX(NUMBER)=INDEX(NUMBER)+1;
  MASK2(NUMBER)=INCR(NUMBER,INDEX(NUMBER));
  MASK4(NUMBER)=OCNP(NUMBER,INDEX(NUMBER));
END;
SOLN:
PUT EDIT(' INTER-WEEKLY OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIB
UTION')(A) PAGE;
PUT EDIT(' WEEKS', 'CAPACITY FACTORS', 'OCNP')( 3(A,X(5)))SKIP;
DO K=1 TO WEEKS;
PUT EDIT(K,MASK1(K), MASK3(K))( F(5),X(12),F(6,2),X(7),F(6,2))SKIP;
END;
END BLOCK;
PUT PAGE;

```

```

ALLC0037
ALLC0038
ALLC0039
ALLC0040
ALLC0041
ALLC0042
ALLC0043
ALLC0044
ALLC0045
ALLC0046
ALLC0047
ALLC0048
ALLC0049
ALLC0050
ALLC0051
ALLC0052
ALLC0053
ALLC0054
ALLC0055
ALLC0056
ALLC0057
ALLC0058
ALLC0059
ALLC0060
ALLC0061
ALLC0062
ALLC0063
ALLC0064
ALLC0065
ALLC0066
ALLC0067
ALLC0068
ALLC0069
ALLC0070
ALLC0071
ALLC0072

```

```

GO TO TOP;
BOTTOM:
END ALLOCAT ;
//L.SYSLMOD DD DSN=U.M9960.8981.LIBRARY.LOAD(ALLOCAT),DISP=OLD,
// DCB=BLKSIZE=13030,SPACE=
//G.PLIDUMP DD SYSOUT=A
//G.SYSIN DD *,DCB=BLKSIZE=2000
//G.SYSIN DD *,DCB=BLKSIZE=2000
.7 26 10 'SAME'
9 .55 .05 .05 .05 .05 .05 .05 .05 .05
6.83 6.83 6.83 6.79 6.79 6.79 6.40 6.40 6.40
6.83 6.83 6.83 6.83 6.83 6.83 6.83 6.79 6.79
6.79 6.40 6.40 6.40 6.40 6.40 6.40 6.40 6.40
6.79 6.69 6.69 6.69 6.69 6.69 5.84 5.39 5.39
7.28 6.83 6.83 6.83 6.83 6.83 6.79 6.79 6.79
6.79 6.79 6.79 6.79 6.40 6.40 6.40 6.40 6.40
6.83 6.83 6.79 6.79 6.79 6.79 6.79 6.40 6.40
7.28 7.28 6.83 6.83 6.83 6.83 6.79 6.79 6.79
6.79 6.40 6.40 6.40 6.40 6.09 6.09 6.09 6.09
6.79 6.50 6.40 6.40 6.40 6.40 6.40 6.40 6.40
6.83 6.83 6.79 6.79 6.79 6.50 6.40 6.40 6.40
6.40 6.40 6.40 6.40 6.40 6.40 6.40 6.09 6.09
6.40 6.40 6.09 6.09 6.09 6.09 6.09 6.09 6.09
5.25 5.23 5.08 5.06 5.03 5.03 5.03 5.03 5.00
6.83 6.83 6.79 6.79 6.79 6.79 6.40 6.40 6.40
6.79 6.79 6.40 6.40 6.40 6.40 6.09 6.09 6.09
6.83 6.83 6.83 6.79 6.79 6.79 6.79 6.50 6.40
6.83 6.79 6.79 6.79 6.79 6.40 6.40 6.40 6.40
8.86 8.83 8.83 8.49 8.49 8.30 8.30 7.74 7.74
7.74 7.28 7.28 6.83 6.83 6.83 6.83 6.83 6.83
7.74 7.28 7.28 6.83 6.83 6.83 6.83 6.83 6.83
8.86 8.83 8.83 8.83 8.49 8.30 8.30 7.74 7.74
6.40 6.40 6.40 6.40 6.40 6.09 6.09 6.09 6.09
7.28 7.28 7.28 6.83 6.83 6.83 6.83 6.79 6.79
6.83 6.79 6.79 6.79 6.79 6.79 6.40 6.40 6.40
6.83 6.83 6.83 6.79 6.79 6.79 6.79 6.50 6.40

```

```

ALLC0073
ALLC0074
ALLC0075
ALLC0076
ALLC0077
ALLC0078
ALLC0079
ALLC0080
ALLC0081
ALLC0082
ALLC0083
ALLC0084
ALLC0085
ALLC0086
ALLC0087
ALLC0088
ALLC0089
ALLC0090
ALLC0091
ALLC0092
ALLC0093
ALLC0094
ALLC0095
ALLC0096
ALLC0097
ALLC0098
ALLC0099
ALLC0100
ALLC0101
ALLC0102
ALLC0103
ALLC0104
ALLC0105
ALLC0106
ALLC0107
ALLC0108

```





INTER-WEEKLY OPTIMAL WEEKLY NUCLEAR CAPACITY FACTOR DISTRIBUTION

WEEKS	CAPACITY FACTORS	OCNP
1	0.80	6.79
2	0.95	6.79
3	0.55	6.79
4	0.55	6.09
5	0.95	6.79
6	0.70	6.79
7	0.80	6.79
8	0.90	6.83
9	0.55	6.79
10	0.55	6.79
11	0.60	6.83
12	0.55	6.40
13	0.55	6.40
14	0.55	5.25
15	0.60	6.83
16	0.55	6.79
17	0.65	6.83
18	0.55	6.83
19	0.65	7.74
20	0.95	6.83
21	0.95	6.83
22	0.95	7.74
23	0.55	6.40
24	0.85	6.83
25	0.55	6.83
26	0.65	6.83

Appendix E: Effect of Time Value of Money

An experiment was made in which the result of optimizing a system for minimum discounted production cost was compared with result of optimizing the the system for minimum undiscounted production cost. Although the optimum system generation schedules for the two cases were quite different, a comparison of discounted production costs for both schedules showed that they were practically identical. In summary, disregarding the time value of money has very little effect on the financial consequences of the short-range optimization.

A system of four units with a system capacity of 2400 MWe of which 44% was nuclear was studied over a one-year time horizon with a discount factor of 8%. Table E.1 lists the parameters used. The time horizon used in this study was one year, consisting of 26 equal time intervals. The biweekly electric system demand was obtained by using 1% of the total biweekly demand of electricity of the United States, from June 1971 to May 1972 (15). The system under consideration consisted of two 536 MWe nuclear plants, each with the heat-rate vs. % power characteristics given in Table E.1 and two 670 MWe fossil plants with the heat-rate vs. % power characteristics given there. These average heat-rate characteristics are those recommended by Commonwealth Edison. The cost of heat to each nuclear plant was taken as 0.45 mills/KWht; to fossil unit No. 1, 1.8 mills/KWht; and to fossil unit No. 2, 2.0 mills/KWht.

TABLE E.1

PARAMETERS OF THE COST OF MONEY EXPERIMENT

<u>PERIOD</u>	<u>BIWEEKLY (10<sup>6</sup>KWH) DEMAND</u>	<u>2 Identical Fossil Units</u> 670 MWe capacity				
1	617					
2	669	% Power	33%	50%	70%	100%
3	665	Heat Rate	9,920	9,340	8,980	8,950
4	666					
5	638	Unit 1:	1.8 mills/KWht fuel cost			
6	667	Unit 2:	2.0 mills/KWht fuel cost			
7	657					
8	654	<u>2 Identical Nuclear Units</u> 536 MWe capacity				
9	613					
10	594					
11	590	% Power	30%	50%	70%	100%
12	606	Heat Rate (Btu/Kwhr)	13,200	11,800	11,000	10,500
13	603					
14	635					
15	631	Unit 3:	refuel date, period No. 20			
16	619		before refueling, 77% avg capacity factor			
17	654		after refueling, 99% avg capacity factor			
18	670					
19	645	Unit 4:	refuel date, period No. 10			
20	645		before refueling, 72% avg capacity factor			
21	638		after refueling, 96% avg capacity factor			
22	628					
23	629					
24	625					
25	615	Average cost of Nuclear Heat	0.45 mills/KWht			
26	638					

- 044 -

Thermal energy available in one nuclear unit (No. 3) was limited to 8.5 million MWhT, prior to scheduled refueling in biweekly period No. 20. After refueling, this unit was assumed available 99% of the time. The thermal energy available in the second nuclear unit (No. 4) was limited to 4.0 million MWhT prior to refueling in biweekly period No. 10. After refueling, this unit was assumed to be available 96% of the time. Refueling downtime was neglected.

The method of optimization used was linear programming, IBM's MPSX program product. The objective function was the variable costs of this system, assumed to be the cost of the fuel for the fossil plants and the income tax depreciation credit for the nuclear heat utilized.

The solution of the optimization studies is displayed as follows: in Figures E.1 and E.2, the solid lines plot the biweekly generation distribution for each of the system's units for the case of no discounting, i.e., zero effective cost of money; and, the dashed lines display the case of discounting both the fossil fuel costs and the nuclear fuel tax credits.

From the comparison of the solid and dashed lines, notice that the effect of the discounting is to shift the assignment of the fossil units to operate at lower capacity factors in the earlier time intervals and at higher capacity in the later time intervals. Correspondingly, the nuclear units are operating at higher capacity factors in the earlier time periods. This is not surprising because




Figure E.1 FOSSIL PRODUCTION SCHEDULE

Legend  
 — no discounting production schedule  
 - - - production shift due to discounting




Figure E.2 NUCLEAR PRODUCTION SCHEDULE

Legend  
 — no discounting production schedule  
 --- production shift due to discounting

Objective Function  
 no discounting, \$29.5 million  
 with discounting, \$29.4 million

discounting naturally has the effect of postponing cash outflows as much as possible and taking tax credits as soon as possible.

But what is the magnitude of this effect? Is it of concern where the largest time period in our studies is only one year? The change in the objective function from the comparison of the total-discounting case with the no-discounting case was 0.31%. But for a system where the average customer demand is about 10,000 MWe and the nuclear plants supplied about 48% of the power, the use of discounting represents a saving of about half million dollars per year. However, the frequent fluctuations of the market price of fossil fuel and the stochastic nature of the customer demand function introduces error bounds larger than the savings involved. As large as this savings may sound economically, the reliability considerations as mentioned in Section 2.4 subjectively outweigh the savings of distorting the production schedule to favor nuclear utilization early in time over later periods of time.

Even though discounting is a very important factor in considering alternatives in the mid-range horizon, its use in the short-range is considered to be swamped by reliability concerns caused by the random statistical nature of events in the short-run (160). Hence, discounting has not been taken into account in the present short-range studies.



Appendix F: FOSSIL

F.1 Input Specifications

Input variables listed by order of input on file SYSIN:

N= number of time intervals in weekly load model.

N1= number of increments in the fossil economic loading order.

NN= number of weeks using the same loading order.

NUMBER= number of nuclear energy values to be read.

DEMAND(NN,N)= array containing the modified customer demand functions.

TIME(NN,N)= array containing the number of hours each time interval (in the load model) represents.

NUCLEAR(NUMBER)= array containing the nuclear energies(MWe).

Economic Loading Order= use card output from PROCOST.

The items of interest on the cards are the cumulative interval sizes(MW), incremental fuel cost (mills/KWHe), and the cumulative generation cost (\$/HR).

For multiple cases, the whole set of variables is repeated for each set of fossil configurations.

The sample input (Appendix F.2) is a portion of that used for Case 4. The sample output (Appendix F.3) is the entire output of FOSSIL for Case 4. The OCNP values obtained from the FOSSIL output are the same as those used in the sample input to ALLOCAT, in Appendix D.2.

```

// EXEC PLIXCGO
//C.SYSIN DD *,DCB=BLKSIZE=2000
FOSSIL: PROC OPTIONS(MAIN);
  DCL (N,N1,NN,NUMBER)FIXED BIN;
  ON ENDFILE(SYSIN) GO TO BOTTOM;
  TOP: GET LIST( N, N1, NN, NUMBER) COPY;

BLOCK: BEGIN;
DCL CCNP FLOAT DEC(16) ;
DCL (DEMAND(NN,N), TIME(NN,N), NTEMP, C_STEP(N1), NUCLEAR(NUMBER) )
FIXED BIN(31), TOTAL FIXED DEC (15,2);
DCL (FUEL(N1), C_FUEL(N1) ) FIXED DEC(15,2);
  GET LIST (DEMAND, TIME, NUCLEAR) COPY;
DO I=1 TO N1;
GET EDIT( C_STEP(I), FUEL(I), C_FUEL(I) )(SKIP,X(15), F(10), F(10,2),
F(15) );
END;
DO J=1 TO NN;
DO M=1 TO NUMBER;
PUT SKIP DATA(NUCLEAR(M));
TOTAL=0;
OCNP=0;
DO I=1 TO N;
NTEMP= DEMAND(J, I) - NUCLEAR(M);
OCNP=OCNP+NTEMP*TIME(J, I);
DO K=N1 TO 1 BY -1 WHILE(NTEMP < C_STEP(K));
END;
  IF K=0 THEN TOTAL=TOTAL+NTEMP*FUEL(K+1)*TIME(J, I); ELSE
TOTAL=TOTAL+TIME(J, I)
      *((NTEMP-C_STEP(K))*FUEL(K+1)+C_FUEL(K));
END;
OCNP=OCNP/168.;
DO K=1 TO N1 WHILE(OCNP > C_STEP(K));
END;
OCNP= FUEL(K);
PUT SKIP;

```

```

FOSS0001 F.2
FOSS0002 Program
FOSS0003 Listing
FOSS0004 and
FOSS0005 Sample
FOSS0006 Input
FOSS0007
FOSS0008
FOSS0009
FOSS0010
FOSS0011
FOSS0012
FOSS0013
FOSS0014
FOSS0015
FOSS0016
FOSS0017
FOSS0018
FOSS0019
FOSS0020
FOSS0021
FOSS0022
FOSS0023
FOSS0024
FOSS0025
FOSS0026
FOSS0027
FOSS0028
FOSS0029
FOSS0030
FOSS0031
FOSS0032
FOSS0033
FOSS0034
FOSS0035
FOSS0036

```

```

PUT DATA(      M,J,TOTAL,OCNP);
PUT FILE(PUNCH) EDIT(OCNP)(F(8,2));
END;
PUT SKIP FILE(PUNCH);
END BLOCK;
GO TO TOP;
BOTTCM:
END FOSSIL;

```

```
//G.SYSIN DD *,DCB=BLKSIZE=2000
```

```

6 61 4 9
7348 6733 5661 4889 4196 3427
7534 6898 5881 5107 4403 3595
7013 6309 5309 4634 3845 3096
6345 5505 4641 3762 3077 2260
62 16 17 20 33 20
65 14 15 22 31 21
61 17 15 19 39 17
60 15 20 22 39 12
755 816 878 943 1004 1070 1133 1194 1254
1 105 105 2.85 299
2 105 210 3.00 614
3 105 315 3.20 950
4 320 635 3.40 2038
5 320 955 3.58 3184
6 320 1275 3.82 4405
7 120 1395 4.07 4894
8 43 1438 4.16 5073
9 120 1558 4.29 5587
10 116 1674 4.43 6101
11 43 1717 4.46 6293
12 80 1797 4.53 6655
13 120 1917 4.57 7204
14 60 1977 4.63 7481
15 116 2093 4.66 8022
16 135 2228 4.66 8652
17 135 2363 4.66 9281

```

```

FOSS0037
FOSS0038
FOSS0039
FOSS0040
FOSS0041
FOSS0042
FOSS0043
FOSS0044
FOSS0045
FOSS0046
FOSS0047
FOSS0048
FOSS0049
FOSS0050
FOSS0051
FOSS0052
FOSS0053
FOSS0054
FOSS0055
FOSS0056
FOSS0057
FOSS0058
FOSS0059
FOSS0060
FOSS0061
FOSS0062
FOSS0063
FOSS0064
FOSS0065
FOSS0066
FOSS0067
FOSS0068
FOSS0069
FOSS0070
FOSS0071
FOSS0072

```

18	43	2406	4.72	9484	FOSS0073
19	43	2449	4.72	9687	FOSS0074
20	80	2529	4.77	10068	FOSS0075
21	60	2589	4.96	10366	FOSS0076
22	116	2705	4.97	10943	FOSS0077
23	135	2840	5.00	11618	FOSS0078
24	168	3008	5.03	12462	FOSS0079
25	168	3176	5.03	13307	FOSS0080
26	43	3219	5.06	13524	FOSS0081
27	80	3299	5.08	13931	FOSS0082
28	43	3342	5.25	14156	FOSS0083
29	168	3510	5.39	15062	FOSS0084
30	60	3570	5.84	15412	FOSS0085
31	520	4090	6.09	18577	FOSS0086
32	520	4610	6.40	21907	FOSS0087
33	96	4706	6.79	22559	FOSS0088
34	96	4802	6.79	23211	FOSS0089
35	520	5322	6.83	26763	FOSS0090
36	96	5418	7.28	27461	FOSS0091
37	60	5478	7.74	27926	FOSS0092
38	60	5538	8.30	28424	FOSS0093
39	48	5586	8.49	28832	FOSS0094
40	48	5634	8.49	29239	FOSS0095
41	160	5794	8.83	30652	FOSS0096
42	160	5954	8.86	32070	FOSS0097
43	48	6002	9.10	32507	FOSS0098
44	56	6058	9.11	33017	FOSS0099
45	56	6114	9.11	33527	FOSS0100
46	160	6274	9.30	35014	FOSS0101
47	160	6434	9.32	36506	FOSS0102
48	260	6694	9.40	38949	FOSS0103
49	56	6750	9.76	39496	FOSS0104
50	60	6810	9.77	40082	FOSS0105
51	260	7070	9.89	42654	FOSS0106
52	160	7230	9.91	44240	FOSS0107
53	160	7390	9.94	45831	FOSS0108

54	21	7411	10.23	46046	FOSS0109
55	260	7671	10.55	48788	FOSS0110
56	21	7692	10.97	49018	FOSS0111
57	21	7713	12.91	49289	FOSS0112
58	29	7742	14.45	49708	FOSS0113
59	29	7771	15.49	50158	FOSS0114
60	29	7800	18.22	50686	FOSS0115
61	1500	9300	25.00	88186	FOSS0116

6 61 4 9  
 7348 6733 5661 4889 4196 3427  
 7534 6898 5981 5107 4403 3595  
 7613 6309 5309 4634 3845 3096  
 6345 5505 4641 3762 3077 2260  
 62 16 17 20 33 20  
 65 14 15 22 31 21  
 61 17 15 19 39 17  
 60 15 20 22 39 12  
 755 816 878 943 1004 1070 1133 1194 1254

NUCLEAR(1)=	755;					
M=	1	J=	1	TOTAL=	4356765.25	OCNP= 6.829999999999999E+00;
NUCLEAR(2)=	816;					
M=	2	J=	1	TOTAL=	4280791.29	OCNP= 6.829999999999999E+00;
NUCLEAR(3)=	878;					
M=	3	J=	1	TOTAL=	4204091.86	OCNP= 6.829999999999999E+00;
NUCLEAR(4)=	943;					
M=	4	J=	1	TOTAL=	4124322.89	OCNP= 6.789999999999999E+00;
NUCLEAR(5)=	1004;					
M=	5	J=	1	TOTAL=	4050036.07	OCNP= 6.789999999999999E+00;
NUCLEAR(6)=	1070;					
M=	6	J=	1	TOTAL=	3969810.57	OCNP= 6.789999999999999E+00;
NUCLEAR(7)=	1133;					
M=	7	J=	1	TOTAL=	3893584.73	OCNP= 6.399999999999999E+00;
NUCLEAR(8)=	1194;					
M=	8	J=	1	TOTAL=	3820676.32	OCNP= 6.399999999999999E+00;
NUCLEAR(9)=	1254;					
M=	9	J=	1	TOTAL=	3748969.61	OCNP= 6.399999999999999E+00;
NUCLEAR(1)=	755;					
M=	1	J=	2	TOTAL=	4622190.77	OCNP= 6.629999999999999E+00;
NUCLEAR(2)=	816;					
M=	2	J=	2	TOTAL=	4542848.02	OCNP= 6.829999999999999E+00;
NUCLEAR(3)=	878;					
M=	3	J=	2	TOTAL=	4463613.90	OCNP= 6.829999999999999E+00;
NUCLEAR(4)=	943;					
M=	4	J=	2	TOTAL=	4381899.37	OCNP= 6.829999999999999E+00;
NUCLEAR(5)=	1004;					
M=	5	J=	2	TOTAL=	4305680.05	OCNP= 6.829999999999999E+00;
NUCLEAR(6)=	1070;					
M=	6	J=	2	TOTAL=	4223667.11	OCNP= 6.829999999999999E+00;
NUCLEAR(7)=	1133;					
M=	7	J=	2	TOTAL=	4146139.81	OCNP= 6.829999999999999E+00;
NUCLEAR(8)=	1194;					
M=	8	J=	2	TOTAL=	4071647.50	OCNP= 6.789999999999999E+00;
NUCLEAR(9)=	1254;					
M=	9	J=	2	TOTAL=	3998435.75	OCNP= 6.789999999999999E+00;
NUCLEAR(1)=	755;					
M=	1	J=	3	TOTAL=	3922184.75	OCNP= 6.789999999999999E+00;
NUCLEAR(2)=	816;					
M=	2	J=	3	TOTAL=	3849245.51	OCNP= 6.399999999999999E+00;
NUCLEAR(3)=	878;					
M=	3	J=	3	TOTAL=	3775572.87	OCNP= 6.399999999999999E+00;
NUCLEAR(4)=	943;					
M=	4	J=	3	TOTAL=	3699452.60	OCNP= 6.399999999999999E+00;
NUCLEAR(5)=	1004;					
M=	5	J=	3	TOTAL=	3628424.77	OCNP= 6.399999999999999E+00;
NUCLEAR(6)=	1070;					
M=	6	J=	3	TOTAL=	3552211.78	OCNP= 6.399999999999999E+00;
NUCLEAR(7)=	1133;					

APPENDIX F.3 SAMPLE OUTPUT FROM FOSSIL



M= 3	J= 2	TOTAL=	3579929.58	OCNP= 6.789999999999999E+00;
NUCLEAR(4)= 1163;	J= 2	TOTAL=	3503182.82	OCNP= 6.789999999999999E+00;
M= 4	J= 2	TOTAL=	3431732.00	OCNP= 6.399999999999999E+00;
NUCLEAR(5)= 1224;	J= 2	TOTAL=	3355881.01	OCNP= 6.399999999999999E+00;
M= 5	J= 2	TOTAL=	3284335.14	OCNP= 6.399999999999999E+00;
NUCLEAR(6)= 1290;	J= 2	TOTAL=	3216348.29	OCNP= 6.399999999999999E+00;
M= 6	J= 2	TOTAL=	3149806.31	OCNP= 6.399999999999999E+00;
NUCLEAR(7)= 1353;	J= 2	TOTAL=	3946690.52	OCNP= 6.829999999999999E+00;
M= 7	J= 3	TOTAL=	3872091.25	OCNP= 6.829999999999999E+00;
NUCLEAR(8)= 1414;	J= 3	TOTAL=	3796514.10	OCNP= 6.789999999999999E+00;
M= 8	J= 3	TOTAL=	3717908.78	OCNP= 6.789999999999999E+00;
NUCLEAR(9)= 1474;	J= 3	TOTAL=	3644872.50	OCNP= 6.789999999999999E+00;
M= 9	J= 3	TOTAL=	3566654.63	OCNP= 6.789999999999999E+00;
NUCLEAR(1)= 975;	J= 3	TOTAL=	3492533.23	OCNP= 6.789999999999999E+00;
M= 1	J= 3	TOTAL=	3421129.87	OCNP= 6.399999999999999E+00;
NUCLEAR(2)= 1036;	J= 3	TOTAL=	3352046.94	OCNP= 6.399999999999999E+00;
M= 2	J= 4	TOTAL=	4263340.76	OCNP= 7.279999999999999E+00;
NUCLEAR(3)= 1098;	J= 4	TOTAL=	4186502.10	OCNP= 7.279999999999999E+00;
M= 3	J= 4	TOTAL=	4109269.05	OCNP= 6.829999999999999E+00;
NUCLEAR(4)= 1163;	J= 4	TOTAL=	4029593.51	OCNP= 6.829999999999999E+00;
M= 4	J= 4	TOTAL=	3954849.36	OCNP= 6.829999999999999E+00;
NUCLEAR(5)= 1224;	J= 4	TOTAL=	3874047.46	OCNP= 6.829999999999999E+00;
M= 5	J= 4	TOTAL=	3797188.11	OCNP= 6.789999999999999E+00;
NUCLEAR(6)= 1290;	J= 4	TOTAL=	3723678.81	OCNP= 6.789999999999999E+00;
M= 6	J= 4	TOTAL=	3651736.67	OCNP= 6.789999999999999E+00;
NUCLEAR(7)= 1353;	J= 4	TOTAL=	3470198.13	OCNP= 6.789999999999999E+00;
M= 7	J= 5	TOTAL=	3399369.48	OCNP= 6.399999999999999E+00;
NUCLEAR(8)= 1414;	J= 5	TOTAL=	3328385.31	OCNP= 6.399999999999999E+00;
M= 8	J= 5	TOTAL=	3254914.17	OCNP= 6.399999999999999E+00;
NUCLEAR(9)= 1474;	J= 5	TOTAL=	3186948.84	OCNP= 6.399999999999999E+00;
M= 9	J= 5	TOTAL=		
NUCLEAR(1)= 975;	J= 5	TOTAL=		
M= 1	J= 5	TOTAL=		
NUCLEAR(2)= 1036;	J= 5	TOTAL=		
M= 2	J= 5	TOTAL=		
NUCLEAR(3)= 1098;	J= 5	TOTAL=		
M= 3	J= 5	TOTAL=		
NUCLEAR(4)= 1163;	J= 5	TOTAL=		
M= 4	J= 5	TOTAL=		
NUCLEAR(5)= 1224;	J= 5	TOTAL=		
M= 5	J= 5	TOTAL=		
NUCLEAR(6)= 1290;	J= 5	TOTAL=		



M=	6	J=	5	TOTAL=	3113392.44	OCNP=	6.089999999999999E+00;
NUCLEAR(7)=		1353;					
M=	7	J=	5	TOTAL=	3043383.73	OCNP=	6.089999999999999E+00;
NUCLEAR(8)=		1414;					
M=	8	J=	5	TOTAL=	2975719.28	OCNP=	6.089999999999999E+00;
NUCLEAR(9)=		1474;					
M=	9	J=	5	TOTAL=	2909906.58	OCNP=	6.089999999999999E+00;

6	52	4	9						
8015	7131	5971	4995	4140	3152				
8322	7416	6150	5172	4247	3189				
7862	6988	5833	4853	4034	3057				
7561	6693	5688	4679	3860	2899				
50	24	19	24	36	15				
52	22	20	26	36	12				
47	27	19	24	36	15				
42	28	20	23	38	17				
1195	1256	1318	1383	1444	1510	1573	1634	1694	

NUCLEAR(1)=	1195;			TOTAL=	4157854.35	OCNP=	6.789999999999999E+00;
M=	1	J=	1				
NUCLEAR(2)=	1256;			TOTAL=	4084603.37	OCNP=	6.500000000000000E+00;
M=	2	J=	1				
NUCLEAR(3)=	1318;			TOTAL=	4011345.41	OCNP=	6.399999999999999E+00;
M=	3	J=	1				
NUCLEAR(4)=	1383;			TOTAL=	3935316.96	OCNP=	6.399999999999999E+00;
M=	4	J=	1				
NUCLEAR(5)=	1444;			TOTAL=	3865075.07	OCNP=	6.399999999999999E+00;
M=	5	J=	1				
NUCLEAR(6)=	1510;			TOTAL=	3789509.28	OCNP=	6.399999999999999E+00;
M=	6	J=	1				
NUCLEAR(7)=	1573;			TOTAL=	3718210.38	OCNP=	6.399999999999999E+00;
M=	7	J=	1				
NUCLEAR(8)=	1634;			TOTAL=	3650111.78	OCNP=	6.399999999999999E+00;
M=	8	J=	1				
NUCLEAR(9)=	1694;			TOTAL=	3584006.20	OCNP=	6.399999999999999E+00;
M=	9	J=	1				
NUCLEAR(1)=	1195;			TOTAL=	4498551.54	OCNP=	6.829999999999999E+00;
M=	1	J=	2				
NUCLEAR(2)=	1256;			TOTAL=	4423197.71	OCNP=	6.829999999999999E+00;
M=	2	J=	2				
NUCLEAR(3)=	1318;			TOTAL=	4346393.40	OCNP=	6.789999999999999E+00;
M=	3	J=	2				
NUCLEAR(4)=	1383;			TOTAL=	4266130.39	OCNP=	6.789999999999999E+00;
M=	4	J=	2				
NUCLEAR(5)=	1444;			TOTAL=	4191389.17	OCNP=	6.789999999999999E+00;
M=	5	J=	2				
NUCLEAR(6)=	1510;			TOTAL=	4111026.07	OCNP=	6.500000000000000E+00;
M=	6	J=	2				
NUCLEAR(7)=	1573;			TOTAL=	4036078.78	OCNP=	6.399999999999999E+00;
M=	7	J=	2				
NUCLEAR(8)=	1634;			TOTAL=	3965460.04	OCNP=	6.399999999999999E+00;
M=	8	J=	2				
NUCLEAR(9)=	1694;			TOTAL=	3896380.97	OCNP=	6.399999999999999E+00;
M=	9	J=	2				
NUCLEAR(1)=	1195;			TOTAL=	3970680.66	OCNP=	6.399999999999999E+00;
M=	1	J=	3				
NUCLEAR(2)=	1256;			TOTAL=	3899736.56	OCNP=	6.399999999999999E+00;
M=	2	J=	3				
NUCLEAR(3)=	1318;						

M= 3	J= 3	TOTAL=	3828840.27	OCNP= 6.399999999999999E+00;
NUCLEAR(4)=	1393:			
M= 4	J= 3	TOTAL=	3754583.52	OCNP= 6.399999999999999E+00;
NUCLEAR(5)=	1444:			
M= 5	J= 3	TOTAL=	3686061.95	OCNP= 6.399999999999999E+00;
NUCLEAR(6)=	1510:			
M= 6	J= 3	TOTAL=	3612946.86	OCNP= 6.399999999999999E+00;
NUCLEAR(7)=	1573:			
M= 7	J= 3	TOTAL=	3544282.85	OCNP= 6.399999999999999E+00;
NUCLEAR(8)=	1634:			
M= 8	J= 3	TOTAL=	3478519.70	OCNP= 6.089999999999999E+00;
NUCLEAR(9)=	1694:			
M= 9	J= 3	TOTAL=	3414299.72	OCNP= 6.089999999999999E+00;
NUCLEAR(1)=	1195:			
M= 1	J= 4	TOTAL=	3592336.61	OCNP= 6.399999999999999E+00;
NUCLEAR(2)=	1256:			
M= 2	J= 4	TOTAL=	3525886.57	OCNP= 6.399999999999999E+00;
NUCLEAR(3)=	1318:			
M= 3	J= 4	TOTAL=	3459669.95	OCNP= 6.089999999999999E+00;
NUCLEAR(4)=	1383:			
M= 4	J= 4	TOTAL=	3390599.10	OCNP= 6.089999999999999E+00;
NUCLEAR(5)=	1444:			
M= 5	J= 4	TOTAL=	3325966.43	OCNP= 6.089999999999999E+00;
NUCLEAR(6)=	1510:			
M= 6	J= 4	TOTAL=	3256220.65	OCNP= 6.089999999999999E+00;
NUCLEAR(7)=	1573:			
M= 7	J= 4	TOTAL=	3190616.00	OCNP= 6.089999999999999E+00;
NUCLEAR(8)=	1634:			
M= 8	J= 4	TOTAL=	3127369.81	OCNP= 6.089999999999999E+00;
NUCLEAR(9)=	1694:			
M= 9	J= 4	TOTAL=	3065844.90	OCNP= 6.089999999999999E+00;

6	67	5	9						
6852	5971	5114	4190	3358	2403				
8012	7111	5929	4937	3981	2935				
7709	6824	5690	4711	3875	2893				
8110	7205	5978	4960	4036	2578				
7936	7037	5873	4901	3576	2501				
40	24	25	19	41	19				
52	22	19	27	36	12				
50	24	19	24	36	15				
52	22	20	26	36	12				
52	22	19	24	39	12				
1415	1476	1538	1603	1660	1730	1793	1854	1914	

NUCLEAR(1)=	1415:			
M= 1	J= 1	TOTAL=	2626639.70	OCNP= 5.250000000000000E+00;
NUCLEAR(2)=	1476:			
M= 2	J= 1	TOTAL=	2564724.70	OCNP= 5.229999999999999E+00;
NUCLEAR(3)=	1538:			
M= 3	J= 1	TOTAL=	2502753.49	OCNP= 5.079999999999999E+00;
NUCLEAR(4)=	1603:			
M= 4	J= 1	TOTAL=	2439412.73	OCNP= 5.059999999999999E+00;
NUCLEAR(5)=	1660:			
M= 5	J= 1	TOTAL=	2384281.56	OCNP= 5.029999999999999E+00;
NUCLEAR(6)=	1730:			
M= 6	J= 1	TOTAL=	2317041.78	OCNP= 5.029999999999999E+00;
NUCLEAR(7)=	1793:			
M= 7	J= 1	TOTAL=	2257416.39	OCNP= 5.029999999999999E+00;
NUCLEAR(8)=	1854:			

- 154 -

M= 9	J= 1	TOTAL=	2201036.51	OCNP= 5.029999999999999E+00;
NUCLEAR(9)=	1914;			
M= 9	J= 1	TOTAL=	2146541.89	OCNP= 5.000000000000000E+00;
NUCLEAR(1)=	1415;			
M= 1	J= 2	TOTAL=	3945692.30	OCNP= 6.829999999999999E+00;
NUCLEAR(2)=	1476;			
M= 2	J= 2	TOTAL=	3872698.80	OCNP= 6.829999999999999E+00;
NUCLEAR(3)=	1538;			
M= 3	J= 2	TOTAL=	3798796.75	OCNP= 6.789999999999999E+00;
NUCLEAR(4)=	1603;			
M= 4	J= 2	TOTAL=	3722664.30	OCNP= 6.789999999999999E+00;
NUCLEAR(5)=	1660;			
M= 5	J= 2	TOTAL=	3656213.93	OCNP= 6.789999999999999E+00;
NUCLEAR(6)=	1730;			
M= 6	J= 2	TOTAL=	3574948.82	OCNP= 6.789999999999999E+00;
NUCLEAR(7)=	1793;			
M= 7	J= 2	TOTAL=	3502221.90	OCNP= 6.399999999999999E+00;
NUCLEAR(8)=	1854;			
M= 9	J= 2	TOTAL=	3432545.88	OCNP= 6.399999999999999E+00;
NUCLEAR(9)=	1914;			
M= 9	J= 2	TOTAL=	3364339.75	OCNP= 6.399999999999999E+00;
NUCLEAR(1)=	1415;			
M= 1	J= 3	TOTAL=	3616676.75	OCNP= 6.789999999999999E+00;
NUCLEAR(2)=	1476;			
M= 2	J= 3	TOTAL=	3548161.05	OCNP= 6.789999999999999E+00;
NUCLEAR(3)=	1538;			
M= 3	J= 3	TOTAL=	3476708.19	OCNP= 6.399999999999999E+00;
NUCLEAR(4)=	1603;			
M= 4	J= 3	TOTAL=	3402555.47	OCNP= 6.399999999999999E+00;
NUCLEAR(5)=	1660;			
M= 5	J= 3	TOTAL=	3337921.52	OCNP= 6.399999999999999E+00;
NUCLEAR(6)=	1730;			
M= 6	J= 3	TOTAL=	3259006.62	OCNP= 6.399999999999999E+00;
NUCLEAR(7)=	1793;			
M= 7	J= 3	TOTAL=	3188190.55	OCNP= 6.089999999999999E+00;
NUCLEAR(8)=	1854;			
M= 8	J= 3	TOTAL=	3121050.00	OCNP= 6.089999999999999E+00;
NUCLEAR(9)=	1914;			
M= 9	J= 3	TOTAL=	3055238.40	OCNP= 6.089999999999999E+00;
NUCLEAR(1)=	1415;			
M= 1	J= 4	TOTAL=	4046839.86	OCNP= 6.829999999999999E+00;
NUCLEAR(2)=	1476;			
M= 2	J= 4	TOTAL=	3972894.81	OCNP= 6.829999999999999E+00;
NUCLEAR(3)=	1538;			
M= 3	J= 4	TOTAL=	3898469.80	OCNP= 6.829999999999999E+00;
NUCLEAR(4)=	1603;			
M= 4	J= 4	TOTAL=	3820950.02	OCNP= 6.789999999999999E+00;
NUCLEAR(5)=	1660;			
M= 5	J= 4	TOTAL=	3753460.75	OCNP= 6.789999999999999E+00;
NUCLEAR(6)=	1730;			
M= 6	J= 4	TOTAL=	3671817.81	OCNP= 6.789999999999999E+00;
NUCLEAR(7)=	1793;			
M= 7	J= 4	TOTAL=	3598482.37	OCNP= 6.789999999999999E+00;
NUCLEAR(8)=	1854;			
M= 8	J= 4	TOTAL=	3528119.30	OCNP= 6.500000000000000E+00;
NUCLEAR(9)=	1914;			
M= 9	J= 4	TOTAL=	3459190.83	OCNP= 6.399999999999999E+00;
NUCLEAR(1)=	1415;			
M= 1	J= 5	TOTAL=	3868022.13	OCNP= 6.829999999999999E+00;
NUCLEAR(2)=	1476;			

M= 2	J= 5	TOTAL=	3795315.72	OCNP= 6.789999999999999E+00;
NUCLEAR(3)= 1538;				
M= 3	J= 5	TOTAL=	3722802.23	OCNP= 6.789999999999999E+00;
NUCLEAR(4)= 1603;				
M= 4	J= 5	TOTAL=	3646962.51	OCNP= 6.789999999999999E+00;
NUCLEAR(5)= 1660;				
M= 5	J= 5	TOTAL=	3580818.23	OCNP= 6.789999999999999E+00;
NUCLEAR(6)= 1730;				
M= 6	J= 5	TOTAL=	3500044.45	OCNP= 6.399999999999999E+00;
NUCLEAR(7)= 1793;				
M= 7	J= 5	TOTAL=	3428097.75	OCNP= 6.399999999999999E+00;
NUCLEAR(8)= 1854;				
M= 8	J= 5	TOTAL=	3358739.40	OCNP= 6.399999999999999E+00;
NUCLEAR(9)= 1914;				
M= 9	J= 5	TOTAL=	3290837.50	OCNP= 6.399999999999999E+00;

6 64 4 2									
8397 7222 6327 5405 4549 3542									
7919 7117 6046 4578 4073 3170									
7935 6501 5441 4572 4068 3151									
8407 7231 6335 5415 4572 3593									
70 11 13 20 38 11									
64 12 21 20 38 13									
65 15 18 19 39 12									
70 11 13 20 37 12									
1635 1696 1758 1823 1884 1950 2013 2074 2134									

NUCLEAR(11)= 1635;	J= 1	TOTAL=	5080038.39	OCNP= 8.859999999999999E+00;
M= 1				
NUCLEAR(12)= 1696;	J= 1	TOTAL=	4996060.45	OCNP= 8.829999999999999E+00;
M= 2				
NUCLEAR(13)= 1758;	J= 1	TOTAL=	4911284.65	OCNP= 8.829999999999999E+00;
M= 3				
NUCLEAR(14)= 1823;	J= 1	TOTAL=	4822539.39	OCNP= 8.489999999999999E+00;
M= 4				
NUCLEAR(15)= 1884;	J= 1	TOTAL=	4739741.39	OCNP= 8.489999999999999E+00;
M= 5				
NUCLEAR(16)= 1950;	J= 1	TOTAL=	4650592.00	OCNP= 8.299999999999999E+00;
M= 6				
NUCLEAR(17)= 2013;	J= 1	TOTAL=	4566223.39	OCNP= 8.299999999999999E+00;
M= 7				
NUCLEAR(18)= 2074;	J= 1	TOTAL=	4484914.73	OCNP= 7.739999999999999E+00;
M= 8				
NUCLEAR(19)= 2134;	J= 1	TOTAL=	4405649.05	OCNP= 7.739999999999999E+00;
M= 9				
NUCLEAR(1)= 1635;	J= 2	TOTAL=	4381344.98	OCNP= 7.739999999999999E+00;
M= 1				
NUCLEAR(2)= 1696;	J= 2	TOTAL=	4301229.29	OCNP= 7.279999999999999E+00;
M= 2				
NUCLEAR(3)= 1758;	J= 2	TOTAL=	4220689.38	OCNP= 7.279999999999999E+00;
M= 3				
NUCLEAR(4)= 1823;	J= 2	TOTAL=	4138001.35	OCNP= 6.829999999999999E+00;
M= 4				
NUCLEAR(5)= 1884;	J= 2	TOTAL=	4062003.78	OCNP= 6.829999999999999E+00;
M= 5				
NUCLEAR(6)= 1950;	J= 2	TOTAL=	3990207.79	OCNP= 6.829999999999999E+00;
M= 6				
NUCLEAR(7)= 2013;	J= 2	TOTAL=	3902490.82	OCNP= 6.829999999999999E+00;
M= 7				
NUCLEAR(8)= 2074;	J= 2	TOTAL=		
M= 8				

- 456 -



M= 5	J= 1	TOTAL=	3112345.50	OCNP= 6.399999999999999E+00;
NUCLEAR(6)= 1950;	J= 1	TOTAL=	3039885.27	OCNP= 6.089999999999999E+00;
M= 6	J= 1	TOTAL=	2971766.16	OCNP= 6.089999999999999E+00;
NUCLEAR(7)= 2013;	J= 1	TOTAL=	2905982.64	OCNP= 6.089999999999999E+00;
M= 7	J= 1	TOTAL=	2841843.38	OCNP= 6.089999999999999E+00;
NUCLEAR(8)= 2074;	J= 1	TOTAL=	4286229.95	OCNP= 7.279999999999999E+00;
M= 3	J= 2	TOTAL=	4210001.21	OCNP= 7.279999999999999E+00;
NUCLEAR(9)= 2134;	J= 2	TOTAL=	4133163.78	OCNP= 7.279999999999999E+00;
M= 9	J= 2	TOTAL=	4053589.56	OCNP= 6.829999999999999E+00;
NUCLEAR(1)= 1635;	J= 2	TOTAL=	3979545.28	OCNP= 6.829999999999999E+00;
M= 1	J= 2	TOTAL=	3900267.93	OCNP= 6.829999999999999E+00;
NUCLEAR(2)= 1696;	J= 2	TOTAL=	3825555.51	OCNP= 6.829999999999999E+00;
M= 2	J= 2	TOTAL=	3753835.53	OCNP= 6.829999999999999E+00;
NUCLEAR(3)= 1758;	J= 2	TOTAL=	3683408.26	OCNP= 6.829999999999999E+00;
M= 3	J= 2	TOTAL=	3850553.22	OCNP= 6.829999999999999E+00;
NUCLEAR(4)= 1823;	J= 3	TOTAL=	3778773.65	OCNP= 6.789999999999999E+00;
M= 4	J= 3	TOTAL=	3706120.47	OCNP= 6.789999999999999E+00;
NUCLEAR(5)= 1834;	J= 3	TOTAL=	3630217.57	OCNP= 6.789999999999999E+00;
M= 5	J= 3	TOTAL=	3559088.66	OCNP= 6.789999999999999E+00;
NUCLEAR(6)= 1950;	J= 3	TOTAL=	3482933.02	OCNP= 6.789999999999999E+00;
M= 5	J= 3	TOTAL=	3410757.61	OCNP= 6.399999999999999E+00;
NUCLEAR(7)= 2013;	J= 3	TOTAL=	3341106.58	OCNP= 6.399999999999999E+00;
M= 7	J= 3	TOTAL=	3272944.04	OCNP= 6.399999999999999E+00;
NUCLEAR(8)= 2074;	J= 3	TOTAL=	3963825.98	OCNP= 6.829999999999999E+00;
M= 8	J= 4	TOTAL=	3890642.13	OCNP= 6.829999999999999E+00;
NUCLEAR(9)= 2134;	J= 4	TOTAL=	3817623.87	OCNP= 6.829999999999999E+00;
M= 9	J= 4	TOTAL=	3741459.90	OCNP= 6.789999999999999E+00;
NUCLEAR(1)= 1635;	J= 4	TOTAL=	3670094.95	OCNP= 6.789999999999999E+00;
M= 1	J= 4	TOTAL=	3592894.41	OCNP= 6.789999999999999E+00;
NUCLEAR(2)= 1696;	J= 4	TOTAL=	3519872.06	OCNP= 6.789999999999999E+00;
M= 2	J= 4	TOTAL=		
NUCLEAR(3)= 1758;	J= 4	TOTAL=		
M= 3	J= 4	TOTAL=		
NUCLEAR(4)= 1823;	J= 4	TOTAL=		
M= 4	J= 4	TOTAL=		
NUCLEAR(5)= 1834;	J= 4	TOTAL=		
M= 5	J= 4	TOTAL=		
NUCLEAR(6)= 1950;	J= 4	TOTAL=		
M= 5	J= 4	TOTAL=		
NUCLEAR(7)= 2013;	J= 4	TOTAL=		
M= 7	J= 4	TOTAL=		
NUCLEAR(8)= 2074;	J= 4	TOTAL=		



REFERENCES

- (1) "Generation", Electrical World, June 1, 1974, Vol. 181, No. 11, pp. 75
- (2) "Comparision of Coal-Fired and Nuclear Power Plants for The TVA System", Office of Power, Tennessee Valley Authority, Chattanooga, Tenn., June, 1966.
- (3) Deaton, Paul F., "Utility System Integration and Optimization Models for Nuclear Power Management" Ph.D. Thesis, MIT Dept. of Nuclear Engineering, June, 1973.
- (4) J. C. Turnage and B. E. Prince, "A Computer Code (ORSIM) for the Simulation and Optimization of Utility System Operation With Nuclear Plants", A collection of papers presented at the Nuclear Utilities Planning Methods Symposium, Chattanooga, Tenn. Jan. 16-18, 1974, ORNL-TM-4443
- (5) G. J. Bonk, et. al, "Interactions Between Nuclear Plant Loadings Changes and Nuclear Fuel Costs", Nuclear News, June, 1971, pp. 53-57.
- (6) Widmer, Hans, "The Optimal Utilization of a Nuclear Power Plant With Fixed Fueling Schedule", Ph.D. Thesis, MIT Dept. of Nuclear Engineering, Sept. 1970.
- (7) Dantzig, G. B., "Linear Programming and Extensions "Princeton University Press, Princeton, N.J., 1963.
- (8) Kearney, Joseph P., "Simulation and Optimization Techniques of Nuclear In-Core Fuel Management Decisions", Ph.D. Thesis, MIT Dept. of Nuclear Engineering, Feb. 1973.
- (9) Watt, Hing Yan, "Incremental Cost and Optimization of In-Core Fuel Management of Nuclear Power Plants", Ph.D. Thesis, MIT Dept. of Nuclear Engineering, Feb. 1973.
- (10) "Nuclear Power Cost: Three Satisfied Customers", Nuclear Industry, Vol. 21, No. 5, May 1974, pp.43.
- (11) L. M. Olmsted, "18-th Steam Station Cost Survey: Nuclear Units Slow Power Cost Rise", Electrical World, Vol. 180, No. 9, Nov. 1, 1973, pp.39.
- (12) Sasson, A. M., "Non-linear Programming Solutions for Load Flow, Minimum-Loss, and Economic Dispatching Problems", IEEE Transaction P.A.S., Vol. PAS-89, No.4, April, 1969, pp. 399-409.
- (13) A. Thanikachalam and J.R. Tudor, "Optimal Rescheduling of Power for System Reliability", IEEE Winter Power



- Meeting, NYC, Jan. 31, 1971, paper 71 TP-61-PWR.
- (14) Schultz, M. A., Control of Nuclear Reactors and Power Plants, 2nd Ed., New York, Mc Graw Hill, 1961.
  - (15) Weekly Output, Electrical World, Jan. 15, 1972, pp 20
  - (16) Personal Communication from Nicholas Tibberts (Head of AEP's Generation Planning Section)
  - (17) Booth, R. R., "Optimal Generation Planning Considering Uncertainty", 1971 PICA conf., Boston, Ma., May 24-26, 1971 Paper 71, c26-PWR-II-D.
  - (18) Booth, R. R., "Power System Simulation Model Based On Probability Analysis", 1971 PICA conf. Boston, Ma., May 24-26, 1971, paper 71, 26-PWR-II-D.
  - (19) Garver, L. L., "Reserve Planning Using Outage Probabilities and Load Outages." IEEE transaction P.A.S. Vol. PAS-89, No. 4, April 1970, pp. 514-521.
  - (20) K. N. Stanton and P. C. Gupta, "Forecasting Annual or Seasonal Peak Demand In Electric Utility Systems", IEEE Transaction P.A.S., Vol. PAS-89, No. 516, May-June 1970, pp. 951-959.
  - (21) Personal Communication from N. A. Kershaw (Supt. Nuclear and Fossil System), Commonwealth Edison, April 15, 1974.
  - (22) "Proceedings of the International Conference on Pumped Storage Development and its Environmental Effects", editors: G. M. Karadi, et al, sponsored by The University of Wisconsin at Milwaukee, and the American Water Resources Association, September 19-24, 1971
  - (23) F. J. Rees and R. E. Larson, "Computer Aided Dispatching and Operations Planning for an Electric Utility With Multiple Types of Generation" IEEE Transaction P.A.S., Vol. PAS-90, No.2, Mar. 1971, pp. 891-899.
  - (24) "Strong Future Predicted For Pumped Storage", Electrical World, June 1, 1974, pp. 92.
  - (25) LSFIT, MIT Information Processing Center, memo AP-13-3, June 16, 1972
  - (26) Mansfield, Edwin, "Microeconomics, Theory and Applications", W. W. Norton and Co., New York, 1970, pp. 215-216

- (27) S. Vajda, "Probabilistic Programming", Academic Press, New York, 1972
- (28) Leon K. Kirchmayer, "Economic Operation of Power Systems", New York, Wiley, 1958.
- (29) "An Introduction to Linear Programming", IBM No. GE 20-8171.
- (30) "Introduction MPSX, MIP and GUB", IBM No. GH 20-0849-3 1973
- (31) "MPSX Control Language User's Manual", IBM No. H 20-0932, 1971
- (32) "MPSX and GUB Program Description", IBM No. SH 20-0968-1, 1972
- (33) Howard Raiffa, "Decision Analysis, Introductory Lectures on Choices under Uncertainty", Addison-Wesley, Reading, Massachusetts, 1968
- (34) PRTPLT, MIT Information Processing Center, memo AP-8-5.
- (35) ISORT, MIT Information Processing Center, memo AP-61

Biographical Note

Raymond Eng was born on February 2, 1948 in Bronx, New York. He attended elementary school at P.S. 200 and junior high school at P.S. 128, and high school at Brooklyn Technical High School, all located in Brooklyn, New York. For his undergraduate studies, he attended Massachusetts Institute of Technology from September 1965 to June 1969. He received a B.S. degree from the Department of Chemistry majoring in Chemical Physics and minoring in Economics. He received a Uniroyal Scholarship during his junior and senior year.

His undergraduate research in Nuclear Chemistry, titled "Isomeric-Yield Ratios of Cd-117 in the (n, $\gamma$ ) and (d,p) Reactions", was published in the Journal of Inorganic and Nuclear Chemistry, Volume 35, 1973, pp 371-380, Pergamon Press, Great Britain.

He was awarded a three-year AEC fellowship to continue his graduate work in M.I.T.'s Department of Nuclear Engineering, majoring in Nuclear Fuel Management. His minor was in Management.

He was also extensively involved in a variety of extra-curricular activities. He was elected member of the Graduate Student Council, elected Social Chairman and Treasurer of Ashdown House, and elected President of the MIT Chinese Student Club during his graduate residence years.