

Published in the Journal of Heat Transfer for  
Fluid Mechanics Institute, June 1951, Stanford University,  
Stanford, Cal.

TECHNICAL REPORT NO. 3

RSC

QC 320  
.M41  
.H43  
no. 3

HEAT TRANSFER AND PRESSURE DROP DATA FOR  
HIGH HEAT FLUX DENSITIES TO WATER AT  
HIGH SUBCRITICAL PRESSURES

Archives

MASS. INST. TECH.  
MAY 16 1953  
LIBRARY

HAYDEN  
T.C.


BY

WARREN M. ROHSENOW AND JOHN A. CLARK

FOR

THE OFFICE OF NAVAL RESEARCH  
CONTRACT N5ori-07827  
NR-035-267  
D.I.C. PROJECT NUMBER 6627

APRIL 1, 1951



MASSACHUSETTS INSTITUTE OF TECHNOLOGY  
DIVISION OF INDUSTRIAL COOPERATION  
CAMBRIDGE 39, MASSACHUSETTS



Room 14-0551  
77 Massachusetts Avenue  
Cambridge, MA 02139  
Ph: 617.253.5668 Fax: 617.253.1690  
Email: docs@mit.edu  
<http://libraries.mit.edu/docs>

## **DISCLAIMER OF QUALITY**

Due to the condition of the original material, there are unavoidable flaws in this reproduction. We have made every effort possible to provide you with the best copy available. If you are dissatisfied with this product and find it unusable, please contact Document Services as soon as possible.

Thank you.

**Some pages in the original document contain pictures, graphics, or text that is illegible.**

TECHNICAL REPORT NO. 3

HEAT TRANSFER AND PRESSURE DROP DATA FOR HIGH HEAT FLUX DENSITIES  
TO WATER AT HIGH SUBCRITICAL PRESSURES

by

Warren M. Rohsenow and John A. Clark

For the Office of Naval Research

N5 ori-07827

NR 035-267

DIC PROJECT NO. 6627

April 1, 1951

DIVISION OF INDUSTRIAL COOPERATION  
Massachusetts Institute of Technology  
Cambridge, Massachusetts



HEAT TRANSFER AND PRESSURE DROP DATA FOR HIGH HEAT FLUX DENSITIES  
TO WATER AT HIGH SUBCRITICAL PRESSURES

by

Warren M. Rohsenow\* and John A. Clark\*\*

SUMMARY

Local surface coefficients of heat transfer, overall pressure drop data and mean friction factor are presented for heat fluxes up to  $3.5 \times 10^6$  Btu/hr ft<sup>2</sup> for water flowing in a nickel tube under the following conditions: mass rates of flow up to  $5.6 \times 10^6$  lb<sub>m</sub>/hr ft<sup>2</sup> (or inlet velocities up to 30 ft/sec), absolute pressures up to 2000 psia, and liquid subcooling between 50 F and 250 F. The test section dimensions were 0.180 inch I.D. and 9.4 inches long.

INTRODUCTION

Very little information has been available to predict heat transfer and pressure drop performance for liquids with severe temperature gradients adjacent to the surface, particularly when the surface temperature exceeds the normal boiling temperatures. Recent works published by Knowles (3), Kreith and Summerfield (1) (2), and McAdams et al (4) present data for this type heat transfer process in the lower pressure ranges. The data presented here for water was obtained in August, 1950, and represents some of the initial data available for water at pressures up to 2000 psia. Simultaneously, similar data has been gathered at U.C.L.A. This particular type of heat transfer process is encountered in liquid-cooled rocket motors and in more recent steam power plant equipment.

---

\* Asst. Prof. Mech. Eng., M. I. T., Cambridge, Mass.

\*\* Instructor, Mech. Eng., M. I. T., Cambridge, Mass.



### APPARATUS

The test apparatus is a closed system consisting of a vertical test section of pure nickel, a Hayward-Tyler centrifugal pump, a calibrated orifice, a heat exchanger, a pressure vessel, and an ion exchanger. A layout is given in Fig. 1. Power is supplied from two 36 KW 12 volt DC Generators driven by 440 volt, 3 phase, AC 600 rpm synchronous motors. The generator outputs are connected in series and provide a range of 0-24 volts and 0-3000 amperes. Thermocouples are located at the test water inlet and outlet and along the outer wall of the test section, readings being taken by means of a Rubicon potentiometer, Model 2703 and a Rubicon spotlight galvanometer Model 3401-H. A bourdon type Heise pressure gage 0-2000 psi is located at the inlet to the test section. A Barton differential pressure gage 0-300 inches of water is connected across inlet and outlet of the test section to record the pressure drop.

The test section (figure 2) consists of a pure nickel tube (International Nickel Co. "L" Nickel) of .1805 in. inside diameter, .2101 in. outside diameter, and a length of 9.4 inches. Threaded bushings of "L" nickel are gold soldered to each end of the test section, and make contact with bronze end mounts, which support the test section assembly and carry current from the bussbars.

The test water was circulated by a four-stage centrifugal pump manufactured by Hayward-Tyler Company, Ltd., of England. The pump impeller and the motor assembly are both enclosed in a single stainless steel casing capable of being operated at a pressure of 4000 psia with a head of 300 ft. of water at 50 gpm. The heat exchange system which removes heat equal to the electrical energy supplied employs an intermediate fluid, silicone DC-701, between the test and city cooling water, in order to assure an absence of local boiling of the cooling<sup>water</sup> in this part of the circuit. Flow measurements were made by a calibrated orifice with a Barton differential pressure gage having a range of 0-100 inches of water.

The system pressure is maintained by the vapor pressure in an insulated pressure vessel heated by chromalox electric heaters.

### EXPERIMENTAL TECHNIQUES

Determination of Temperatures at Liquid-Wall Interface. Because of mechanical problems it was impractical to measure the tube inner wall temperature directly. Instead, this temperature was calculated from measurements of the outer wall temperature, the electric current, and the geometrical and physical properties of the nickel tube.

The tube outer wall temperature was measured at seven points above the tube as shown in fig. 3 from twelve chromel-constantan thermocouples electrically insulated from the tube wall by a small sheet of 0.0015 in. thick mica. Around the tube was a copper shield electrically heated in three sections, each controlled by a variac. The space between the tube and the shield was filled with Kaolin wool insulation.

The shield temperature was adjusted to the same temperature as the test section thermocouple. Under such conditions the reading of the outer wall thermocouple can be considered to be the temperature of the tube outer wall.

In the surface boiling region the tube wall temperatures are fairly uniform; hence a uniform setting of shield temperatures for any one operating condition resulted in accurately determined wall temperatures. In the non-boiling region, the test section had an axial temperature gradient requiring adjustments of the three variacs to cause the shield to follow closely the tube temperatures.

A mock-up of the test section assembly (fig. 2) was tested with condensing steam in the test section to determine the effect of shield temperature variation on tube thermocouple reading. It was found that when the difference between steam temperature and shield temperature was 10°F, the difference between steam temperature and tube thermocouple temperature was between 1/2 and 1°F as recorded by the various thermocouples along the length. These differences varied approximately linearly with each other.

The inner wall temperature was calculated from a Taylor Series solution of the temperature distribution for heat conduction in an electrically heated tube with an adiabatic outer wall. This equation which is similar to that proposed by Kreith and Summerfield (1) is:

$$t_o - t_w = \frac{m}{k_o \rho_o} \left\{ \Delta \bar{x}^2 + \frac{\Delta \bar{x}^3}{r_o} + \Delta \bar{x}^4 \left[ \frac{m(3\alpha + 4\alpha\beta t_o + \beta)}{6(1+\beta t_o)(1+\alpha t_o)} + \frac{1}{4r_o^2} + \dots \right] \right\} \quad (1)$$

where: 
$$m \equiv \frac{3.412 I^2 \rho_m^2}{2\pi^2 (r_o^2 - r_i^2)^2}$$

For accuracy within 0.5% the third term may be neglected, the working equation then becoming:

$$t_o - t_w = \frac{m}{k_o \rho_o} \left\{ \Delta \bar{x}^2 + \frac{\Delta \bar{x}^3}{r_o} + \dots \right\} \quad (1a)$$

This relation includes allowance for variation of electrical resistivity and thermal conductivity with temperature and for electrical resistivity with radius.

Measurement of Heat-Flux Density. The power dissipated in any portion of the test section is dependent upon the resistance, which, being a function of temperature, varies from point to point along the tube. The heat flux density then varies along the test section length and must be calculated to obtain accurate results. For a small element of length  $dx$ ,

$$\frac{q}{A} = \frac{3.412 I^2 \rho_m dx}{\pi D_i dx \pi (r_o^2 - r_i^2)} = 1.148 \times 10^6 I^2 \rho_m \quad (2)$$

for the tube of 0.1805 in. I.D. and 0.2101 in. O.D.

The electric current was determined from the measured voltage drop across a 0.00001667 ohm G. E. manganin shunt calibrated by the National Bureau of Standards. The shunt was in series with the test section and its voltage drop was measured by a Rubicon potentiometer.



The voltage drop across the test section was measured by a potentiometer and a voltage divider network as illustrated in fig. 4. The resistors were General Radio Company resistors calibrated at the M.I.T. Electrical Instruments Laboratory. The potential taps were made of nickel held in place by stainless steel spring clips. The voltage drop across the test section is then

$$E_{ts} = E_1 \frac{R_1 + R_2 + R_3}{R_1} \quad (3)$$

Test Water Bulk Temperature. The method of determining the fluid temperature at any station along the tube consisted of integrating  $q/A$  from the inlet to the station in question and calculating the fluid temperature rise from the inlet. Neglecting axial heat flow and neglecting the effect of vapor bubbles on the effective specific heat of the water, an energy balance results in

$$\int_{\tau_{in}}^{\tau_n} d\tau = \frac{\pi D_i}{C_p W} \int_0^n \left(\frac{q}{A}\right) dx \quad (4)$$

For purposes of graphical integration, a plot as shown in fig. 5 was made. In general it was sufficiently accurate to make the actual calculation by a step-wise integration between any two stations  $n$  and  $(n-1)$  in the form

$$\tau_n - \tau_{(n-1)} = \frac{\pi D_i}{W C_p} X_{n-(n-1)} \left(\frac{q}{A}\right)_{n-(n-1)} \quad (5)$$

Data from this apparatus affords several checks on itself. The average  $(q/A)$  calculated from the power measurement should be equal to the average  $(q/A)$  as calculated from equation (2). Also the sum of the water temperature rises between stations should equal  $\tau_{out} - \tau_{in}$ .

Flow Measurement. The pressure drop across the orifice was measured with Barton Differential Pressure Gages with 0-100" H<sub>2</sub>O scale. Its accuracy calibrated at atmospheric pressure against a water column was within 1% of full scale reading. The orifice coefficient calibrated by direct weighing at eight Reynolds numbers for pressure drop readings from 10 to 90" H<sub>2</sub>O had a root-mean-square

deviation of 0.5% for the high flow range orifice and 0.9% for the low range orifice. The accuracy of the flow measurement should be within 1 per cent.

Test-Section Pressure Drop Measurement. Pressure drop across the test section is measured by means of a Barton Differential Pressure Gage, 0-300 inches of water, connected at the pressure taps as shown in Fig. 2. The pressure drop,  $\Delta p_i$ , across the heated section was determined from corrected gage reading by subtracting the pressure drops in the unheated sections at either end of the tube as determined from isothermal friction factors. The temperature of the water in the vertical test section is considerably higher than the temperature of the ambient water in the gage lead-in tubing, necessitating a correction factor to determine the actual pressure drop due to friction and momentum change. The equation relating these pressure drop values is as follows:

$$\Delta p_{f,m} = \Delta p_i + L_p (\gamma_0 - \bar{\gamma}) \quad (6)$$

Because of the addition of heat to the fluid its density changed in passing through the test section. This resulting momentum change must be subtracted from  $\Delta p_{f,m}$  to obtain the pressure drop associated with friction alone. Then

$$\Delta p_f = \Delta p_{f,m} - \frac{G^2}{g_0} \left( \frac{1}{\rho_2} - \frac{1}{\rho_1} \right) \quad (7)$$

A friction factor based on the friction pressure drop may be defined by the equation

$$\Delta p_f = 4 f_f \frac{G^2}{2 g_0 D_i} \int_0^L \frac{dx}{\rho} \quad (8)$$

and when based on the pressure drop including both frictional and momentum effects

$$\Delta p_{f,m} = 4 f_{f,m} \frac{G^2}{2 g_0 D_i} \int_0^L \frac{dx}{\rho} \quad (9)$$

In each case the actual variation of density along the tube length was used in evaluating the integral.

Accuracy of Results. The tube thickness varied  $\pm 0.0003$  in. Equation (2)

with the value of  $m$  introduced shows the first and major term of the series to be approximately inversely proportional to the square of the tube diameter. For the high heat flux tests the value of  $T_o - T_w$  was about  $60^\circ\text{F}$ ; then the maximum error of  $T_w$  attributable to tube thickness variation was  $0.4^\circ\text{F}$  and decreases as the heat flux is lowered.

The thermal conductivity data was obtained from the International Nickel Company and the electrical resistivity was determined experimentally to an estimated accuracy of  $\pm 0.5\%$ .

It is expected that the inner-wall temperature has been determined within a  $\pm 3$  degree F error.

#### ION EXCHANGER

During early test runs black iron oxide was found to be depositing in the test section causing as much as a  $50^\circ\text{F}$  increase in tube wall temperature in two hours of operation at a fixed set of conditions. The source of iron ions was probably the Hayward-Tyler pump which, contrary to expectations, had a considerable amount of ordinary iron in contact with the test water. It was suggested that the deposit was formed because of the electrical potential gradient along the test water in the tube and the ions (hence electrical conductivity) of the test water. A mono-bed ion exchanger consisting of Rohn and Haas Resin MB-1 "Amberlite" in a stainless steel jacket equipped with suitable filters was added to the circuit as shown in figure 1. It is not as yet known whether this ion-exchanger actually removed the objectionable ions or simply acted as a high grade filter, but subsequent to its installation all difficulty with deposition of scale on the heat transfer surface ceased.

#### EXPERIMENTAL PROCEDURE

The system was filled with freshly distilled water (0.70 ppm as NaCl and approximately 15 ml air/l) by means of an aspirator located at the top of the Hayward-Tyler pump. As soon as it was certain that the upper thrust bearing on



the Hayward-Tyler pump was immersed in water, the pump was started and water was circulated through the test loop. Degassing was accomplished by circulating the test circuit water through the heated pressure vessel vented to the atmosphere for a period of 1/2 to 3/4 of an hour. This period was found to be of sufficient length to reduce the oxygen content to approximately 1.5 ml air/l, as determined by the Winkler Technique. Subsequent to degassing, the system was sealed by closing the degassing vent valve and test water was circulated through the test section at high velocity. The bulk temperature of the water was increased by applying power to the test section and the system pressure was increased to the desired level by heating the water in the closed pressure vessel. The system pressure could be controlled to  $\pm 2$  psi by the chromalox strip heaters regulated by a variac. The inlet bulk temperature was controlled and maintained at the desired level by regulating the flow of silicone fluid through the intermediate heat exchanger. Cooling water flow through the ion-exchanger heat exchanger and the city water heat exchanger was fixed at its maximum rate at the beginning of the run and not thereafter adjusted. The water at the discharge of the ion-exchanger was consistently at approximately 0.1 ppm NaCl.

#### EXPERIMENTAL RESULTS

##### Heat Transfer in Forced Convection Without Surface Boiling.

Local values of the heat transfer coefficient at stations 2 through 6 (Fig. 3) were evaluated by assuming a linear variation of fluid temperature with distance along the tube. The tube wall temperature varied along the tube in the non-boiling runs; so  $q/A$  was not uniform because the wall electrical resistivity varies with temperature. Nevertheless the assumption of linear fluid temperature resulted in at most a 3% error in the resulting local heat transfer coefficient for runs involving high rates of heat transfer at lower velocities.

The results of these runs are shown in Table I and figure 6. The local value of  $j$  is shown plotted against the local  $N_{Ref}$ . It is noted that there exists a separate curve for the points along the tube for each run and the points near the

end of the tube are correlated by the equation

$$\frac{h}{c_p G} \left( \frac{c_p \mu_f}{k} \right)^{2/3} = 0.019 \left( \frac{G D_i}{\mu_f} \right)^{-0.2} \quad (10)$$

which is below the Colburn correlation line by about 17%. The values of the heat transfer coefficient at the points toward the inlet end of the tube are higher than the correlation line which is drawn for the points near the outlet end of the tube. This is to be expected because of the build up of the thermal boundary layer. The tube has an L/d of 52. For most cases an L/d of approximately 50 is found to be necessary to form a fully developed thermal boundary layer; hence, the trend of the data seems to be reasonable.

There is, of course, the possibility that a film of contamination on the heat transfer surface would result in too high a temperature difference and thus reduce the j value. However, this effect is discounted as being negligible since it would have to account for an interface temperature error of from 20°F to 40°F to bring the correlation in line with the Colburn correlation. Doubtless the film exists since examination of used tubes showed a slight discoloring of the heat transfer surface. It was extremely thin, however, reflecting incident light as blue suggesting its thickness as the order of the wave length of that color light. Also, inspection of Fig. 8 shows that if the true  $\Delta t$  is as much as 10°F below that reported then boiling would occur at temperatures less than saturation, which is improbable.

Energy balances comparing enthalpy change of liquid with the electrical energy were all within  $\pm 2\%$ , most of them being within  $\pm 0.5\%$ . Isothermal runs with the liquid temperatures above 400°F showed the inlet and outlet liquid thermocouple to agree within  $\pm 1^\circ\text{F}$  of the tube wall temperatures.

The values of the fluid properties were obtained from data taken from Wellman (8).

### Heat Transfer in Forced Convection with Surface Boiling

Again local values of  $q/A$  as a function of temperature difference are studied. In these boiling runs the tube temperature, and hence  $q/A$ , is very nearly uniform along the tube. The temperature of the fluid is assumed to vary linearly with distance along the tube. This assumption is not strictly valid for conditions of high heat flux or heat transfer to a liquid with low subcooling where the percentage of volume occupied by vapor becomes significant. Since the effect of these vapor bubbles on bulk temperature changes could not be determined from the measurements taken it was assumed the fluid behaved as a liquid and as a check on the assumption the longitudinal variation in bulk enthalpy and thus bulk temperature was determined by a numerical integration of  $q/A$  with length. The results agreed within  $2^\circ\text{F}$  of the assumed linear variation.

Figure 7 illustrates the type of information obtained from a set of runs. Five data points are obtained for a run, each at nearly the same  $q/A$  value but a different value of liquid subcooling. Similar curves for other conditions are shown in figures 13 through 17 from the data in Tables I and II.

The curves of figure 7 for various values of subcooling can be brought together to fall on a single line by plotting  $q/A$  vs.  $(t_w - t_{\text{sat}})$ , the wall superheat, as shown in figure 8. Here data in the region of surface boiling (Table II) are plotted for various values of fluid velocities and pressures. The points plotted here are the average values of the five points along the tube for each run. The value of  $q/A$  along the tube did not vary significantly but the value of  $(t_w - t_{\text{sat}})$  varied within  $\pm 2^\circ\text{F}$  from the mean value plotted. It is observed that at these high pressures the amount of wall superheat is very small, generally less than  $10^\circ\text{F}$  at 2000 psia and less than  $15^\circ\text{F}$  at 1500 psia. At lower values of pressure near atmospheric Kreith and Summerfield (1) found values of wall superheat to be around  $60^\circ\text{F}$ . Errors in the smaller values of wall superheat are magnified on the log-log type of plot in figure 8. The uncertainties of  $\pm 2$  or  $3^\circ\text{F}$  in wall temperature values have greater emphasis here. These discrepancies



when referred to the value of  $(t_w - t_b)$  are very small, however.

The general trend of the curves of figure 8 shows the same effect reported by previous investigators (1), (2), (3), and (4) in the lower pressure range, e.g., at the higher heat transfer rates the effect of fluid velocity decreases and the agitation of the fluid by the bubbles governs the rate of heat transfer and at the higher pressures less wall superheat exists at a given rate of heat transfer.

#### Pressure Drop in Forced Convection Without Surface Boiling

Local values of pressure drop could not be obtained because such measurements would interfere with the heat transfer measurements; hence, overall values of pressure drop were obtained and are tabulated in Table III, and friction factors are shown in figure 9 as a function of bulk Reynolds number at the arithmetic mean value of inlet and outlet fluid temperatures. The  $f_f$  and  $f_{f,m}$  values are shown compared with the isothermal values found in figure 51 of McAdams (5).

In figure 10 the ratio of isothermal friction factor to the friction factor with heat transfer is plotted as a function of  $(\mu_b / \mu_w)$  at the arithmetic mean value of inlet and outlet fluid temperatures. The ratio involving  $f_{f,m}$  is seen to correlate with the generally accepted line having a slope of 0.14, but the ratio involving  $f_f$  is correlated with a line having a slope of 0.60 for these data.

#### Pressure Drop in Forced Convection With Surface Boiling

Data of Table IV is plotted in figures 11 and 12 and show the effect of heat flux on the pressure drop quantities for friction alone and for friction plus momentum change. When surface boiling begins the pressure drop begins to rise slightly as  $q/A$  is increased. A velocity effect and an effect of liquid subcooling or absolute pressure is observed. It appears that the effect of liquid subcooling is more pronounced than the effect of absolute pressure.

Since five local values of heat transfer coefficients were obtained for each value of overall pressure drop there is much less pressure drop data available. Generally one particular range of liquid subcooling values was associated with particular values of absolute pressure and velocity. At 2000 psia and 20 ft/sec

most of the data were taken with a mean subcooling of around 160°F; however, two runs were made at a liquid subcooling of around 237°F. The curves drawn through points indicate that the effect on pressure drop of liquid subcooling is probably more important than the effect of absolute pressure in ranges of these tests. More test data is needed to explore more fully this effect.

Summary of Results

1. For fully developed flow the non-boiling heat transfer data at 1500 psia and 2000 psia is correlated by the equation

$$\frac{h}{c_p G} \left( \frac{c_p \mu_f}{k} \right)^{2/3} = 0.019 \left( \frac{G D_i}{\mu_f} \right)^{-0.2}$$

2. With surface boiling the heat transfer data plotted against  $(t_w - t_{sat})$ , wall superheat, shows a principal effect due to absolute pressure and a secondary effect due to fluid velocity. At high  $q/A$  values the wall superheat becomes nearly independent of fluid velocity and decreases as pressure increases.
3. For non-boiling heat transfer the friction factors may be correlated by

$$\frac{f_{(isothermal)}}{f_{f,m}} = \left( \frac{\mu_b}{\mu_w} \right)^{0.14}$$

$$\frac{f_{(isothermal)}}{f_f} = \left( \frac{\mu_b}{\mu_w} \right)^{0.60}$$

4. With surface boiling the pressure drop increases with increasing heat flux and decreasing subcooling and decreasing pressure.

### Acknowledgments

The work reported here was sponsored by the Office of Naval Research, Contract N5-ori-07827, NR-035-267. The authors gratefully acknowledge this aid and also the help of the following persons. The many problems associated with the design of the high pressure apparatus were for the most part solved by Mr. Milton W. Raymond, project design engineer, who also originally conceived and successfully built the ion-exchanger with very little design data. The maintenance and operation of the equipment and the gathering of the test data was accomplished by Messrs. William W. Barton, Edward H. Scama, Paul V. Osborn, Francis J. Zimmerman and Frank Mullin, graduate students in the Department of Mechanical Engineering, Massachusetts Institute of Technology.

### Bibliography

1. Kreith, F. and Summerfield, M., "Heat Transfer to Water at High Flux Densities With and Without Surface Boiling," A.S.M.E. Trans., Vol. 71, No. 7, p. 805, Oct., 1949.
2. Kreith, F. and Summerfield, M., "Pressure Drop and Convective Heat Transfer with Surface Boiling at High Heat Flux; Data for Aniline and n-Butyl Alcohol," A.S.M.E. Trans., Vol. 72, No. 6, p. 869, Aug., 1950.
3. Knowles, J. W., "Heat Transfer With Surface Boiling," Canadian Journal of Research, 26A, 268-278, 1948.
4. McAdams, W. H., Kennel, W. E., Minden, C. S., Rudolf, C., Picornell, P. M., Dew, J. E., "Heat Transfer at High Rates to Water With Surface Boiling," Ind. and Eng. Chem., Vol. 41, p. 1945, Sept., 1949.
5. McAdams, W. H., Heat Transmission, McGraw-Hill, 1942.
6. Rohsenow, W. M., Scama, E. H., Osborn, P. V., "Construction and Operation of Apparatus for Study of Heat Transfer with Surface Boiling," Tech. Report No. 2, D.I.C. Project No. 6627, Mass. Inst. of Tech., July, 1950.
7. Clark, J. A. and Rohsenow, W. M., "Statement of Progress for Period 23 July 1950 to 1 September 1950," D.I.C. Project No. 6627, Mass. Inst. of Tech.
8. Wellman, E. J., "A Survey of the Thermodynamic and Physical Properties of Water," M. S. Thesis, Purdue University, 1950.
9. Rohsenow, W. M., and Clark, J. A., "Heat Transfer and Pressure Drop Data for High Heat Flux Densities to Water at High Subcritical Pressures," Heat Transfer and Fluid Mechanics Institute, Stanford, California, June, 1951.
10. Buchberg, H., Romie, F., "Heat Transfer, Pressure Drop, and Burnout Studies With and Without Surface Boiling For De-Aerated and Gassed Water at Elevated Pressures in a Forced Flow System," Heat Transfer and Fluid Mechanics Institute, Stanford, California, June, 1951.




Nomenclature

- A Heat transfer area, sq feet
- $c_p$  Specific heat, Btu/lb °F
- $D_i$  Inner diameter of test section, feet
- E Test section voltage, volts
- G Mass velocity, lb/hr ft<sup>2</sup>
- h Surface coefficient of heat transfer, Btu/hr ft<sup>2</sup>°F
- I Test section current, amperes
- k Thermal conductivity of fluid, Btu/hr ft °F
- $k_o$  Thermal conductivity of tube wall at  $t_o$ , Btu/hr ft °F
- $L_p$  Test section heated length, ft
- $N_{Re,f} = \frac{D_i G}{\mu_f}$
- P Pressure, psia
- $\Delta P_i$  Pressure drop reading across test section, in. H<sub>2</sub>O
- $\Delta P_{f,m}$  Pressure drop due to friction and momentum change, in. H<sub>2</sub>O
- $\Delta P_f$  Pressure drop due to friction alone
- $q/A$  Heat flux density, Btu/hr ft<sup>2</sup>
- $(q/A)_{n-(n-1)} = \frac{1}{2} \left[ (q/A)_n + (q/A)_{(n-1)} \right]$
- $f_f$  Defined by eq. (8)
- $f_{f,m}$  Defined by eq. (9)
- $J = \frac{h}{c_p G} \left( \frac{c_p \mu_f}{k} \right)^{2/3}$
- $r_o$  Outer radius of test section, feet
- $r_i$  Inner radius of test section, feet
- R Resistance, ohms
- $\tau_b$  Test water bulk temperature, °F
- $\tau_{in}$  Test water inlet bulk temperature, °F
- $\tau_{out}$  Test water outlet bulk temperature, °F
- $t_o$  Test section outer wall temperature, °F

- $t_w$  Test section inner wall temperature, °F
- $t_{sat}$  Saturation temperature, °F
- $T_x$  Wall temperature minus saturation temperature,  $t_w - t_{sat}$ , °F
- $V$  Flow velocity, feet/sec
- $w$  Flow rate, lb/hr
- $\Delta X$  =  $(r_o - r_i)$
- $X$  Distance between thermocouple stations, 1.4 inches
- $\rho$  Temperature coefficient of electrical resistivity, °F<sup>-1</sup>
- $\alpha$  Temperature coefficient of thermal conductivity, °F<sup>-1</sup>
- $\bar{\gamma}$  Mean density of fluid in test section, lb<sub>f</sub>/cu ft
- $\gamma_o$  Density of liquid in lead lines to pressure gage, lb<sub>f</sub>/cu ft
- $\rho_o$  Electrical resistivity at  $t_o$ , ohm feet
- $\rho_m$  Electrical resistivity at temperature  $t_m = \frac{1}{\Delta X} \int_{r_i}^{r_o} (t - t_w) dr$
- $\rho$  Mass density of fluid at fluid temperature, lb<sub>m</sub>/cu ft
- $\mu_f$  Viscosity at film temperature,  $\frac{\tau_o + t_w}{2}$ , lb/hr ft

## Figure Captions


1. Layout of Test Apparatus
2. Test Section Assembly
3. Location of Thermocouples and Potential Taps
4. Test Section Voltage Measurement
5. Heat Flux Density and Bulk Temperature Along the Tube, Non-Boiling Run
6. j-Factor vs. Reynolds Number for Forced Convection Without Surface Boiling
7. Heat Flux vs. Temperature Difference for Forced Convection with Surface Boiling of Water at 2000 psia and 20 ft/sec Inlet Velocity
8. Heat Flux vs. Wall Superheat for Forced Convection with Surface Boiling
9. Friction Factor vs. Reynolds Number for Forced Convection without Surface Boiling
10. Correction Factor for Friction Factor with Heat Transfer Without Surface Boiling
11. Effect of Heat Flux on  $\Delta P_{f,m}$
12. Effect of Heat Flux on  $\Delta P_f$
13. Heat Flux vs. Temperature Difference for Forced Convection with Surface Boiling of Water at 2000 psia and 30 ft/sec Inlet Velocity
14. Heat Flux vs. Temperature Difference for Forced Convection with Surface Boiling of Water at 2000 psia and 10 ft/sec Inlet Velocity
15. Heat Flux vs. Temperature Difference for Forced Convection with Surface Boiling of Water at 1500 psia and 30 ft/sec inlet Velocity
16. Heat Flux vs. Temperature Difference for Forced Convection with Surface Boiling of Water at 1500 psia and 20 ft/sec Inlet Velocity
17. Heat Flux vs. Temperature Difference for Forced Convection with Surface Boiling of Water at 1500 psia and 10 ft/sec Inlet Velocity




LAYOUT OF TEST APPARATUS

FIGURE 1







LOCATION OF THERMOCOUPLES AND POTENTIAL TAPS

FIGURE 3

TEST SECTION VOLTAGE MEASUREMENT




FIGURE 4




FIGURE 5






FIGURE 6




FIGURE 7




FIGURE 8




FIGURE 9






FIGURE 10




FIGURE II







FIGURE 12



$$\Delta t = t_w - t_b$$










FIG 16

DIC 6627-MIT

$\Delta t = t_w - t_b$




FIG 17



Table I Heat Transfer Data Without Surface Boiling

Run No.	Station	P <sub>in</sub> psia	V <sub>in</sub> f.p.s.	G lb m sec/ft <sup>2</sup>	t <sub>in</sub> °F	t <sub>out</sub> °F	ΔP "H <sub>2</sub> O	Nu <sub>D</sub>	Re <sub>f</sub> x10 <sup>-3</sup>	$\frac{C_p \mu}{k}$	$f$ x10 <sup>-3</sup>	
19-1	2	2000	29	1570	410	437	152	503	292	.82	1.84	
	3							477	300	.77	1.7	
	4							482	302	.82	1.7	
	5							479	303	.82	1.6	
	6							471	307	.80	1.6	
20-1	2	2000	29.8	1585	400	436		468	299	.85	1.6	
	3							475	305	.785	1.6	
	4							458	307	.78	1.6	
	5							461	309	.79	1.6	
	6							462	311	.795	1.6	
20-2	2	2000	29.9	1585	406	454		448	314	.765	1.5	
	3							442	323	.76	1.5	
	4							444	329	.755	1.4	
	5							444	332	.745	1.4	
	6							445	339	.73	1.4	
21-1	2	2000	29.8	1561	427	482	140	443	329	.75	1.4	
	3							443	341	.73	1.4	
	4							442	348	.73	1.4	
	5							447	353	.715	1.4	
	6							446	359	.715	1.3	
22-1	2	2000	30.0	1558	446	498	150	481	343	.73	1.5	
	3							478	350	.715	1.5	
	4							472	353	.715	1.5	
	5							483	359	.725	1.5	
	6							478	373	.72	1.4	
22-2	2	2000	30.0	1548	453	520	155	495	360	.695	1.5	
	3											
	4											
	5											
	6											
23-1	2	2000	29.9	1585	383	388	193	441	254	.945	1.7	
	3							434	254	.94	1.7	
	4							402	355	.94	1.6	
	5							397	256	.935	1.5	
	6							391	256	.925	1.5	

Table I Heat Transfer Data Without Surface Boiling (cont.)

Run No.	Station	Pin psia	Vin f.p.s.	G lb sec/ft <sup>2</sup>	t <sub>in</sub> °F	t <sub>out</sub> °F	ΔP "H <sub>2</sub> O	Nu <sub>b</sub>	Re <sub>f</sub> x 10 <sup>-3</sup>	$\frac{C_p \mu}{k}$	J x 10 <sup>-3</sup>
23-2	2	2000	30.0	1562	442	502	130	498	346	.735	1.60
	3							502	356		
	4							506	362		
	5										
	6										
23-3	2	2000	30.0	1570	444	504	130	503	349	.725	1.61
	3							493	356		
	4							477	368		
	5										
	6										
33-11	2	2000	30.0	1618	386	470		453	345	.705	1.48
	3						446	361			
	4										
	5										
	6										
23-4	2	2000	19.9	1051	407	462	64.5	338	210	.785	1.74
	3							335	217		
	4							330	221		
	5							327	228		
	6							324	233		
23-5	2	2000	20.0	1049	426	491	63.5	347	226	.735	1.70
	3							341	233		
	4							332	238		
	5							349	243		
	6										
23-6	2	2000	20.0	1043	438	514	67	350	241	.705	1.63
	3										
	4										
	5										
	6										
30-1	2	2000	20.1	1099	373	414	53.6	313	197	.835	1.69
	3							326	198		
	4							315	202		
	5							314	207		
	6							313	210		

Table I Heat Transfer Data Without Surface Boiling

Run No.	Station	Pin psia	Vin f.p.s.	$G^3$ $\frac{lb}{m^2 \cdot sec}$	$t_{in}$ °F	$t_{out}$ °F	$\Delta P$ "H <sub>2</sub> O	$Nu_b$	$Re_f$ $\times 10^{-3}$	$\frac{C_{eff}}{K}$	$J_{10}$
30-2	2	2000	20.0	1083	409	467	52.9	315	225		
	3							332	226	.740	1.55
	4							321	236	.745	1.55
	5							321	241	.72	1.52
	6							317	244	.715	1.49
31-1	2	2000	20.1	1132	327	358	57.2	311	170	.71	1.46
	3							322	173	.96	1.86
	4							308	178	.935	1.91
	5							308	180	.916	1.78
	6							304	181	.90	1.77
31-2	2	2000	20.0	1111	350	391	55	311	187	.89	1.74
	3							325	189	.855	1.75
	4							308	195	.865	1.80
	5							315	199	.835	1.63
	6							309	202	.825	1.69
31-3	2	2000	20.1	1100	382	429	54.3	324	203	.820	1.64
	3							334	209	.805	1.72
	4							321	212	.785	1.73
	5							323	217	.785	1.64
	6							319	222	.765	1.63
31-4	2	2000	20.4	1083	408	466	52.2	327	221	.750	1.53
	3							338	226	.745	1.63
	4							325	233	.745	1.65
	5							328	239	.725	1.55
	6							328	244	.710	1.54
31-5	2	2000	20.3	1063	431	504	53	354	239	.720	1.50
	3							347	246	.710	1.66
	4									.720	1.57
	5										
	6										
31-9	2	2000	20.2	1130	340	454	62	331	236	.70	1.58
	3										
	4										
	5										
	6										

Table I Heat Transfer Data Without Surface Boiling (cont.)

Run No.	Station	Pin psia	Vin f.p.s.	G $\frac{\text{lb}_m}{\text{sec/ft}^2}$	$t_{in}$ °F	$t_{out}$ °F	$\Delta P$ "H <sub>2</sub> O	$Nu_b$	$Re_1$ $\times 10^{-3}$	$\frac{C_{p44}}{k}$	$\frac{L}{D} \times 10^3$
34-2	2	2000	10	590	223	252	25	163	59.9	1.38	2.42
	3							164	61.3	1.35	2.42
	4							157	63.8	1.31	2.35
	5							160	64.7	1.28	2.28
	6							161	66.1	1.25	2.26
34-3	2	2000	10	544	371	470	22.9	168	113	.715	1.66
	3							183	118	.690	1.81
	4							198	122	.685	1.86
	5										
	6										
34-4	2	2000	10	560	389	512	22.9				
	3										
	4										
	5										
	6							275	124	.695	2.50
35-1	2	2000	10.0	548	355	370					
	3						173	84.1	.945	2.10	
	4						169	85.3	.940	2.02	
	5						159	86.5	.940	1.88	
	6						155	86.8	.930	1.83	
							157	87.1	.935	1.85	
35-2	2	2000	10.0	552	357	405					
	3						172	94.8	.855	1.92	
	4						177	97.9	.830	1.92	
	5						166	100	.830	1.77	
	6						169	102	.820	1.77	
							172	104	.795	1.79	
32-1	2	1500	30.0	1727	305	318	117				
	3							404	227	1.06	1.71
	4							422	228	1.06	1.78
	5							403	230	1.04	1.78
	6							406	232	1.04	1.77
								397	234	1.04	1.72
32-2	2	1500	30.0	1711	314	333	114				
	3							439	238	1.01	1.84
	4							432	242	.995	1.79
	5							413	244	.990	1.70
	6							409	245	.990	1.68
								412	280	.990	1.68

Table I Heat Transfer Data Without Surface Boiling (cont.)

5

Run No.	Station	Pin psia	Vin f.p.s.	G $\frac{\text{lb}_m}{\text{sec/ft}^2}$	$t_{in}$ °F	$t_{out}$ °F	$\Delta P$ "H <sub>2</sub> O	$\frac{q}{A}$ $\times 10^{-3}$	$\frac{q}{A}$ $\times 10^{-3}$	$\frac{q}{A}$ $\times 10^{-3}$	$\frac{q}{A}$ $\times 10^{-3}$
32-3	2	1500	30.0	1665	348	373	110	442	262	.910	1.77
	3							433	264	.910	1.77
	4							414	268	.910	1.77
	5							413	272	.895	1.58
	6							405	276	.875	1.54
32-4	2	1500	30.0	1641	379	412	106	455	291	.850	1.61
	3							446	295	.825	1.52
	4							426	299	.820	1.55
	5							428	303	.810	1.52
	6							421	312	.795	1.4
32-5	2	1500	30.2	1570	423	467	102	439	321	.765	1.44
	3							461	327	.745	1.42
	4							442	335	.740	1.42
	5							441	341	.730	1.44
	6							438	349	.715	1.4
33-2	2	1500	20.6	1161	323	357	56.2	323	174	.960	1.81
	3							317	177	.940	1.83
	4							307	182	.910	1.74
	5							305	185	.895	1.71
	6							302	188	.885	1.67
33-3	2	1500	20.2	1090	376	427	52.2	334	201	.820	1.73
	3							330	206	.795	1.73
	4							319	211	.770	1.65
	5							320	216	.770	1.67
	6							316	222	.760	1.58
35-3	2	1500	10.0	545	355	404	16.4	177	94	.845	1.93
	3							178	96.5	.835	1.96
	4							169	98.8	.825	1.83
	5							169	100	.810	1.82
	6							171	103	.790	1.79
35-4	2	1500	10.0	549	357	439	16.4	182	105	.785	1.83
	3							181	109	.765	1.82
	4							175	114	.730	1.72
	5										
	6										

Cp 4  
FJ  
x 10<sup>-3</sup>



TABLE II

## HEAT TRANSFER DATA WITH SURFACE BOILING

Run No.	Station	G lb lb/sec.ft <sup>2</sup>	p psia	V <sub>in</sub> ft/sec.	t <sub>w</sub> °F	τ °F	T <sub>x</sub> °F	Δt subcool °F	q/A Btu/hr.ft <sup>2</sup>	T <sub>x</sub> avg.
21-2	2	1585	2000	30.1	641.5	445	5.7	191	2.4 x 10 <sup>6</sup>	6.5
	3				642.5	457	6.7	179	2.4 x 10 <sup>6</sup>	
	4				643.5	469	7.7	167	2.41 x 10 <sup>6</sup>	
	5				641.5	481	5.7	155	2.40 x 10 <sup>6</sup>	
	6				642.5	493	6.7	143	2.40 x 10 <sup>6</sup>	
21-3	2	1561	2000	29.9	641	448	5.2	188	2.57 x 10 <sup>6</sup>	6.6
	3				642	461	6.2	175	2.58 x 10 <sup>6</sup>	
	4				643.5	473.5	7.7	152.5	2.59 x 10 <sup>6</sup>	
	5				642	486	6.2	150	2.58 x 10 <sup>6</sup>	
	6				643.5	499	7.7	137	2.59 x 10 <sup>6</sup>	
22-2	3	1548	2000	30.0	640	476.5	4.2	159.5	2.04 x 10 <sup>6</sup>	5.45
	4				642	486.5	6.2	149.5	2.055 x 10 <sup>6</sup>	
	5				641	496.5	5.2	139.5	2.054 x 10 <sup>6</sup>	
	6				642	506.5	6.2	129.5	2.055 x 10 <sup>6</sup>	
22-3	2	1553	2000	30.0	642	468.5	6.2	167.5	2.44 x 10 <sup>6</sup>	7.8
	3				643	480	7.2	156	2.44 x 10 <sup>6</sup>	
	4				645	492	9.2	144	2.44 x 10 <sup>6</sup>	
	5				644	504	8.2	132	2.44 x 10 <sup>6</sup>	
	6				644	516	8.2	120	2.44 x 10 <sup>6</sup>	
22-4	2	1553	2000	30.0	644	473	8.2	163	2.89 x 10 <sup>6</sup>	9.8
	3				645	487	9.2	149	2.90 x 10 <sup>6</sup>	
	4				647	501	11.2	135	2.90 x 10 <sup>6</sup>	
	5				646	515	10.2	121	2.90 x 10 <sup>6</sup>	
	6				646	529	10.2	107	2.90 x 10 <sup>6</sup>	
22-5	2	1553	2000	30.0	646	471.5	10.2	164.5	2.895 x 10 <sup>6</sup>	10.8
	3				646	485.5	10.2	150.5	2.895 x 10 <sup>6</sup>	
	4				648	499.5	12.2	136.5	2.91 x 10 <sup>6</sup>	
	5				646	513.5	10.2	122.5	2.895 x 10 <sup>6</sup>	
	6				647	527.5	11.2	108.5	2.91 x 10 <sup>6</sup>	
22-6	2	1548	2000	30.0	647	473	11.2	163	3.15 x 10 <sup>6</sup>	11.4
	3				647	489	11.2	147	3.15 x 10 <sup>6</sup>	
	4				649	505	13.2	131	3.16 x 10 <sup>6</sup>	
	5				647	520	11.2	116	3.15 x 10 <sup>6</sup>	
	6				646	534	10.2	102	3.15 x 10 <sup>6</sup>	
22-7	2	1548	2000	30.0	646.5	471	10.7	165	3.12 x 10 <sup>6</sup>	10.1
	3				646.5	486.5	10.7	149.5	3.12 x 10 <sup>6</sup>	
	4				646.5	501.5	10.7	134.5	3.12 x 10 <sup>6</sup>	
	5				645.5	516.5	9.7	119.5	3.12 x 10 <sup>6</sup>	
	6				644.5	531.5	8.7	104.5	3.11 x 10 <sup>6</sup>	



TABLE II

HEAT TRANSFER DATA WITH SURFACE BOILING

Run No.	Station	G lb lb/sec.ft <sup>2</sup>	p psia	Vin ft/sec.	tw °F	T °F	Tx °F	Δt subcool °F	q/A Btu/hr.ft <sup>2</sup>	Tx avg.
23-2	5	1562	2000	30.0	640.5	481	4.7	155	1.86 x 10 <sup>6</sup>	4.7
	6				640.5	489.5	4.7	146.5	1.86 x 10 <sup>6</sup>	
23-3	5	1570	2000	30.0	641	483	5.2	153	1.86 x 10 <sup>6</sup>	4.2
	6				639	491.5	3.2	144.5	1.86 x 10 <sup>6</sup>	
33-11	4	1618	2000	30.0	643.5	428	7.7	208	2.53 x 10 <sup>6</sup>	7.33
	5				643.5	440.5	7.7	195.5	2.53 x 10 <sup>6</sup>	
	6				642.5	453	6.7	183	2.53 x 10 <sup>6</sup>	
33-12	2	1610	2000	30.0	642	416.5	6.2	219.5	2.75 x 10 <sup>6</sup>	7.0
	3				643.5	430	7.7	206	2.76 x 10 <sup>6</sup>	
	4				644	443.5	8.2	192.5	2.76 x 10 <sup>6</sup>	
	5				643	457	7.2	179	2.76 x 10 <sup>6</sup>	
	6				641.5	470.5	5.7	165.5	2.75 x 10 <sup>6</sup>	
33-13	2	1602	2000	29.7	644.5	423	8.7	213	3.00 x 10 <sup>6</sup>	8.1
	3				644.5	438	8.7	198	3.00 x 10 <sup>6</sup>	
	4				644.5	453	8.7	183	3.00 x 10 <sup>6</sup>	
	5				643.5	468	7.7	168	3.00 x 10 <sup>6</sup>	
	6				642.5	483	6.7	153	2.99 x 10 <sup>6</sup>	
23-6	3	1043	2000	20.0	639	465	3.2	171	1.57 x 10 <sup>6</sup>	5.7
	4				642	476	6.2	160	1.58 x 10 <sup>6</sup>	
	5				643	487	7.2	149	1.58 x 10 <sup>6</sup>	
	6				642	499	6.2	137	1.58 x 10 <sup>6</sup>	
23-5	6	1049	2000	20.0	639.5	478	3.7	158	1.37 x 10 <sup>6</sup>	3.7
30-3	2	1051	2000	20.1	642.5	454	6.7	182	1.78 x 10 <sup>6</sup>	7.9
	3				643.5	467	7.7	169	1.78 x 10 <sup>6</sup>	
	4				644.5	479	8.7	157	1.79 x 10 <sup>6</sup>	
	5				644.5	492	8.7	144	1.79 x 10 <sup>6</sup>	
	6				643.5	505	7.7	131	1.78 x 10 <sup>6</sup>	
30-4	2	1052	2000	20.1	643	460	7.2	176	2.03 x 10 <sup>6</sup>	8.3
	3				643.5	475	7.7	161	2.03 x 10 <sup>6</sup>	
	4				645	489	9.2	147	2.03 x 10 <sup>6</sup>	
	5				645	504	9.2	132	2.03 x 10 <sup>6</sup>	
	6				644	519	8.2	117	2.03 x 10 <sup>6</sup>	
30-5	2	1059	2000	20.1	644.5	450	8.7	186	2.21 x 10 <sup>6</sup>	9.6
	3				645	466	9.2	170	2.20 x 10 <sup>6</sup>	
	4				646.5	482	10.7	154	2.23 x 10 <sup>6</sup>	
	5				646	498	10.2	138	2.23 x 10 <sup>6</sup>	
	6				645	514	9.2	122	2.23 x 10 <sup>6</sup>	

TABLE II

## HEAT TRANSFER DATA WITH SURFACE BOILING

Run No.	Station	G lb lb/sec.ft <sup>2</sup>	p psia	V <sub>in</sub> ft/sec.	t <sub>w</sub> °F	T °F	T <sub>x</sub> °F	Δt subcool °F	q/A Btu/hr.ft <sup>2</sup>	T <sub>x</sub> avg.
30-6	2	1059	2000	20.1	643	445	7.2	191	2.02 x 10 <sup>6</sup>	7.8
	3				644	459	8.2	177	2.02 x 10 <sup>6</sup>	
	4				644	474	8.2	162	2.03 x 10 <sup>6</sup>	
	5				644	488	8.2	148	2.03 x 10 <sup>6</sup>	
	6				643	503	7.2	133	2.03 x 10 <sup>6</sup>	
31-5	4	1063	2000	20.3	643	468	7.2	168	1.54 x 10 <sup>6</sup>	7.2
	5				643	479	7.2	157	1.54 x 10 <sup>6</sup>	
	6				643	489	7.2	147	1.54 x 10 <sup>6</sup>	
31-6	2	1060	2000	20.3	642.5	452	6.7	184	1.74 x 10 <sup>6</sup>	7.9
	3				643.5	464	7.7	172	1.74 x 10 <sup>6</sup>	
	4				644.5	477	8.7	159	1.74 x 10 <sup>6</sup>	
	5				644.5	489	8.7	147	1.74 x 10 <sup>6</sup>	
	6				643.5	502	7.7	134	1.74 x 10 <sup>6</sup>	
31-7	2	1057	2000	20.1	643.5	440	7.7	196	1.91 x 10 <sup>6</sup>	8.3
	3				644.5	454	8.7	182	1.92 x 10 <sup>6</sup>	
	4				644.5	468	8.7	168	1.92 x 10 <sup>6</sup>	
	5				644.5	482	8.7	154	1.92 x 10 <sup>6</sup>	
	6				643.5	495	7.7	141	1.91 x 10 <sup>6</sup>	
31-8	2	1057	2000	20.1	644.5	204.5	8.7	196	2.09 x 10 <sup>6</sup>	8.9
	3				645.5	190.5	9.7	181	2.11 x 10 <sup>6</sup>	
	4				645.5	175.5	9.7	166	2.11 x 10 <sup>6</sup>	
	5				644.5	159.5	8.7	151	2.09 x 10 <sup>6</sup>	
	6				643.5	143.5	7.7	136	2.07 x 10 <sup>6</sup>	
31-9	3	1130	2000	20.2	645	380	9.2	256	2.34 x 10 <sup>6</sup>	9.95
	4				647	397	11.2	239	2.34 x 10 <sup>6</sup>	
	5				646	413	10.2	213	2.34 x 10 <sup>6</sup>	
	6				645	430	9.2	206	2.34 x 10 <sup>6</sup>	
31-10	2	1118	2000	20.1	643.5	365	7.7	271	2.53 x 10 <sup>6</sup>	8.9
	3				645.5	384	9.7	252	2.54 x 10 <sup>6</sup>	
	4				646.5	403	10.7	234	2.54 x 10 <sup>6</sup>	
	5				644.5	421	8.7	216	2.54 x 10 <sup>6</sup>	
	6				643.5	439	7.7	197	2.53 x 10 <sup>6</sup>	
34-3	5	544	2000	10.0	639.5	434	3.7	200	1.08 x 10 <sup>6</sup>	4.7
	6				641.5	450	5.7	185	1.08 x 10 <sup>6</sup>	
34-4	2	560	2000	10.0	642	413.5	6.2	222.5	1.29 x 10 <sup>6</sup>	(4.8)
	3				638	431.5	2.2	204.5	1.28 x 10 <sup>6</sup>	
	5				641	467.5	5.2	168.5	1.29 x 10 <sup>6</sup>	
	6				641.5	485.5	5.7	150.5	1.29 x 10 <sup>6</sup>	

TABLE II

## HEAT TRANSFER DATA WITH SURFACE BOILING

Run No.	Station	G lb lb/sec.ft <sup>2</sup>	p psia	V <sub>in</sub> ft/sec.	t <sub>w</sub> °F	T °F	T <sub>x</sub> °F	Δt subcool °F	q/A Btu/hr.ft <sup>2</sup>	T <sub>x</sub> avg.
34-5	2	541	2000	10.0	641.5	415	5.7	221	1.46 x 10 <sup>6</sup>	7.1
	3				643	436	7.2	200	1.47 x 10 <sup>6</sup>	
	4				644.5	457	8.7	179	1.47 x 10 <sup>6</sup>	
	5				643.5	478	7.7	158	1.47 x 10 <sup>6</sup>	
	6				642	499	6.2	137	1.46 x 10 <sup>6</sup>	
34-6	2	545	2000	10.0	642.5	407	6.7	229	1.61 x 10 <sup>6</sup>	7.5
	3				643.5	430	7.7	206	1.62 x 10 <sup>6</sup>	
	4				645	453	9.2	183	1.62 x 10 <sup>6</sup>	
	5				643.5	476	7.7	160	1.62 x 10 <sup>6</sup>	
	6				642	499	6.2	137	1.61 x 10 <sup>6</sup>	
34-7	2	550	2000	9.8	643	346	7.2	290	1.82 x 10 <sup>6</sup>	7.8
	3				644	374	8.2	262	1.82 x 10 <sup>6</sup>	
	4				645	402	9.2	234	1.82 x 10 <sup>6</sup>	
	5				643.5	428	7.7	212	1.82 x 10 <sup>6</sup>	
	6				642.5	454	6.7	182	1.81 x 10 <sup>6</sup>	
32-6	2	1552	1500	29.9	604	451.5	7.8	144.5	1.82 x 10 <sup>6</sup>	11.5 (12.4)
	3				607	460.5	10.8	135.5	1.84 x 10 <sup>6</sup>	
	4				610	469.5	13.8	127.5	1.85 x 10 <sup>6</sup>	
	5				609	478.5	12.8	118.5	1.84 x 10 <sup>6</sup>	
	6				608.5	487.5	12.3	108.5	1.84 x 10 <sup>6</sup>	
32-7	2	1552	1500	29.9	608.5	445.5	12.8	150.5	2.09 x 10 <sup>6</sup>	13.5
	3				610	456	13.8	140	2.10 x 10 <sup>6</sup>	
	4				611	466.5	14.8	129.5	2.11 x 10 <sup>6</sup>	
	5				609.5	477	13.3	119	2.10 x 10 <sup>6</sup>	
	6				609	487.5	12.8	108.5	2.10 x 10 <sup>6</sup>	
32-8	2	1618	1500	30.0	600.5	406	4.3	190	2.25 x 10 <sup>6</sup>	10.7 (12.3)
	3				607	417.5	10.8	178.5	2.28 x 10 <sup>6</sup>	
	4				609.5	429	13.3	167	2.29 x 10 <sup>6</sup>	
	5				609	440.5	12.8	155.5	2.29 x 10 <sup>6</sup>	
	6				608.5	452	12.3	144	2.29 x 10 <sup>6</sup>	
32-9	2	1610	1500	29.8	607	413.5	10.8	182.5	2.40 x 10 <sup>6</sup>	12.6
	3				609.5	425.5	13.3	170.5	2.42 x 10 <sup>6</sup>	
	4				610	437.5	13.8	159.5	2.42 x 10 <sup>6</sup>	
	5				609	449.5	12.8	146.5	2.42 x 10 <sup>6</sup>	
	6				608.5	461.5	12.3	134.5	2.41 x 10 <sup>6</sup>	
32-10	2	1610	1500	29.8	610	414.5	13.8	181.5	2.58 x 10 <sup>6</sup>	14.1
	3				610.5	427.5	14.3	169.5	2.59 x 10 <sup>6</sup>	
	4				610.5	440.5	14.3	155.5	2.59 x 10 <sup>6</sup>	
	5				610.5	453.5	14.3	142.5	2.59 x 10 <sup>6</sup>	
	6				610	466.5	13.8	129.5	2.58 x 10 <sup>6</sup>	

TABLE II

HEAT TRANSFER DATA WITH SURFACE BOILING

Run No.	Station	G lb/sec.ft <sup>2</sup>	p psia	V <sub>in</sub> ft/sec.	t <sub>w</sub> °F	T °F	T <sub>x</sub> °F	Δt subcool °F	q/A Btu/hr.ft <sup>2</sup>	T <sub>x</sub> avg.
32-11	2	1593	1500	29.7	611	414.5	14.8	181.5	2.75 x 10 <sup>6</sup>	14.5
	3				611	428	14.8	168	2.75 x 10 <sup>6</sup>	
	4				611	442	14.8	154	2.75 x 10 <sup>6</sup>	
	5				610.5	456	14.3	140	2.75 x 10 <sup>6</sup>	
	6				609.5	469.5	13.3	126.5	2.74 x 10 <sup>6</sup>	
33-4	2	1051	1500	20.1	606	444	9.8	152	1.40 x 10 <sup>6</sup>	12.4
	3				608.5	454	12.3	142	1.41 x 10 <sup>6</sup>	
	4				610	464	13.8	132	1.42 x 10 <sup>6</sup>	
	5				609.5	474	13.3	122	1.42 x 10 <sup>6</sup>	
	6				609	484	12.8	112	1.42 x 10 <sup>6</sup>	
33-5	2	1059	1500	20.1	609.5	441	13.3	155	1.62 x 10 <sup>6</sup>	13.8
	3				610.5	452.5	14.3	143.5	1.62 x 10 <sup>6</sup>	
	4				610.5	464	14.3	132	1.62 x 10 <sup>6</sup>	
	5				610	475.5	13.8	120.5	1.62 x 10 <sup>6</sup>	
	6				609.5	487	13.3	109	1.62 x 10 <sup>6</sup>	
33-6	2	1051	1500	20.0	610.5	443.5	14.3	152.5	1.81 x 10 <sup>6</sup>	14.4
	3				611.5	457	15.3	139	1.82 x 10 <sup>6</sup>	
	4				611	470	14.8	126	1.81 x 10 <sup>6</sup>	
	5				610.5	483.5	14.3	112.5	1.81 x 10 <sup>6</sup>	
	6				609.5	496.5	13.3	99.5	1.81 x 10 <sup>6</sup>	
33-7	2	1051	1500	20.0	611.5	441	15.3	155	1.91 x 10 <sup>6</sup>	15.2
	3				612	455	15.8	141	1.91 x 10 <sup>6</sup>	
	4				611.5	469	15.3	127	1.91 x 10 <sup>6</sup>	
	5				610.5	483	14.3	113	1.90 x 10 <sup>6</sup>	
	6				609.5	497	13.3	99	1.90 x 10 <sup>6</sup>	
33-8	2	1050	1500	20.0	613	445	16.8	151	2.06 x 10 <sup>6</sup>	15.2
	3				612.5	461	16.3	135	2.06 x 10 <sup>6</sup>	
	4				611.5	476	15.3	120	2.05 x 10 <sup>6</sup>	
	5				610.5	491	14.3	105	2.05 x 10 <sup>6</sup>	
	6				609.5	506	13.3	90	2.04 x 10 <sup>6</sup>	
33-9	2	1051	1500	20.1	612	449	15.8	147	2.32 x 10 <sup>6</sup>	14.8
	3				612	465.5	15.8	130.5	2.31 x 10 <sup>6</sup>	
	4				611	482	14.8	114	2.31 x 10 <sup>6</sup>	
	5				610.5	498.5	14.3	97.5	2.31 x 10 <sup>6</sup>	
	6				609.5	515	13.3	81	2.30 x 10 <sup>6</sup>	
33-10	2	1057	1500	20.1	611.5	437	15.3	159	2.49 x 10 <sup>6</sup>	14.4
	3				611.5	455	15.3	141	2.49 x 10 <sup>6</sup>	
	4				610.5	473	14.3	123	2.48 x 10 <sup>6</sup>	
	5				610.0	491	13.8	105	2.48 x 10 <sup>6</sup>	
	6				609.5	509	13.3	97	2.48 x 10 <sup>6</sup>	



TABLE II

## HEAT TRANSFER DATA WITH SURFACE BOILING

Run No.	Station	G lb lb/sec.ft <sup>2</sup>	p psia	Vin ft/sec.	tw °F	$\bar{T}$ °F	Tx °F	$\Delta t$ subcool °F	q/A Btu/hr.ft <sup>2</sup>	Tx avg
35-4	5	549	1500	10.02	603.5	410	7.3	186	.896 x 10 <sup>6</sup>	8.8
	6				606.5	422	10.3	174	.896 x 10 <sup>6</sup>	
35-5	2	543	1500	10.02	605	398.5	8.8	197.5	1.12 x 10 <sup>6</sup>	10.6
	3				606	415	9.8	181	1.13 x 10 <sup>6</sup>	
	4				608	431.5	11.8	164.5	1.14 x 10 <sup>6</sup>	
	5				607.5	448	11.3	148	1.14 x 10 <sup>6</sup>	
	6				607.5	464.5	11.3	131.5	1.14 x 10 <sup>6</sup>	
35-6	2	541	1500	10.03	604	422.5	7.8	173.5	1.39 x 10 <sup>6</sup>	8.3
	3				604	442	7.8	154	1.39 x 10 <sup>6</sup>	
	4				605	461.5	8.8	134.5	1.39 x 10 <sup>6</sup>	
	5				604.5	481	8.3	115	1.39 x 10 <sup>6</sup>	
	6				604	500.5	7.8	95.5	1.39 x 10 <sup>6</sup>	
35-7	2	541	1500	10.01	604.5	415	8.3	181	1.56 x 10 <sup>6</sup>	8.0
	3				604.5	437	8.3	159	1.56 x 10 <sup>6</sup>	
	4				604.5	459	8.3	137	1.56 x 10 <sup>6</sup>	
	5				604.5	481	8.3	115	1.56 x 10 <sup>6</sup>	
	6				603	503	6.8	93	1.55 x 10 <sup>6</sup>	
35-8	2	559	1500	9.9	606.5	344	10.3	252	1.81 x 10 <sup>6</sup>	9.7
	3				606.5	370	10.3	226	1.81 x 10 <sup>6</sup>	
	4				606.5	396	10.3	200	1.81 x 10 <sup>6</sup>	
	5				605.5	422	9.3	174	1.80 x 10 <sup>6</sup>	
	6				604.5	448	8.3	148	1.80 x 10 <sup>6</sup>	
35-9	2	556	1500	9.9	607	355	10.8	241	1.85 x 10 <sup>6</sup>	9.4
	3				606.5	382	10.3	234	1.84 x 10 <sup>6</sup>	
	4				606.5	409	10.3	187	1.84 x 10 <sup>6</sup>	
	5				604.5	436	8.3	160	1.84 x 10 <sup>6</sup>	
	6				603.5	463	7.3	133	1.83 x 10 <sup>6</sup>	





Table IV PRESSURE DROP WITH SURFACE BOILING

Run No.	p psia.	$V_{in}$ ft/sec	G lb <sub>m</sub> /sec.ft <sup>2</sup>	$q/A \times 10^{-6}$ Btu/hr.ft <sup>2</sup>	$t_{w,avg}$ F	$\tau_{in}$ F	$\tau_{out}$ F	$t_{sat\ avg}$ F	$\Delta P_{fm}$ "H <sub>2</sub> O	$\Delta P_f$ "H <sub>2</sub> O
33-11	2000	30.0	1618	2.53	643	386	470			
12		30.0	1610	2.76	643	398	491	208	111.1	90.1
13		29.7	1602	3.00	644	403	503	191	115.8	90.3
30-3	2000	20.1	1051	1.78	644	436	523	183	123.1	94.8
4		20.1	1052	2.03	644	440	539	156	97.0	44.7
5		20.1	1059	2.23	645	428	537	146	63.8	49.5
6		20.1	1059	2.20	644	424	523	153	65.6	50.3
31-5		20.3	1063	1.54	643	431	504	162	65.7	51.9
6		20.3	1060	1.74	644	435	519	168	53.5	43.7
7		20.1	1057	1.92	644	421	514	159	57.7	46.1
8		20.1	1057	2.10	645	420	520	168	62.6	50.3
9		20.2	1130	2.34	646	340	454	166	62.7	49.5
10		20.1	1118	2.54	645	340	464	239	59.9	47.8
34-5	2000	10.0	541	1.47	643	387	527	234	60.5	47.2
6		10.0	545	1.62	643	376	531	179	26.8	21.9
7		9.8	550	1.82	644	309	487	182	29.6	24.3
32-6	1500	29.9	1552	1.84	608	439	500	242	31.1	25.3
7		29.9	1552	2.10	609	431	501	107	107.5	89.5
8		30.0	1618	2.29	608	390	468	130	118.1	97.5
9		29.8	1610	2.42	609	397	478	167	115.4	95.1
10		29.8	1610	2.59	610	397	484	158	117.3	96.1
11		29.7	1593	2.75	611	396	489	156	123.0	99.5
31-4	1500	20.1	1051	1.42	609	430	499	154	126.0	101.0
5		20.1	1059	1.62	610	425	504	132	55.6	46.4
6		20.0	1051	1.81	610	426	515	131	61.2	52.6
7		20.0	1051	1.91	611	422	517	125	67.7	55.2
8		20.0	1050	2.05	611	426	527	126	72.0	59.2
9		20.1	1051	2.31	611	427	539	119	74.3	60.3
10		20.1	1057	2.59	611	413	534	113	81.8	54.0
35-5	1500	10.0	543	1.14	607	376	487	122	84.6	66.7
6		10.0	541	1.39	604	396	528	164	22.6	19.3
7		10.0	541	1.56	604	385	534	134	26.7	22.2
8		9.9	559	1.81	606	309	485	136	27.7	22.5
9		9.9	556	1.84	606	319	499	199	27.9	21.9
								187	29.0	24.0

DISTRIBUTION LIST

April 27, 1950

Chief of Naval Research Department of the Navy Washington 25, D. C. Attn: Code 438 (2)	Library of Congress Washington 25, D. C. Attn: Navy Research Section (2)
Director, Naval Research Laboratory Washington 25, D. C. Attn: Tech. Info. Officer (9) Technical Library (1) Mechanics Division (2)	Research and Development Board Department of Defense Pentagon Building Washington 25, D. C. Attn: Library (Code 3D-1075) (1)
Commanding Officer Office of Naval Research Branch Office 495 Summer Street Boston 10, Mass. (2)	Chief of Bureau of Aeronautics Navy Department Washington 25, D. C. Attn: TD-41, Technical Library (1) PP-22 (1)
Commanding Officer Office of Naval Research Branch Office 346 Broadway New York 13, N. Y. (1)	Chief of Bureau of Ordnance Navy Department Washington 25, D. C. Attn: Ad-3, Technical Library (2)
Commanding Officer Office of Naval Research Branch Office 844 N. Rush Street Chicago 11, Illinois (1)	Chief of Bureau of Ships Navy Department Washington 25, D. C. Attn: Director of Research (2) Code 390 (3) Code 646 (2) Code 432 (1)
Commanding Officer Office of Naval Research Branch Office 801 Donahue Street San Francisco 24, Calif. (1)	Superintendent Post Graduate School U. S. Naval Academy Annapolis, Maryland (1)
Commanding Officer Office of Naval Research Branch Office 1030 Green Street Pasadena, Calif. (1)	Naval Ordnance Laboratory White Oak, Maryland RFD 1, Silver Spring, Maryland Attn: Mechanics Division (1)
Contract Administrator, SE Area Office of Naval Research Department of the Navy Washington 25, D. C. Attn: Mr. R. F. Lynch (1)	Naval Ordnance Test Station Inyokern, California Attn: Scientific Officer (1)
Assistant Naval Attache for Research London U. S. Navy FPO 100 New York, N. Y. (5)	Director, Naval Engineering Experiment Station Annapolis, Maryland (2)
	Chief of Staff Department of the Army The Pentagon Washington 25, D. C. Attn: Director of Research and Development (1)

Distribution List (cont.)

Office of Chief of Ordnance Research and Development Service Department of the Army The Pentagon Washington 25, D. C. Attn: OPDTB	(1)	Professor W. H. McAdams Department of Chemical Engineering Massachusetts Institute of Technology Cambridge 39, Massachusetts	(1)
Commanding General U. S. Air Forces The Pentagon Washington 25, D. C. Attn: Research & Development Div.	(1)	Professor A. L. London Department of Mechanical Engineering Stanford University Stanford, California	(1)
Office of Air Research Wright-Patterson Air Force Base Dayton, Ohio Attn: Chief, Applied Mechanics Group	(1)	Professor Warren Rohsenow Mechanical Engineering Department Massachusetts Institute of Technology Cambridge 39, Massachusetts	(15)
U. S. Atomic Energy Commission Division of Research Washington, D. C.	(1)	Lt. Cdr. E. P. Wilkinson c/o U. S. Atomic Energy Commission P. O. Box 1105 Pittsburgh 30, Pa.	(2)
Argonne National Laboratory P. O. Box 5207 Chicago 80, Illinois Attn: W. H. Jens	(25)	Mr. R. A. Bowman Westinghouse Electric Co. Atomic Power Division P. O. Box 1468 Pittsburgh, Pa.	(1)
U. S. Coast Guard 1300 E Street, N. W. Washington, D. C. Attn: Chief, Testing and Development Division	(1)	Dean L. M. K. Boelter Dept. of Engineering University of California Los Angeles, California	(1)
National Advisory Committee for Aeronautics Cleveland Municipal Airport Cleveland, Ohio Attn: J. H. Collins, Jr.	(2)	Professor J. H. Keenan Dept. of Mechanical Engr. Mass. Inst. of Technology Cambridge 39, Massachusetts	(1)
Dr. William Sibbitt Purdue Research Foundation Purdue University Lafayette, Indiana	(1)	Professor J. N. Addams Dept. of Chemical Engr. Mass. Inst. of Technology Cambridge 39, Massachusetts	(1)
Professor E. D. Kane University of California Berkeley, California	(1)	Dean W. J. Wohlenberg School of Engineering Yale University New Haven, Conn.	(1)
Dr. J. V. Foa Cornell Aeronautical Laboratory Buffalo, New York	(1)	Mr. E. E. Ross Room 20-E-226 Mass. Inst. of Technology Cambridge 39, Mass.	(1)
Professor John W. Hazen Engineering Research Division University of California Los Angeles 24, California	(1)		



Distribution Also to Include the Following

Mr. Robert Bromberg Engineering Research Department of Engineering University of California Los Angeles 24, California	(1)	Mr. Gilbert L. Campbell Library Los Alamos Scientific Laboratory P. O. Box 1663 Los Alamos, New Mexico	(3)
Commander E. B. Roth Office of Chicago Directed Operations U. S. Atomic Energy Commission P. O. Box 4160 A Chicago 80, Illinois	(1)	J. C. Morris Chief Librarian Oak Ridge National Laboratory P. O. Box P Oak Ridge, Tennessee	(3)
Mr. H. Etherington, Director Naval Reactor Division Argonne National Laboratory P. O. Box 5207 Chicago 80, Illinois	(4)	Miss Hazel Hutcheson, Librarian Westinghouse Electric Corporation Atomic Power Division P. O. Box 1468 Pittsburgh 30, Pennsylvania	(3)
Mr. Ben Pinkel National Advisory Committee for Aeronautics Lewis Flight Propulsion Laboratory Municipal Airport Cleveland, Ohio	(2)	Mr. Joel V. Levy Department of the Navy Bureau of Ships Washington 25, D. C.	(1)
Reference Services Branch Technical Information Service U. S. Atomic Energy Commission Oak Ridge, Tennessee Attn: I. A. Warheit, Chief	(4)	Mr. Spencer C. Stanford Library Brookhaven National Laboratory Upton, Long Island, New York	(3)
Mr. E. P. Kranzfelder Babcock & Wilcox Company Research & Development Dept. Alliance, Ohio	(2)	Mr. W. E. Shoupp Director of Research Westinghouse Electric Corporation Atomic Power Division P. O. Box 1468 Pittsburgh 30, Pennsylvania	(1)
Dr. George A. Hawkins Purdue University Lafayette, Indiana	(1)	Library Fairchild Engine & Airplane Corp. NEPA Division P. O. Box 415 Oak Ridge, Tennessee	(3)
Mr. Fred Gunther Jet Propulsion Laboratory California Institute of Technology Pasadena, California	(1)	Dr. R. M. Lyon Technical Division Oak Ridge National Laboratory Oak Ridge, Tennessee	(1)
Mr. H. S. Isbin Hanford Works P. O. Box 550 Richland, Washington	(1)	Mr. W. E. Woods 3703 Building General Electric Company Richland, Washington	(1)

Distribution (cont.)

Mr. N. F. Lansing  
Oak Ridge National Laboratory  
P. O. Box F  
Oak Ridge, Tennessee (1)

Mr. Frederick T. Hobbs  
Technical Cooperation Branch  
Division of Research  
AEC  
Washington, D. C. (1)

Mr. H. V. Lichtenberger  
Argonne National Laboratory  
P. O. Box 5207  
Chicago 80, Illinois (1)

H. D. Young  
Information Division  
Argonne National Laboratory  
P. O. Box 5207  
Chicago 80, Illinois (2)

Mr. John R. Huffman  
Reactor Engineering Division  
Argonne National Laboratory  
P. O. Box 5207  
Chicago 80, Illinois (1)

Mr. Frank Kreith  
Project Squid  
Princeton University  
Princeton, New Jersey (1)

Dr. Martin Summerfield  
Project Squid  
Princeton University  
Princeton, New Jersey (1)

Dr. Alfred G. Lundquist  
Code 429  
Power Branch  
Room 2714, Bldg. 3  
Office of Naval Research  
Department of the Navy  
Washington 25, D. C. (1)