



Room 14-0551
77 Massachusetts Avenue
Cambridge, MA 02139
Ph: 617.253.5668 Fax: 617.253.1690
Email: docs@mit.edu
<http://libraries.mit.edu/docs>

DISCLAIMER OF QUALITY

Due to the condition of the original material, there are unavoidable flaws in this reproduction. We have made every effort possible to provide you with the best copy available. If you are dissatisfied with this product and find it unusable, please contact Document Services as soon as possible.


Thank you.

Due to the poor quality of the original document, there is some spotting or background shading in this document.

Phys.
Handbook

MASS. INSTITUTE
OF
TECHNOLOGY
JUL 5 1894
LIBRARY.

*A Study of the Variation
Efficiency of Commercial
Storage Batteries*



✓

✓

✓

Index.

	Page
Introduction	3
Description of Apparatus	12
The Ideal Cell	19
The Soreby Cell	39
The American cell	56
The Accumulator Cell	85
The Chloride Cell	101
Conclusion	123
Set of cells for Am-meter Calibration	129

A Study of the Variation in Efficiency of Commercial Storage Batteries.

This thesis is an account of an attempt to find out how much a difference in the voltage to which the cell is raised on closed circuit affects the efficiency, and includes an efficiency test on a system of 16 cells designed to be used to supply the current needed in the calibration of ammeters. As this test is separate I will treat of it at the end of the thesis in connection with its Data.

The

The cells tested consisted of 5 different kinds and were of two types. Those of the Plante type were the Chloride and the American and of the Faure type the Sorely, Ideal, and Accumulator.

The cells were new this year with the exception of the accumulator and I followed the directions sent with the cells carefully in setting them up and had no trouble with them during the tests.

The only thing that happened to any of them being a slight buckling of the outside plates of the Sorely cell. It was

It was necessary to have the cells take about 10 amp on the charge and give out about 9 amp on the discharge.

I chose the cells that were nearest to these conditions. To show exactly what the maker guaranteed for them, I append the following table taken directly from the manufacturer's price list describing the cells I used.

Cell	Type	Normal charging rate	discharge rate	Cap. in amp hours at average discharge rate
Ideal	B7	15	6-15	99
Sorley	3	10-15	1-15	120
American	T2	12	12	80
Accumulator	E _{plate} ⁵	15 (?)	(15) (?)	150 (?)
Chloride	E _{plate}	10	10	100

Cell	Weight	Dimensions	Height
Ideal	35 lbs	$4\frac{1}{2}'' - 8\frac{1}{2}''$	11"
Sorely	38 lbs	$6\frac{1}{4}'' - 7\frac{3}{4}''$	$9\frac{1}{2}''$
American	34 lbs	$7\frac{3}{4}'' - 4\frac{3}{4}''$	10"
Accumulator chloride	22 lbs	$3\frac{1}{4}'' - 8\frac{1}{4}''$	$10\frac{1}{2}''$

The cells were arranged in series for charging and were discharged separately through constant German silver resistances. A current of about 9.5 amperes was used for charging and a current of about 9 amp for the discharge.

Before the tests were begun the cells were given several charges and discharges to get them in condition.

In none.

In none of the cells was the boiling point well marked. The cells were stopped from charging or discharging according to its voltage on closed circuit and no particular attention was paid to the voltage on open circuit. Except that I noticed that the voltage on open circuit some hours after a charge was about 2.1 volts and

that the voltage some hours after discharge was not lower than 1.8 volts in any case.

Measurements were taken every half hour on the voltage and current except at the beginning and end of the test when

when an effort was made to stop the discharge or charge at exactly the right voltage. The capacity given is obtained from the discharge of the test having nearest the average efficiency of each set of tests.

I made no measurements on the internal resistance of the cells.

The current for the charge was measured by a direct reading Weston am meter and current of discharge was calculated from the fall of potential around a German silver resistance which resistance was determined by comparison with


with a standard Dani
and was known to
within 1% of one percent.

The fall of potential
was measured by a direct
reading Weston volt-meter
reading to $\frac{1}{300}$ of a volt.

Both instruments were calibrated
by the Clark cell method
which is correct to 1% of one
percent.

The tests were in nearly
all cases continuous in
that all current but in
was measured as was
also all that was taken
out. In front of time I
found it impossible to charge
then discharge at once
and I assumed that there

is no perceptible leakage
from a well insulated cell
left on open circuit for
24 hours. The results seem
to show that this assumption
is correct.



Description of Apparatus

The board outside the storage battery room is drawn on the preceding page.

At A are the wires carrying the charging current from the dynamo room. B is a double fuse box. C is the automatic circuit breaker. D is a two pole knife switch. E is a resistance frame connected as seen.

At each circle there is a hole for a plug connection. The three plugs with their flexible connections being shown in position.

The resistance of each separate spool one ohm


and

and of the whole frame 7
ohms. F is a variable resistance
of $\frac{1}{2}$ an ohm which can
be added or subtracted by
joints. From f and c the
wires lead to my set of cells.

At G is a switch for
throwing the 16 cells used
in am meter calibration
in series for charging
or in series-parallel for
discharging. N being the
wires leading to the cells.
When these cells are dis-
charging an equivalent
resistance between 1 and 1'
is thrown in. K is a Edison
am meter and L an indicat-
ing lamp to show if the
dynamoe is in action

All wires which were connected with cells inside the Storage Battery room, passed through holes in a piece of slate, and in all cases were carried on porcelain slats.

The wires H, all connected with room six for use in Am-meter calibration, and the wires M go to a table near the board to be used for the same purposes.



On the succeeding page is a drawing showing the connection of the cells being tested.

Only one cell is shown the other being connected similarly to 2, 3, etc.

A is the constant German silver resistance in series with it. E is an equivalent resistance to be thrown in the dynamo circuit when the cell is discharging. The dotted connections *uv* show the cell as discharging, and the full connections *xy* as charging.

As it will be seen each cell is entirely independent of the others when it is discharging.

discharging.

The switch board was horizontal instead of vertical as shown. The connections being made through mercury cups spaced as shown and well shellaced.

The am-meter and volt-meter with their connections as shown in position on a shelf in front of and on a level with the switch board. The volt-meter having a flexible cord and connector can be inserted in cord give the volt drop around a or the volt at the cell as required.



The

The charging current
enters at x and leaves at
 y . The cells were disposed
three at the left and
two at the right of the
board and were spaced
about eight inches apart.

The Ideal Cell

This cell is of the frame type having 3 positive and 4 negative plates. The plates are cast so as to have the active material in the form of pencils as shown in the two views given.

They are separated by hard rubber combs and have also thin sheets of perforated rubber interposed between each plate.



The whole element is raised from the bottom of the cell by two wedge shaped pieces of vulcanite.

The bar at a, a etc extending clear through the plate giving great rigidity.

This cell gave no trouble during the tests has every indication of durability though the cell does not seem to be fitted for very rough mechanical usage.

The data and plots are appended. The results will be found tabulated at the end of the tests

April 3-4-5

Ideal


Charge

Discharge

T	A	V	W	WM	T	A	V	W	WM
3.00	9.59	2.018	19.35	290.2	12.10	9.83	2.075	20.90	306.0
3.30	9.64	2.085	20.10	603.0	12.40	9.34	1.995	18.63	1117.8
4.00	9.44	2.118	19.99	599.7	2.05	9.27	1.965	18.22	1002.1
4.30	9.24	2.141	19.78	296.7	2.30	9.22	1.955	18.02	450.5
9.00	9.79	2.092	20.48	307.2	3.00	9.09	1.943	17.66	529.8
9.30	9.59	2.127	20.40	612.0	3.30	9.04	1.926	17.41	522.3
10.00	9.54	2.137	20.39	611.7	4.00	8.98	1.896	16.96	508.8
10.30	9.54	2.151	20.52	615.6	4.30	8.79	1.863	16.37	245.5
11.00	9.64	2.151	20.73	621.9	9.00	9.31	1.929	17.96	269.4
11.30	9.54	2.164	20.64	721.5	9.30	8.87	1.886	16.73	501.9
12.10	9.49	2.184	20.73	414.6	10.00	8.69	1.849	16.07	241.1
				5694.1					5695.2

Eff = 100.02

Eff with next ch = 107.41



CHARGE

IDEAL

APRIL 3-4-5

APRIL 5-6

121

120

119

118

117

116

115

114

113

112

111

110

1

2

3

4

5

6

7

8

Ideal

April 5-6-9

Charge

Discharge


T	A	V	W	WM	T	A	V	W	WM
10.00	9.64	2.018	19.45	209.2	11.00	9.41	1.978	18.61	800.2
10.30	9.55	2.088	19.94	598.2	12.25	9.20	1.949	17.93	1344.7
11.00	9.42	2.122	19.99	599.7	1.30	9.08	1.923	17.47	820.6
11.30	9.51	2.127	20.23	606.9	2.00	8.96	1.893	16.96	508.8
12.00	9.49	2.127	20.19	302.8	2.30	8.80	1.853	16.31	244.5
9.23									3718.8
9.35	9.34	2.127	19.87	476.8					
9.58	9.49	2.141	20.32	548.6					
10.30	9.36	2.154	20.16	564.5					
10.54	9.44	2.164	20.43	612.9					
11.30	9.59	2.174	20.48	573.4					
11.50	9.59	2.184	20.94	209.4					
				5302.4					

Eff = 70.13

Eff with switch = 98.11

22
21
20
19
18
17
16
15
14
13
12

WATTS



IDEAL
APRIL 5-6-9
APRIL 9-10

TIME - HOURS.

April 9-10

Ideal


Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
2.30	9.48	2.005	19.01	285.1	11.00	10.03	2.075	20.81	312.2
3.00	9.45	2.095	19.80	594.0	11.30	9.42	1.988	18.73	561.9
3.30	9.41	2.122	19.96	598.8	12.00	9.35	1.975	18.47	831.1
3.55	9.44	2.134	20.14	201.4	1.00	9.20	1.933	17.78	800.1
9.15	9.46	2.085	19.72	453.6	1.30	8.99	1.903	17.11	513.3
10.00	9.34	2.151	20.09	743.3	2.00	8.87	1.869	16.58	248.7
10.30	9.31	2.164	20.15	604.5					3267.3
11.00	9.51	2.174	20.67	310.0					
				3790.6					

Eff = 86.19

Eff with reexsch = 102.12



IDEAL
 APRIL 9-10
 APRIL 10

April 10-11

Ideal


Charge

Discharge

T	A	V	W	WM	T	A	V	W	WM
2.00	9.54	2.028	19.35	290.2	9.12	9.38	1.985	18.62	986.9
2.30	9.39	2.115	19.86	655.4	10.57	8.96	1.916	17.17	944.4
3.05	9.44	2.137	20.17	605.1	11.00				
3.30	9.41	2.144	20.18	544.9	2.00	9.01	19.19	17.29	276.6
4.00	9.49	2.157	20.47	675.5	2.32	8.92	1.849	16.49	313.3
4.35	9.39	2.174	20.41	387.8	2.35				2521.2
4.39	9.36	2.174	20.33	40.7					

3199.6

$Eff = 78.79\%$



IDEAL
APRIL 10-11

April 11-12

9 deal

Charge

Exchange

T	A	V	W	WM	T	A	V	W	WM
---	---	---	---	----	---	---	---	---	----

2.35	9.49	2.028	19.25	2.695
------	------	-------	-------	-------

3.03	9.39	2.115	19.86	5.759
------	------	-------	-------	-------

3.33	9.49	2.134	26.25	5.872
------	------	-------	-------	-------

4.00	9.44	2.141	20.21	6.669
------	------	-------	-------	-------

4.37	9.39	2.154	20.23	3.844
------	------	-------	-------	-------

4.39				
------	--	--	--	--

9.04	9.63	2.095	20.17	40.3
------	------	-------	-------	------

9.07	9.39	2.131	20.01	3.202
------	------	-------	-------	-------


9.37	9.39	2.161	20.29	5.681
------	------	-------	-------	-------

10.03	9.46	2.171	20.54	4.118
-------	------	-------	-------	-------

10.16	9.49	2.174	20.63	1.238
-------	------	-------	-------	-------

				3.938.1
--	--	--	--	---------

Split last charge = 64.02%



April 17th 20

Deal


Change

Change

T	3.39	9.42		4.38	9.39	2.197	20.61	30.92
A	3.41	9.42	2.008	18.92	7.57	9.02		
V	3.45	9.44	2.028	19.12	19.12	9.04	9.75	2.154
	4.00	9.61	2.062	18.75	13.85	9.06	9.49	2.164
	9.45					9.37	9.36	2.107
	9.48	9.55	2.118	20.21	18.19	10.05	9.33	2.217
	10.00	9.49	2.124	20.16	50.40	10.30	9.32	2.237
	10.38	9.56	2.124	20.28	60.84	11.00	9.37	2.247
	11.00	9.69	2.127	20.61	56.28	11.30	9.46	2.274
	11.30	9.46	2.127	20.10	60.30			
	12.00	9.54	2.141	20.30	60.90			
	12.30	9.59	2.144	20.54	30.8.1			
2.02	2.04	9.54	2.127	20.27	30.40			
2.30	2.30	9.55	2.157	20.52	57.4.6			
3.00	3.00	9.53	2.161	20.59	61.7.7			
3.30	3.30	9.34	2.174	20.37	61.1.1			
4.00	4.00	9.39	2.184	20.49	61.4.7			

3% = 81.10%

30.99.1
66.04.7
97.03.8



APRIL 11-12-16-17
 EFF = 71.95 %
 APRIL 17-18-20
 EFF = 81.10 %

April 27-30

Goal


Discharge Discharge

T	10.20	9.88	2.141	2.137	64.1	2.15	8.60	1876	1613	1452			
A	10.25	9.24	2.015	18.62	93.1	2.18	8.60	1876	1613	1452			
V	10.30	9.15	1.995	18.25	127.7	2.30	8.51	1859	1582	332.2			
A	11.00	9.10	1.978	17.99	539.7	3.00	8.32	1813	1509	286.7			
T	11.30	9.07	1.975	17.91	537.3	3.08	8.24	1796	1480	59.2			
WM	12.00	9.04	1.972	17.82	534.6								
W	12.30	9.04	1.968	17.79	120.9								
V	2.16	8.89	1.953	17.38	104.3								
A	2.30	8.89	1.953	17.36	381.9								
T	3.00	8.86	1.943	17.21	753.6								
V	4.00	8.79	1.926	16.93	507.9								
8.55													
9.00	8.89	1.953	17.14	342.8									
9.30	8.79	1.929	16.89	506.7									
10.00	9.77	1.919	16.84	757.8									
11.00	8.60	1.886	16.22	729.9									
11.30	8.51	1.839	15.82	711.9									
12.30	8.40	1.833	15.40	462.0									
7276.1													


$\frac{214}{318} = 67.45\%$

4.14

~~8099.4~~
823.3
7276.1



Negative and positive
being made in the same
way.



The Daniell Cell
This cell is of the same type
and consists of three
positive and four negative
plates, separated in the
same way as those in the
Daniell cell. The element
is held up from the bottom
of the cell by two ribs in
the glass.
The plates are built up
of silver lead as shown.

The active material for this cell, not lead, is present in the intercell.

This form of plate has little resistance against buckling. Indeed the

outer plates of the cell & tested did buckle some what through the cell

was used in a compact manner.

The plates are spaced

about $\frac{3}{8}$ of an inch apart or $\frac{1}{8}$ of an inch more than the Q dead spacing.

T	12.40	9.64	2.025	1952	7808	1100	949	1968	1868	7472
A	9.58	2.026	1979			1225	9.30	1953	1816	1362
V	2.05	9.52	2.108	2.007	11038	1.30	9.25	1936	1781	890.5
V	2.30	9.59	2.125	2.038	6114	2.00	9.18	1926	1770	531.0
V	3.00	9.64	2.127	2.050	6150	2.30	9.07	1903	1726	517.8
V	3.30	9.44	2.127	2.008	6024	3.00	8.94	1869	1671	501.3
V	4.00	9.44	2.127	2.008	6024	3.30	8.75	1827	1597	479.1
V	4.30	9.49	2.141	2.032	3048	3.55	8.63	1800	1553	453.3
V	9.00	9.49	2.082	1976	2964	9.15	9.49	1.941	1842	3684
V	9.30	9.41	2.141	2.055	6045	10.00	8.75	1820	1592	636.8
V	10.00	9.54	2.141	2.032	6096	10.30	8.56	1774	1519	258.2
V	10.30	9.46	2.154	2.038	6114	10.34	8.56	1777	1521	3044
V	11.00	9.49	2.161	2.041	6123					
V	11.30	9.54	2.171	2.071	6213					
V	12.00	9.59	2.174	2.085	3127					
8288.8										
692.6										
75962										


$\frac{3}{8} = 94.80\%$
 With next change
 $\frac{3}{8} = 78.29\%$

5252.2

Sorley

Change

April 4-5 + 7-10



April 10 + 11


Soley

Charge Discharge

T	A	V	W	WM	T	A	V	W	WM
1034	944	2023	1910	2101	912	949	1985	1884	10174
1100	949	2112	2004	6012	1100	928	1949	1809	21527
1130	942	2127	2004	6012	110	882	1843	2625	14625
1200	944	2134	2013	6039	200	832	1727	1437	4317
100	944	2151	2031	6093					50643
200	949	2118	2010	3015					
230	953	2157	2056	6168					
305	953	2167	2065	6195					
330	938	2174	2039	6117					
400	949	2181	2070	4605					

5540.3

SB = 91.41%



SORLEY
APRIL 10-11

Apr 11 + 12

Sorter

Charge Discharge

T	A	V	W	WM	T	A	V	W	WM
2.00	9.39	2.025	19.01	285.2	2.32	9.44	2.087	19.70	291.0
3.03	9.41	2.112	19.87	596.1	3.33	9.51	2.122	20.18	654
4.00	9.42	2.127	20.04	661.3	4.37	9.49	2.141	20.32	726.7
4.39					9.04	9.53	2.095	19.96	20.0
9.07	9.43	2.122	20.01	340.2	9.37	9.49	2.147	20.36	570.1
10.03	9.44	2.154	20.33	508.2	10.30	9.46	2.161	20.44	613.2
11.00	9.39	2.164	20.32	609.6	11.30	9.41	2.174	20.46	306.9
6033.9									

With Last Exchange
off = 83.93%

WATTS

12 13 14 15 16 17 18 19 20 21 22

TIME - HOURS

1
2
3
4
5
6
7
8

DISCHARGE

CHARGE

SORLEY
APRIL 11 + 12
APRIL 11



322:72


85:37

49:8

77:10

71:1

#3



April 23-24-25

Sony

Discharge

Charge


T	9.30	9.45	2.131	20.14	4.639	10.03							
A	10.00	9.50	2.159	20.51	6.045	10.05	9.84	2.028	19.95	29.92			
V	10.30	9.51	2.174	20.67	6.201	10.30	9.49	1.995	18.95	51.7			
V	11.00	9.39	2.197	20.45	6.215	11.00	9.40	1.985	18.66	55.8			
V	11.30	9.46	2.207	20.88	5.715	11.30	9.37	1.975	18.51	55.3			
V	12.00	9.42	2.214	21.13	6.339	12.00	9.37	1.975	18.51	55.3			
V	12.30	9.54	2.221	21.99	4.178	12.30	9.34	1.963	18.33	29.3			
	12.34					12.31							
2.00	9.64	2.197	21.18	3.177	1.30	9.49	1.978	18.77	150.2				
2.30	9.29	2.227	20.69	6.207	1.45	9.34	1.968	18.38	27.57				
3.00	9.49	2.241	21.27	6.381	2.00	9.34	1.965	18.35	41.27				
3.30	9.64	2.247	21.66	6.498	2.30	9.34	1.962	18.33	54.99				
4.00	9.39	2.254	21.16	4.867	3.00	9.31	1.955	18.20	54.60				
4.15	9.42	2.261	21.30	14.91	3.30	9.28	1.949	18.09	54.27				
9.27					4.00	9.18	1.949	17.84	26.76				
9.29	9.79	2.194	21.51	8.60	8.45	9.00	2.032						
9.32	9.39	2.234	20.88	3.132	8.53	9.30	1.958	18.21	21.85				
10.00	9.62	2.274	21.87	3.718	9.00	9.28	1.956	18.15	32.67				
10.03					9.00								

Total 13670.0

4/ = 77.10

6064.6

7565.6
6104.4



SORLEY

APRIL 19-20-23-24-25

APRIL 16-17

T A V V W W WM

12.30 9.59 2.21 12.20 318.0

2.16

2.18 9.59 2.18 20.94 187.5

2.30 9.59 2.19 21.07 442.4

3.00 9.49 2.21 120.98 629.4

9.05

9.07 9.79 2.15 320.82 124.9

9.15 9.54 2.20 121.00 252.0

9.30 9.54 2.21 21.15 465.3

10.00 9.69 2.23 121.62 972.9

11.00 9.52 2.26 121.52 968.4

11.30 9.49 2.26 72.51 645.3

12.00 9.49 2.28 121.65 324.7

2.15

2.17 9.69 2.22 121.52 193.7

2.30 9.49 2.25 72.14 249.8

3.00 9.49 2.28 72.17 325.8

6620.0
7481.6


Sum 14101.6

~~8537~~

Change

Solving


May 1



SORLEY
 APRIL 26-27
 MAY 1-4
 APRIL 24-25

The American Cell


This cell is of the Plate type and is built up of an intermediate lead frame as shown. The drawing given is of the formed plate.



The plates are separated by hard rubber combs and are kept off the bottom of the cell by glass ribs.


This form of plate seems
to indicate good strength
and would be suited
perhaps if mounted
properly to traction work.
While being tested the
active material sealed off
of the positive plate
somewhat. And the
negative plate seemed to
be slightly sulphated
between the wires.
This may indicate that
the cell was not in the
best condition and
explain the low capacity
and efficiency got
from it
I can see no other

Learn why it should
give such low results.




AMERICAN
 APRIL 10
 APRIL 10-11-12

22
21
20
19
18
17
16
15
14
13
12



AMERICAN
APRIL 10-11-12




WATTS

CHARGE


TIME - HOURS

AMERICAN
 APRIL 12
 APRIL 11-12

WATTS




AMERICAN
APRIL 12-16-17




T	10.36	9.35	1.958	1830	.91	2.47							
A	10.37	9.44	2.141	2020	2.52	2.48	9.78	2.174	2.126	2.13			
V	11.00	9.60	2.157	2071	5.385	2.49	9.09	2.028	1.843	2.212			
W	11.30	9.49	2.184	2073	6.219	3.10	8.91	1.988	1.771	4.073			
WM	12.00	9.52	2.241	2133	6.399	3.35	8.83	1.975	1.744	2.093			
V	12.30	9.57	2.301	2195	4.390	9.47							
V	12.35						9.53	8.77	1.965	1.723	1.723		
W	2.00	2.00	10.00	8.75	1.965	1.719	3.78.2						
W	2.04	9.52	2.307	2196	3.733	10.38	8.66	1.952	1.690	5.070			
W	2.30	9.54	2.354	2246	4.717	11.00	8.59	1.928	1.656	4.30.6			
W	2.45	9.49	2.381	2260	2.034	11.30	4.2	.133	.04	.7			
WM	2.47					11.32							
WM													2.346.9

$\frac{3549.3}{11.32} = 313.5$
 $\frac{3549.3}{11.30} = 314.1$
 $\frac{3549.3}{11.27} = 314.9$
 $\frac{3549.3}{11.24} = 316.2$
 $\frac{3549.3}{11.21} = 317.0$
 $\frac{3549.3}{11.18} = 318.0$
 $\frac{3549.3}{11.15} = 318.8$
 $\frac{3549.3}{11.12} = 320.0$
 $\frac{3549.3}{11.09} = 321.0$
 $\frac{3549.3}{11.06} = 322.0$
 $\frac{3549.3}{11.03} = 323.0$
 $\frac{3549.3}{11.00} = 324.0$
 $\frac{3549.3}{10.97} = 325.0$
 $\frac{3549.3}{10.94} = 326.0$
 $\frac{3549.3}{10.91} = 327.0$
 $\frac{3549.3}{10.88} = 328.0$
 $\frac{3549.3}{10.85} = 329.0$
 $\frac{3549.3}{10.82} = 330.0$
 $\frac{3549.3}{10.79} = 331.0$
 $\frac{3549.3}{10.76} = 332.0$
 $\frac{3549.3}{10.73} = 333.0$
 $\frac{3549.3}{10.70} = 334.0$
 $\frac{3549.3}{10.67} = 335.0$
 $\frac{3549.3}{10.64} = 336.0$
 $\frac{3549.3}{10.61} = 337.0$
 $\frac{3549.3}{10.58} = 338.0$
 $\frac{3549.3}{10.55} = 339.0$
 $\frac{3549.3}{10.52} = 340.0$
 $\frac{3549.3}{10.49} = 341.0$
 $\frac{3549.3}{10.46} = 342.0$
 $\frac{3549.3}{10.43} = 343.0$
 $\frac{3549.3}{10.40} = 344.0$
 $\frac{3549.3}{10.37} = 345.0$
 $\frac{3549.3}{10.34} = 346.0$
 $\frac{3549.3}{10.31} = 347.0$
 $\frac{3549.3}{10.28} = 348.0$
 $\frac{3549.3}{10.25} = 349.0$
 $\frac{3549.3}{10.22} = 350.0$
 $\frac{3549.3}{10.19} = 351.0$
 $\frac{3549.3}{10.16} = 352.0$
 $\frac{3549.3}{10.13} = 353.0$
 $\frac{3549.3}{10.10} = 354.0$
 $\frac{3549.3}{10.07} = 355.0$
 $\frac{3549.3}{10.04} = 356.0$
 $\frac{3549.3}{10.01} = 357.0$
 $\frac{3549.3}{9.98} = 358.0$
 $\frac{3549.3}{9.95} = 359.0$
 $\frac{3549.3}{9.92} = 360.0$
 $\frac{3549.3}{9.89} = 361.0$
 $\frac{3549.3}{9.86} = 362.0$
 $\frac{3549.3}{9.83} = 363.0$
 $\frac{3549.3}{9.80} = 364.0$
 $\frac{3549.3}{9.77} = 365.0$
 $\frac{3549.3}{9.74} = 366.0$
 $\frac{3549.3}{9.71} = 367.0$
 $\frac{3549.3}{9.68} = 368.0$
 $\frac{3549.3}{9.65} = 369.0$
 $\frac{3549.3}{9.62} = 370.0$
 $\frac{3549.3}{9.59} = 371.0$
 $\frac{3549.3}{9.56} = 372.0$
 $\frac{3549.3}{9.53} = 373.0$
 $\frac{3549.3}{9.50} = 374.0$
 $\frac{3549.3}{9.47} = 375.0$
 $\frac{3549.3}{9.44} = 376.0$
 $\frac{3549.3}{9.41} = 377.0$
 $\frac{3549.3}{9.38} = 378.0$
 $\frac{3549.3}{9.35} = 379.0$
 $\frac{3549.3}{9.32} = 380.0$
 $\frac{3549.3}{9.29} = 381.0$
 $\frac{3549.3}{9.26} = 382.0$
 $\frac{3549.3}{9.23} = 383.0$
 $\frac{3549.3}{9.20} = 384.0$
 $\frac{3549.3}{9.17} = 385.0$
 $\frac{3549.3}{9.14} = 386.0$
 $\frac{3549.3}{9.11} = 387.0$
 $\frac{3549.3}{9.08} = 388.0$
 $\frac{3549.3}{9.05} = 389.0$
 $\frac{3549.3}{9.02} = 390.0$
 $\frac{3549.3}{8.99} = 391.0$
 $\frac{3549.3}{8.96} = 392.0$
 $\frac{3549.3}{8.93} = 393.0$
 $\frac{3549.3}{8.90} = 394.0$
 $\frac{3549.3}{8.87} = 395.0$
 $\frac{3549.3}{8.84} = 396.0$
 $\frac{3549.3}{8.81} = 397.0$
 $\frac{3549.3}{8.78} = 398.0$
 $\frac{3549.3}{8.75} = 399.0$
 $\frac{3549.3}{8.72} = 400.0$
 $\frac{3549.3}{8.69} = 401.0$
 $\frac{3549.3}{8.66} = 402.0$
 $\frac{3549.3}{8.63} = 403.0$
 $\frac{3549.3}{8.60} = 404.0$
 $\frac{3549.3}{8.57} = 405.0$
 $\frac{3549.3}{8.54} = 406.0$
 $\frac{3549.3}{8.51} = 407.0$
 $\frac{3549.3}{8.48} = 408.0$
 $\frac{3549.3}{8.45} = 409.0$
 $\frac{3549.3}{8.42} = 410.0$
 $\frac{3549.3}{8.39} = 411.0$
 $\frac{3549.3}{8.36} = 412.0$
 $\frac{3549.3}{8.33} = 413.0$
 $\frac{3549.3}{8.30} = 414.0$
 $\frac{3549.3}{8.27} = 415.0$
 $\frac{3549.3}{8.24} = 416.0$
 $\frac{3549.3}{8.21} = 417.0$
 $\frac{3549.3}{8.18} = 418.0$
 $\frac{3549.3}{8.15} = 419.0$
 $\frac{3549.3}{8.12} = 420.0$
 $\frac{3549.3}{8.09} = 421.0$
 $\frac{3549.3}{8.06} = 422.0$
 $\frac{3549.3}{8.03} = 423.0$
 $\frac{3549.3}{8.00} = 424.0$
 $\frac{3549.3}{7.97} = 425.0$
 $\frac{3549.3}{7.94} = 426.0$
 $\frac{3549.3}{7.91} = 427.0$
 $\frac{3549.3}{7.88} = 428.0$
 $\frac{3549.3}{7.85} = 429.0$
 $\frac{3549.3}{7.82} = 430.0$
 $\frac{3549.3}{7.79} = 431.0$
 $\frac{3549.3}{7.76} = 432.0$
 $\frac{3549.3}{7.73} = 433.0$
 $\frac{3549.3}{7.70} = 434.0$
 $\frac{3549.3}{7.67} = 435.0$
 $\frac{3549.3}{7.64} = 436.0$
 $\frac{3549.3}{7.61} = 437.0$
 $\frac{3549.3}{7.58} = 438.0$
 $\frac{3549.3}{7.55} = 439.0$
 $\frac{3549.3}{7.52} = 440.0$
 $\frac{3549.3}{7.49} = 441.0$
 $\frac{3549.3}{7.46} = 442.0$
 $\frac{3549.3}{7.43} = 443.0$
 $\frac{3549.3}{7.40} = 444.0$
 $\frac{3549.3}{7.37} = 445.0$
 $\frac{3549.3}{7.34} = 446.0$
 $\frac{3549.3}{7.31} = 447.0$
 $\frac{3549.3}{7.28} = 448.0$
 $\frac{3549.3}{7.25} = 449.0$
 $\frac{3549.3}{7.22} = 450.0$
 $\frac{3549.3}{7.19} = 451.0$
 $\frac{3549.3}{7.16} = 452.0$
 $\frac{3549.3}{7.13} = 453.0$
 $\frac{3549.3}{7.10} = 454.0$
 $\frac{3549.3}{7.07} = 455.0$
 $\frac{3549.3}{7.04} = 456.0$
 $\frac{3549.3}{7.01} = 457.0$
 $\frac{3549.3}{6.98} = 458.0$
 $\frac{3549.3}{6.95} = 459.0$
 $\frac{3549.3}{6.92} = 460.0$
 $\frac{3549.3}{6.89} = 461.0$
 $\frac{3549.3}{6.86} = 462.0$
 $\frac{3549.3}{6.83} = 463.0$
 $\frac{3549.3}{6.80} = 464.0$
 $\frac{3549.3}{6.77} = 465.0$
 $\frac{3549.3}{6.74} = 466.0$
 $\frac{3549.3}{6.71} = 467.0$
 $\frac{3549.3}{6.68} = 468.0$
 $\frac{3549.3}{6.65} = 469.0$
 $\frac{3549.3}{6.62} = 470.0$
 $\frac{3549.3}{6.59} = 471.0$
 $\frac{3549.3}{6.56} = 472.0$
 $\frac{3549.3}{6.53} = 473.0$
 $\frac{3549.3}{6.50} = 474.0$
 $\frac{3549.3}{6.47} = 475.0$
 $\frac{3549.3}{6.44} = 476.0$
 $\frac{3549.3}{6.41} = 477.0$
 $\frac{3549.3}{6.38} = 478.0$
 $\frac{3549.3}{6.35} = 479.0$
 $\frac{3549.3}{6.32} = 480.0$
 $\frac{3549.3}{6.29} = 481.0$
 $\frac{3549.3}{6.26} = 482.0$
 $\frac{3549.3}{6.23} = 483.0$
 $\frac{3549.3}{6.20} = 484.0$
 $\frac{3549.3}{6.17} = 485.0$
 $\frac{3549.3}{6.14} = 486.0$
 $\frac{3549.3}{6.11} = 487.0$
 $\frac{3549.3}{6.08} = 488.0$
 $\frac{3549.3}{6.05} = 489.0$
 $\frac{3549.3}{6.02} = 490.0$
 $\frac{3549.3}{5.99} = 491.0$
 $\frac{3549.3}{5.96} = 492.0$
 $\frac{3549.3}{5.93} = 493.0$
 $\frac{3549.3}{5.90} = 494.0$
 $\frac{3549.3}{5.87} = 495.0$
 $\frac{3549.3}{5.84} = 496.0$
 $\frac{3549.3}{5.81} = 497.0$
 $\frac{3549.3}{5.78} = 498.0$
 $\frac{3549.3}{5.75} = 499.0$
 $\frac{3549.3}{5.72} = 500.0$

American
 upon 11-20
 Exchange




AMERICAN
 APRIL 17-20
 APRIL 16-17



AMERICAN
APRIL 20
APRIL 17-20

WATTS



AMERICAN

APRIL 23

April 27-20

American

Charge Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
3.32					11.30				
3.34	9.43	2.151	20.28	304.2	11.33	8.99	2.017	18.13	308.2
4.00	9.39	2.164	20.32	436.7	12.00	8.86	1.991	17.64	493.9
4.15	9.42	2.184	20.57	144.0	12.30	8.77	1.965	17.23	310.1
9.27					12.33				
9.30	9.64	2.197	21.18	381.2	2.00	8.91	1.975	17.59	263.8
10.00	9.62	2.251	21.65	649.5	2.30	8.68	1.953	16.95	508.5
10.30	9.49	2.321	22.03	660.9	3.00	8.60	1.928	16.58	497.4
11.00	9.61	2.361	22.69	431.1	3.30	.10	.123	.01	.2
11.08	9.36	2.384	22.41	89.6	3.31				2382.1
				3097.2					

Eff = 76.91


Eff with last Charge = 82.34

AMERICAN
APRIL 24-25
APRIL 23

CHARGE
CHARGE

DISCHARGE

TIME - HOURS



April 25-26

American


Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
2.30	9.39	2.157	20.25	3037	11.08				
3.00	9.49	2.174	20.63	618.9	11.10	9.07	2.032	18.43	221.2
3.30	9.54	2.207	21.04	631.2	11.30	8.91	1.995	17.75	443.7
4.00	9.41	2.264	21.36	319.5	12.00	8.83	1.975	17.44	593.2
9.00	9.44	2.241	21.15	63.5	12.30	8.81	1.958	17.25	276.0
9.05	9.40	2.297	21.59	323.8	12.31				
9.30	9.55	2.357	22.51	607.8	1.30	8.86	1.962	17.38	139.0
10.00	9.52	2.384	22.70	340.5	1.45	8.77	1.955	17.14	257.1
				3205.9	2.00	8.68	1.948	16.9	372.0
					2.30	.10	.123	.01	.2
									23024

Eff = 71.82%

Eff with last ch. = 74.33%



AMERICAN
 APRIL 25-26
 APRIL 24-25

April 26-27

American


Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
2.15					10.00				
2.20	9.49	2.157	20.47	204.7	10.05	8.91	20.15	17.95	323.1
2.30	9.42	2.157	20.32	406.4	10.30	8.81	19.85	17.49	472.2
3.00	9.59	2.184	20.84	625.2	11.00	8.77	19.75	17.32	519.6
3.30	9.51	2.241	21.31	639.3	11.30	8.68	19.58	16.99	509.7
4.00	9.45	2.284	21.59	496.6	12.00	8.60	19.42	16.71	501.3
4.15	9.42	2.351	22.15	155.0	12.30	10	1.23	.01	2
9.03									2326.1
9.06	9.52	2.297	21.87	328.1					
9.30	9.41	2.364	22.25	333.7					
9.36	9.41	2.374	22.7	68.2					
				3257.2					

Eff = 71.41%

Eff with last ch = 72.24%



AMERICAN
 APRIL 26-27
 APRIL 25-26

VOLT

TIME - HOURS

CHARGE

CHARGE

DISCHARGE

American

April 27-30

May 1-2

Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
3.00					11.07	9.57	2.125	20.34	40.7
3.02	9.49	2.108	20.00	620.0	11.10	8.92	2.018	18.00	198.0
4.00	9.59	2.167	20.78	602.6	11.30	8.77	1.985	17.41	435.2
9.05	9.99	2.157	21.55	107.5	12.00	8.75	1.975	17.28	259.2
9.15	9.54	2.177	20.77	270.0	2.15				
9.30	9.54	2.187	20.86	458.9	2.17	8.71	1.972	17.17	154.5
10.00	9.69	2.231	21.62	1037.8	2.30	8.68	1.965	17.06	358.3
11.05	9.52	2.384	22.70	726.4	3.00	8.65	1.955	16.91	896.2
			382.33		4.15	8.33	1.893	15.77	583.5
					9.10				
					9.15	8.39	1.896	15.91	206.8
					9.30	.10	.213	.02	.1
								31	32.5

Eff = 81.93

CHARGE

DISCHARGE

AMERICAN
APRIL 27-30
MAY 1-2

TIME - HOURS

22

21

20

19

18

17

16

15

14

13

12

11

2

3

4


5

6

7

8

WATTS



American May 2

Charge

T	A	V	W	WM	T	A	V	W	WM
9.35	9.49	2.032	19.28	250.6					
10.00	9.44	2.131	20.12	543.2					
10.30	9.55	2.154	20.57	617.1					
11.30	9.49	2.217	21.04	946.8					
12.30	9.39	2.297	21.57	647.1					
2.10									
2.30	9.64	2.327	22.44	785.4					
3.00	9.54	2.361	22.52	1013.5					
4.00	9.54	2.374	22.65	679.5					
				5483.2					
		Eff = 57.11							

CHARGE

DISCHARGE

AMERICAN
MAY 2
MAY 1-2

TIME-HOURS

22

21

20

19

18

17

16

15

14

13

12

11

10

9

8

7

6

5


4

3

2

1

WATTS




The Accumulator.

This cell is one of the old cells owned by the Institute and was tested so as to give me some means of comparing the modern cells with the older ones.

On the whole no gain in efficiency seems to have been made although the newer cells are quite superior in mechanical strength.

This cell has plates of the form shown.



The active material thus
has the form of rivets.

The plates are separated
and raised from the
bottom of the cell by
means of hard rubber
crumbs inserted from
below.


April 4-5-6

Accumulator

Charge Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
1240	9.59	2.022	19.39	833.8	2.37	9.09	2.088	18.98	246.7
-35 ^m			19.92	697.2	3.03	8.88	2.052	18.22	570.2
205	9.59	2.134	20.46	1125.3	3.33	8.80	2.042	17.96	520.8
2.30	9.49	2.147	20.37	550.0	4.00	8.74	2.028	17.72	567.0
3.00	9.54	2.147	20.48	614.4	4.38	8.68	2.008	17.43	331.2
3.30	9.54	2.147	20.48	614.4	9.00	8.77	2.022	17.73	356.9
4.00	9.54	2.147	20.48	614.4	9.38	8.46	1.955	16.55	546.1
4.30	9.49	2.151	20.51	307.6	10.05	7.89	1.796	14.18	212.7
9.00	9.49	2.108	20.00	300.0	10.08	7.48	1.395	10.43	10.4
9.30	9.41	2.151	20.24	607.2					3302.0
10.00	9.54	2.154	20.55	616.5					
10.30	9.53	2.161	20.59	617.7					
11.00	9.54	2.164	20.64	619.2					
11.30	9.59	2.167	20.78	623.4					
12.00	9.49	2.174	20.63	309.4					
				8353.3					
				697.2					
				<u>7656.1</u>					

$E_k = 43.12$



ACCUMULATOR
APRIL 4-5-6

CHARGE

DISCHARGE

TIME - HOURS

VOLTS

22
21
20
19
18
17
16
15
14
13
12
11
10

8
7
6
5
4
3
2
1

April 6-1

Accumulator


Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
10.08	9.49	1.985	18.84	207.2	11.00	8.70	2.015	17.53	753.8
10.30	9.49	2.164	20.53	533.8	12.25	8.58	2.005	17.20	1290.0
11.00	9.46	2.164	20.47	614.1	1.30	8.48	1.965	16.66	783.0
11.30	9.54	2.171	20.71	621.3	2.00	8.30	1.923	16.06	481.8
12.00	9.47	2.174	20.59	617.7	2.30	8.21	1.695	13.92	208.8
12.30	9.39	2.181	20.48	450.6					3517.4
12.43	9.47	2.184	20.68	124.1					
				3168.8					

Eff = 111.00%

Eff with last Dist = 104.20%



ACCUMULATOR
APRIL 6-9
APRIL 5-6

CHARGE

DISCHARGE

DISCHARGE

TIME - HOURS

WATTS

Accumulator

Charge


Discharge

T	A	V	W	WM	T	A	V	W	WM
2.30	9.49	2.005	19.03	2.854	10.00	9.31	2.108	19.63	2945
3.00	9.46	2.164	20.47	614.2	10.30	8.79	2.032	17.86	5358
3.30	9.44	2.164	20.43	4698	11.00	8.68	2.002	17.38	5214
3.45	9.42	2.164	20.37	142.3	11.30	8.40	1.943	16.32	489.6
9.45	9.39	2.108	19.79	458.3	12.00	7.44	1.718	12.78	191.7
10.00	9.46	2.174	20.57	473.1					2033.0
				2443.1					

Eff = 83.21

Eff with last Dis = 143.97

ACCUMULATOR
APRIL 9-10
APRIL 9



Accumulator

Charge

Discharge

Charge					Discharge				
T	V	A	W	WM	T	A	V	W	WM
12.00	9.45	1.995	18.85	565.5	3.30	9.25	2.102	19.44	291.6
1.00	9.39	2.174	20.41	612.3	4.00	8.87	2.049	18.17	545.1
2.00	9.50	2.115	20.09	301.4	4.35	8.77	2.025	17.76	355.2
2.30	9.39	2.174	20.41	612.3	9.12	8.89	2.035	18.12	978.5
3.05	9.46	2.181	20.63	618.9	11.00	4.68	1.149	5.38	990.5
3.30	9.42	2.184	20.57	308.5					2460.9
				3018.9					

Eff = 8151

Eff with last Dist = 67.34

22

21

20

19

18

17

16

15

14

13

12

WATTS

CHARGE

DISCHARGE

DISCHARGE

ACCUMULATOR

APRIL 10-11
APRIL 10

11

10

9

8

7

6

5

4

3

2

1

0

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

TIME - HOURS

April 11-12

Accumulator

Charge

Discharge


T	A	V	W	WM	T	A	V	W	WM
11.00	9.39	2.112	19.83	1288.9					
1.10	9.42	2.167	20.41	1326.7					
2.00	9.55	2.157	20.54	328.6					
2.32	9.44	2.184	20.62	329.9					
				3274.1					

Eff with last Dist 75.16

ACCUMULATOR

APRIL 12

APRIL 11



Documentary

~~SP~~ 67.49

Accumulator

Discharge

Discharge

T	A	V	W	WM	T	A	V	W	WM
11.00					10.30	8.68	20.28	17.60	528.0
11.02	9.09	21.07	19.15	306.4	11.00	8.63	20.22	17.45	523.5
11.30	8.89	20.84	18.53	537.4	11.30	8.60	20.18	17.35	520.5
12.00	8.86	20.57	18.22	546.6	12.00	8.60	20.18	17.35	520.5
12.30	8.86	20.57	18.22	291.5	12.30	8.60	20.12	17.30	259.5
12.31					2.15				
1.30	8.92	20.65	18.42	147.4	2.20	8.60	20.18	17.35	86.6
1.45	8.83	20.58	18.17	272.5	2.30	8.60	20.12	17.30	346.0
2.00	8.83	20.55	18.15	399.3	3.00	8.56	20.08	17.19	560.7
2.30	8.80	20.52	18.06	541.8	3.30	8.50	19.95	16.96	508.8
3.00	8.77	20.42	17.91	537.3	4.00	8.48	19.92	16.89	405.4
3.30	8.77	20.42	17.91	537.3	4.17	8.48	19.92	16.89	135.1
4.00	8.75	20.35	17.81	267.2	9.00	8.76	20.22	17.81	53.4
8.45					9.05	8.59	20.08	17.25	258.7
8.53	8.75	20.45	17.89	214.7	9.30	8.50	19.85	16.87	455.5
9.00	8.71	20.42	17.79	320.2	10.00	8.48	19.85	16.83	504.9
9.30	8.71	20.32	17.70	531.0	10.30	8.42	19.75	16.63	498.9
10.00	8.68	20.28	17.60	528.0	11.00	8.40	19.62	16.48	494.4
				5978.6					6660.4

Accumulator

April 25. 26. 30.

Discharge

Charge

T	A	V	W	WM	T	A	V	W	WM
11.30	8.31	1.943	16.15	242.3	11.03	9.49	2.008	19.06	19.1
9.55	8.56	1.978	16.92	50.8	11.05	9.59	2.0.25	19.42	271.9
10.00	8.48	1.972	16.82	285.9	11.30	9.54	2.141	20.42	551.2
11.30	8.18	1.909	15.62	468.6	12.00	9.59	2.164	20.75	621.5
11.00	6.67	1.365	9.10	1547	12.30	9.59	2.164	20.75	310.7
11.02				12023					
				59786	2.16				
				66604	2.30	9.59	2.151	20.63	598.3
<i>Total</i>				138413					
					3.00	9.59	2.157	20.47	614.1
					4.00	9.59	2.163	20.74	311.1
					9.05	9.99	2.137	21.35	106.8
					9.15	9.54	2.151	20.52	266.8
					9.30	9.54	2.154	20.55	452.1
					10.00	9.69	2.164	20.97	943.7
					11.00	9.52	2.174	20.70	931.5
					11.30	9.49	2.174	20.63	618.9
					12.00	9.49	2.177	20.66	309.9
					2.15				
					2.16	9.69	2.144	20.77	166.2
					2.30	9.49	2.167	20.66	452.3

April 25-26-30

May 1-2


Accumulator

Charge

T	A	V	W	WM					
3.00	9.49	2.184	20.73	1098.7					
4.15	9.49	2.187	20.75	767.8					
9.10									
9.15	9.49	2.161	20.51	266.6					
9.30	9.49	2.167	20.56	452.3					
10.00	9.44	2.177	20.55	616.5					
10.30	9.55	2.184	20.86	938.7					
11.00	9.49	2.194	20.82	1249.2					
12.30	9.39	2.197	20.82	1546.5					
2.00	9.41	2.214	20.83	1562.3					
3.00	9.54	2.217	21.15	1269.0					
4.00	9.49	2.221	21.08	948.6					
4.30	9.79	2.224	21.77	326.5					
9.55	9.79	2.207	21.61	64.8					
10.00	9.53	2.241	21.36	149.5					
10.10	9.59	2.261	21.78	653.4					
11.00	9.49	2.287	21.70	667.0					
10.05									
	Total Charge			20507.5					

Eff = 67.49%

ACCUMULATOR
APRIL 25-2630



The Chloride Cell.


This cell is of the Plante type made in a peculiar manner which its makers claim cause it to be stronger; lighter and more efficient than any other.

The improvement affecting this is the method of making and forming the active material for the plate.

I shall not describe the process, but it results in giving the tablets of active material, which the plate is cast around a very porous crystalline structure.

The method of keeping the plates apart is worthy of notice as it may

explain the results I got.



As shown in the drawing, the two plates are marked + and -. a, a, are sheets of asbestos cloth covering the whole surface of the plates, and b is a grooved sheet of wood of the same size as the plates inserted to allow circulation of the liquid.

April 3 + 4 + 5

Chloride


Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
2.40	9.59	2.042	19.58	195.8	11.30	9.67	2.075	20.07	301.1
3.00	9.54	2.131	20.33	508.2	12.00	9.41	2.018	18.99	569.7
3.30	9.49	2.164	20.54	616.2	12.40	9.32	1.995	18.59	557.7
4.00	9.69	2.184	21.16	634.8	2.05	9.05	1.943	17.58	527.4
4.30	10.09	2.207	22.27	334.1	2.30	8.99	1.916	17.22	516.6
9.00	9.64	2.181	21.02	315.3	3.00	8.81	1.883	16.59	497.7
9.30	9.64	2.207	21.27	638.1	3.30	8.71	1.849	16.10	483.0
10.00	9.59	2.224	21.33	639.9	4.00	8.49	1.810	15.37	461.1
10.30	9.54	2.247	21.44	643.2	4.30	8.18	1.744	14.27	214.1
11.00	9.54	2.257	21.53	645.9	9.00	8.77	1.876	16.45	246.7
11.30	9.54	2.281	21.75	326.2	9.30	8.74	1.797	15.71	471.3
				5487.7	10.00	8.05	1.711	13.77	413.1
					10.30	5.99	1.282	7.68	115.2
									5384.7

Eff = 98.12

CHLORIDE
APRIL 3-4-5



April 6-9

Chloride


Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
10.30	9.63	2.055	19.80	2970	11.00	9.40	1.978	18.59	743.2
11.00	9.45	2.161	20.42	6126	12.25	9.21	1.933	17.80	1435.0
11.30	9.69	2.174	21.07	632.1	1.30	8.58	1.873	16.07	808.5
12.00	9.59	2.184	20.94	314.1	2.00	8.46	1.846	15.62	468.6
9.23					2.30	8.27	1.800	14.89	454.7
9.35	9.34	2.191	20.46	450.1	3.00	7.87	1.718	13.52	405.6
9.57	9.49	2.207	20.94	628.2	3.30	6.49	1.409	9.76	146.4
10.30	9.40	2.224	20.90	627.0					4562.0
10.55	9.34	2.234	20.86	623.8					
11.30	9.54	2.254	21.45	643.5					
11.50	9.64	2.264	21.82	436.4					
12.15	9.62	2.281	21.94	219.4					
				5486.2					

Eff. = 83.15

Eff with Best Dist = 98.13



CHLORIDE
 APRIL 6-9
 APRIL 2-5

April 9+10

Chloride

Charge

Discharge


Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
3.30	9.42	2.032	19.12	191.2	12.00	9.94	2.227	22.10	663.0
3.45	9.49	2.147	20.38	101.9	1.00	9.13	1.995	18.21	910.5
9.15	9.37	2.161	20.25	405.0	1.30	9.01	1.962	17.68	528.4
10.00	9.39	2.181	20.48	8.19.2	2.00	8.82	1.923	16.96	508.8
10.30	9.39	2.227	20.91	627.3	2.30	8.63	1.873	16.16	484.8
11.00	9.45	2.241	21.18	635.4	3.05	8.28	1.797	14.88	446.4
11.30	9.42	2.261	21.30	639.0	3.30	7.65	1.329	10.07	157.0
12.00	9.43	2.274	21.45	321.8					3692.9
				3740.8					

Eff = 98.72

Eff with next ch = 58.28

Eff with last Dist = 121.96

CHLORIDE
APRIL 9 & 10
APRIL 9



April 10-11-12

Chloride

Charge

Discharge

Charge					Discharge				
T	A	V	W	WM	T	A	V	W	WM
3.30	9.47	2.085	19.73	295.9	2.00	9.43	2.065	19.49	311.8
4.00	9.43	2.164	20.41	653.1	2.33	9.27	2.035	18.86	603.5
4.35	9.39	2.191	20.57	370.3	3.03	9.21	2.008	18.49	554.7
9.13	9.47	2.181	20.66	1096.0	3.33	9.12	1.988	18.12	507.4
11.00	9.39	2.247	21.10	2510.9	4.00	9.03	1.972	17.80	587.4
1.10	9.41	2.307	21.71	1411.2	4.38	8.91	1.949	17.36	329.8
				6336.4	9.00	9.21	1.975	18.19	345.6
					9.38	8.81	1.909	16.82	538.2
					10.05	8.68	1.899	16.48	412.0
					10.30	8.56	1.869	15.99	463.7
					11.00	8.37	1.827	15.29	458.7
					11.30	8.09	1.764	14.27	428.1
					12.00	7.21	1.593	11.49	172.3
									5713.2

Eff = 90.17

Eff with next ch = 120.22

CHARGE

DISCHARGE

CHLORIDE

APRIL 10-11-12
APRIL 10

TIME - HOURS

22

21

20

19

18

17

16

15

14

13

12

11

1

2

3

4

5

6

7

8


April 13

Chloride

Charge

Discharge

T	A	V	W	WM	T	A	V	W	WM
12.00	9.44								
12.02	9.44	2.082	19.64	294.6					
12.30	9.49	2.151	20.41	449.0					
12.45	9.44	2.161	20.39	1039.9					
- 12 ^m	9.41	2.184	20.53	246.6					
2.12	9.39	2.207	20.72	1118.2					
2.30	9.31	2.217	20.64	495.4					
3.00	9.49	2.234	21.20	636.0					
3.27	9.51	2.254	21.43	64.29					
4.00	9.43	2.274	21.53	32.29					
				4998.9					
				<u>246.6</u>					
				4752.3					
Eff with Cor Dis = 120.22%									



CHARGE

CHLORIDE

APRIL 13
APRIL 11-12

WATTS

TIME - HOURS

22
21
20
19
18
17
16
15
14
13
12
11

8

7

6

5

4

3

2

1


0

Chloride

Charge

Charge

T	A	V	W	WM	T	A	V	W	WM
12.00					2.15	9.49	2.307	22.88	294.6
12.02	9.44	2.082	19.64	294.6	2.30	9.49	2.324	22.05	485.1
12.30	9.49	2.151	20.41	449.0	3.00	8.79	2.331	20.49	307.4
12.45	9.44	2.161	20.39	1039.9	9.00				
-12 ^m	9.41	2.184	20.55	246.6	9.03	9.46	2.284	21.61	367.4
2.12	9.39	2.207	20.72	118.2	9.30	9.56	2.331	22.28	623.8
2.30	9.31	2.217	20.64	495.4	10.00	9.41	2.347	22.06	661.8
3.00	9.49	2.234	21.20	636.0	10.30	9.41	2.361	22.22	666.6
3.27	9.51	2.254	21.43	642.9	11.00	9.41	2.384	22.43	336.5
4.00	9.43	2.274	21.53	322.9	2.10				
10.15					2.15	9.46	2.341	22.15	332.2
10.17	9.54	2.231	21.28	255.4					4065.4
10.37	9.51	2.264	21.53	258.3					7735.4
11.00	9.51	2.287	21.75	565.5					11800.8
11.30	9.59	2.307	22.12	663.6					246.8
12.00	9.49	2.324	22.05	661.5					11554.2
12.30	9.48	2.337	22.15	332.2					
2.10									
				7735.4					



April 19-20-23-24

Chloride

Changes Charges

T	1134	955	2032	1941	194	1130	946	2264	2136	3204
A	1200	954	2163	2066	3522	209	946	2224	2104	2104
V	1230	959	2173	2084	3126	220	919	2241	2059	2059
WM	2.05	948	2261	2163	432.8	230	948	2261	2163	432.8
V	2.05	954	2174	2074	3318	3.00	949	2284	2168	650.4
A	2.30	949	2184	2073	3597	3.30	942	2294	2161	648.3
V	3.00	953	2194	2091	6273	4.00	931	2314	2154	646.2
T	3.30	944	2197	2074	6292	4.30	922	2327	2145	321.8
V	4.00	939	2207	2072	6216	9.10				
A	4.30	939	2224	2088	3132	9.13	934	2274	2124	254.9
V	9.02					9.30	945	2307	2180	501.4
T	9.04	975	2174	2120	636	10.00	950	2307	2192	657.6
V	9.06	949	2184	2073	3524	10.30	951	2331	2217	665.1
A	9.37	936	2217	2075	601.7	11.00	939	2367	2223	666.9
V	10.05	933	2231	2072	5394	11.30	946	2381	2252	337.8
WM	10.30	932	2241	2089	5640					
V	11.00	937	2251	2109	632.7					
<p>6997.0</p> <p>6519.7</p> <p>6997.0</p> <p>13516.7</p> <p>7563.7</p>										

Chloride


Exchanges & exchanges

T	11.30	8.62	1.886	16.26	260.2
A	11.33	9.55	2.112	20.17	342.9
V	12.00	9.35	2.068	19.34	541.5
W	12.30	9.21	2.032	18.71	336.8
WM	12.33	9.00	8.58	1.876	1610.35
2.00	9.35	2.042	19.09	2.63	8.47
2.30	8.47	1.846	15.64	469.2	
2.30	9.21	2.018	18.59	5.77	3.00
3.00	9.17	2.012	18.46	5.53	5.30
3.30	9.09	1.992	18.11	5.43	3.40
4.00	9.03	1.985	17.92	4.22	8.45
4.15	9.03	1.982	17.90	2.53	8.52
9.27	9.00	8.34	1.833	5.29	290.5
9.30	9.12	1.995	18.19	3.27	9.30
10.00	9.00	1.975	17.77	5.33	10.00
10.30	8.93	1.958	17.48	5.44	
11.00	8.87	1.946	17.26	5.17	
11.30	8.78	1.913	16.80	5.04	
12.00	8.72	1.903	16.59	4.97	

$\frac{6603.9}{72.46\%} = 9113.8$

$6603.9 \times 1.0222.5 = 6750.8$

3618.6
6603.9



CHLORIDE

APRIL 19-20-23-24-25-26

EFF = 75.63%

APRIL 24-25-26

EFF = 72.46%

April 25-26-27

Chloride

Change

Change

T	1000	1100	954	2274	2169	6507
A	1005	950	2141	2034	3661	1130
V	1030	949	2161	2651	5538	1200
A	1100	949	2164	9038	6114	1230
V	1130	949	2174	2063	6189	215
W	1200	945	2184	2064	6182	220
W	1230	948	2197	2083	3124	230
T	215	220	949	2181	2070	2070
A	230	942	2184	2057	4114	400
V	300	959	2207	2166	348	955
A	330	951	2217	2108	6324	957
V	400	945	2234	2111	4855	1000
T	415	942	2241	2111	1478	1030
V	903	952	2197	2091	924	929
W	930	941	2227	2096	5869	929
A	1000	953	2247	2151	6453	929
V	1030	953	2264	2157	6474	929

65.73%

13128.7

7871.9

5256.8

23742.05

3307

23279.92

3507

86.6

22942.155

23312.212

331.8

23212.12

663.6

23072.189

656.7

22812.165

433.0

22642.148

150.4

22272.158

64.7


23072.173

326.0

22972.180

654.0

WM



CHLORIDE

APRIL 24-25-26-27-30

EFF = 69.23%

APRIL 30

MAY 1-2

EFF = 65.24

Conclusion.

I instead of giving a lengthy description of the results I obtained I give the table on the next page which shows everything at a glance

The two results which are most noticeable are first, the capacity of the American cell in the two sets of tests and second the great variation in efficiency of the chloride.

The first of these characteristics I cannot explain except that the cell may have been 'anodized' more on the inside surface of the lead

which than it was on the outside of the plate.

The record of these facts

Name of cell	Amperes	Voltage	an. amp.	an. %	Cap. hours
Standard	1st	2.178	1.855	88.35	27.6
"	2nd	2.482	1.805	73.51	66.5
Sony	1st	2.176	1.752	87.11	43.1
"	2nd	2.278	1.736	80.68	104.5
American 1st	1st	2.315	1.012	75.85	20.0
"	2nd	2.380	1.130	70.56	19.7
Chloride 1st	1st	2.283	1.403	96.89	57.6
"	2nd	2.384	1.672	72.29	89.0
Accumulator 1st	1st	2.180	1.487	88.69	17.0
"	2nd	2.287	1.365	67.49	122.5
Set of cells for Am-meter Calibration		40.1	3.75	24.88	422.1
Pen cell		2.51	1.87		52.8

is explained I think by the
dehydrating device of the chlorine
cell.

In the first set of tests
the highest voltage was not
that at which gas is evolved
in the second tests. It would
seem that this gas had great
difficulty in passing up to
the surface through the
cathodic cloth and in the
next series. Thus the
surface of the plate touching
the liquid was much cut
down and this by raising
the internal resistance of
the cell increased the
difference of efficiency by

about seven per cent
As I expected the
efficiency fell off greatly
at the higher changing limits.
But it fell off much more
than I expected or rather the
higher efficiency was much
higher than I expected to get
I can show no curve of
variation of efficiency as I
had only time to test the
cells at two points. It
seems from the great rise
of capacity and lowering of
efficiency with the raising
of the changing limit that
the curve showing their
relation would be very
interesting. I am sure however

In regard to the
correctness of the results
I believe, from noticing
the variation from the mean
in effluence got from the
changes and two discharges
beginning and ending at the


than a consideration of
the results it appears that
with a lead cell giving a
nearmate storage capacity
one cannot expect more than
65-70% efficiency.

Should try to get them
should advise him to take
maximum charge limits at
a distance apart of at most
.05 of a volt.

at the lower limit and
therefore on the steep part
of the potential curve that
the average efficiency got
where the efficiency was
given is within 5% of correct
where air efficiencies are given
within 2% and where 9 is
more or less within 1%.

Set of cell for Am-meter
Calibration

The cells were of two kinds
and were crimped as shown
being charged in series and
discharged in series parallel
Two in series and eight
series in parallel. All of
them were old cells and
most of them were pretty
made over with solder.



A is the accumulator cell B the
galvan. W are the two wires
leading to the physical
contacts outside the room.

The voltage at the cells
was taken outside the
storage battery boxes and
upon the special switch
thus allowing the multiple
spacing contacts and lead
wires to the cells to have
an effect

The discharge current was
passed through a variable
carbon and iron wire.

resistance mounted by

Mr. Duffie and it was

made to test this than

to test the cells that the

made on three other cells

were made.

The cells showed a very
low efficiency which has

been given, but the
necessance worked
admirably, it being
extremely easy to find the
amplitude at 71.3 without
allowing a variation of
more than 1.1 of an Ampere.

April 17-18-20

System for Amette Calibration Change

T	2.00	9.51	4.00	9.39	38.0	3568	96336
A	2.03	9.51	36.0	9.39	38.3	3673	55095
V	2.08	9.52	36.3	9.02	44538	9.02	
V	2.30	9.54	36.3	9.04	310353	9.04	350.0/050.0
V	3.10	9.55	36.3	9.06	11408.1	9.06	349.15934.7
A	3.35	9.42	36.4	9.37	85725	9.37	351.010179.0
V	4.00	9.61	36.4	9.05	41976	9.05	351.79495.9
V	9.45	9.55	36.2	10.30	27656	10.30	354.29562.4
V	10.00	9.49	36.4	11.00	345496	11.00	357.01071.0
V	10.41	9.56	36.5	11.30	810364	11.30	362.75440.6
V	11.00	9.69	36.5	2.05	368486	2.05	9.46
V	11.30	9.46	36.6	2.10	210386	2.10	9.46
V	12.00	9.54	36.7	2.20	110503	2.20	9.19
V	12.30	9.59	37.0	2.30	53220	2.30	9.48
V	2.02	9.53	36.7	3.00	47572	3.00	9.49
V	2.30	9.49	37.0	3.30	110181	3.30	9.42
V	3.00	9.53	37.3	4.00	117315	4.00	9.31
V	3.35	9.44	37.6	4.30	106470	4.30	9.92
V	3.35	9.44	37.6	136237.5	136237.5		

119882.5

April 17-18-20

System for Quota Calculations

Charge

T	A	V	W	WM	T	A	V	W	WM
9.10	9.14	9.30	9.30	9.30	9.10	9.14	9.30	9.30	9.30
10.00	9.35	9.50	9.50	9.50	10.00	9.35	9.50	9.50	9.50
10.30	9.39	9.51	9.51	9.51	10.30	9.39	9.51	9.51	9.51
11.00	9.39	9.39	9.39	9.39	11.00	9.39	9.39	9.39	9.39
11.30	9.46	9.46	9.46	9.46	11.30	9.46	9.46	9.46	9.46
12.00	9.42	9.42	9.42	9.42	12.00	9.42	9.42	9.42	9.42
12.30	9.54	9.54	9.54	9.54	12.30	9.54	9.54	9.54	9.54
1.234					1.234				
2.00	9.64	9.64	9.64	9.64	2.00	9.64	9.64	9.64	9.64
2.30	9.29	9.29	9.29	9.29	2.30	9.29	9.29	9.29	9.29
3.00	9.49	9.49	9.49	9.49	3.00	9.49	9.49	9.49	9.49
3.30	9.64	9.64	9.64	9.64	3.30	9.64	9.64	9.64	9.64
4.00	9.39	9.39	9.39	9.39	4.00	9.39	9.39	9.39	9.39
4.15	9.42	9.42	9.42	9.42	4.15	9.42	9.42	9.42	9.42
9.27					9.27				
9.30	9.59	9.59	9.59	9.59	9.30	9.59	9.59	9.59	9.59
133573.9					133573.9				

Total 418193.9

28500.0

T	9.34	71.3	10.36	3.84	271.8	842.8		
A	9.42	39.5	281.6	478.2	11.02	3.84	271.8	733.8
V	10.00	3.89	275.4	650.6	11.30	3.83	271.1	786.9
WM	10.30	3.88	274.4	823.0	12.00	3.80	270.9	812.0
W	11.00	3.88	274.4	411.6	12.30	3.78	269.5	404.5
"	2.07	"	"	"	"	"	"	"
"	2.10	3.92	279.4	447.4	"	"	"	"
"	2.35	3.88	274.4	686.0	"	"	"	"
"	3.00	3.88	274.4	823.0	"	"	"	"
"	3.35	3.87	273.9	866.4	"	"	"	"
"	4.04	3.87	273.9	383.4	"	"	"	"
"	8.12	4.10	299.3	292.3	"	"	"	"
"	8.14	3.88	274.4	548.8	"	"	"	"
"	8.15	3.88	274.4	219.5	"	"	"	"
"	8.30	3.88	274.4	603.8	"	"	"	"
"	9.00	3.86	273.2	952.0	"	"	"	"
"	9.39	3.86	273.2	819.6	"	"	"	"
"	10.00	3.85	272.5	790.2	"	"	"	"


$\frac{3.78}{3.84} = 30.14\%$

$\frac{3.78}{3.84} = 12623.50$

35794.8

System for Ammeter Calibration
 Discharge

April 17-18-20



SYSTEM
FOR AMMETER
CALIBRATION
APRIL 17-18-20

101

March 26-27-30
 Mary 1

Cells for Ann-Mitt Calibration

Changes

T	9.32	16.30	9.29	37.7	350.2	10506.0
A	9.35	11.00	9.49	38.2	362.5	10875.0
V	9.34	11.30	9.54	38.4	366.3	10989.0
W	9.53	12.00	9.59	38.6	370.1	11103.0
WM	9.53	12.30	9.59	38.8	373.1	11597.0
W	9.54	12.30	9.59	38.8	373.1	11597.0
WM	9.59	12.18	9.74	37.8	368.2	11472.8
W	9.49	12.00	9.59	39.3	376.9	11307.0
V	9.30	9.05	9.99	31.7	348.0	1740.0
W	9.49	9.15	9.54	39.0	372.0	4836.0
WM	9.54	9.30	9.54	39.1	373.0	8206.0
W	9.49	10.00	9.69	39.4	381.2	17154.0
V	9.55	11.00	9.52	39.5	375.1	16880.0
W	9.58	11.30	9.49	39.5	374.9	12470.0
T	10.00	12.00	9.49	39.6	375.8	153457.0


104999.2

Cells for Am-metric Calibration

May 1

Changes

T	2.15	9.79	37.6	368.12	944.8	11.00	949	40.2	381.5	1445.0	
A	3.00	9.49	39.7	376.7	866.4					1144.50	
V	4.15	9.49	39.7	376.7	2636.9					19394.15	
W	9.10									15345.70	
WM	9.15	9.49	39.0	370.1	4811.3					10492.92	463762.7
T	9.30	9.49	39.3	371.9	8181.8						
V	10.00	9.44	39.5	372.9	1187.0						
W	10.30	9.55	39.6	377.7	16996.0						
WM	11.30	9.49	39.6	375.8	2548.0						
T	12.30	9.39	39.6	371.8	2788.50						
V	2.00	9.42	39.5	372.1	2790.70						
W	3.00	9.54	39.5	376.4	2608.0						
WM	4.00	9.54	39.6	382.8	17226.0						
T	4.30	9.79	39.6	388.7	5830.0						
V	9.55	9.79	37.5	367.1	1008.3						
W	10.00	9.52	39.4	375.1	2625.7						
WM	10.10	9.59	39.7	380.7	11421.0						19394.5



CELLS FOR

AMMETER CALIBRATION

APRIL 26-27-30

MAY 1

EFF = 20.99%